

Water Basis of Design Report

For
URBIS 77

Southwest Corner of 78th Street & Camelback Road
Scottsdale, AZ

Project #-
Job No.: 06-065

Prepared for:


Silo Urban Homes

Prepared by:

Christopher J. Wilson, PE

Metro/Land Consultants, LLC

1850 North Central Avenue, Suite 525
Phoenix, AZ 85004
(602) 393-2030 Phone
(602) 393-2031 Fax



84-DR-2005
REV: 5/11/2006

**Water and Sewer Basis of Design Report
FOR
URBIS 77
Scottsdale, Arizona**

1 0	WATER INTRODUCTION	3
2 0	WATER ANALYSIS	3
3 0	WATER CALCULATIONS	4
4 0	EXHIBITS	5
4 1	VICINITY MAP	
4 2	PRELIMINARY UTILITY PLAN	

1.0 WATER INTRODUCTION

The proposed project is located at the southwest corner of Camelback Road and 78th Street in the City of Scottsdale. The site is situated within the Southeast Quarter of Section 23, Township 2 North, Range 4 East of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. The site is bordered to the west by Parkway Avenue, to the east by 78th Street, to the north by Camelback Road and to the south by Fireside West apartments and Adobe Villas Condominiums.

The proposed and existing site are condominiums and are zoned Residential

There is an existing 8" water main located in 78th Street and an existing 6" water main located in Parkway Avenue. This project will utilize both the existing 8 and 6" waterlines. The site will be served by an 8" line in both Phase I and Phase II. The estimated maximum daily domestic demand is 131,098 GPD, see calculations below.

A fire hydrant flow test was completed on April 28, 2006 (See attached flow test summary in Exhibit 6 2) The static pressure was 101 psi, residual pressure was 99 psi.

2.0 WATER ANALYSIS

Multi-Family Development

288 units

Average Daily Demand	227.60 gpd (See figure 6 2)
Average Daily Water Demand	$227.60 \times 288 = 65,549 \text{ gpd} = 45.52 \text{ gpm}$
Max Demand Peaking Factor	2
Max Daily Demand	$227.6 \times 2 \times 288 = 131,098 \text{ gpd} = 91.04 \text{ gpm}$
Peak Hourly Demand Peaking Factor	3.5
Peak Hourly Demand	$65,549 \text{ gpd} \times 3.5 = 229,422 \text{ gpd} = 159.32 \text{ gpm}$
Max Daily demand with fire flow	$91.04 \text{ gpm} + 1500 \text{ gpm} = 1591.04 \text{ gpm}$

The City of Scottsdale design requirement for this water system is to maintain 50 psi minimum system pressure to the highest finish floor and to maintain 30 psi system pressure to the highest finish floor under fire flow conditions

This site lies within pressure zone 1 of the City of Scottsdale water system. Based on the furthest run from the existing water main and considering it not be looped, the furthest remote location pressure at the building would be approximately 70 psi. The existing water system should have adequate pressure to serve the site both under normal operations as well as under fire flow conditions.

3.0 WATER CALCULATIONS



Flow Test Summary



Prior to conducting test you must contact Inspection Services at 480-312-6760 to activate permit and schedule test date and inspection.

Project Address. SW corner 78th St. @ Camelback


Encroachment Permit No. C30486

Date of Test: 4/28/06

Time of Test: 12:00 PM

Test requires using two (2) hydrants on the water system

1. Attach water quarter section map identifying (#1) pressure and (#2) flow hydrant used to conduct the test OR
2. Show location of pressure hydrant and flow hydrant with cross streets and distance between hydrants and main size tested below



Test Data


Static pressure: 101 psi
 Residual pressure: 99 psi
 Pilot reading: 65 psi
 Flow GPM: 1350 gpm
 Hydrant orifice Diameter: 2 1/2
 Coefficient of Discharge: .9

Conducted By: _____

Testing to be witnessed and certified by a NICET Level III or IV (Fire Sprinkler) OR a Civil/Fire Protection Engineer licensed within the State of Arizona.

Witnessed By (print name). Frank Martinez

NICET Certification # or Engineers seal & signature: _____



Planning & Development Services Department

7447 E Indian School Road, Suite 100, Scottsdale, AZ 85251 • Phone: 480-312-2500 • Fax: 480-312-7088

HEADLOSS xlt

HEADLOSS Version 2 0

Copyright 2002 Timmons Engineering Software All Rights Reserved

INITIAL FLOW	FLOW STEP	FLOW UNITS	FLOW CONV	C	DIA INCHES	LENGTH FEET
0	100	gpm	1	100	8	1000

Table of Velocity, Velocity Head and Loss of Head

Flow	Velocity (fps)	Velocity Head	Loss of Head (ft)	Loss of Head (psi)
0	0 00	0 00	0 00	0
100	0 64	0 01	0 42	0 18
200	1 28	0 03	1 50	0 65
300	1 91	0 06	3 15	1 36
400	2 55	0 10	5 33	2 31
500	3 19	0 16	8 02	3 47
600	3 83	0 23	11 20	4 85
700	4 47	0 31	14 85	6 43
800	5 11	0 40	18 96	8 21
900	5 74	0 51	23 52	10 18
1000	6 38	0 63	28 52	12 35
1100	7 02	0 77	33 96	14 70
1200	7 66	0 91	39 82	17 24
1300	8 30	1 07	46 10	19 96
1400	8 94	1 24	52 80	22 86
1500	9 57	1 42	59 90	25 93
→ 1600	10 21	1 62	67 41	→ 29 18 ←
1700	10 85	1 83	75 32	32 61
1800	11 49	2 05	83 62	36 20
1900	12 13	2 28	92 32	39 97
2000	12 77	2 53	101 41	43 90
2100	13 40	2 79	110 88	48 00
2200	14 04	3 06	120 73	52 26
2300	14 68	3 35	130 96	56 69
2400	15 32	3 64	141 57	61 29
2500	15 96	3 95	152 55	66 04
2600	16 60	4 28	163 90	70 95
2700	17 23	4 61	175 62	76 03
2800	17 87	4 96	187 71	81 26
2900	18 51	5 32	200 16	86 65
3000	19 15	5 69	212 97	92 19

HYDFLOW Version 2 0
 Hydrant Flow Test Calculations Template
 Copyright 2002 Timmons Engineering Software All Rights Reserved

Situation Urbis 77 Condominiums Date 05/11/06
 78th Street & Camelback Road

HYDRANT FLOW CALCULATIONS

Supply Pressure	101 00	
Supply Elevation	1252 00	
Test Point Static Pressure	101 00	(No Hydrant Flow)
Test Point Elevation	1250 00	
Test Point Residual Pressure	99 00	(Hydrant Flowing)

a	Supply HGL	1485 31
b	Test Point Static HGL	1483 31
c	Test Point Residual HGL	1478 69

Static Head Loss (a-b)	2
Residual Head Loss(a-c)	6 62

Hydrant

	#1	#2	#3
Flow Pressure in PSI	65 00	0 00	0 00
Nozzle Diameter in Inches	2 50	2 50	2 50
Calculated Flow in GPM	1353 2	0 0	0 0

Total Hydrant Flows in GPM	1353 2
----------------------------	--------


System Equivalent Base Flow in GPM	1489 4
------------------------------------	--------

System Base Flow Peaking Factor	1
Source Pressure	101
Source HGL	1485 31

Test Point Available Flow

Residual Pressure	HGL	Total Flow	Equip Base Flow	Available GPM
20	1296	17405	1489	15916
30	1320	16206	1489	14717
40	1343	14927	1489	13437
50	1366	13547	1489	12057
61	1390	12035	1489	10545
71	1413	10340	1489	8851
81	1437	8367	1489	6878
91	1460	5879	1489	4389
101	1483	1488	1489	0

HYDFLOW
Timmons Engineering Software



4.0 EXHIBITS

4.1 VICINITY MAP

CHAPPARAL AVENUE

SCOTTSDALE ROAD

ROAD

CAMELBACK

23

ROAD

MILLER



78TH ST

PROJECT SITE

HAYDEN ROAD



INDIAN SCHOOL ROAD

VICINITY MAP



NTS

4.2 PRELIMINARY UTILITY PLAN

PRELIMINARY QUANTITIES

6" WATER METER	4 EA
8" PRV	4 EA
8" DIP WATER LINE	1 310 LF
6" DIP WATER LINE	3 150 LF
1-1/4" HDPE SEWER	912 LF
8" TSK&VBC	3 EA
6" TSK&VBC	3 EA
LIFT STATION(6000 GPD)	18 EA
5 DIA MANHOLE	4 EA
FIRE HYDRANT	7 EA

**PRELIMINARY UTILITY PLAN
URBIS 77 CONDOMINIUMS
78TH STREET & CAMELBACK ROAD SCOTTSDALE, AZ**




DATE	DESCRIPTION	REVISIONS

**URBIS 77
CONDOMINIUMS**
CAMELBACK ROAD AND 78TH ST
SCOTTSDALE, ARIZONA

Metro/Land Consultants, LLC
1850 N CENTRAL AVE SUITE 625 PHOENIX AZ 85004 PH 602-393-2030 FAX 602-393-2031

DESIGN	CJW	DRAFTING	VF/CW
CHECKED	CJW	DATE	MAY 3, 2006

PRELIMINARY UTILITY PLAN



For working drawings call for the blue stamp
602-263-1100
Blue Stake Center
CALL COLLECT

JOB NO 06-065
U-1
1 OF 1

SILO URBAN HOMES

BASIS OF DESIGN REPORT FOR WATER

PREPARED FOR:

URBAN SILO HOMES DEVELOPMENT CORPORATION

7530 E Main Street #105
Scottsdale, Arizona 85251





Christopher G. Patton, P.E.

SEPTEMBER 26, 2005

Prepared By

RICK ENGINEERING COMPANY

6150 North 16th Street
Phoenix, Arizona 85016-1705
(602) 957-3350

JOB NUMBER 3503

TABLE OF CONTENTS

1 0	INTRODUCTION	1
2 0	SITE LOCATION	1
3 0	EXISTING WATER INFRASTRUCTURE	1
4 0	PROPOSED WATER SYSTEM	1
APPENDIX A	VICINITY MAP	
APPENDIX B	SILO URBAN HOMES ABBREVIATED WATER NEEDS REPORT	
MAP POCKET 1	CONCEPTUAL WATER & SEWER PLAN	

1 0 INTRODUCTION

The purpose of this report is to address the basis of design for water service to the proposed Silo Urban Homes Condominiums. The new condominiums will contain 288 units.

2 0 SITE LOCATION

Silo Urban Homes project is located in a portion of the Southeast Quarter of Section 23, Township 2 North, Range 4 East of the Gila and Salt River Meridian, Maricopa County, Arizona. The site is bounded by 78th Street to the east, Camelback Road to the north, Parkway Avenue to the west and Fireside West Apartments and Adobe Villas Condominiums to the south. See Vicinity Map in Appendix A.

3 0 EXISTING WATER INFRASTRUCTURE

There is an existing 6" water line in Parkway Avenue and an existing 8" water line in 78th Street that services the current Madeira Apartments (332 units). The water system is owned and operated by City of Scottsdale.


4 0 PROPOSED WATER SYSTEM

We propose to loop an 8" public water line through the site from the existing stubs off Parkway Avenue and 78th street. The estimated domestic demand is calculated in the Silo Urban Homes Abbreviated Water Needs Report in Appendix B. The system will adequately provide the peak water demand and a fire flow of 1500 g p m as demonstrated in Appendix C.

5 0 CONCLUSION

The proposed and existing water system is adequate to serve the proposed 288 condominium units and is consistent with the City of Scottsdale guidelines.

APPENDIX A



SILO URBAN HOMES

RICK
ENGINEERING COMPANY

6150 NORTH 16TH STREET
PHOENIX, AZ 85016
602 957 3350
(FAX) 602 285 2396

rickengineering.com

Phoenix Tucson San Diego Riverside Orange Sacramento

VICINITY MAP

JOB NUMBER	3503	PREPARED BY	MJ	DATE PREPARED	20-SEP-2015
------------	------	-------------	----	---------------	-------------

APPENDIX B



**SILO URBAN HOMES
ABBREVIATED WATER NEEDS REPORT
RICK ENGINEERING JOB NUMBER 3503**

AUGUST 2005

Silo Urban Homes project is a Multi family residential development located in a portion of the Southeast Quarter of Section 23, Township 2 North, Range 4 East of the Gila and Salt River Meridian, Maricopa County, Arizona. The site is bounded by 78th Street to the east, Camelback Road to the north, Parkway Avenue to the west and Fireside West Apartments and Adobe Villas Condominiums to the south.

DESIGN CRITERIA

As required by the City of Scottsdale Design Standards and Policies Manual and Average daily water demand per dwelling unit (gpd) per City of Scottsdale Design Standards and Policies Manual, Section 4 1, Figure 4 1-3

Type of development	Multiple-family residential
Number of dwelling units	288
City of Scottsdale Pressure Zone Location	Zone 1
Pressure Zone 1 boundary ground elevation range	1180-1280 ft
Minimum system pressure (under fire flow conditions)	50 psi (30 psi)
Maximum system pressure	120 psi

Average daily water demand per D U (residential 12-22 DU per acre) = 227 60 gpd

Average daily water demand = 288 x 227 60 = 65,549 gpd = 45 52 gpm


Maximum demand peaking factor = 2

Maximum daily demand = 65,549 x 2 = 131,038 gpd = 91 00 gpm

Peak hourly demand peaking factor = 3 5

Peak hourly demand = 65,549 x 3 5 = 229,317 gpd = 159 32 gpm

Maximum daily demand + fire flow = 159 32 gpm + 1,500 gpm = 1,659 32 gpm



SUMMARY

The public water system through Silo Urban Homes has been designed in accordance with City of Scottsdale design requirements

F:\3500's\3503\Reports\R3503Abb_Wat.doc