

**CONCEPTUAL MASTER  
WASTEWATER SYSTEM REPORT  
FOR  
McDOWELL MOUNTAIN BACK BOWL**

January 25, 2005  
WP# 042054 06

*Prepared for*  
**Crown Community Development**  
Ms Teri Frankiewicz  
3600 Thayer Court, Suite 100  
Aurora, Illinois 60504  
*Phone (630) 851-5490*  
*Fax (630) 898-0480*

*Prepared by*  
**Wood, Patel & Associates, Inc**  
2051 West Northern Avenue, Suite 100  
Phoenix, Arizona 85021  
*Phone (602) 335-8500*  
*Fax (602) 335-8580*



## TABLE OF CONTENTS

|     |   |   |
|-----|---|---|
| 1 0 | INTRODUCTION                                    | 1 |
| 1 1 | General Background and Project History          | 1 |
| 1 2 | Scope of Master Wastewater System Report        | 1 |
| 1 3 | Topographic Conditions                          | 2 |
| 2 0 | DESIGN REQUIREMENTS                             | 3 |
| 2 1 | Population                                      | 3 |
| 2 2 | Wastewater Flow Criteria                        | 3 |
| 2 3 | Wastewater System Criteria                      | 3 |
| 3 0 | WASTEWATER FLOW CALCULATIONS                    | 4 |
| 3 1 | Pipe Sizing and Capacity Calculations           | 4 |
| 4 0 | GENERAL PLAN FOR THE ON-SITE WASTEWATER SYSTEM  | 5 |
| 4 1 | Proposed On-Site Collection System for Option 1 | 5 |
| 4 2 | Proposed On-Site Collection System for Option 2 | 6 |
| 5 0 | GENERAL PLAN FOR THE OFF-SITE WASTEWATER SYSTEM | 7 |
| 6 0 | CONCLUSIONS                                     | 9 |

## APPENDICES

|            |  |
|------------|--|
| Appendix A | <u>Option 1</u><br>Table 1 Estimated Wastewater Flow Calculations<br>Table 2 Estimated Pipe Capacities |
| Appendix B | <u>Option 2</u><br>Table 1 Estimated Wastewater Flow Calculations<br>Table 2 Estimated Pipe Capacities |
| Appendix C | References   |

## PLATES

|         |  |
|---------|--|
| Plate 1 | Vicinity Map                                 |
| Plate 2 | Option 1 Conceptual Master Wastewater System |
| Plate 3 | Option 2 Conceptual Master Wastewater System |

km  
Y:\WP\Reports\Residents\042054 Conceptual Master Wastewater System Report for McDowell Mountain Back Bowl.doc



## 1 0 INTRODUCTION

### 1 1 General Background and Project History

The *McDowell Mountain Back Bowl* (herein referred to as the *Back Bowl*), is located at the eastern edge of the City of Scottsdale, Maricopa County, Arizona, within a portion of Section 11, Township 4 North, Range 5 East. The site is currently an assemblage of undeveloped parcels bound to the west by the existing Sonoran Crest Development (122<sup>nd</sup> Street alignment), to the east by the 128<sup>th</sup> Street alignment, to the north by the Happy Valley Road alignment, and to the south by the McDowell Mountain Sonoran Preserve. Access to the development is planned from the west via the ½-mile section roadway, Alameda Road. Plate 1 provides a vicinity map for the project and surrounding areas.

The *Back Bowl* is a 330-acre residential custom lot sub-division, nestled at the northern base of the McDowell Mountains. The development includes approximately 121 lots ranging in size from 2 to 3 acres and a clubhouse with amenities such as jacuzzis, pools, water falls, and restaurant facilities. Interpretive trails and scattered pocket parks with water features will also be incorporated into the site plan.

Crown Community Development has considered expanding the *Back Bowl* to approximately 400 acres which would include the acquisition of the 40-acre parcel located at the northeast ¼ of Section 11, four (4) 2.5-acre parcels located at the northeast boundary of Sonoran Crest, and the 30-acre parcel located in the middle of the southern ½ portion of Section 11.

This *Conceptual Master Wastewater System Report for McDowell Mountain Back Bowl* is prepared as two options: Option 1 which represents the proposed 330-acre development, and Option 2 which includes the potential expansion (400-acre development). Land use information is provided by LVA Urban Design Studio L L C (LVA), January 6, 2004.

### 1.2 Scope of Master Wastewater System Report

The intent of the *Conceptual Master Wastewater System Report for McDowell Mountain Back Bowl* is to identify the locations and preliminary sizes of the proposed sewer infrastructure required to provide sanitary service to the development for Options 1 and 2. The components of the sewer infrastructure discussed in this report include on-site and off-site sanitary sewer lines, a sewage pumping station and force main. This report also presents the estimated wastewater flow calculations and the estimated pipe capacities.

13 **Topographic Conditions**

Topography on the site slopes from the south to the northeast and northwest. Slopes vary, with the majority in the 3 to 5 percent range, and some minor portions being much steeper. Steeper slopes (5% and greater) are associated with the southern portion of the subject site. Gentler slopes (3% or less) are located within the northern portion of the subject site.

The majority of the subject site drains towards the northeast. The remainder of the site drains either westerly or northwesterly towards Alameda Road.

## 2.0 DESIGN REQUIREMENTS

The design criteria for the *Back Bowl* development are consistent with the requirements set by the *City of Scottsdale Design Standards and Policy Manual* and with *Arizona Department of Environmental Quality, Bulletin No 11*. Please refer to Appendix C – *References* for these agency standards.

### 2.1 Population

The equivalent population is calculated based on the land use information for the development. It is computed as the ratio of the total wastewater flow for all land uses within a sub area to the average daily wastewater flow per person. The equivalent population inflow at each node of the proposed wastewater system is included with the peak flow calculations in Appendix A. A summary of the land use for Options 1 and 2 are provided in Table 2-1 *McDowell Mountain Back Bowl Land Use*.

**Table 2-1· McDowell Mountain Back Bowl Land Use**

| Land Use                | Option 1      | Option 2      |
|-------------------------|---------------|---------------|
| Residential Custom Lots | 125           | 146           |
| Commercial Area         | 10,000 Sq. ft | 10,000 Sq. ft |

### 2.2 Wastewater Flow Criteria

The following is a summary of the major wastewater flow criteria utilized:

1. The average wastewater flow for a *residential* dwelling unit with a density less than or equal to 2 dwelling units per acre is 250 gallons per day (gpd), based on an average wastewater flow of 100 gpd/person, and a density of 2.5 persons/dwelling unit.
2. The average wastewater flow for *non-residential* land use (club house) is 0.9 gpd/sq. ft.
3. The peak hour flow is 4.0 times the average-day flow.

### 2.3 Wastewater System Criteria

1. Sewer lines are designed to provide mean velocities during full-flow conditions greater than 2.5 feet per second (fps) and less than 10.0 fps, based upon Manning's formula, with a roughness coefficient value of "n" equal to 0.013.
2. Sewer lines are designed to convey the peak flow such that ratio of depth of flow to pipe diameter (d/D ratio) is less than or equal to 0.65 for pipe sizes less than 12 inches.
3. Sewer lines 8 inches in diameter shall be designed at the minimum slope of 0.0052 ft/ft.

**3 0 WASTEWATER FLOW CALCULATIONS**

The average-day and peak wastewater flows are calculated using the criteria discussed in Section 2 0 of this report Table 3 1 presents a summary of the average-day and peak-flow calculations for Options 1 and 2 Please refer to Appendix A – *Table 1 Estimated Peak Flow Calculations* for detailed flow calculations for Option 1, and Appendix B – *Table 1 Estimated Peak Flow Calculations* for detailed flow calculations for Option 2

**Table 3-1 Average and Peak Flows for Options 1 and 2**

| System   | Average-Day Flow | Peak-Flow |
|----------|------------------|-----------|
|          | (gpd)            | (gpd)     |
| Option 1 | 34,750           | 139,000   |
| Option 2 | 41,000           | 164,000   |

**3 1 Pipe Sizing and Capacity Calculations**

The pipe sizes are designed at the minimum slope using peak-flow pipe capacity and velocity calculations During peak-flow conditions, d/D ratios are less than the minimum requirement of 0 65 During full-flow conditions, pipe velocities are within the design range of 2 5 to 10 0 fps The actual pipe slopes and locations may vary upon final determination of subdivision layout Deviations from the proposed system in this report shall ensure minimum design criteria are followed

4 0 **GENERAL PLAN FOR THE ON-SITE WASTEWATER SYSTEM**

The proposed on-site master wastewater system for Options 1 and 2 consist of 8-inch diameter gravity sewer lines. Details of these systems are presented below.

4 1 **Proposed On-Site Collection System for Option 1**

Based on the topographic conditions, the proposed wastewater system for Option 1 consists of three (3) sewer systems and outfall locations. A description of these systems and the direction of the flow are as follows:

- Sewer System 1 Alameda Road outfall (Node A to Node I) in the northwest direction
- Sewer System 2 128<sup>th</sup> Street outfall (Node J to Node Q) in the eastern direction
- Sewer System 3 Happy Valley Road alignment outfall (Node R to Node AM) in the northern direction

Please refer to Plate 2 – *Option 1 Conceptual Master Wastewater System* for the pipe sizes and outfall locations. Sewer System 1 collects wastewater flow from Node A to Node I northwesterly and outfalls to the existing 8-inch gravity sewer along Alameda Road in Sonoran Crest. Sewer System 2 collects flows from Node J to Node Q easterly and outfalls to the proposed 8-inch gravity sewer along the 128<sup>th</sup> street alignment. System 3 collects flows from Node R to Node AM northerly and outfalls to the proposed 8-inch gravity sewer along the Happy Valley Road alignment. The proposed sewer systems consist of 8-inch diameter sewer lines to be constructed in the local collector roadways and sewer easements. Table 4-1 presents the average day and peak wastewater flows for the three (3) systems for Option 1. Please refer to Appendix A for detailed results.

**Table 4-1 Average and Peak Wastewater Flows for Option 1**

| System       | Average-Day Flow | Peak-Flow      |
|--------------|------------------|----------------|
|              | (gpd)            | (gpd)          |
| 1            | 7,000            | 28,000         |
| 2            | 6,500            | 26,000         |
| 3            | 21,250           | 85,000         |
| <b>Total</b> | <b>34,750</b>    | <b>139,000</b> |

**4 2 Proposed On-Site Collection System for Option 2**

Based on the topographic conditions, the proposed wastewater system for Option 2 consists of three (3) different sewer systems and outfall locations. A description of these systems and the direction of the flow are as follows:

Sewer System 1 Alameda Road outfall (Node A to Node I) in the northwest direction

Sewer System 2 Southerly 128<sup>th</sup> Street outfall (Node J to Node Q) in the eastern direction

Sewer System 3 Northerly 128<sup>th</sup> Street outfall (Node R to Node AM) in the northeast direction

Please refer to Plate 3 – *Option 2 Conceptual Master Wastewater System* for the pipe sizes and outfall locations. Sewer System 1 collects wastewater flow from Node A to Node I northwesterly and outfalls to the existing 8-inch gravity sewer along Alameda Road in Sonoran Crest. Sewer System 2 and System 3 collect wastewater flow from Node J to Node Q easterly and Node R to Node AM northeasterly, respectively, and outfall to the proposed 8-inch gravity sewer along the 128<sup>th</sup> street alignment. The proposed sewer systems consist of 8-inch diameter sewer lines to be constructed in the local collector roadways and sewer easements. Table 4-2 presents the average-day and peak wastewater flows for the three (3) systems for Option 2. Please refer to Appendix B for detailed results.

**Table 4-2 Average and Peak Wastewater Flows for Option 2**

| System       | Average-Day Flow | Peak-Flow      |
|--------------|------------------|----------------|
|              | (gpd)            | (gpd)          |
| 1            | 8,000            | 32,000         |
| 2            | 7,750            | 31,000         |
| 3            | 25,250           | 101,000        |
| <b>Total</b> | <b>41,000</b>    | <b>164,000</b> |

The 8-inch diameter on-site sewer lines proposed for Options 1 and 2 have adequate capacity to convey the estimated wastewater flow to the outfall locations. Please refer to *Table 2 Estimated Pipe Capacities* in Appendices A & B for Options 1 and 2 respectively. It is anticipated that some lots may require individual grinder pumps with private force mains that would discharge into the proposed gravity sewer system.



5 0 **GENERAL PLAN FOR THE OFF-SITE WASTEWATER SYSTEM**

The off-site sewer infrastructure for development Options 1 and 2 consists of existing gravity sewer systems within the Sonoran Crest and Granite Ridge development, proposed 8-inch gravity sewer lines, a sewage pumping station and force-main. The ultimate outfall for the wastewater flow generated by the *Back Bowl* will be conveyed southerly via the existing 10-inch sewer line along Happy Valley Road to the City of Scottsdale Water Reclamation Facility. Plates 2 and 3 (*Option 1 and 2 Conceptual Master Wastewater System*) identify the locations of the off-site sewer infrastructure.

For Option 1, flows directed in the north-west direction (sewer system 1) will outfall to the existing 8-inch gravity sewer system within Sonoran Crest. Flows directed in the eastern direction (sewer system 2) will be conveyed northerly via a proposed 8-inch gravity sewer line along 128<sup>th</sup> Street, from Node Q to a proposed sewage pumping station located near the intersection of 128<sup>th</sup> Street and the Happy Valley Road alignment. The proposed sewage pumping station will also collect flow from sewer system 3 via a proposed 8-inch gravity sewer line along the Happy Valley Road alignment.

Flows collected at the sewage pumping station would be pumped westerly through a proposed force-main along the Happy Valley Road alignment to the point of discharge into the existing 8-inch gravity sewer system within the Granite Ridge development. Please refer to Plate 2 for an illustration of the off-site sewer plan for Option 1.

The off-site sewer system for Option 2 is similar to Option 1, except for the proposed 8-inch gravity sewer line along the Happy Valley Road alignment. Option 2 allows flow from sewer system 3 to outfall to the proposed 8-inch gravity sewer along 128<sup>th</sup> Street. Please refer to Plate 3 for an illustration of the off-site sewer plan for Option 2.

The proposed sewage pumping station would be required to pump a design wastewater flow of 111,000 gpd or 132,000 gpd for Options 1 and 2 respectively, at an approximate total dynamic head of 42 feet. The force-main size necessary to convey these design flows at a minimum velocity of 4.0 fps is approximately 3-inches. The force main would be constructed of ductile iron pipe, and would be aligned along a graded and re-vegetated sewer easement to assure continual access to City maintenance crews. The preliminary design and location of this force main is conceptual and is intended to be finalized with the actual design of the force main.

According to the sewer improvement plan for the Sonoran Crest sewer system, the 8-inch outfall line is adequate to intercept the 28,000 gpd and 32,000 gpd peak wastewater flows generated by sewer system 1 for Options 1 and 2, respectively, with a surplus capacity of approximately 1.07 MG. Please refer to Appendix C – *Reference*) for the Sonoran Crest sewer improvement plan.

The outfall system within Granite Ridge has adequate capacity to intercept flows from the force-main, with a surplus capacity of roughly 0.42 MG. Information regarding the existing sewer system in Granite Ridge is obtained from the *Engineering Report for Sewer Construction Facilities for the Granite Ridge Subdivision*, prepared by Arcadis, dated January 23, 2003. A copy of this report is provided in Appendix C – *References*. Please refer to Table 2 under Appendices A and B for the capacity calculations for the Granite Ridge sewer system. Provisions will be made to accommodate odor control of the receiving manhole in the Granite Ridge Sewer System with the actual design of the force main.

## 6 0 CONCLUSIONS

Based on the analysis of the *Conceptual Master Wastewater System Report*, the following conclusions can be made

- 1 The wastewater demand and system criteria are consistent with the criteria established with the *City of Scottsdale Design Standards and Policies Manual* and *Arizona Department of Environmental Quality (ADEQ) Bulletin No 11*
- 2 Wastewater service will be supplied to the development through 8-inch diameter sewer lines
- 3 Average-day flow and peak-hour flow calculations are developed in order to provide preliminary sizing for the capacity of the sewer lines
- 4 Pipe capacities are such that the d/D ratio is not to exceed 0.60 during peak-hour conditions
- 5 The system is designed at the minimum slopes required to achieve a velocity under full-flow conditions between 2.5 fps and 10.0 fps
- 6 The existing 8-inch sewer along Alameda Road in Sonoran Crest and has adequate capacity to accommodate peak flows generated by the *back Bowl* development in the northwest direction for both Options 1 and 2
- 7 The existing 8-inch Granite Ridge gravity sewer system has adequate capacity to accommodate peak flows generated by the *back Bowl* development conveyed by the proposed force main for both Options 1 and 2
- 8 Finally, the existing sewer collector system along Happy Valley Road is more than capable of accommodating the additional flows from the *Back Bowl* development for both Options 1 and 2

**APPENDIX A**

**Option 1**

**Table 1: Estimated Wastewater Flow Calculations**

TABLE 1 WASTEWATER FLOW CALCULATIONS

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location City of Scottsdale  
 Date January 13 2005  
 References City of Scottsdale Design Standards and Policies Manual  
 Site Plan for Sonoran Crest dated 2/22/1999  
 Engineering Report for Construction of Sewer Facilities Granite Ridge Subdivision, Arizona Dated January 23, 2002  
 Sewer Quarter Section Map (48 55) City of Scottsdale, Arizona

| UPSTREAM NODE                                      | DOWNSTREAM NODE | PIPE DIA (IN) | PIPE SLOPE (FT / FT) | RESIDENTIAL                |            | NON-RESIDENTIAL |           | SUB AREA ADF (GPD) | EQUIVALENT POPULATION | TOTAL ADF (GPD) | PEAKING FACTOR | PEAK FLOW (GPD) |
|--|-----------------|---------------|----------------------|----------------------------|------------|-----------------|-----------|--------------------|-----------------------|-----------------|----------------|-----------------|
|  |                 |               |                      | DWELLING UNITS < 2 DU/ACRE | ADF/UNIT   | AREA (SQ FT)    | ADF/SQ FT |                    |                       |                 |                |                 |
| Gravity Outfall to Alameda Road                    |                 |               |                      |                            |            |                 |           |                    |                       |                 |                |                 |
| A  | B               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 1 000           | 4 00           | 4 000           |
| C  | B               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| B  | E               | 8             | 0 0052               | 8                          | 250        |                 |           | 2 000              | 20 0                  | 3 750           | 4 00           | 15 000          |
| D  | E               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 1 000           | 4 00           | 4 000           |
| E  | F               | 8             | 0 0052               | 1                          | 250        |                 |           | 250                | 2 5                   | 5 000           | 4 00           | 20 000          |
| G  | F               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 1 000           | 4 00           | 4 000           |
| F  | H               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 7 000           | 4 00           | 28 000          |
| H  | I               | 8             | 0 0052               |                            |            |                 |           |                    |                       | 7 000           | 4 00           | 28 000          |
| <b>Subtotal</b>                                    |                 |               |                      | <b>28</b>                  | <b>250</b> |                 |           | <b>7 000</b>       | <b>70 0</b>           | <b>7 000</b>    |                | <b>28 000</b>   |
| Gravity Outfall to 128th Street Alignment          |                 |               |                      |                            |            |                 |           |                    |                       |                 |                |                 |
| J1   | K               | 8             | 0 0052               | 5                          | 250        |                 |           | 1 250              | 12 5                  | 1 250           | 4 00           | 5 000           |
| L  | K               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 1 000           | 4 00           | 4 000           |
| K  | N               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 3 000           | 4 00           | 12 000          |
| M  | N               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| N  | P               | 8             | 0 0052               | 6                          | 250        |                 |           | 1 500              | 15 0                  | 5 250           | 4 00           | 21 000          |
| O  | P               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| P  | Q               | 8             | 0 0052               | 2                          | 250        |                 |           | 500                | 5 0                   | 6 500           | 4 00           | 26 000          |
| <b>Subtotal</b>                                    |                 |               |                      | <b>26</b>                  |            |                 |           | <b>6 500</b>       | <b>65 0</b>           | <b>6 500</b>    |                | <b>26 000</b>   |
| Gravity Outfall to the Happy Valley Road Alignment |                 |               |                      |                            |            |                 |           |                    |                       |                 |                |                 |
| R  | S               | 8             | 0 0052               | 4                          | 250        | 5000            | 0 0       | 5 500              | 55 0                  | 5 500           | 4 00           | 22 000          |
| S  | U               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 6 500           | 4 00           | 26 000          |
| T  | U               | 8             | 0 0052               | 2                          | 250        |                 |           | 500                | 5 0                   | 500             | 4 00           | 2 000           |
| U  | V               | 8             | 0 0052               | 2                          | 250        |                 |           | 500                | 5 0                   | 7 500           | 4 00           | 30 000          |
| W  | X               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| X  | Z               | 8             | 0 0052               | 4                          | 250        |                 |           | 1 000              | 10 0                  | 1 750           | 4 00           | 7 000           |
| Y  | Z               | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| Z  | V               | 8             | 0 0052               | 1                          | 250        |                 |           | 250                | 2 5                   | 2 750           | 4 00           | 11 000          |
| V  | AA              | 8             | 0 0052               | 6                          | 250        |                 |           | 1 500              | 15 0                  | 11 750          | 4 00           | 47 000          |
| AA   | AJ              | 8             | 0 0052               | 5                          | 250        |                 |           | 1 250              | 12 5                  | 13 000          | 4 00           | 52 000          |
| AK   | AJ              | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| AJ   | AH              | 8             | 0 0052               | 2                          | 250        |                 |           | 500                | 5 0                   | 14 250          | 4 00           | 57 000          |
| AB   | AC              | 8             | 0 0052               | 5                          | 250        |                 |           | 1 250              | 12 5                  | 1 250           | 4 00           | 5 000           |
| AD   | AC              | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| AC   | AE              | 8             | 0 0052               | 2                          | 250        |                 |           | 500                | 5 0                   | 2 500           | 4 00           | 10 000          |
| AE   | AF              | 8             | 0 0052               | 8                          | 250        |                 |           | 2 000              | 20 0                  | 4 500           | 4 00           | 18 000          |
| AG   | AF              | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| AF   | AH              | 8             | 0 0052               | 3                          | 250        |                 |           | 750                | 7 5                   | 6 000           | 4 00           | 24 000          |

**TABLE 1 WASTEWATER FLOW CALCULATIONS**

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location City of Scottsdale  
 Date January 13 2005  
 References City of Scottsdale Design Standards and Policies Manual  
 Site Plan for Sonoran Crest dated 2/22/1999  
 Engineering Report for Construction of Sewer Facilities Granite Ridge Subdivision, Arizona Dated January 23, 2002  
 Sewer Quarter Section Map (46 55) City of Scottsdale Arizona

| UPSTREAM NODE   | DOWNSTREAM NODE | PIPE DIA (IN) | PIPE SLOPE (FT / FT) | RESIDENTIAL                |          | NON RESIDENTIAL |            | SUB-AREA ADF (GPD) | EQUIVALENT POPULATION | TOTAL ADF (GPD) | PEAKING FACTOR | PEAK FLOW (GPD) |
|---|-----------------|---------------|----------------------|----------------------------|----------|-----------------|------------|--------------------|-----------------------|-----------------|----------------|-----------------|
|   |                 |               |                      | DWELLING UNITS < 2 DU/ACRE | ADF/UNIT | AREA (SQ FT)    | ADF/SQ FT  |                    |                       |                 |                |                 |
| AI  | AH              | 8             | 0 0052               | 3                          | 250      |                 |            | 750                | 7 5                   | 750             | 4 00           | 3 000           |
| AH  | AM              | 8             | 0 0052               | 1                          | 250      |                 |            | 250                | 2 5                   | 21 250          | 4 00           | 85 000          |
| AM  | AN              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 21 250          | 4 00           | 85 000          |
| <b>Subtotal</b>   |                 |               |                      | <b>67</b>                  |          | <b>5000</b>     | <b>0 9</b> | <b>21 250</b>      | <b>212 5</b>          | <b>21 250</b>   |                | <b>85 000</b>   |
| <b>Total</b>  |                 |               |                      | <b>121</b>                 |          |                 |            | <b>34 750</b>      | <b>347 5</b>          | <b>34 750</b>   |                | <b>139 000</b>  |
| <b>Outfall to Offsite Gravity Sewer System in Sonoran Crest</b> |                 |               |                      |                            |          |                 |            |                    |                       |                 |                |                 |
| I   | NODE 1          | 8             | 0 0200               |                            |          |                 |            | 7 000 0            | 70 0                  | 7 000           | 4              | 28 000          |
| NODE 1  | NODE 2          | 8             | 0 0239               |                            |          |                 |            |                    |                       | 7 000           | 4              | 28 000          |
| NODE 2  | NODE 3          | 8             | 0 0196               |                            |          |                 |            |                    |                       | 7 000           | 4              | 28 000          |
| NODE 4  | NODE 5          | 8             | 0 0052               |                            |          |                 |            |                    |                       | 7 000           | 4              | 28 000          |
| NODE 5 <sup>(1)</sup>   | NODE 6          | 8             | 0 0052               | 58 0                       | 250      |                 |            | 14 500 0           | 145 0                 | 21 500          | 4              | 86 000          |
| NODE 6  | NODE 7          | 8             | 0 0250               |                            |          |                 |            |                    |                       | 21 500          | 4              | 86 000          |
| NODE 7  | NODE 8          | 8             | 0 0281               |                            |          |                 |            |                    |                       | 21 500          | 4              | 86 000          |
| <b>Outfall to Offsite Gravity Sewer System in Granite Ridge</b> |                 |               |                      |                            |          |                 |            |                    |                       |                 |                |                 |
| Q   | NODE 4          | 8             | 0 0052               |                            |          |                 |            |                    |                       | 6 500           | 4              | 26 000          |
| NODE 4  | AM              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 6 500           | 4              | 26 000          |
| AM  | AN              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 27 750          | 4              | 111 000         |
| AN  | A0              |               |                      | FM                         |          |                 |            |                    |                       | 27 750          | 4              | 111 000         |
| A0 <sup>(2)</sup>   | AP              | 8             | 0 0052               | 12 0                       | 250      |                 |            | 3 000 0            | 30 0                  | 30 750          | 4              | 123 000         |
| AP <sup>(3)</sup>   | AQ              | 8             | 0 0052               | 114 0                      | 250      |                 |            | 28 500 0           | 285 0                 | 59 250          | 4              | 237 000         |
| AQ <sup>(4)</sup>   | AR              | 10            | 0 0040               | 76 0                       | 250      |                 |            | 19 000 0           | 180 0                 | 78 250          | 4              | 313 000         |
| AR  | AS              | 10            | 0 0040               |                            |          |                 |            |                    |                       | 78 250          | 4              | 313 000         |

Note

- 1) Contributing flows include flows generated from 58 dwelling units in Sonoran Crest
- 2) Contributing flows include flows generated from 12 lots in Granite Ridge
- 3) Contributing flows include flows generated from 114 lots in Desert Ridge
- 4) Contributing flows include flows generated from 18 lots in Boulder Mountain and 58 lots in Quarter Section 46-55

**Table 2: Estimated Pipe Capacities**



TABLE 2 ESTIMATED PIPE CAPACITIES

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location Scottsdale Arizona  
 Date January 12 2005

Project Number 042054 06  
 Project Engineer Gordon W Wark P E

| FROM NODE   | TO NODE | PIPE SIZE (IN) | PEAK FLOW (GPD) | PIPE SLOPE (FT/FT) | FULL FLOW VELOCITY, V <sub>f</sub> (FPS) | PARTIAL FLOW VELOCITY, V <sub>p</sub> (FPS) | PIPE CAPACITY (GPD) | SURPLUS CAPACITY (GPD) | d/D  |
|---|---------|----------------|-----------------|--------------------|--|---|---------------------|------------------------|------|
| <b>Gravity Outfall to the West</b>                                |         |                |                 |                    |  |   |                     |                        |      |
| A   | B       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| C   | B       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| B   | E       | 8              | 15 000          | 0 0052             | 2 5                                      | 1 1   | 564 339             | 549 339                | 0 11 |
| D   | E       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| E   | F       | 8              | 20 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 544 339                | 0 13 |
| G   | F       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| F   | H       | 8              | 28 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 536 339                | 0 15 |
| H   | I       | 8              | 28 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 536 339                | 0 15 |
| <b>Gravity Outfall to the East at Node S</b>                      |         |                |                 |                    |  |   |                     |                        |      |
| J1  | K       | 8              | 5 000           | 0 0052             | 2 5                                      | 0 8   | 564 339             | 559 339                | 0 07 |
| L   | K       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| K   | N       | 8              | 12 000          | 0 0052             | 2 5                                      | 1 0   | 564 339             | 552 339                | 0 10 |
| M   | N       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| N   | P       | 8              | 21 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 543 339                | 0 13 |
| O   | P       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| P   | Q       | 8              | 26 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 538 339                | 0 15 |
| <b>Gravity Outfall to the East at Node AF</b>                     |         |                |                 |                    |  |   |                     |                        |      |
| R   | S       | 8              | 22 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 542 339                | 0 13 |
| S   | U       | 8              | 26 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 538 339                | 0 15 |
| T   | U       | 8              | 2 000           | 0 0052             | 2 5                                      | 0 6   | 564 339             | 562 339                | 0 04 |
| U   | V       | 8              | 30 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 534 339                | 0 16 |
| W   | X       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| X   | Z       | 8              | 7 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 557 339                | 0 08 |
| Y   | Z       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| Z   | V       | 8              | 11 000          | 0 0052             | 2 5                                      | 1 0   | 564 339             | 553 339                | 0 10 |
| V   | AA      | 8              | 47 000          | 0 0052             | 2 5                                      | 1 5   | 564 339             | 517 339                | 0 20 |
| AA  | AJ      | 8              | 52 000          | 0 0052             | 2 5                                      | 1 6   | 564 339             | 512 339                | 0 21 |
| AK  | AJ      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| AJ  | AH      | 8              | 57 000          | 0 0052             | 2 5                                      | 1 6   | 564 339             | 507 339                | 0 21 |
| AB  | AC      | 8              | 5 000           | 0 0052             | 2 5                                      | 0 8   | 564 339             | 559 339                | 0 07 |
| AD  | AC      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| AC  | AE      | 8              | 10 000          | 0 0052             | 2 5                                      | 1 0   | 564 339             | 554 339                | 0 09 |
| AE  | AF      | 8              | 18 000          | 0 0052             | 2 5                                      | 1 1   | 564 339             | 546 339                | 0 12 |
| AG  | AF      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| AF  | AH      | 8              | 24 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 540 339                | 0 14 |
| AI  | AH      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| AH  | AM      | 8              | 85 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 479 339                | 0 26 |
| AM  | AN      | 8              | 85 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 479 339                | 0 26 |
| <b>Gravity Outfall to the Alameda Sewer Line in Sonoran Crest</b> |         |                |                 |                    |  |   |                     |                        |      |
| I   | NODE 1  | 8              | 28 000          | 0 0200             | 4 9                                      | 2 1   | 1 106 761           | 1 078 761              | 0 11 |
| NODE 1  | NODE 2  | 8              | 28 000          | 0 0239             | 5 4                                      | 2 2   | 1 209 867           | 1 181 867              | 0 11 |
| NODE 2  | NODE 3  | 8              | 28 000          | 0 0196             | 4 9                                      | 2 1   | 1 095 637           | 1 067 637              | 0 11 |
| NODE 4  | NODE 5  | 8              | 28 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 536 339                | 0 15 |
| NODE 5(1)   | NODE 6  | 8              | 86 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 478 339                | 0 26 |
| NODE 6  | NODE 7  | 8              | 86 000          | 0 0250             | 5 5                                      | 3 2   | 1 237 396           | 1 151 396              | 0 18 |
| NODE 7  | NODE 8  | 8              | 86 000          | 0 0281             | 5 8                                      | 3 3   | 1 311 873           | 1 225 873              | 0 17 |
| <b>Outfall to the Granite Ridge Gravity System</b>                |         |                |                 |                    |  |   |                     |                        |      |
| Q   | NODE 4  | 8              | 26 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 538 339                | 0 15 |
| NODE 4  | AM      | 8              | 26 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 538 339                | 0 15 |
| AM  | AN      | 8              | 111 000         | 0 0052             | 2 5                                      | 1 9   | 564 339             | 453 339                | 0 30 |
| AN  | AQ      | FM             | 111 000         |                    |  |   |                     |                        |      |
| AQ (2)  | AP      | 8              | 123 000         | 0 0052             | 2 5                                      | 2 0   | 564 339             | 441 339                | 0 32 |
| AP (3)  | AQ      | 8              | 237 000         | 0 0052             | 2 5                                      | 2 4   | 564 339             | 327 339                | 0 45 |
| AQ (4)  | AR      | 10             | 313 000         | 0 0040             | 2 5                                      | 2 3   | 897 486             | 584 486                | 0 41 |
| AR  | AS      | 10             | 313 000         | 0 0040             | 2 5                                      | 2 3   | 897 486             | 584 486                | 0 41 |

# WOOD/PATEL

CIVIL ENGINEERS \* HYDROLOGISTS \* LAND SURVEYORS \* CONSTRUCTION MANAGERS

## Force Main Calculations

|            |   |                  |              |
|------------|---|------------------|--------------|
| Project    | Master Wastewater Plan for McDowell Mountain Back Bowl  |                  |              |
| Location   | Scottsdale, Arizona                                     |                  |              |
| Date       | January 7, 2005   |                  |              |
| References | City of Scottsdale Design Standards and Policies Manual | Project Number   | 042054 06    |
| References | Hazen-Williams formula                                  | Project Engineer | Gordon W. W. |

### Known Values

|  |         |                                  |
|--|---------|----------------------------------|
| Hazen-Williams coefficient, C =                | 140     | PVC Force Main, "C" = 140        |
| Initial Elevation =                            | 2,640   | located at proposed sewage pump  |
| Final Elevation =                              | 2,660   | Existing Stub of Granite Ridge C |
| Forcemain Length (ft) =                        | 5,660   |                                  |
| Minor Loss Equivalent Length (10% of Length) = | 566     |                                  |
| Average Flow                                   | 27,750  | gpd                              |
| Peak Hour Flow                                 | 111,000 | gpd                              |

### Calculated Values

Referenced Equations

$$v = Q / A \quad (1 \text{ cfs} = 449 \text{ gpm})$$

$$A = \pi * [(D / 12) ^2] / 4$$

$$H_f = 3022 * [(v / C) ^1.85] / [(D / 12) ^1.65]$$

where v = velocity, feet per second (fps)

Q = flow rate, gallons per minute (gpm)

A = conveyance area, square feet

D = inside pipe diameter, inches

H<sub>f</sub> = head loss, feet per thousand feet of pipe

| Peak Flow (gpd) | Peak Flow (gpm) | Pipe Dia (in.) | Velocity (fps) | Head Loss per 1,000 ft (ft) | Total Friction Head Loss (ft) | Total Dynamic Head Loss (ft) | Pressure Loss (psi) |
|-----------------|-----------------|----------------|----------------|-----------------------------|-------------------------------|------------------------------|---------------------|
| 111,000         | 77.08           | 2              | 7.87           | 118.65                      | 49.0                          | 69.0                         | 30                  |
|                 |                 | 2.5            | 5.04           | 40.07                       | 31.4                          | 51.4                         | 22                  |
|                 |                 | 3              | 3.50           | 16.50                       | 21.8                          | 41.8                         | 18                  |
|                 |                 | 3.25           | 2.98           | 11.18                       | 18.6                          | 38.6                         | 17                  |
|                 |                 | 3.5            | 2.57           | 7.80                        | 16.0                          | 36.0                         | 16                  |

**Design Pipe Size = 3**

### Notes

- 1) The velocity and head loss calculations are based on the peak flow rate. The pump capacity should be used for the actual flow rate during the final lift station design.
- 2) Wet well sizing, pump cycling and pump discharge rates would be designed such that the minimum flow velocity in the forcemain is not less than 4 fps.
- 4) For higher-velocity force mains, it may be required to increase the size of the forcemain prior to discharging to a manhole, etc. in order to reduce the discharge velocity.
- 5) Surge calculations should be performed to ensure that the proper pipe class is being used.
- 6) When wastewater is pumped over a considerable distance, increasing the forcemain size may reduce horsepower requirements (and operation & maintenance costs) of the lift station pumps, due to reduced friction.

**APPENDIX B**

**Option 2**

**Table 1: Estimated Wastewater Flow Calculations**

TABLE 1 WASTEWATER FLOW CALCULATIONS

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location City of Scottsdale  
 Date January 25 2005  
 References City of Scottsdale Design Standards and Policies Manual  
 Site Plan for Sonoran Crest dated 2/22/1999  
 Engineering Report for Construction of Sewer Facilities Granite Ridge Subdivision Arizona Dated January 23 2002  
 Sewer Quarter Section Map (46-55) City of Scottsdale Arizona

Project Number 042054 06  
 Project Engineer Gordon W Wark P E

| UPSTREAM NODE                                  | DOWNSTREAM NODE | PIPE DIA (IN) | PIPE SLOPE (FT / FT) | RESIDENTIAL                |            | NON-RESIDENTIAL |           | SUB AREA ADF (GPD) | EQUIVALENT POPULATION | TOTAL ADF (GPD) | TOTAL EQUIVALENT POPULATION | PEAKING FACTOR | PEAK FLOW (GPD) |
|--|-----------------|---------------|----------------------|----------------------------|------------|-----------------|-----------|--------------------|-----------------------|-----------------|-----------------------------|----------------|-----------------|
|  |                 |               |                      | DWELLING UNITS < 2 DU/ACRE | ADF/UNIT   | AREA (SQ FT)    | ADF/SQ FT |                    |                       |                 |                             |                |                 |
| <b>Gravity Outfall to the West</b>             |                 |               |                      |                            |            |                 |           |                    |                       |                 |                             |                |                 |
| A1   | A               | 8             | 0.0052               | 4                          | 250        |                 |           | 1 000              | 10                    | 1 000           | 10                          | 4.00           | 4 000           |
| A  | B               | 8             | 0.0052               | 4                          | 250        |                 |           | 1 000              | 10                    | 2 000           | 20                          | 4.00           | 8 000           |
| C  | B               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3 000           |
| B  | E               | 8             | 0.0052               | 8                          | 250        |                 |           | 2,000              | 20                    | 4 750           | 48                          | 4.00           | 19 000          |
| D  | E               | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 1,000           | 10                          | 4.00           | 4 000           |
| E  | F               | 8             | 0.0052               | 1                          | 250        |                 |           | 250                | 3                     | 6,000           | 60                          | 4.00           | 24 000          |
| G  | F               | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 1 000           | 10                          | 4.00           | 4 000           |
| F  | H               | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 8,000           | 80                          | 4.00           | 32 000          |
| H  | I               | 8             | 0.0052               |                            | 0          |                 |           | 0                  | 0                     | 8,000           | 80                          | 4.00           | 32,000          |
| <b>Subtotal</b>                                |                 |               |                      | <b>32</b>                  | <b>250</b> |                 |           | <b>8,000</b>       |                       | <b>8,000</b>    | <b>80</b>                   |                | <b>32,000</b>   |
| <b>Gravity Outfall to the East at Node S</b>   |                 |               |                      |                            |            |                 |           |                    |                       |                 |                             |                |                 |
| J  | J1              | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3,000           |
| A1   | K               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3,000           |
| J1   | K               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 2 250           | 23                          | 4.00           | 9,000           |
| L  | K               | 8             | 0.0052               | 5                          | 250        |                 |           | 1,250              | 13                    | 1 250           | 13                          | 4.00           | 5,000           |
| K  | N               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 4 250           | 43                          | 4.00           | 17 000          |
| M  | N               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 50                          | 4.00           | 3 000           |
| N  | P               | 8             | 0.0052               | 8                          | 250        |                 |           | 1 500              | 15                    | 6 500           | 65                          | 4.00           | 26,000          |
| O  | P               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3 000           |
| P  | Q               | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 7,750           | 78                          | 4.00           | 31,000          |
| <b>Subtotal</b>                                |                 |               |                      | <b>31</b>                  |            |                 |           | <b>7,750</b>       |                       | <b>7,750</b>    | <b>78</b>                   |                | <b>31,000</b>   |
| <b>Gravity Outfall to the East at Node AFA</b> |                 |               |                      |                            |            |                 |           |                    |                       |                 |                             |                |                 |
| R  | S               | 8             | 0.0052               | 4                          | 250        | 5000            | 0.9       | 5 500              | 55                    | 5 500           | 55                          | 4.00           | 22 000          |
| S  | U               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 6 250           | 63                          | 4.00           | 25,000          |
| T  | U               | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 500             | 5                           | 4.00           | 2 000           |
| U  | V               | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 7 250           | 73                          | 4.00           | 29,000          |
| W  | X               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3 000           |
| X  | Z               | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 1,750           | 18                          | 4.00           | 7 000           |
| Y  | Z               | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3 000           |
| Z  | V               | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 3 000           | 30                          | 4.00           | 12,000          |
| V  | AA              | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 11,250          | 113                         | 4.00           | 45,000          |
| AA   | AJ              | 8             | 0.0052               | 4                          | 250        |                 |           | 1 000              | 10                    | 12,250          | 68                          | 5.00           | 61,250          |
| AB   | AC              | 8             | 0.0052               | 5                          | 250        |                 |           | 1 250              | 13                    | 1 250           | 13                          | 4.00           | 5 000           |
| AD   | AC              | 8             | 0.0052               | 4                          | 250        |                 |           | 1,000              | 10                    | 1 000           | 10                          | 4.00           | 4 000           |
| AC   | AE              | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 2 750           | 28                          | 4.00           | 11,000          |
| AE   | AE1             | 8             | 0.0052               | 8                          | 250        |                 |           | 1,500              | 15                    | 4,250           | 43                          | 4.00           | 17,000          |
| AE2  | AE1             | 8             | 0.0052               | 7                          | 250        |                 |           | 1,750              | 18                    | 1 750           | 18                          | 4.00           | 7 000           |
| AE1  | AH              | 8             | 0.0052               | 6                          | 250        |                 |           | 1,500              | 15                    | 7,500           | 75                          | 4.00           | 30 000          |
| AI   | AH              | 8             | 0.0052               | 3                          | 250        |                 |           | 750                | 8                     | 750             | 8                           | 4.00           | 3 000           |
| AH   | AJ              | 8             | 0.0052               | 2                          | 250        |                 |           | 500                | 5                     | 6 000           | 68                          | 4.00           | 32 000          |

**TABLE 1: WASTEWATER FLOW CALCULATIONS**

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location City of Scottsdale  
 Date January 25 2005  
 References City of Scottsdale Design Standards and Policies Manual  
 Site Plan for Sonoran Crest dated 2/22/1999  
 Engineering Report for Construction of Sewer Facilities Granite Ridge Subdivision, Arizona Dated January 23, 2002  
 Sewer Quarter Section Map (48 55) City of Scottsdale Arizona

Project Number 042054 06  
 Project Engineer Gordon W Wark, P E

| UPSTREAM NODE   | DOWNSTREAM NODE | PIPE DIA (IN) | PIPE SLOPE (FT / FT) | RESIDENTIAL                |          | NON-RESIDENTIAL |            | SUB-AREA ADF (GPD) | EQUIVALENT POPULATION | TOTAL ADF (GPD) | TOTAL EQUIVALENT POPULATION | PEAKING FACTOR | PEAK FLOW (GPD) |
|---|-----------------|---------------|----------------------|----------------------------|----------|-----------------|------------|--------------------|-----------------------|-----------------|-----------------------------|----------------|-----------------|
|   |                 |               |                      | DWELLING UNITS < 2 DU/ACRE | ADF/UNIT | AREA (SQ FT)    | ADF/SQ FT  |                    |                       |                 |                             |                |                 |
| AJ  | AK              | 8             | 0 0052               | 4                          | 250      |                 |            | 1,000              | 10                    | 22,000          | 98                          | 4 00           | 88 000          |
| AK  | AA2             | 8             | 0 0052               | 5                          | 250      |                 |            | 1,250              | 13                    | 23,250          | 110                         | 4 00           | 93 000          |
| AA1   | AA2             | 8             | 0 0052               | 8                          | 250      |                 |            | 2 000              | 20                    | 2 000           | 133                         | 4 00           | 8 000           |
| AA2   | AM              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 25,250          | 233                         | 4 00           | 101,000         |
| <b>Subtotal</b>   |                 |               |                      | <b>83</b>                  |          | <b>5,000</b>    | <b>0 9</b> | <b>25,250</b>      |                       | <b>25,250</b>   | <b>233</b>                  |                | <b>101,000</b>  |
| <b>Total</b>  |                 |               |                      | <b>146</b>                 |          |                 |            | <b>41,000</b>      |                       | <b>41,000</b>   | <b>390</b>                  |                | <b>164,000</b>  |
| <b>Gravity Outfall to the Alameda Sewer Line in Sonoran Crest</b> |                 |               |                      |                            |          |                 |            |                    |                       |                 |                             |                |                 |
| I   | NODE 1          | 8             | 0 0200               |                            |          |                 |            |                    |                       | 8,000           | 80                          | 4              | 32 000          |
| NODE 1  | NODE 2          | 8             | 0 0239               |                            |          |                 |            |                    |                       | 8,000           | 80                          | 4              | 32 000          |
| NODE 2  | NODE 3          | 8             | 0 0196               |                            |          |                 |            |                    |                       | 8,000           | 80                          | 4              | 32 000          |
| NODE 4  | NODE 5          | 8             | 0 0052               |                            |          |                 |            |                    |                       | 8,000           | 80                          | 4              | 32 000          |
| NODE 5 <sup>(1)</sup>   | NODE 6          | 8             | 0 0052               | 58                         | 250      |                 |            | 14,500             | 145                   | 22 500          | 225                         | 4              | 90,000          |
| NODE 6  | NODE 7          | 8             | 0 0250               |                            |          |                 |            |                    |                       | 22 500          | 225                         | 4              | 90 000          |
| NODE 7  | NODE 8          | 8             | 0 0281               |                            |          |                 |            |                    |                       | 22,500          | 225                         | 4              | 90,000          |
| <b>Outfall to the Granite Ridge Gravity System</b>                |                 |               |                      |                            |          |                 |            |                    |                       |                 |                             |                |                 |
| Q   | NODE 4          | 8             | 0 0052               |                            |          |                 |            |                    |                       | 7 750           | 78                          | 4              | 31,000          |
| NODE 4  | AM              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 7,750           | 78                          | 4              | 31,000          |
| AM  | AN              | 8             | 0 0052               |                            |          |                 |            |                    |                       | 33 000          | 310                         | 4              | 132 000         |
| AN  | A0              |               |                      | FM                         | 250      |                 |            |                    |                       | 33 000          | 310                         |                | 132 000         |
| A0 <sup>(2)</sup>   | AP              | 8             | 0 0052               | 12                         | 250      |                 |            | 3 000              | 30                    | 36 000          | 340                         | 4              | 144,000         |
| AP <sup>(3)</sup>   | AQ              | 8             | 0 0052               | 114                        | 250      |                 |            | 28 500             | 285                   | 64 500          | 625                         | 4              | 258 000         |
| AQ <sup>(4)</sup>   | AR              | 10            | 0 0040               | 76                         | 250      |                 |            | 18,000             | 190                   | 83 500          | 815                         | 4              | 334 000         |
| AR  | AS              | 10            | 0 0040               |                            |          |                 |            |                    |                       | 83,500          | 815                         | 4              | 334,000         |

- Note
- 1) Contributing flows include flows generated from 58 dwelling units in Sonoran Crest
  - 2) Contributing flows include flows generated from 12 lots in Granite Ridge
  - 3) Contributing flows include flows generated from 114 lots in Desert Ridge
  - 4) Contributing flows include flows generated from 18 lots in Boulder Mountain and 58 lots in Quarter Section 46-55

**Table 2: Estimated Pipe Capacities**

WOOD/PATEL

CIVIL ENGINEERS HYDROLOGISTS LAND SURVEYORS CONSTRUCTION MANAGERS

TABLE 2 ESTIMATED PIPE CAPACITIES

Project Master Wastewater Plan for McDowell Mountain Back Bowl  
 Location Scottsdale Arizona  
 Date January 25 2005

Project Number 042054 06  
 Project Engineer Gordon W Wark P E

| FROM NODE   | TO NODE | PIPE SIZE (IN) | PEAK FLOW (GPD) | PIPE SLOPE (FT/FT) | FULL FLOW VELOCITY, V <sub>f</sub> (FPS) | PARTIAL FLOW VELOCITY, V <sub>i</sub> (FPS) | PIPE CAPACITY (GPD) | SURPLUS CAPACITY (GPD) | d/D  |
|---|---------|----------------|-----------------|--------------------|--|---|---------------------|------------------------|------|
| <b>Gravity Outfall to the West</b>                                |         |                |                 |                    |  |   |                     |                        |      |
| A1  | A       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| A   | B       | 8              | 8 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 556 339                | 0 08 |
| C   | B       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| B   | E       | 8              | 19 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 545 339                | 0 13 |
| D   | E       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| E   | F       | 8              | 24 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 540 339                | 0 14 |
| G   | F       | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| F   | H       | 8              | 32 000          | 0 0052             | 2 5                                      | 1 4   | 564 339             | 532 339                | 0 16 |
| H   | I       | 8              | 32 000          | 0 0052             | 2 5                                      | 1 4   | 564 339             | 532 339                | 0 16 |
| <b>Gravity Outfall to the East at Node S</b>                      |         |                |                 |                    |  |   |                     |                        |      |
| J   | J1      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| A1  | K       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| J1  | K       | 8              | 9 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 555 339                | 0 09 |
| L   | K       | 8              | 5 000           | 0 0052             | 2 5                                      | 0 8   | 564 339             | 559 339                | 0 07 |
| K   | N       | 8              | 17 000          | 0 0052             | 2 5                                      | 1 1   | 564 339             | 547 339                | 0 12 |
| M   | N       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| N   | P       | 8              | 26 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 538 339                | 0 15 |
| O   | P       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| P   | Q       | 8              | 31 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 533 339                | 0 16 |
| <b>Gravity Outfall to the East at Node AF</b>                     |         |                |                 |                    |  |   |                     |                        |      |
| R   | S       | 8              | 22 000          | 0 0052             | 2 5                                      | 1 2   | 564 339             | 542 339                | 0 13 |
| S   | U       | 8              | 25 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 539 339                | 0 14 |
| T   | U       | 8              | 2 000           | 0 0052             | 2 5                                      | 0 6   | 564 339             | 562 339                | 0 04 |
| U   | V       | 8              | 29 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 535 339                | 0 15 |
| W   | X       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| X   | Z       | 8              | 7 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 557 339                | 0 08 |
| Y   | Z       | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| Z   | V       | 8              | 12 000          | 0 0052             | 2 5                                      | 1 0   | 564 339             | 552 339                | 0 10 |
| V   | AA      | 8              | 45 000          | 0 0052             | 2 5                                      | 1 5   | 564 339             | 519 339                | 0 19 |
| AA  | AJ      | 8              | 61 250          | 0 0052             | 2 5                                      | 1 6   | 564 339             | 503 089                | 0 22 |
| AB  | AC      | 8              | 5 000           | 0 0052             | 2 5                                      | 0 8   | 564 339             | 559 339                | 0 07 |
| AD  | AC      | 8              | 4 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 560 339                | 0 06 |
| AC  | AE      | 8              | 11 000          | 0 0052             | 2 5                                      | 1 0   | 564 339             | 553 339                | 0 10 |
| AE  | AE1     | 8              | 17 000          | 0 0052             | 2 5                                      | 1 1   | 564 339             | 547 339                | 0 12 |
| AE2   | AE1     | 8              | 7 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 557 339                | 0 08 |
| AE1   | AH      | 8              | 30 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 534 339                | 0 16 |
| AI  | AH      | 8              | 3 000           | 0 0052             | 2 5                                      | 0 7   | 564 339             | 561 339                | 0 05 |
| AH  | AJ      | 8              | 32 000          | 0 0052             | 2 5                                      | 1 4   | 564 339             | 532 339                | 0 16 |
| AJ  | AK      | 8              | 88 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 476 339                | 0 27 |
| AK  | AA2     | 8              | 93 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 471 339                | 0 27 |
| AA1   | AA2     | 8              | 8 000           | 0 0052             | 2 5                                      | 0 9   | 564 339             | 556 339                | 0 08 |
| AA2   | AM      | 8              | 101 000         | 0 0052             | 2 5                                      | 2   | 564 339             | 463 339                | 0 29 |
| <b>Gravity Outfall to the Alameda Sewer Line in Sonoran Crest</b> |         |                |                 |                    |  |   |                     |                        |      |
| I   | NODE 1  | 8              | 32 000          | 0 0200             | 4 9                                      | 2 2   | 1 106 761           | 1 074 761              | 0 12 |
| NODE 1  | NODE 2  | 8              | 32 000          | 0 0239             | 5 4                                      | 2 3   | 1 209 867           | 1 177 867              | 0 11 |
| NODE 2  | NODE 3  | 8              | 32 000          | 0 0196             | 4 9                                      | 2 2   | 1 095 637           | 1 063 637              | 0 12 |
| NODE 4  | NODE 5  | 8              | 32 000          | 0 0052             | 2 5                                      | 1 4   | 564 339             | 532 339                | 0 16 |
| NODE 5(1)   | NODE 6  | 8              | 90 000          | 0 0052             | 2 5                                      | 1 8   | 564 339             | 474 339                | 0 27 |
| NODE 6  | NODE 7  | 8              | 90 000          | 0 0250             | 5 5                                      | 3 2   | 1 237 396           | 1 147 396              | 0 18 |
| NODE 7  | NODE 8  | 8              | 90 000          | 0 0281             | 5 8                                      | 3 3   | 1 311 873           | 1 221 873              | 0 18 |
| <b>Outfall to the Granite Ridge Gravity System</b>                |         |                |                 |                    |  |   |                     |                        |      |
| Q   | NODE 4  | 8              | 31 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 533 339                | 0 16 |
| NODE 4  | AM      | 8              | 31 000          | 0 0052             | 2 5                                      | 1 3   | 564 339             | 533 339                | 0 16 |
| AM  | AN      | 8              | 132 000         | 0 0052             | 2 5                                      | 2 0   | 564 339             | 432 339                | 0 33 |
| AN  | A0      | 0              | 132 000         |                    |  |   |                     |                        |      |
| A0 (2)  | AP      | 8              | 144 000         | 0 0052             | 2 5                                      | 2 1   | 564 339             | 420 339                | 0 34 |
| AP (3)  | AQ      | 8              | 258 000         | 0 0052             | 2 5                                      | 2 4   | 564 339             | 306 339                | 0 47 |
| AQ (4)  | AR      | 10             | 334 000         | 0 0040             | 2 5                                      | 2 4   | 897 486             | 563 486                | 0 42 |
| AR  | AS      | 10             | 334 000         | 0 0040             | 2 5                                      | 2 4   | 897 486             | 563 486                | 0 42 |



**Force Main Calculations**

|            |   |                               |
|------------|---|-------------------------------|
| Project    | Master Wastewater Plan for McDowell Mountain Back Bowl  |                               |
| Location   | Scottsdale, Arizona                                     |                               |
| Date       | January 7, 2005   |                               |
| References | City of Scottsdale Design Standards and Policies Manual | Project Number 042054 06      |
| References | Hazen-Williams formula                                  | Project Engineer Gordon W. W. |

**Known Values**

|  |         |                                  |
|--|---------|----------------------------------|
| Hazen-Williams coefficient, C =                | 140     | PVC Force Main, "C" = 140        |
| Initial Elevation =                            | 2,640   | located at proposed sewage pump  |
| Final Elevation =                              | 2,660   | Existing Stub of Granite Ridge C |
| Forcemain Length (ft) =                        | 5,660   |                                  |
| Minor Loss Equivalent Length (10% of Length) = | 566     |                                  |
| Average Flow                                   | 33,000  | gpd                              |
| Peak Hour Flow                                 | 132,000 | gpd                              |

**Calculated Values**

Referenced Equations  
 $v = Q / A$  (1 cfs = 449 gpm)  
 $A = \pi * [(D / 12) ^2] / 4$   
 $H_f = 3022 * [(v / C) ^1.85] / [(D / 12) ^1.65]$

where v = velocity, feet per second (fps)  
 Q = flow rate, gallons per minute (gpm)  
 A = conveyance area, square feet  
 D = inside pipe diameter, inches  
 H<sub>f</sub> = head loss, feet per thousand feet of pipe

| Peak Flow (gpd) | Peak Flow (gpm) | Pipe Dia (in) | Velocity (fps) | Head Loss per 1,000 ft (ft) | Total Friction Head Loss (ft) | Total Dynamic Head Loss (ft) | Pressure Loss (psi) |
|-----------------|-----------------|---------------|----------------|-----------------------------|-------------------------------|------------------------------|---------------------|
| 132,000         | 91.67           | 2             | 9.36           | 163.49                      | 58.3                          | 78.3                         | 34                  |
|                 |                 | 2.5           | 5.99           | 55.21                       | 37.3                          | 57.3                         | 25                  |
|                 |                 | 3             | 4.16           | 22.74                       | 25.9                          | 45.9                         | 20                  |
|                 |                 | 3.25          | 3.55           | 15.41                       | 22.1                          | 42.1                         | 18                  |
|                 |                 | 3.5           | 3.06           | 10.74                       | 19.0                          | 39.0                         | 17                  |

**Design Pipe Size:** 3

**Notes**

- 1) The velocity and head loss calculations are based on the peak flow rate. The pump capacity should be used for the actual flow rate during the final lift station design.
- 2) Wet well sizing, pump cycling and pump discharge rates would be designed such that the minimum flow velocity in the forcemain is not less than 4 fps.
- 4) For higher-velocity force mains, it may be required to increase the size of the forcemain prior to discharging to a manhole, etc. in order to reduce the discharge velocity.
- 5) Surge calculations should be performed to ensure that the proper pipe class is being used.
- 6) When wastewater is pumped over a considerable distance, increasing the forcemain size may reduce horsepower requirements (and operation & maintenance costs) of the lift station pumps, due to reduced friction.

# WOOD/PATEL

CIVIL ENGINEERS \* HYDROLOGISTS \* LAND SURVEYORS \* CONSTRUCTION MANAGERS

## References

Project Master Wastewater Plan for McDowell Mountain Back Bowl Project Number 042054 06  
 Location Scottsdale, Arizona Project Engineer Gordon W Wark, P E  
 Date January 13, 2005  
 References City of Scottsdale Design Standards and Policies Manual

| Land Use       | Average Day Flow | Type                   | Pipe Size (IN) | Min Slope (FT/FT) | Design Flow (GPCD) | Peaking Factor | Manhole Spacing |
|----------------|------------------|------------------------|----------------|-------------------|--------------------|----------------|-----------------|
| Residential    | 250 gpd/DU       | Residential            | 8              | 0 00520           | 100                | 4              | 500             |
| Commercial     | 0 90 gpd/sf      | Commercial             | 10             | 0 00400           | 100                | 4              | 500             |
| General Office | 0 50 gpd/sf      | Retail                 | 12             | 0 00300           | 100                | 4              | 500             |
| Hotel          | 402 gpd/room     | Resort                 | 15             | 0 00220           | 105                | Harmons        | 500             |
|                |                  | Cultural/Institutional |                |                   | 105                | Harmons        | 600             |
|                |                  |                        |                |                   | 105                | Harmons        | 600             |
|                |                  |                        |                |                   | 105                | Harmons        | 600             |

Minimum Pipe Velocity 2 5 FPS  
 Maximum Pipe Velocity 10 FPS

Source ADEQ Bulletin

**APPENDIX C**

**References**

ductile iron pipe (DIP) with an approved interior and exterior liners. Those systems designed with velocities of 2.5 feet per second shall be constructed of either Vitrified Clay or Ductile Iron pipe. Alternate material will be considered by the City upon submittal of written request by the engineer.

*In general, pipe materials should not change between manholes.*

Where standard strength pipe is not structurally sufficient or when proper cover cannot be maintained, additional strength must be obtained by using extra-strength pipe, special bedding specifications or special construction methods.

All types of pipe material used in design shall have established ASTM, ANSI, or NSF standards of manufacture or seals of approval and shall be designated for use as sewer pipe.

No public sewers shall be less than eight (8) inches in diameter unless permission is received in writing from the Water Resources Department.

## **B SYSTEM LAYOUT**

If the horizontal direction or slope of the sewer line changes, a manhole shall be constructed. The horizontal angle formed between the two lines shall not be less than ninety (90) degrees. In sewers that are twelve (12) inches or larger, angles formed shall be between one hundred-twenty (120) and one hundred-fifty (150) degrees to the downstream pipe, for odor control purposes.

Horizontal curvilinear sewers will not be allowed.

Sewer flows shall not pass through collection systems that have not been accepted by the City of Scottsdale.

Public sewer flows shall not flow through a private sewer system.

All public sewer lines shall be located within a dedicated street right-of-way or private street access easement. All sewers shall be aligned parallel to and south or west of the street centerline. In general, sewer lines should not cross the street centerline except in cases where curvilinear roadway alignments are encountered.

## **C DESIGN FLOWS**

In the absence of flow data provided by the designer, new domestic sewage systems shall be designed in accordance with the following:

1. Sewers eight (8) to twelve (12) inches in diameter shall be designed with peak capacities, when flowing full, of not less than four hundred (400) gallons per capita per day (gpcd).
2. Sewer lines larger than twelve (12) inches in diameter shall be designed using one hundred five (105) gpcd and a peaking factor developed from "Harmon's Formula"

$$Q_{max} = Q_{avg} [1 + 14 / (4 + P^{1/2})]$$

WHERE P = Population / 1,000

Commercial flows should be based upon known regional data or accepted engineering reference sources, approved by the City.

Density data to be used in sewer design \*

|                       |                  |
|-----------------------|------------------|
| Single-family units   | 2.5 persons/unit |
| Multi-family units    |                  |
| Townhouse/Patio homes | 2.5 persons/unit |
| Apartments            | 2.5 persons/unit |

\*Subject to regional variations as approved by the City's Planning Department

#### D HYDRAULIC DESIGN

Sewer lines should be designed and constructed to give mean velocities of not less than 2.5 fps, based upon Manning's Formula, using an "n" value of 0.013. Hydrogen sulfide problems continue to be a concern, therefore must be analyzed in the Design Report and be provided for the design of the system where required. Conversely, to prevent abrasion and erosion of the pipe material, the maximum velocity shall be limited to 10 fps at estimated peak flow. Where velocities exceed this maximum figure, the line shall be constructed of DIP or its equivalent. In no case shall the velocities greater than 15 fps be allowed. All velocities should be analyzed under peak flow conditions.

The d/D ratio for gravity sewer pipes 12 inches in diameter and less shall be no greater than 0.65 in the ultimate peak flow condition. The d/D ratio for gravity sewers greater than 12 inches in diameter shall be no greater than 0.70 in the ultimate peak flow condition.

#### E MANHOLES AND CLEAN OUTS

Manholes in City streets must be located near the center of the traffic lane of the interior lane, rather than on or near the line separating traffic lanes. Manholes should not be located in bike trails, equestrian trails, sidewalks, or crosswalks. Manholes shall be installed at the end of each line, at all changes of grade, pipe sizes, alignments and at distances not to exceed those shown below:

| SPACING<br>Pipe Size - Inches | Maximum Manhole<br>Spacing - Feet |
|-------------------------------|-----------------------------------|
| 8 - 15                        | 500                               |
| 18 - 30                       | 600                               |
| 36 - 60                       | 800                               |
| Over 60                       | 1,300                             |

Cleanouts may be used in place of manholes at the end of laterals which cannot be extended and are less than one hundred fifty (150) feet in length. Cleanouts must be placed on the end of all line extensions to allow for cleaning and televising of lines. To assure line, grade and material compatibility, a manhole shall be installed at the point of connection when a cleanout is removed for a sewerline extension.

All manholes should be the pre-cast concrete type as detailed in the Maricopa Association of Governments (MAG) standard details for Public Works Construction, detail No. 420, excluding the steps and/or cast in anchors for steps. If a manhole is more than ten (10) feet deep or the line is over twelve (12) inches in diameter, the manhole shall be five (5) feet in diameter.

- 3) In addition to the acceptance test, the sewer line shall be cleaned to remove foreign material.
- 4) Manholes shall be placed at each end of the curve not to exceed 400 feet spacing

4 Manholes and Cleanouts

- a Location - Except as itemized below, manholes shall be installed at the end of each line at all changes of grade, pipe size, or alignment, at all sewer pipe intersections, and at distances not exceeding those shown below

MANHOLE SPACING

| Pipe Size (in ) | Max Manhole Spacing (ft ) |
|-----------------|---------------------------|
| 8 - 15          | 500                       |
| 18 - 30         | 600                       |
| 36 - 60         | 800                       |
| Over 60         | 1300                      |

Cleanouts may be used in place of manholes at the end of laterals less than 200 feet in length

Where manholes are located in areas of flooding, consideration shall be given in design to eliminate storm water entrance.

| Sewer Size |      | Minimum Slope to Maintain Velocity of |       |      |                    |      |      |
|------------|------|---------------------------------------|-------|------|--------------------|------|------|
| (in)       | (mm) | 2 0 fps (0 6 m/s)                     |       |      | 2 5 fps (0 75 m/s) |      |      |
| n          |      | 010                                   | 013   | 015  | 010                | 013  | 015  |
| 8          | 200  | 0020                                  | 0033  | 0045 | 0031               | 0052 | 0070 |
| 10         | 250  | 0015                                  | 0024  | 0033 | 0023               | 0037 | 0052 |
| 12         | 300  | 0011                                  | 0019  | 0026 | 0018               | 0030 | 0040 |
| 15         | 380  | 00085                                 | 0014  | 0019 | 0013               | 0022 | 0030 |
| 18         | 450  | 00067                                 | 0011  | 0015 | 0010               | 0017 | 0023 |
| 24         | 600  | 00045                                 | 00077 | 0010 | 00071              | 0012 | 0016 |

Table IV-1

Minimum Slope To Maintain Indicated Velocities Flowing Full  
(From Manning's Formula)

SAGUARO CANYON  
(BOOK 581 PART 4 M.L.N.)  
BEGIN CONSTRUCTION  
STA 1+00.00

MATCH SHEET 4  
STA 5+50.00

120TH PLACE  
STA 5+43.21  
MATCH SHEET 12

120TH PLACE  
STA 5+45.55  
BEGIN PHASE 2 CONSTRUCTION  
END PHASE 1 CONSTRUCTION

STA 1+44.00  
MATCH SHEET 6  
SAND HILLS ROAD

ALAMEDA ROAD  
SEWER 'A'

LINE DATA


| LINE | BEARING    | DISTANCE |
|------|------------|----------|
| L1   | S101°14'E  | 2.31     |
| L2   | S100°47'E  | 2.30     |
| L3   | S2°01'17"E | 6.97     |
| L4   | S2°10'17"E | 6.92     |

CURB/GUTTER DATA

| NO. | STATION | OFFSET   | TOP CURB | GUTTER  |
|-----|---------|----------|----------|---------|
| 1   | 5+43.21 | 8.50 RT  | 2669.54  | 2669.54 |
| 2   | 5+43.18 | 22.50 RT | 2669.70  | 2669.37 |
| 3   | 1+37.08 | 26.00 LT | 2690.46  | 2690.13 |
| 4   | 1+37.08 | 8.50 LT  | 2690.65  | 2690.32 |

CURVE DATA

| CURVE | DELTA  | RADIUS  | ARC LENGTH |
|-------|--------|---------|------------|
| C1    | 173.14 | 1000.00 | 21.30      |
| C2    | 80.00  | 30.00   | 47.12      |
| C3    | 100.00 | 8.75    | 27.49      |
| C4    | 90.00  | 30.00   | 47.12      |
| C5    | 91.13  | 30.00   | 47.76      |
| C6    | 80.00  | 7.00    | 21.99      |
| C7    | 86.54  | 30.00   | 46.55      |



**CONSTRUCTION NOTES**

**PAVING**

- INSTALL SURVEY MONUMENT PER M.A.G. STD. DTL. 1.24 I-B
- INSTALL STOP SIGN R-1 PER COS. STD. D.L. 2.1 & MUTCD
- INSTALL ROLL CURB AND OUTER (H=4) PER M.A.G. STD. DTL. 270-C
- INSTALL 5' CURB TRANSITION PER M.A.G. STD. DTL. 221
- INSTALL A.C. PAVEMENT-SEE STRUCTURAL SECTION ON SHEET 2
- INSTALL RIP RAP D=12" STONE TO BE NATIVE TO SITE AND TREATED WITH EON TE OR EQUIVALENT
- ADJUST MANHOLE RING TO GRADE PER COS. STD. DTL. 22.0
- INSTALL 2-4" PVC CONDUITS (32.5 LF)
- INSTALL 18" RIBBON CURB PER COS. STD. DTL. 2.20-B
- INSTALL SALVAGED BARRICADE PER M.A.G. STD. DTL. 1.30 TYPE 'B'
- INSTALL THICKENED EDGE PAVEMENT PER M.A.G. STD. DTL. TYPE 'B'
- ADJUST VALVE BOX TO GRADE PER M.A.G. STD. DTL. 391-1
- INSTALL TYPE 'A' BARRICADE PER M.A.G. STD. D.L. 30)

**SEWER**

- INSTALL 4" DIA. SEWER MANHOLE PER M.A.G. STD. DTL. 420 & 424
- INSTALL 4" SEWER SERVICE PER M.A.G. STD. DTL. 440
- INSTALL 8" PVC SEWER
- INSTALL SEWER STUB AT END OF LINE PER M.A.G. STD. DTL. 427
- INSTALL 5" DIA. SEWER MANHOLE PER M.A.G. STD. DTL. 420 & 424
- INSTALL 5" DIA. SEWER MANHOLE PER M.A.G. STD. DTL. 420 & 424 & 426 TYPE 'B'
- INSTALL FORCEMAIN MANHOLE DISCHARGE (SEE SHEET 2)
- INSTALL 1 1/2" SCH 80 PVC SEWER LINE (SEE DETAIL ON SHT 2)
- IN-LINE LOW-PRESSURE CLEAN-OUT (SEE DETAIL ON SHEET 2)
- INSTALL JUNCTION CLEAN-OUT PER DETAIL (SEE SHEET 2)
- INSTALL TERMINAL CLEAN-OUT PER DETAIL (SEE SHEET 2)
- INSTALL 1 1/2" SCH 80 PVC SEWER SERVICE (SEE DETAIL SHT 2)
- INSTALL SEWAGE AIR RELEASE MANHOLE (SEE DETAIL SHEET 2)
- CONCRETE ENCASEMENT OF SEWER PIPE PER M.A.G. STD. DTL. 404

**WATER**


- INSTALL 8" D.P. WATERLINE CLASS 350(TYP) (3' MIN. COVER)
- INSTALL 8" V.B. & C PER M.A.G. STD. DTL. 391-1-C
- INSTALL ELECTRONIC BALL MARKER PER COS. SS 6.04
- INSTALL 1" WATER SERVICE PER COS. STD. DTL. 2330
- INSTALL 8" X 8" D.I.P. 11 1/4" BEND W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL 8" X 2" BLOWOFF PER M.A.G. STD. DTL. 380-B W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL 6" FIRE HYDRANT (COMPLETE) PER M.A.G. STD. DTL. 360 W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL FIRE HYDRANT MARKER PER COS. STD. DTL. 2363
- INSTALL 8" X 8" D.I.P. 90° BEND W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL VERTICAL REALIGNMENT (COMPLETE) PER COS. STD. DTL. 2370 (AIR RELEASE VALVES INCLUDED)
- INSTALL 8" X 8" 45° BEND W/ MEGA LUG JOINT RESTRAINTS
- INSTALL 8" X 8" TEE W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL 6" D.I.P. WATERLINE CLASS 350(TYP) (3' MIN. COVER)
- INSTALL 6" V.B. & C PER M.A.G. STD. DTL. 391-1-C
- INSTALL 12" D.I.P. WATERLINE CLASS 350(TYP) (4' MIN. COVER)
- INSTALL 12" V.B. & C PER M.A.G. STD. DTL. 391-1-C
- INSTALL 17" X 8" D.I.P. TEE W/ MEGA LUG JOINT RESTRAINTS
- INSTALL 8" X 6" TEE W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
- INSTALL 12" CAP WITH 2" CURB STOP AND FLUSHING PIPE PER M.A.G. STD. DTL. 390, TYPE 'B'

**SKG ENTERPRISES INC**  
CONSULTING CIVIL ENGINEERS

**SONORAN CREST PAVING-WATER AND SEWER PLANS**

DATE: 11-14-00  
SCALE: AS SHOWN  
SHEET: 3 OF 21

227-PA-97 CS #57-4657-45 5-ZN-69 14-PP-69 3249-69A 3283-89-2



**LINE DATA**

| LINE | BEARING      | DISTANCE |
|------|--------------|----------|
| L1   | N26°21'35" W | 6.48     |

**CURVE DATA**


| CURVE | DATA    | RADIUS | ARC LENGTH |
|-------|---------|--------|------------|
| C1    | 2718.44 | 175.00 | 178.87     |
| C2    | 89.11   | 30.00  | 46.61      |
| C3    | 75.30   | 30.00  | 39.54      |
| C4    | 2718.44 | 161.00 | 172.18     |
| C5    | 80.00   | 7.00   | 21.99      |

**ALAMEDA ROAD SEWER 'A'**

NOTE CONTRACTOR SHALL LOCATE & MARK C.O.S. ON CURRENT VALVE STATUS (OPEN/CLOSED) CONTRACTOR LARRY TRITZ AT (480) 312-5631

**CONSTRUCTION NOTES**

- PAVING**
1. INSTALL ALL SURVEY MONUMENT PER MAG STD D.L. 120-B
  2. INSTALL STOP SIGN R1-1 PER COS STD D.L. 21.1 & MU CD
  3. INSTALL POLE CURB AND GUTTER (M=4) PER MAG STD D.L. 220-C
  4. INSTALL 5 CURB PANSION PER MAG STD D.L. 221
  5. INSTALL A.C. PAVEMENT-SEE STRUCTURAL SECTION ON SHEET 2
  6. INSTALL ALL R.P. RAP D. 12 (STONE TO BE NA VE 10 SITE AND TREATED WITH EMUL OR EQUIVALENT)
  7. ADJUST MANHOLE RINGS TO GRADE PER COS S.D. D.L. 227C
  8. INSTALL 2-4" PVC CONDUITS (32.5 L.F.)
  9. INSTALL 18" RIBBON CURB PER COS STD D.L. 2270-B
  10. INSTALL SALVAGED BARRICADE PER MAG S.D. D.L. 130 TYPE B
  11. INSTALL THICKENED EDGE PAVEMENT PER MAG STD D.L. 227C
  12. ADJUST VALVE BOX TO GRADE PER MAG STD D.L. 391-1-C
- SEWER**
1. INSTALL 4" DIA SEWER MANHOLE PER MAG S.D. D.L. 420 & 424
  2. INSTALL 4" SEWER SERVICE PER MAG STD D.L. 440
  3. INSTALL 8" PVC SEWER
  4. INSTALL SEWER STUB AT END OF LINE PER MAG STD D.L. 427
  5. INSTALL 5" DIA SEWER MANHOLE PER MAG STD D.L. 420 & 424
  6. INSTALL 5" DIA SEWER MANHOLE PER MAG STD D.L. 420 & 424
  7. INSTALL FORCEMAIN MANHOLE DISCHARGE (SEE DETAIL 2)
  8. INSTALL 1 1/2" SCH 80 PVC SEWER LINE (SEE DETAIL ON SHEET 2)
  9. IN-LINE LOW-PRESSURE CLEAN-OUT (SEE DETAIL ON SHEET 2)
  10. INSTALL JUNCTION CLEAN-OUT PER DETAIL (SEE SHEET 2)
  11. INSTALL TERMINAL CLEAN-OUT PER DETAIL (SEE SHEET 2)
  12. INSTALL 1 1/2" SCH 80 PVC SEWER SERVICE (SEE DETAIL SHEET 2)
  13. INSTALL SEWAGE AIR RELEASE MANHOLE (SEE DETAIL SHEET 2)
  14. CONCRETE ENCASUREMENT OF SEWER PIPE PER MAG STD D.L. 404
- WATER**
1. INSTALL 8" D.I.P. WATERLINE CLASS 350(TYP), (3 MM COVER)
  2. INSTALL 8" V.B. & L. PER MAG STD D.L. 391-1-C
  3. INSTALL ELECTRONIC BALL MARKER PER COS SS 010.4
  4. INSTALL 1" WATER SERVICE PER COS STD D.L. 2330
  5. INSTALL 8" X 8" D.I.P. 1/4 BEND W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  6. INSTALL 8" X 2" BLOWOFF PER MAG STD D.L. 390-B P/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  7. INSTALL 6" FIRE HYDRANT (COMPLETE) PER MAG STD D.L. 36. W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  8. INSTALL FIRE HYDRANT MARKER PER COS STD D.L. 2383
  9. INSTALL 8" X 8" D.I.P. 90° BEND W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  10. INSTALL VERTICAL REALIGNMENT (COMPLETE) PER COS STD D.L. 2370 (AIR RELEASE VALVES INCLUDED)
  11. INSTALL 5" X 8" 45° BEND W/ MEGA LUG JOINT RESTRAINTS
  12. INSTALL 8" X 8" TEE W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  13. INSTALL 6" D.I.P. WATERLINE CLASS 350(TYP), (3 MM COVER)
  14. INSTALL 2" V.B. & C PER MAG STD D.L. 391-1-C
  15. INSTALL 2" D.I.P. WATERLINE CLASS 350(TYP), (4 MM COVER)
  16. INSTALL 2" V.B. & C PER MAG STD D.L. 391-1-C
  17. INSTALL 12" X 8" D.I.P. TEE W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  18. INSTALL 8" X 8" TEE W/ MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL
  19. INSTALL ALL 12" CAP WITH 2" CURB STOP AND FLUSHING PIPE PER MAG STD D.L. 190 TYPE B
  20. INSTALL 12" 90° BEND W/ MEGA LUG JOINT RESTRAINTS
  21. INSTALL 8" PLUG W/ MEGA LUG JOINT RESTRAINTS
  22. INSTALL 12" PLUG W/ MEGA LUG JOINT RESTRAINTS
- \* INSTALL MEGA LUG JOINT RESTRAINTS OR C.O.S. APPROVED EQUAL AT ALL BENDS, TEES, CROSSINGS, VALVES AND END OF LINES



**SKG ENTERPRISES INC**

SONORAN CREST PAVING-WATER AND SEWER PLANS

227-PA-97 OS #57-4657-45 5-ZN-69 14-PP-99 3253-99A



*Presented to*

**MARICOPA COUNTY ENVIRONMENTAL SERVICES DEPARTMENT**

**WATER & WASTE MANAGEMENT DIVISION**

1001 North Central Avenue, Suite 150  
Phoenix, Arizona 85004

*and*

**CITY OF SCOTTSDALE WATER RESOURCES DIVISION**

4388 East San Salvador Drive  
Scottsdale, Arizona 85258

Triple Five Group of Companies  
Granite Ridge Subdivision  
Scottsdale, Arizona

Engineering Report for Construction  
of Sewer  
Facilities


**PREPARED FOR** \_\_\_\_\_


Triple Five Group of Companies


ARCADIS

Triple Five Group of Companies  
Granite Ridge Subdivision  
Scottsdale, Arizona

Engineering Report for  
Construction of Sewer  
Facilities

  
\_\_\_\_\_  
Jamie A. Sanders, PE  
Project Engineer

  
\_\_\_\_\_  
Jeffrey W. Bower, PE  
Project Engineer  
Arizona PE No. 37214

  
\_\_\_\_\_  
Burke P. Lokey, PE  
Project Manager  
Arizona PE No. 20809

Prepared for  
Triple Five Group of Companies

Prepared by  
ARCADIS G&M, Inc  
8222 S 48<sup>th</sup> Street  
Suite 140  
Phoenix, Arizona 85044  
Tel 602 438 0883  
Fax 602 438 0102

Our Ref  
AZ000809 0004

Date  
January 23 2002

*This document is intended only for the use of the individual or entity for which it was prepared and may contain information that is privileged confidential and exempt from disclosure under applicable law. Any dissemination distribution or copying of this document is strictly prohibited.*

|            |                            |           |
|------------|----------------------------|-----------|
| <b>1 0</b> | <b>Introduction</b>        | <b>1</b>  |
| 1 1        | Purpose                    | 1         |
| 1 2        | Project Contacts           | 2         |
| 1 3        | Site Location              | 2         |
| 1 4        | Existing Site Conditions   | 4         |
| <b>2 0</b> | <b>Sewer System Design</b> | <b>5</b>  |
| 2 1        | Materials                  | 5         |
| 2 2        | Hydraulic Design           | 5         |
| 2 3        | System Layout              | 8         |
| 2 4        | Pump Station Design        | 9         |
| 2 5        | Force Mains                | 9         |
| <b>3 0</b> | <b>References</b>          | <b>10</b> |

Appendices

Appendix Hydraulic Analysis of Sewer System



## 1 0 Introduction

### 1 1 Purpose

ARCADIS G&M, Inc (ARCADIS) was contracted by Triple Five Group of Companies to prepare construction drawings, specifications and County and City permit applications to construct a new sewer system for Granite Ridge subdivision in Scottsdale, Arizona. The new sanitary sewer system construction will include installation of 8-inch PVC gravity sewer mains and building service connections in accordance with City of Scottsdale, State, and County regulations.

This engineering report is part of the City of Scottsdale and Maricopa County Environmental Services Department (MCESD) subdivisions plan review package, and was prepared in accordance with the following standards:

- City of Scottsdale Design Standards and Policies, Revised 1999, Chapter 5, Wastewater
- ADEQ Aquifer Protection Permit, Arizona Administrative Code R18-9-E301 and
- City of Scottsdale Supplement to MAG Uniform Standard Specifications and Details for Public Works Construction and
- City of Scottsdale Design Guidelines and Policies for Environmentally Sensitive Lands
- Maricopa Association of Governments (MAG) Uniform Standard Specifications and Details for Public Works Construction

## 1.2 Project Contacts

The construction project owner is Triple Five Group of Companies. Barry Markham is the owner's representative. ARCADIS has prepared engineering analysis, reports, and construction drawings and specifications for this project. The owner and engineer contact information is as follows:

### *Owner*

Barry Markham  
Triple Five Group of Companies  
1201 S Alma School Road, Suite 10550  
Mesa, AZ 85210  
(480) 890-0555  
Fax (480) 898-0832

### *Engineers*

Burke Lokey, PE, Project Manager  
Jeff Bower, PE, Project Engineer  
ARCADIS G&M, Inc  
8222 S 48<sup>th</sup> Street, Suite 140  
Phoenix, AZ 85044  
(602) 438-0883  
Fax (602) 438-0102

## 1.3 Site Location

The project location is Scottsdale, Arizona just east of Troon Mountain from the intersection of Happy Valley and Alma School Roads. The project is bounded on the south by 118<sup>th</sup> Place and La Junta Road intersection, on the east by state owned lands, on the north by undeveloped private property, and on the west by the future 118<sup>th</sup> Street alignment. A vicinity map is provided as Figure 1.

The construction site is located in Section 3 of Township 4 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. The latitude and longitude near the center of the construction site are approximately 33°43'00" North and 111°50'00" West, respectively.

DATE 1/22/02 | PRJ# AZ000809 0004 | DWG G \TLR\LANDRESOURCES\809GRANITERIDGE\80904\ENGINEERING\_REPORTS\FIGURE1 DWG | CHK BPL | MAN BPL | ART JAS



NTS



VICINITY MAP

FIGURE

1

1.4 Existing Site Conditions

At this time, the project site consists of undeveloped desert, classified as Environmentally Sensitive Land (ESL) by the City of Scottsdale. No existing roads or utilities are presently known to exist on the property. Soil conditions were provided in a report by Construction Inspection & Testing Company titled *Soil Investigation, Residential Development 118<sup>th</sup> Street and Happy Valley Road, Scottsdale, Arizona* dated June 23, 1994. According to the report, the site predominantly consists of clayey sands (SC) with interbedded gravel deposits.

According to City of Scottsdale maps and verified by engineering reconnaissance, a sanitary sewer manhole exists at the intersection of North 118<sup>th</sup> Place and East La Junta Road. The manhole was measured and it was determined that the existing invert is approximately 7.4 feet below the rim elevation. The new sewer system intended for Granite Ridge will tie to this manhole and the manhole grouting will be modified as necessary to provide smooth flow lines.

## 2.0 Sewer System Design

This section presents an analysis of the proposed sewer system design as required to show compliance with the aforementioned regulations (see Figure 2 for system layout) This section is as follows

- 1 Materials
- 2 Hydraulic Design
- 3 System Layout
- 4 Pump Station Design
- 5 Force Mains

### 2.1 Materials

The material selected for the new sewer mains is Polyvinyl Chloride (PVC), SDR 35, which is permitted by the City of Scottsdale and MAG In general, sewer pipe burial depths will be from 4-ft to 10-ft, which are within the recommended design range for trench cover soil load and H-20 truck live loads (Umbell, 1997)


All sewer mains for this project will be minimum diameter of 8-in Building connection laterals will be 4-in pipes Building connections will be installed to the Right of way and marked for future building tie-in

### 2.2 Hydraulic Design

The hydraulic design of the sewerage system consists of determining the peak flow required, peak capacity available, and computing applicable sewer pipe slopes to meet requirements



FIGURE 2 PROPOSED WATER & SEWER SYSTEM LAYOUT



**LEGEND**

- |     |                   |       |               |
|-----|-------------------|-------|---------------|
| ——— | 8-IN WATER LINE   | ----- | SETBACKS      |
| ——— | 8-IN SEWER LINE   | ———   | LOT LINES     |
| ——— | ROADWAY C/L       | 12    | LOT NUMBER    |
| ——— | EXISTING FEATURES | ———   | CONCRETE CURB |
| ——— | SITE BOUNDARY     | ———   | P U E         |
|     |                   | ———   | RIGHT-OF-WAY  |



*Peak Capacity Required*

The City of Scottsdale design policies require that the peak capacity of the new sewer system be designed to handle 400-gallons per capita per day (gpcd) when flowing full. Using the City's planning data for typical density data of 2.5 persons per dwelling unit, the twelve (12) home lots planned for Granite Ridge will require a peak capacity of 12,000 gallons per day (gpd).

Granite Ridge will tie to the sewer system already in place for the Desert Crest subdivision. An analysis of the new total peak capacity for these two systems as they discharge to the City's 10-in main at Happy Valley Road is provided in the Appendix. Using Quarter Section map 46-56 showing the existing sewerage and home lots, the number of Desert Crest home lots was estimated to be 114. Peak capacity required for Desert Crest was computed to be 114,000 gpd for a total peak capacity required for the two subdivisions of 126,000 gpd.

The Contractor will be required to test the sewer system upon installation in accordance with MAG standards. According to MAG requirements, the maximum allowable leakage rate is 0.5-gallon per hour per 100 ft of pipe per inch diameter of pipe. Since the Contractor must meet this requirement for all pipe segments, it was assumed that the average infiltration rate for the system will be  $\frac{1}{2}$  of the required rate, which is 0.25 gallon per hour per 100 ft of pipe per inch diameter. For a total pipe length of 10,400 ft (1,500 ft for Granite Ridge and 8,900 ft for Desert Crest), a total infiltration rate of 4,992 gpd was estimated for the 8-in sewer mains. Desert Crest sewer pipe lengths were measured from Quarter Section map 46-56.

Total peak capacity required for Granite Ridge, Desert Crest, and estimated groundwater infiltration was computed to be 130,992 gpd (0.20 cfs).

*Peak Capacity Available*

An analysis for the Peak capacity available is included in the Appendix. The analysis is based upon the Manning's formula for a full circular pipe with roughness coefficient,  $n$ , of 0.013. With a minimum velocity criterion of 2.5 feet per second (fps), the required sewer pipe slope is 0.0052 and available capacity of 563,157 gpd. Available capacity at the required minimum slope exceeds the required capacity, indicating that the proposed 8-in pipe will adequately convey the wastewater. Calculations are included showing the

depth-to-diameter (d/D) ratios, flowrates, and velocities for several reaches within the subdivision. Results indicate that d/D will not exceed the 0.65 requirement for 8" pipe as per the City of Scottsdale DS&PM.

#### *Hydrogen Sulfide Generation Potential*

Hydrogen sulfide is known to be produced from within the slime layer that develops along the interior wall of sewer pipes. Key factors in the production of excessive amounts of hydrogen sulfide include the following (ASCE, 1982)

- Insufficient dissolved oxygen present in the wastewater
- High temperatures
- Inadequate pipe slope causing low wastewater velocities

Pipe slope and estimated wastewater velocities were computed and results indicate that the proposed slopes will not cause low velocities. Therefore, the high wastewater temperatures and insufficient oxygen are the operative parameters. An estimation of the hydrogen sulfide potential is provided in the Appendix. Results of the analysis show that the effective biological oxygen demand (EBOD) of the wastewater greatly affects hydrogen sulfide generation potential. If EBOD of the wastewater is kept less than 316-mg/l, then marginal conditions will exist for sulfide generation. Higher EBOD conditions may make sulfide generation more common.

### 2.3 System Layout

This project consists of installation of a wastewater collection system that will tie to the city's collection system at East Happy Valley Road (through the Desert Crest system). In accordance with ESL guidelines, the sewerage system will only be located within the road right of way.

To maintain velocity requirements, the proposed sewer pipes will be sloped at a minimum of 0.0052 ft / ft (0.52%). All proposed pipe runs will be straight, with manholes between runs where horizontal and vertical grade breaks, alignment changes, end of runs, or maximum spacing of 500-ft are required. Curvilinear pipe will not be used.

All manholes will be pre-cast concrete type as specified by MAG detail no 420. Additional manhole requirements by the City of Scottsdale are noted on the drawings.

*Separation between Water and Other Utilities*

New sewer mains will be installed such that they are at least horizontally 6 ft (outside diameter to outside diameter) from water mains and other utilities. At locations where the water mains must cross sewer mains, both mains will be encased in concrete as required by MAG Standard Specifications.

New sewer service connections (lateral) will be required to cross the water main. The sewer laterals will be installed below the water main and provide at least 12-inches of clearance. If it is not possible to place the new laterals at least 12-inches below the water mains, then the sewer laterals will be encased in 6-inches of concrete as required per City of Scottsdale requirements.

*Installation of Sewer Mains*

Gravity sewer mains will be installed and tested according to Section 615, Sewer Line Construction, MAG Uniform Standard Specifications for Public Works Construction and City of Scottsdale Supplement to MAG Construction drawings show the plan and profile views and include the required pipe slope, diameter, and estimated length for each pipe run. Sewer pipes will be placed at least four (4) feet below grade, and the pipes will be aligned to follow the paved streets.

**2.4 Pump Station Design**

Pump stations are not proposed for this development.

**2.5 Force Mains**

Force mains are not proposed for this development.

ARCADIS

Triple Five Group of  
Companies  
Granite Ridge Subdivision  
Scottsdale, Arizona

*Engineering Report for  
Construction of Sewer  
Facilities*

### 3 0 References

American Society of Civil Engineers (ASCE) Gravity Sanitary Sewer Design  
and Construction Manuals and Reports of Engineering Practice, No  
60 New York 1982

Unibell PVC Pipe Association Deflection The Pipe / Soil Mechanism UNI-  
TR-1-97 1997

ARCADIS

**Appendix**

Hydraulic Analysis of Sewer System

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## PURPOSE

This analysis was conducted to show compliance with City of Scottsdale and ADEQ regulations for sanitary sewer engineering design. This analysis is part of the Engineering Report to be submitted to both aforementioned agencies for review and approval of the Granite Ridge Subdivision sanitary sewer system. The analysis includes the following:

- 1 Estimate of design sewer flows
- 2 Hydraulic analysis of sewer
- 3 Analysis of hydrogen sulfide generation potential

## SUMMARY OF CONCLUSIONS

The results of the sanitary sewer system analysis indicate that the new sewer system for Granite Ridge will not adversely effect the existing system in Desert Crest. To maintain required flow velocities, the new system will be constructed with a minimum design slope of 0.0052 ft per ft of main.

### Revisions

| Rev No | Revision Descriptions |
|--------|-----------------------|
| 0      | Original Issue        |
|        |                       |
|        |                       |

### Sign off

| Rev No | Originator (Print) Sign/Date            | Verification/Checking Method | Verifier/Checker (Print) Sign/Date  |
|--------|---|------------------------------|-------------------------------------|
| 0      | J W Bower, PE<br><i>JWB</i> 21 Jan 2002 | Individual Critical Review   | B P Lokoy, PE<br><i>BPL</i> 1/22/02 |

GRANITE RIDGE SUBDIVISION  
BURIED SEWER PIPE DESIGN

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## TABLE OF CONTENTS

| <u>SECTION</u>                    | <u>PAGE NO</u> |
|-----------------------------------|----------------|
| I ASSUMPTIONS                     | 3              |
| II REFERENCES                     | 3              |
| III ANALYTICAL METHODS AND INPUTS | 4              |
| IV CALCULATIONS                   | 7              |
| V CONCLUSIONS                     | 14             |



# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## I. ASSUMPTIONS

- 1 The new sewer system will be flow by gravity and flow partially full
- 2 The flow conditions for the new system will approximate uniform flow conditions, thus the Manning formula will provide a reasonable approximation of the design flow conditions Solids were not considered within analysis
- 3 Existing Desert Crest sewer system consists of approximately 114 potential home sites Analysis will include addition of new sewer main to the Desert Crest system to Happy Valley Road

## II REFERENCES

- 1 City of Scottsdale Design Standards and Policies, Revised December 1999
- 2 City of Scottsdale Water and Sewer Quarter Section Map No 46-56 NE 1/4 Section 10, T4N, R5E undated
- 3 <removed>
- 4 Arcadis, G&M, Inc Preliminary Plat for Granite Ridge Subdivision March 2001
- 5 American Society of Civil Engineers (ASCE) Gravity Sanitary Sewer Design and Construction Manuals and Reports on Engineering Practice No 60 New York 1982
- 6 Maricopa Association of Governments (MAG) Uniform Standard Specifications for Public Works Construction (Rev 1999)

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

### III. ANALYTICAL METHODS AND INPUTS

#### A ESTIMATION OF DESIGN SANITARY SEWER FLOWS

In accordance with the City of Scottsdale Design Standards and Policies [1], the domestic sewage system planned for Granite Ridge will be designed for peak capacities, when flowing full, of at least 400 gallons per capita per day (gpcd) The proposed sewer line will be 8-in in diameter

Existing system for Desert Crest subdivision consists of 8-in PVC sewer mains [2] From Happy Valley Road, the existing sewer follows North 117th Street to Whispering Wind Drive and North 118th Place An additional 8-in branch ties to the 117th Street main from East Juan Tabo Road An estimation of the existing and addition of twelve new lots for Granite Ridge peak capacity when flowing full is computed below

#### PEAK DESIGN CAPACITY:

|                                    |                  |
|------------------------------------|------------------|
| Existing Lots (Desert Ridge)=      | 114              |
| Peak Capacity per capita per day = | 400 gpcd         |
| Density =                          | 2.5 persons/unit |
| Exist Peak Cap Total =             | 114,000 gpd      |
| <br>                               |                  |
| New lots (Granite Ridge) =         | 12               |
| Peak Capacity per capita per day = | 400 gpcd         |
| Density =                          | 2.5 persons/unit |
| New Lots Peak Cap Total =          | 12,000 gpd       |
| <br>                               |                  |
| Total New Peak Capacity =          | 126,000 gpd      |

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## B HYDRAULIC ANALYSIS

### MANNINGS FULL PIPE CALCULATION

The gravity sanitary sewer peak capacity, when flowing full, can be approximated using the Manning formula. The formula computes the estimated flowrate based on pipe diameter and pipe bed slope.

$$Q = \frac{1.486}{n} R^{2/3} S^{1/2} A$$

where,

- Q flowrate [cfs]
- n Mannings roughness factor
- R Hydraulic radius (area / wetted perimeter) [ft]
- S Pipe bed slope [ft/ft]
- A Pipe cross-sectional area [ft<sup>2</sup>]

The Manning's roughness factor is the approximate resistance to flow within the pipe. PVC pipe is very smooth, but will be approximately 0.013 when a slime layer develops – which is normal [1]. The hydraulic radius is one-fourth of the diameter (0.25 x D) for a full, circular pipe. The bed slope will vary for this project as shown in the design plans. Since the flowrate is directly proportional to the slope, the most shallow slope will be analyzed to estimate the least available flowrate for the subdivision. The pipe cross-sectional area is one-fourth of the diameter squared multiplied by pi (pi x D<sup>2</sup> / 4).

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002  
Project Name Granite Ridge subdivision  
Subject Sewer Design Calculations  
By JWB Date Dec 2001  
Checked by BPL Date Dec 2001

## C ESTIMATED SULFIDE GENERATION POTENTIAL

Sanitary sewers are at risk of internal corrosion damage due to hydrogen sulfide generation. The hydrogen sulfide is generally known to be produced from within the slime layer that develops along the interior wall of the sewer pipes. Key factors in the production of excessive amounts of hydrogen sulfide include insufficient dissolved oxygen present in the wastewater, high temperature wastewater, and inadequate sewer pipe slope causing low velocities [5]. Analysis of the anticipated wastewater DO and temperature are beyond the scope of this analysis and are difficult to control. However, the sewer pipe slope can be kept steep enough to reduce the potential for low velocities and hydrogen sulfide buildup.

One method proposed by ASCE, called the Z formula was applied to estimate the potential for hydrogen sulfide buildup in this new system [5]

$$Z = \frac{EBOD}{S^{0.5} Q^{0.33}} \times \frac{P}{b}$$

where,

$P$  wetted perimeter ( $= \theta \times D$ )  
 $b$  surface width ( $= ID \times \sin(180-\theta)$ )

For a partially flowing pipe,

$$\theta = \arccos\left(1 - 2\frac{d}{D}\right)$$

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## IV CALCULATIONS AND RESULTS

### INPUT PARAMETERS

Pipe ID = 8 in (inside diameter)  
n = 0.013 Mannings roughness coefficient

### A REQUIRED FLOWRATE

The total required peak flowrate is the calculated population density flow and infiltration by groundwater [3] MAG testing requirements allow a maximum groundwater infiltration rate of 0.5 gph per 100-ft of pipe per inch diameter of pipe [6] Since the Contractor must meet this requirement for all pipe segments, it was assumed that on average, the infiltration will be 1/2 of the MAG requirement or 0.25 per 100-ft of pipe per inch diameter Pipe length is approximate based on subdivision layout

#### New Pipe (Granite Ridge)

Pipe Dia = 8 in  
Pipe Ln = 1500 feet

Infiltration = 30 gph  
720 gpd

#### Existing Pipe (Desert Crest)

Pipe Dia = 8 in  
Pipe Ln = 8900 feet

Infiltration = 178 gph  
4272 gpd

Total Infiltration = 4992 gpd

#### Peak Capacity for Full Flowing Pipe

|                | (gpd)   | Discharge<br>(gpm) | (cfs)  |
|----------------|---------|--------------------|--------|
| Usage          | 126,000 | 87.50              | 0.1950 |
| + infiltration | 130,992 | 90.97              | 0.2027 |

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## B AVAILABLE DISCHARGE - FULL CIRCULAR PIPE

Pipe ID= 8 in  
A = 0.349 sf  
R = 0.167 ft

Available Discharge for varying slopes and FULL pipe

Required Full pipe discharge = 130,992 gpd

| Slope   | Discharge |       |         | Velocity<br>(ft/s) |
|---------|-----------|-------|---------|--------------------|
|         | (cfs)     | (gpm) | (gpd)   |                    |
| 0.00029 | 0.21      | 92    | 132,992 | 0.59               |
| 0.003   | 0.66      | 297   | 427,749 | 1.90               |
| 0.005   | 0.85      | 383   | 552,221 | 2.45               |
| 0.0052  | 0.87      | 391   | 563,157 | 2.50               |
| 0.01    | 1.21      | 542   | 780,959 | 3.46               |
| 0.013   | 1.38      | 618   | 890,430 | 3.95               |
| 0.015   | 1.48      | 664   | 956,475 | 4.24               |

Slope to meet required discharge

Slope to meet required velocity

Required Slope = 0.0052 ft/ft

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Jan 2001

Checked by BPL

Date Jan 2001

## AVAILABLE DISCHARGE - PARTIALLY FULL CIRCULAR PIPE

Flowrate estimates for three reaches within the subdivision are calculated below. Calculations are based on the city's Design Standard and Policies Manual data which advises 400 gpcd. Calculations assumed 2.5 persons per unit for this subdivision for a total of 1,000 gallons per unit per day (400 gpcd x 2.5 ppu).

### Reach No 1

Areas north of intersection Lots 2, 3, 4, 5, 6, 7, 8

No of Lots = 7

Peak Capacity = 7000 gpd

### Reach No 2

Areas east of intersection Lots 9, 10, 11, 12

No of Lots = 4

Peak Capacity = 4000 gpd

### Reach No 3

Subdivision entrance All Lots

No of Lots = 12

Peak Capacity = 12000 gpd

Analysis of the pipe flow depths, flowrates, and velocities were computed with FlowMaster, Version 6.1 by Haestad Methods. Minimum pipe slopes for the three reaches were selected from the design drawings to complete the analysis. Reaches 1 and 3 were sloped at 0.0052 ft/ft minimum and Reach 2 was sloped at 0.04 ft/ft.

Results from the FlowMaster analysis follow (3 pages). A summary table is provided below.

| Reach No | Slope [ft/ft] | Q [gpd] | Velocity [ft/s] | d/D   |
|----------|---------------|---------|-----------------|-------|
| 1        | 0.0052        | 7000    | 0.86            | 0.075 |
| 2        | 0.04          | 4000    | 1.47            | 0.03  |
| 3        | 0.0052        | 12000   | 1.01            | 0.105 |

Worksheet  
Worksheet for Circular Channel

OUTPUT - REACH No. 1

---

|                     |                        |
|---------------------|------------------------|
| Project Description |                        |
| Worksheet           | Granite Ridge Sanitary |
| Flow Element        | Circular Channel       |
| Method              | Manning's Formula      |
| Solve For           | Channel Depth          |

---

---

Input Data

---

|                      |                |                       |
|----------------------|----------------|-----------------------|
| Mannings Coefficient | 0.013          |                       |
| Slope                | 0.005200 ft/ft | ← slope from drawings |
| Diameter             | 8 in           |                       |
| Discharge            | 4860 gpm       | ← 7,000 gpd           |

---

---

Results

---

|                   |                        |
|-------------------|------------------------|
| Depth             | 0.05 ft                |
| Flow Area         | 1.3e-2 ft <sup>2</sup> |
| Wetted Perimeter  | 0.38 ft                |
| Top Width         | 0.36 ft                |
| Critical Depth    | 0.05 ft                |
| Percent Full      | 7.8 %                  |
| Critical Slope    | 0.008250 ft/ft         |
| Velocity          | 0.86 ft/s              |
| Velocity Head     | 0.01 ft                |
| Specific Energy   | 0.06 ft                |
| Froude Number     | 0.80                   |
| Maximum Discharge | 420698 gpm             |
| Discharge Full    | 391090 gpm             |
| Slope Full        | 0.000001 ft/ft         |
| Flow Type         | Subcritical            |

---



Worksheet  
Worksheet for Circular Channel

| Project Description |                        |
|---------------------|------------------------|
| Worksheet           | Granite Ridge Sanitary |
| Flow Element        | Circular Channel       |
| Method              | Manning's Formula      |
| Solve For           | Channel Depth          |

| Input Data           |                |
|----------------------|----------------|
| Mannings Coefficient | 0.013          |
| Slope                | 0.040000 ft/ft |
| Diameter             | 8 in           |
| Discharge            | 2780 gpm       |

— slope from drawings  
— 4,000 gpd

| Results           |                        |
|-------------------|------------------------|
| Depth             | 0.02 ft                |
| Flow Area         | 4.2e-3 ft <sup>2</sup> |
| Wetted Perimeter  | 0.26 ft                |
| Top Width         | 0.25 ft                |
| Critical Depth    | 0.04 ft                |
| Percent Full      | 3.7 %                  |
| Critical Slope    | 0.009078 ft/ft         |
| Velocity          | 1.47 ft/s              |
| Velocity Head     | 0.03 ft                |
| Specific Energy   | 0.06 ft                |
| Froude Number     | 2.00                   |
| Maximum Discharge | 1,166.805 gpm          |
| Discharge Full    | 1,084.688 gpm          |
| Slope Full        | 2.627485e-7 ft/ft      |
| Flow Type         | Supercritical          |

Worksheet  
Worksheet for Circular Channel

Output - REACH No. 3

---

|                     |                        |
|---------------------|------------------------|
| Project Description |                        |
| Worksheet           | Granite Ridge Sanitary |
| Flow Element        | Circular Channel       |
| Method              | Manning's Formula      |
| Solve For           | Channel Depth          |

---

---

|                      |                                      |
|----------------------|--------------------------------------|
| Input Data           |                                      |
| Mannings Coefficient | 0.013                                |
| Slope                | 0.005200 ft/ft ← slope from drawings |
| Diameter             | 8 in                                 |
| Discharge            | 8330 gpm ← 12,000 gpd                |

---

---

|                   |                        |
|-------------------|------------------------|
| Results           |                        |
| Depth             | 0.07 ft                |
| Flow Area         | 1.8e-2 ft <sup>2</sup> |
| Wetted Perimeter  | 0.43 ft                |
| Top Width         | 0.40 ft                |
| Critical Depth    | 0.06 ft                |
| Percent Full      | 10.1 %                 |
| Critical Slope    | 0.007676 ft/ft         |
| Velocity          | 1.01 ft/s              |
| Velocity Head     | 0.02 ft                |
| Specific Energy   | 0.08 ft                |
| Froude Number     | 0.83                   |
| Maximum Discharge | 420698 gpm             |
| Discharge Full    | 391090 gpm             |
| Slope Full        | 0.000002 ft/ft         |
| Flow Type         | Subcritical            |

---

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## C CHECK FOR HYDROGEN SULFIDE GENERATION POTENTIAL

### INPUT DATA

Pipe ID = 8 0 inches

Slope = 0 0052 ft/ft

Discharge = 130992 gpd

0 203 cfs

d = 3 0 in (assumed depth of partial flow in the pipe)

### CALCULATIONS

$\theta$  = 1 3181

P = 0 8787 ft

b = 0 645 ft

Check Z formula for several potential EBOD conditions

| EBOD (mg/l) | Z     | condition                 |
|-------------|-------|---------------------------|
| 156         | 4987  | sulfide rarely generated  |
| 157         | 5019  | marginal conditions       |
| 312         | 9974  | marginal conditions       |
| 313         | 10006 | sulfide generation common |
| 500         | 15984 | sulfide generation common |

Sewer system EBOD conditions are a function of several factors, like climate, temperature, loading rate, and others. Typical residential EBOD may be 200 mg/l to 500 mg/l [5]

# ARCADIS G&M

8222 South 48 Street, Phoenix, Arizona 85044

Project Number AZ000809 0004 TASK 00002

Project Name Granite Ridge subdivision

Subject Sewer Design Calculations

By JWB

Date Dec 2001

Checked by BPL

Date Dec 2001

## V CONCLUSIONS

Once tied into the Scottsdale wastewater system, The Granite Ridge subdivision will add 12 homes sites to the existing Desert Crest subdivision sewer main. Based on an estimate of available home sites from a city utility map [2], the proposed Granite Ridge layout [4], and estimated infiltration, a required sewer peak capacity flowrate of 135,984-gpd was computed.


Using Manning's equation for a gravity flowing pipe, the peak capacity will be maintained with a minimum slope of 0.0003 ft/ft and a pipe velocity requirement of 2.5-ft/sec can be met with a **minimum design slope of 0.0052 ft/ft**.

The potential for hydrogen sulfide generation within the new sewer system is greatly dependent upon the Biological Oxygen Demand (BOD) of the incoming wastewater. If the BOD is less than approximately 158-mg/l, then hydrogen sulfide generation is likely to be rare. If BOD is less than approximately 316-mg/l, then hydrogen sulfide generation is likely to be marginal. Greater BOD values will make hydrogen sulfide generation more common.

Hydrogen sulfide generation is due to several factors like amount of oxygen in the wastewater, ability of oxygen to get into the sewerage, flowrate, and temperature [5].

**PLATE 1**

**Vicinity Map**



**CROWN**  
COMMUNITY DEVELOPMENT  
*A Henry Crown Company*

**MCDOWELL MOUNTAIN BACK BOWL**


Plate I  
Vicinity Map

**WOOD/PATEL ASSOCIATES**  
Civil Engineers  
Hydrologists  
Land Surveyors  
(802) 335-8500

0

**PLATE 2**

**Option 1 Master Wastewater System**



OUTFALL TO EXISTING 8" GRAVITY SEWER IN GRANITE RIDGE

UNDEVELOPED STATE LAND

PROPOSED FORCE MAIN

OUTFALL TO PROPOSED 8" GRAVITY SEWER IN HAPPY VALLEY ROAD

HAPPY VALLEY ROAD (ALIGNMENT)

8" GRAVITY SEWER

PROPOSED SEWAGE PUMPING STATION

PROPOSED 8" GRAVITY SEWER



120TH STREET (ALIGNMENT)

SONORAN CREST

OUTFALL TO EXISTING 8" GRAVITY SEWER IN SONORAN CREST

128TH STREET

OUTFALL TO PROPOSED GRAVITY SEWER IN 128th ST.




PINNACLE PEAK ROAD (ALIGNMENT)

**LEGEND**

- DIRECTION OF FLOW
- 8-INCH SEWER LINE
- FORCE MAIN
- GRAVITY SEWER
- PROJECT BOUNDARY
- SEWER NODE
- LIFT STATION
- EXISTING 1 FOOT CONTOURS
- EXISTING 5 FOOT CONTOURS

**NOTE**  
 LOTTING AND ROADWAY LAYOUTS ARE CONCEPTUAL AND SUBJECT TO CHANGE. THE SEWER SYSTEM LAYOUT IS A CONCEPTUAL DESIGN ILLUSTRATING THE PIPE SIZES NECESSARY TO SERVE THE DEVELOPMENT AND IS NOT SPECIFIC TO ITS LOCATION.



**MCDOWELL MOUNTAIN BACK BOWL**

Plate 2


"Option 1 - Conceptual Master Wastewater System"

**WOOD/PATEL ASSOCIATES**  
 Civil Engineers  
 Hydrologists  
 Land Surveyors  
 (602) 335-8500



**PLATE 3**


**Option 2 Master Wastewater System**



**LEGEND**

- DIRECTION OF FLOW
- 8-INCH SEWER LINE
- FORCE MAIN
- GRAVITY SEWER
- PROJECT BOUNDARY
- SEWER NODE
- LIFT STATION
- EXISTING 1 FOOT CONTOURS
- EXISTING 5 FOOT CONTOURS

**NOTE**  
 LOTTING AND ROADWAY LAYOUTS ARE CONCEPTUAL AND SUBJECT TO CHANGE. THE SEWER SYSTEM LAYOUT IS A CONCEPTUAL DESIGN ILLUSTRATING THE PIPES SIZE NECESSARY TO SERVE THE DEVELOPMENT AND IS NOT SPECIFIC TO ITS LOCATION.



**McDOWELL MOUNTAIN BACK BOWL**

Plate 3

"Option 2 - Conceptual Master Wastewater System"

**WOOD/PATEL ASSOCIATES**  
 Civil Engineers  
 Hydrologists  
 Land Surveyors  
 (602) 335-8500