



SOUTHWEST GAS CORPORATION

March 23, 2010

Jeannette Miller
BERRY & DAMORE, LLC
6750 East Camelback Road, Suite 100
Scottsdale, Arizona 85251

SUBJECT: Right-of-Way Abandonment
SE Corner of 68th Street and Camelback Road - 10' alley (north
half)

After reviewing the plans for the above-referenced project, it has been determined that there are **no apparent conflicts** between the Southwest Gas system and your proposed abandonment as shown on the application you provided. Southwest Gas would like to recommend the abandonment of the right-of-way located at the above-referenced location.

Also be aware that it is against Southwest Gas Corporation standards to locate meter sets and regulators within enclosed structures. We prohibit developers from creating such an environment due to the risks and potential hazards associated with the presence of a gas meter in a confined space. If the scope of your project includes the construction, addition, or remodeling of a facility resulting in the enclosure of a gas meter, please contact us immediately to coordinate the meter and/or regulator relocations.

Thank you for your cooperation on this project. Please contact me if you have any questions or require additional information.

Sincerely,

Greg Cooper
Supervisor/Right-of-Way
Mail Station 420-588
(602) 484-5276

3-AB-2010
1st: 4/16/2010