

---

**Exterior Building Color & Material Samples**  
**Color Drawdowns**  
**Drainage Reports**  
**TIMA**  
**Abbreviated Water & Sewer Need Report**  
**Archaeological Resources**  
**Airport Vicinity Development Checklist**  
**Parking Study**  
**Trip Generation Comparison**  
**Parking Master Plan**  
**Water Study**  
**Wastewater Study**  
**Stormwater Waiver Application**



51 DR 2014

DATE: 11/18/14

Inspire on Earl  
7300 Earl  
Scottsdale

### FIRE ORDINANCE REQUIREMENTS

(INCORPORATE INTO BUILDING PLANS AS GENERAL NOTE BLOCK - USE ONLY THE DESIGNATED STIPULATIONS)

- 1. PREMISES IDENTIFICATION TO BE LEGIBLE FROM STREET OR DRIVE.
- 2. FIRE LANES & EMERGENCY ACCESS SHALL BE PROVIDED & MARKED IN COMPLIANCE WITH CITY ORDINANCE AND INTERNATIONAL FIRE CODE REQUIREMENTS.
- 3. PROVIDE ALL WEATHER ACCESS ROADS (MINIMUM 16' IN WIDTH) TO ALL BUILDINGS AND HYDRANTS FROM PUBLIC WAY DURING CONSTRUCTION.
- 4. PROVIDE A KNOX ACCESS SYSTEM:
  - A. KNOX BOX
  - B. PADLOCK
  - C. KEY SWITCH AND PREEMPTION DEVICE OVERRIDE FOR AUTOMATIC GATES
- 5. BUILDINGS ARE SUBJECT TO INSTALLATION AND TESTING REQUIREMENTS FOR A PUBLIC SAFETY RADIO AMPLIFICATION SYSTEM.
- 6. SUBMIT HAZARDOUS MATERIAL INVENTORY STATEMENT FOR ALL HAZARDOUS MATERIAL WHEN IFC PERMIT THRESHOLDS ARE MET. SUBMIT HMIS WITH BUILDING PLANS.
- 7. A FIRE SPRINKLER SYSTEM SHALL BE INSTALLED AND COMPLY WITH CURRENTLY ADOPTED NFPA STANDARDS.
- 8. FIRELINES SPRINKLERS AND STANDPIPE SYSTEMS SHALL BE FLUSHED AND PRESSURE TESTED PER NFPA STANDARDS AND SCOTTSDALE REVISED CODES.
- 9. BACKFLOW PREVENTION IS REQUIRED FOR CLASS 1 & 2 FIRE SPRINKLER SYSTEMS PER SCOTTSDALE REVISED CODE.
- 10. FIRE DEPARTMENT CONNECTIONS SHALL BE INSTALLED AT A LOCATION APPROVED BY THE AUTHORITY HAVING JURISDICTION.
- 11. FIRE SPRINKLER SYSTEM DESIGN FOR WAREHOUSE/STORAGE OCCUPANCIES SHALL BE BASED ON THE FULL HEIGHT CAPACITY OF THE BUILDING PER SCOTTSDALE REVISED CODE.
- 12. FIRE SPRINKLER SYSTEM DESIGN CRITERIA FOR UNSPECIFIED SHELL BUILDINGS SHALL BE .45GPM OVER 3000 SQUARE FEET.
- 13. PROVIDE (NFPA) OWNER'S CERTIFICATE WITH FIRE SPRINKLER PLAN SUBMITTAL.
- 14. \_\_\_\_\_
- 15. \_\_\_\_\_
- 16. \_\_\_\_\_
- 17. \_\_\_\_\_
- 18. \_\_\_\_\_

Submit three (3) complete sets of drawings submitted by installing contractor, after building plan review is complete. Please refer questions to Fire Dept. Plan Review, 312-2500.

ATTACHMENT B