

**Crossroads South Mixed-Use
Development
Scottsdale, Arizona**

PRELIMINARY
**Basis of Design
Water and Wastewater Needs Report**

Accepted for
**City of Scottsdale
Water Resources Administration
9379 E. San Salvador
Scottsdale, AZ 85258**

Prepared for:
*JLB Partners
9237 E Via de Ventura
Suite 215
Scottsdale, Arizona 85258*

*Doug Mann 4/14/16
(SEE COMMENTS)*

Prepared by:
*Kimley-Horn and Associates, Inc.
7740 North 16th Street
Suite 300
Phoenix, Arizona 85020*

191447017
March 2016

Copyright © 2016, Kimley-Horn and Associates, Inc.
Kimley»»Horn



Expires: 9/30/17

Crossroads South Mixed-Use Development Scottsdale, Arizona

Basis of Design Water and Wastewater Needs Report

Prepared for:

*JLB Partners
9237 E Via de Ventura
Suite 215
Scottsdale, Arizona 85258*

Prepared by:

*Kimley-Horn and Associates, Inc.
7740 North 16th Street
Suite 300
Phoenix, Arizona 85020*

191447014
March 2016

Copyright © 2016, Kimley-Horn and Associates, Inc.

This document, together with the concepts and designs presented herein, as an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kimley-Horn and Associates, Inc., shall be without liability to Kimley-Horn and Associates, Inc.

INTRODUCTION

Kimley-Horn and Associates, Inc. has prepared this water and wastewater report for the proposed Crossroads South Mixed-Use Development at the SEC of Scottsdale Road and Chauncey Lane as required per the City of Scottsdale.

The proposed project encompasses approximately 11.3 acres with 49,725 S.F. of mixed commercial use and a multi-story residential apartment building totaling 294 units.

DOMESTIC WATER SUPPLY

A 16" DIP water main exists in Scottsdale Road and a 12" DIP water main exists in Chauncey Lane adjacent to the site. The 16" water main within Scottsdale Road includes an 8" DIP stub to the proposed development. An 8" DIP water main loop will be constructed on-site that will serve new on-site fire hydrants and 8" firelines to the proposed buildings. This on-site water main will be connected to the 12" water main in Chauncey Lane and will be looped to the existing 8" DIP water main stub along Scottsdale Road. Domestic water supplies are proposed to serve the mixed-use commercial and apartment buildings. See Appendix C for the Preliminary Utility Plan.

Public w/L in 20' wide esmt

DOMESTIC WATER DEMANDS

clear of all parking spaces

According to the guidelines provided in Figure 6.1-2 of the City of Scottsdale *Standards and Policies, Chapter 6, Water*, the proposed building will add the following demands to the City of Scottsdale's existing system:

		Inside Demand	Outside Demand	Total Demand	ADD (GPM)	Peak Hour (GPM)	Maximum Day (GPM)
High Density Condo	294 Dwelling Units (DU)	155.3 (GPD/DU)	30 (GPD/DU)	185.3 (GPD/DU)	37.6	131.6	75.2
Commercial/Retail	33,050 S.F.	0.7 (GPD/SF)	0.1 (GPD/SF)	0.8 (GPD/SF)	18.2	63.7	36.4
Restaurant	16,675 S.F.	1.2 (GPD/SF)	0.1 (GPD/SF)	1.3 (GPD/SF)	15.0	52.5	30.0
TOTAL					70.8	247.8	141.6

The Peak Hour demand is 3.5 times the Average Daily Demand (ADD). The Maximum Day Demand is two times the ADD.

According to the 2012 International Fire Code (IFC), fire flow to Group R (residential) buildings may be reduced by 75% if an approved fire sprinkler system is installed. A fire sprinkler system will be installed with all buildings. The largest proposed building is 516,743 S.F. with a III-B Construction Type. Therefore, the required maximum building fire flow rate for the proposed buildings is 2,000 gallons per minute. Refer to Appendix A for the 2012 IFC excerpts.

Line hydraulics + FH flow test provided w/ final Report to be accepted prior to submittal of plans to the 1-stop shop.

WASTERWATER COLLECTION SYSTEM

A 15" VCP sewer main exists within Scottsdale Road. This sewer main includes an 8" stub to the site. A new 8" PVC private sewer main and sewer services are proposed on-site that will connect to the 8" PVC stub. See Appendix C for the Preliminary Utility Plan. The following demand calculations are based on Figure 7.1-2 of the City of Scottsdale *Design Standards and Policies Manual*.

		Demand	ADD (GPM)	Peaking Factor	Peak Demand (GPM)	Maximum Day (GPM)
High Density Condo	294 Dwelling Units	140 (GPD/DU)	28.4	4.5	127.8	56.8
Commercial/Retail	33,050 S.F.	0.5 (GPD/S.F.)	11.4	3	34.2	22.8
Restaurant	16,675 S.F.	1.2 (GPD/S.F.)	13.8	6	82.8	27.6
TOTAL			53.6		244.8	107.2

The Maximum Day Demand is two times the Average Day Demand (ADD).

CONCLUSION

Water

This development proposes to connect to City of Scottsdale water mains located adjacent to the site in Scottsdale Road and Chauncey Lane. The water main serving the Crossroads South Mixed-Use Development will be a looped system.

Wastewater

This development proposes to connect the building sewer services to the 8" PVC sewer main in Scottsdale Road via a new on-site 8" PVC sewer main. The proposed 8" PVC private sewer main has adequate capacity for the flows generated by the proposed buildings and their associated uses. Refer to Appendix B for the Sewer Capacity Calculations.

STATUS OF ANY REQUESTED PAYBACK IN 73RD
OR IS THE ~~SEWER~~ ^{WATER} AT THE SOLE COST OF THIS DEVELOPER.
I BELIEVE YOU NEED AN ADDITIONAL FFA IN THE CENTER OF
THE SITE (BUT EX SITE PLAN APPEARS TO CONFORM TO OUR
CRITERIA) ALL RDCS MUST BE W/IN 200' OF A FFA

Appendix A
2012 International Fire Code

SECTION B105 FIRE-FLOW REQUIREMENTS FOR BUILDINGS

B105.1 One- and two-family dwellings.

The minimum fire-flow and flow duration requirements for one- and two-family *dwellings* having a fire-flow calculation area that does not exceed 3,600 square feet (344.5 m²) shall be 1,000 gallons per minute (3785.4 L/min) for 1 hour. Fire-flow and flow duration for *dwellings* having a fire-flow calculation area in excess of 3,600 square feet (344.5m²) shall not be less than that specified in Table B105.1.

Exception: A reduction in required fire-flow of 50 percent, as *approved*, is allowed when the building is equipped with an *approved automatic sprinkler system*.

TABLE B105.1 MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS

FIRE-FLOW CALCULATION AREA (square feet)					FIRE-FLOW (gallons per minute) ^b	FLOW DURATION (hours)
Type IA and IB ^a	Type IIA and IIIA ^a	Type IV and V-A ^a	Type IIB and IIIB ^a	Type V-B ^a		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	3
83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	4
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-	92,401-	59,101-	42,701-	26,301-	4,500	

183,400	103,100	66,000	47,700	29,300	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000
—	—	115,801-125,500	83,701-90,600	51,501-55,700	6,250
—	—	125,501-135,500	90,601-97,900	55,701-60,200	6,500
—	—	135,501-145,800	97,901-106,800	60,201-64,800	6,750
—	—	145,801-156,700	106,801-113,200	64,801-69,600	7,000
—	—	156,701-167,900	113,201-121,300	69,601-74,600	7,250
—	—	167,901-179,400	121,301-129,600	74,601-79,800	7,500
—	—	179,401-191,400	129,601-138,300	79,801-85,100	7,750
—	—	191,401-Greater	138,301-Greater	85,101-Greater	8,000

For SI: 1 square foot = 0.0929 m², 1 gallon per minute = 3.785 L/m, 1 pound per square inch = 6.895 kPa.

- a. Types of construction are based on the *International Building Code*.
- b. Measured at 20 psi residual pressure.

B105.2 Buildings other than one- and two-family dwellings.

The minimum fire-flow and flow duration for buildings other than one- and two-family dwellings shall be as specified in Table B105.1.

Exception: A reduction in required fire-flow of up to 75 percent, as *approved*, is allowed when the building is provided with an *approved automatic sprinkler system* installed in accordance with Section 903.3.1.1 or 903.3.1.2. The resulting fire-flow shall not be less than 1,500 gallons per minute (5678 L/min) for the prescribed duration as specified in Table B105.1.

Appendix B
Sewer Capacity Calculations

Worksheet for 6" PVC Max. Slope

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.010
Channel Slope	4.53 %
Normal Depth	0.50 ft
Diameter	6.00 in
Discharge	697 gpm

Results

Discharge	697 gpm
Normal Depth	0.50 ft
Flow Area	0.20 ft ²
Wetted Perimeter	1.57 ft
Hydraulic Radius	0.13 ft
Top Width	0.00 ft
Critical Depth	0.49 ft
Percent Full	100.0 %
Critical Slope	0.04168 ft/ft
Velocity	7.91 ft/s
Velocity Head	0.97 ft
Specific Energy	1.47 ft
Froude Number	0.00
Maximum Discharge	1.67 ft ³ /s
Discharge Full	1.55 ft ³ /s
Slope Full	0.04530 ft/ft
Flow Type	SubCritical

*Final check to show
Actual flow, velocity
& D/1012 in each pipe
segment.*

GVF Input Data

Downstream Depth	0.00 ft
Length	0.00 ft
Number Of Steps	0

*On site system will
require county review.*

GVF Output Data

Upstream Depth	0.00 ft
Profile Description	
Profile Headloss	0.00 ft
Average End Depth Over Rise	0.00 %

Worksheet for 6" PVC Max. Slope

GVF Output Data

Normal Depth Over Rise	100.00	%
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	0.50	ft
Critical Depth	0.49	ft
Channel Slope	4.53	%
Critical Slope	0.04168	ft/ft

Worksheet for 6" PVC Min. Slope

Project Description

Friction Method Manning Formula
Solve For Full Flow Capacity

Input Data

Roughness Coefficient 0.010
Channel Slope 1.10 %
Normal Depth 0.50 ft
Diameter 6.00 in
Discharge 343 gpm

Results

Discharge 343 gpm
Normal Depth 0.50 ft
Flow Area 0.20 ft²
Wetted Perimeter 1.57 ft
Hydraulic Radius 0.13 ft
Top Width 0.00 ft
Critical Depth 0.44 ft
Percent Full 100.0 %
Critical Slope 0.00998 ft/ft
Velocity 3.90 ft/s
Velocity Head 0.24 ft
Specific Energy 0.74 ft
Froude Number 0.00
Maximum Discharge 0.82 ft³/s
Discharge Full 0.76 ft³/s
Slope Full 0.01100 ft/ft
Flow Type SubCritical

GVF Input Data

Downstream Depth 0.00 ft
Length 0.00 ft
Number Of Steps 0

GVF Output Data

Upstream Depth 0.00 ft
Profile Description
Profile Headloss 0.00 ft
Average End Depth Over Rise 0.00 %

Worksheet for 6" PVC Min. Slope

GVF Output Data		
-----------------	--	--

Normal Depth Over Rise	100.00	%
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	0.50	ft
Critical Depth	0.44	ft
Channel Slope	1.10	%
Critical Slope	0.00998	ft/ft

Worksheet for 8" PVC Max. Slope

Project Description

Friction Method Manning Formula
Solve For Full Flow Capacity

Input Data

Roughness Coefficient	0.010
Channel Slope	2.02 %
Normal Depth	0.67 ft
Diameter	8.00 in
Discharge	1002 gpm

Results

Discharge	1002 gpm
Normal Depth	0.67 ft
Flow Area	0.35 ft ²
Wetted Perimeter	2.09 ft
Hydraulic Radius	0.17 ft
Top Width	0.00 ft
Critical Depth	0.64 ft
Percent Full	100.0 %
Critical Slope	0.01759 ft/ft
Velocity	6.40 ft/s
Velocity Head	0.64 ft
Specific Energy	1.30 ft
Froude Number	0.00
Maximum Discharge	2.40 ft ³ /s
Discharge Full	2.23 ft ³ /s
Slope Full	0.02020 ft/ft
Flow Type	SubCritical

GVF Input Data

Downstream Depth	0.00 ft
Length	0.00 ft
Number Of Steps	0

GVF Output Data

Upstream Depth	0.00 ft
Profile Description	
Profile Headloss	0.00 ft
Average End Depth Over Rise	0.00 %

Worksheet for 8" PVC Max. Slope

GVF Output Data

Normal Depth Over Rise	100.00	%
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	0.67	ft
Critical Depth	0.64	ft
Channel Slope	2.02	%
Critical Slope	0.01759	ft/ft

Worksheet for 8" PVC Min. Slope

Project Description

Friction Method Manning Formula
Solve For Full Flow Capacity

Input Data

Roughness Coefficient	0.010
Channel Slope	0.40 %
Normal Depth	0.67 ft
Diameter	8.00 in
Discharge	446 gpm

Results

Discharge	446 gpm
Normal Depth	0.67 ft
Flow Area	0.35 ft ²
Wetted Perimeter	2.09 ft
Hydraulic Radius	0.17 ft
Top Width	0.00 ft
Critical Depth	0.47 ft
Percent Full	100.0 %
Critical Slope	0.00551 ft/ft
Velocity	2.85 ft/s
Velocity Head	0.13 ft
Specific Energy	0.79 ft
Froude Number	0.00
Maximum Discharge	1.07 ft ³ /s
Discharge Full	0.99 ft ³ /s
Slope Full	0.00400 ft/ft
Flow Type	SubCritical

GVF Input Data

Downstream Depth	0.00 ft
Length	0.00 ft
Number Of Steps	0

GVF Output Data

Upstream Depth	0.00 ft
Profile Description	
Profile Headloss	0.00 ft
Average End Depth Over Rise	0.00 %


Worksheet for 8" PVC Min. Slope

GVF Output Data

Normal Depth Over Rise	100.00	%
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	0.67	ft
Critical Depth	0.47	ft
Channel Slope	0.40	%
Critical Slope	0.00551	ft/ft

SEEK REDLINES

Appendix C
Preliminary Utility Plan



PRIVATE DOMESTIC WATER NOTES

- BUILDING DOMESTIC WATER CONNECTION, REF MEP PLANS FOR CONTINUATION.
- 2" SCH 40 PVC DOMESTIC WATER SERVICE.
- 2" DOUBLE CHECK VALVE BACKFLOW PREVENTION ASSEMBLY PER COS STD DET 2352.

PRIVATE FIRELINE NOTES

- 4" CLASS 350 DIP WATER MAIN POLYWRAPPED WITH TRACER WIRE, MINIMUM 3" COVER, BEDDING AND BACKFILL PER MAG SPEC 601.
- 4" GATE VALVE PER MAG STD DET 391-1 TYPE 'C'.
- BUILDING FIRELINE CONNECTION, REF MEP PLANS FOR CONTINUATION. FIRELINE RISER AND BACKFLOW PREVENTOR PER COS STD DET 2368 TO BE LOCATED IN FIRE RISER ROOM.

- PUBLIC WATER MAIN NOTES**
- 8" CLASS 350 DIP WATER MAIN POLYWRAPPED, MINIMUM 3" COVER, BEDDING AND BACKFILL PER MAG SPEC 601.
 - 8"x8" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 8" BEND WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 6" CLASS 350 DIP WATER MAIN POLYWRAPPED, MINIMUM 3" COVER, BEDDING AND BACKFILL PER MAG SPEC 601.
 - 8"x6" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - FIRE HYDRANT ASSEMBLY PER MAG STD DET 360.
 - 8" WATER MAIN GATE VALVE PER MAG STD DET 360.
 - 8"x4" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 2" WATER SERVICE LINE CONNECTION PER COS STD DET 2330. METER TO BE INSTALLED BY CITY FORCES.
- PRIVATE SEWER NOTES**
- 8" SDR 35 PVC PRIVATE SEWER MAIN, LENGTH AND SLOPE PER PLAN.
 - 48" SEWER MANHOLE PER MAG STD DET 420-2, INVERTS PER PLAN.
 - "WYE" CONNECTION, INVERT PER PLAN.
 - CONNECT TO BUILDING SEWER AT TWO-WAY CLEANOUT, INVERT PER PLAN, REF MEP PLANS FOR CONTINUATION.
 - 6" SDR 35 PVC SEWER SERVICE, LENGTH AND SLOPE PER PLAN.


MATCHLINE: SEE SHEET UT2

CIVIL ENGINEER
 KIMLEY-HORN AND ASSOCIATES, INC.
 7740 N. 16TH STREET, SUITE 300
 PHOENIX, ARIZONA 85020
 TEL. NO. (602) 944-5500
 CONTACT: STEVE HANEY, PE

ARCHITECT
 HENSLEY LAMKIN RACHEL, INC.
 11200 BROADWAY, SUITE 2749
 PEARLAND, TEXAS 77584
 PH: (832) 375-2983
 CONTACT: ROBERT BOOTH

LAND SURVEYOR
 SURVEY INNOVATION GROUP, INC
 7301 EAST EVANS ROAD
 SCOTTSDALE, ARIZONA 85260
 PH: (480) 922-0780
 CONTACT: JASON SEGNERI, P.L.S.

DEVELOPER/OWNER
 JLB PARTNERS
 9237 E VIA DE VENTURA, SUITE 215
 SCOTTSDALE, ARIZONA 85258
 PH: (480) 800-3070
 CONTACT: KEVIN RANSLI



KEY MAP
N.T.S.


GRAPHIC SCALE IN FEET
0 10 20 40

CALL TWO WORKING DAYS BEFORE YOU DIG
602-263-1100
1-800-STAKE-IT
(OUTSIDE MARICOPA COUNTY)

PRELIMINARY
 FOR REVIEW ONLY
 NOT FOR CONSTRUCTION

Kimley-Horn
 ENGINEER S. HANEY
 PE NO. 37029, DATE 03/16

447014Pre-UT.dwg



VICINITY MAP
 SCOTTSDALE, AZ
 N.T.S.

Kimley-Horn © 2016
 7740 North 16th Street, Suite 300
 Phoenix, Arizona 85020 (602) 944-5500

JLB PARTNERS

SEC SCOTTSDALE ROAD AND CHAUNCEY LANE
PRELIMINARY UTILITY PLAN
 SCOTTSDALE, ARIZONA

PROJECT No.
191447014

SCALE (H): 1"=20'
 SCALE (V): NONE

DRAWN BY: CGF
 DESIGN BY: TMJ
 CHECK BY: SEH
 DATE: 3/31/16

PRELIMINARY
 FOR REVIEW ONLY
 NOT FOR CONSTRUCTION


Kimley-Horn
 ENGINEER S. HANEY
 PE NO. 37029, DATE 03/16

447014Pre-UT.dwg


UT1
 1 OF 4 SHEETS

K:\PHX_Civil\191447014 - JLB Crossroads South\CADD\447014Pre-UT.dwg Layout:UT1 Mar 31, 2016 - 4:21pm Ethon_Casterton
 XREFS: X447014F X447014B X447014D X447014E X447014G X447014H X447014I X447014J X447014K X447014L X447014M X447014N X447014O X447014P X447014Q X447014R X447014S X447014T X447014U X447014V X447014W X447014X X447014Y X447014Z
 IF YOU PURCHASE OR REPRODUCE THIS DOCUMENT WITHOUT WRITTEN AUTHORIZATION AND ADJUSTED BY KIMLEY-HORN AND ASSOCIATES, INC. YOU WILL BE WITHOUT LIABILITY TO KIMLEY-HORN AND ASSOCIATES, INC.

MATCHLINE: SEE SHEET UT3



K:\PHX_Civil\191447014 - JLB Crossroads South\CADD\447014Pre-UT.dwg, Layout:UT1
 Mar 31, 2016 - 4:21pm Ethon, Costerton
 THIS DOCUMENT, DRAWING, DESIGN, AND/OR SPECIFICATIONS ARE THE PROPERTY OF KIMLEY-HORN AND ASSOCIATES, INC. AND SHALL BE WITHOUT LIABILITY TO KIMLEY-HORN AND ASSOCIATES, INC. IF AND UNLESS REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN AUTHORIZATION AND ADAPTATION BY KIMLEY-HORN AND ASSOCIATES, INC.



- PUBLIC WATER MAIN NOTES**
- 1 8" CLASS 350 DIP WATER MAIN POLYWRAPPED, MINIMUM 3' COVER. BEDDING AND BACKFILL PER MAG SPEC 601.
 - 3 8"x8" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 4 8" BEND WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 9 6" CLASS 350 DIP WATER MAIN POLYWRAPPED, MINIMUM 3' COVER. BEDDING AND BACKFILL PER MAG SPEC 601.
 - 10 8"x6" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 11 FIRE HYDRANT ASSEMBLY PER MAG STD DET 360.
 - 13 8" WATER MAIN GATE VALVE PER MAG STD DET 360.
 - 14 8"x4" TEE WITH RESTRAINED JOINTS PER MAG STD DET 303.
 - 15 2" WATER SERVICE LINE CONNECTION PER COS STD DET 2330. METER TO BE INSTALLED BY CITY FORCES.
- PRIVATE SEWER NOTES**
- 1 8" SDR 35 PVC PRIVATE SEWER MAIN, LENGTH AND SLOPE PER PLAN.
 - 2 48" SEWER MANHOLE PER MAG STD DET 420-2, INVERTS PER PLAN.
 - 3 "WYE" CONNECTION, INVERT PER PLAN.
 - 5 CONNECT TO BUILDING SEWER AT TWO-WAY CLEANOUT, INVERT PER PLAN. REF MEP PLANS FOR CONTINUATION.
 - 6 8" SDR 35 PVC SEWER SERVICE, LENGTH AND SLOPE PER PLAN.

- PRIVATE DOMESTIC WATER NOTES**
- 1 BUILDING DOMESTIC WATER CONNECTION, REF MEP PLANS FOR CONTINUATION.
 - 2 2" SCH 40 PVC DOMESTIC WATER SERVICE.
 - 3 2" DOUBLE CHECK VALVE BACKFLOW PREVENTION ASSEMBLY PER COS STD DET 2352.

- PRIVATE FIRELINE NOTES**
- 1 4" CLASS 350 DIP WATER MAIN POLYWRAPPED WITH TRACER WIRE, MINIMUM 3' COVER. BEDDING AND BACKFILL PER MAG SPEC 601.
 - 2 4" GATE VALVE PER MAG STD DET 391-1 TYPE 'C'.
 - 3 BUILDING FIRELINE CONNECTION, REF MEP PLANS FOR CONTINUATION. FIRELINE RISER AND BACKFLOW PREVENTOR PER COS STD DET 2368 TO BE LOCATED IN FIRE RISER ROOM.

PROP. RETAIL / RESTAURANT
 9,200 SF
 LF₈₈=1573.24


PROP. RETAIL / RESTAURANT
 8,050 SF
 LF₈₈=1573.24

CIVIL ENGINEER
 KIMLEY-HORN AND ASSOCIATES, INC.
 7740 N. 16TH STREET, SUITE 300
 PHOENIX, ARIZONA 85020
 TEL. NO. (602) 944-5500
 CONTACT: STEVE HANEY, PE

ARCHITECT
 HENSLEY LAMKIN RACHEL, INC.
 11200 BROADWAY, SUITE 2749
 PEARLAND, TEXAS 77584
 PH: (832) 379-2983
 CONTACT: ROBERT BOOTH

LAND SURVEYOR
 SURVEY INNOVATION GROUP, INC
 7301 EAST EVANS ROAD
 SCOTTSDALE, ARIZONA 85260
 PH: (480) 922-0780
 CONTACT: JASON SEGNERI, P.L.S.

DEVELOPER/OWNER
 JLB PARTNERS
 9237 E VIA DE VENTURA, SUITE 215
 SCOTTSDALE, ARIZONA 85258
 PH: (480) 800-3070
 CONTACT: KEVIN RANSIL



KEY MAP
 N.T.S.

GRAPHIC SCALE IN FEET
 0 10 20 40

CALL TWO WORKING DAYS BEFORE YOU DIG
602-263-1100
1-800-STAKE-IT
 (OUTSIDE MARICOPA COUNTY)

PROJECT No. 191447014
 SCALE (H): 1"=20'
 SCALE (V): NONE
 DRAWN BY: CGF
 DESIGN BY: TMJ
 CHECK BY: SEH
 DATE: 3/31/16

PRELIMINARY
 FOR REVIEW ONLY
 NOT FOR CONSTRUCTION

Kimley-Horn
 ENGINEER S. HANEY
 PE NO. 37059 DATE 03/16

