



Preliminary Engineering Report
Prepared: October 2016

StoryRock Lift Station #2

Prepared for:

CAV-RANCH, LLC.
14400 North 7th Place
Scottsdale, Arizona 85260

Prepared by:

Kimley-Horn and Associates, Inc.
7740 N. 16th Street, Suite 300
Phoenix, AZ 85020
(602) 944-5500

191069013
© Kimley-Horn and Associates, Inc
October, 2016.

*NO COMMENTS
12/6/2016*

Kimley»Horn

Preliminary Engineering Report

Prepared: October 2016

StoryRock Lift Station #2


Prepared for:

CAV-RANCH, LLC.
14400 North 7th Place
Scottsdale, Arizona 85260

Prepared by:

Kimley-Horn and Associates, Inc.
7740 N. 16th Street, Suite 300
Phoenix, AZ 85020
(602) 944-5500

191069013
© Kimley-Horn and Associates, Inc
October, 2016.



Expires 08/30/17

TABLE OF CONTENTS

EXECUTIVE SUMMARY	4
LIFT STATION ANALYSIS SITE ANALYSIS	4
PUMPS	4
FORCE MAIN ANALYSIS	4
ELECTRICAL SYSTEMS ANALYSIS	4
ODOR CONTROL ANALYSIS	4
OPINION OF PROBABLE COST	4
1.0 INTRODUCTION	5
1.1 PROJECT BACKGROUND	5
1.2 PROJECT SCOPE	5
2.0 DESIGN CRITERIA	8
2.1 LIFT STATIONS	8
2.2 FORCE MAIN	8
2.3 LIFT STATION DESIGN	9
3.0 CIVIL ANALYSIS	11
3.1 ADJACENT SANITARY SYSTEMS	11
3.2 EXISTING LIFT STATION AND SERENO CANYON SERVICE AREA	13
3.3 PROPOSED SYSTEM LAYOUT	13
3.4 PROPOSED SITE LAYOUT	13
4.0 HYDRAULIC AND CAPACITY ANALYSIS OF PROPOSED LIFT STATION	15
4.1 SERENO CANYON LIFT STATION ALLOCATION	15
4.2 SERENO CANYON SERVICE AREA	15
4.3 SITE REQUIRED CAPACITY	15
4.4 PUMP & FORCE MAIN PHASING	16
5.0 SITEWORK	19
5.0 SITE OPTIONS	19
5.1 WALL	19
5.2 ODOR CONTROL	19
5.3 GENERATOR	20
5.4 CONTROLS	20
5.5 LIGHTING	20
5.6 PUMP ENCLOSURE	20
6.0 PERMITS REQUIRED	22
7.0 RECOMMENDATIONS	23
8.0 REFERENCES	24

LIST OF APPENDICES

- APPENDIX A – CITY OF SCOTTSDALE LIFT STATION DESIGN CRITERIA**
- APPENDIX B – CITY OF SCOTTSDALE WASTEWATER DESIGN GUIDE**
- APPENDIX C – MP 3127 HT 3 - 262 (170MM IMPELLER) PUMP INFORMATION**
- APPENDIX D – LIFT STATION LAYOUT EXAMPLES**
- APPENDIX E – ODOR CONTROL**
- APPENDIX F – FIBERGLASS WET WELL PRODUCT INFORMATION**
- APPENDIX G – PUMP STATION PLANNER**
- APPENDIX H – OPINION OF PROBABLE COST (OPC)**

LIST OF FIGURES

FIGURE 1: VICINITY MAP	6
FIGURE 2: STORYROCK VICINITY MAP	7
FIGURE 3: SYSTEM LAYOUT	12
FIGURE 4: SITE LAYOUT	14
FIGURE 5: DESIGN FLOWS.....	17
FIGURE 6: MP 3127 HT 3 – 262 SYSTEM & PUMP CURVE.....	18

EXECUTIVE SUMMARY

The purpose of this report is to provide preliminary design analysis for the construction of a new lift station serving StoryRock, a proposed master planned community development consisting of 462-acres of single family residential construction. The purpose of this report is to provide for review and comment a preliminary design for the lift station layout, pumping alternatives, and associated pumping and force main options. The following points summarize the findings of the preliminary design work that has been completed to date:

Lift Station Analysis Site Analysis

- Analyzed location based on the following criteria; existing topography, proximity to a 100-year flood plain, integration with the proposed gravity sewer system along N 128th Street.

Pumps

- Two 11hp pumps to be installed to accommodate an anticipated 70 gpm flow.

Force Main Analysis

- Preliminary alignment and sizing options for redundant force main lines based on flow and pump requirements for StoryRock site development.

Electrical Systems Analysis

- Electrical and instrumentation needs for the lift station include: power delivery and collaboration with utility, design of control specifics, lighting design, and instrumentation selection and implementation.

Odor Control Analysis

- Options to install odor control into either wet well and gravity sewer manhole. Odor control will not be required at the lift station site, however the site will be configured so that a chemical feed system could fairly easily be added at a later time.

Opinion of Probable Cost

- An OPC was generated for the proposed lift station improvements which is estimated to at \$427,000. OPC can be found in **Appendix H**.

1.0 INTRODUCTION

1.1 Project Background


Storyrock is a proposed master planned community development consisting of 462 acres of single family residential construction. Storyrock is located within Section 12 of Township 4 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. The site is bound to the north by the Happy Valley Road Alignment and to the west by 128th Street. The Pinnacle Peak Road alignment bounds the site to the south. The McDowell Sonoran Preserve borders the site to the east and portions of the site to the north and south. See **Figure 1: Vicinity Map** & **Figure 2 – StoryRock Vicinity Map**. The proposed site is located within the City of Scottsdale and falls under the City's Environmentally Sensitive Lands Ordinance (ESLO). Residential development is planned at a density of 0.96 dwelling units per acre within Environmentally Sensitive Lands (ESL).

This Preliminary Engineering Report for StoryRock establishes lift station design parameters and criteria for site planning and preliminary design. The report presents a conceptual layout of the Lift Station #2 site, as well as associated gravity sewer and force mains. Wastewater demands have been calculated based on the overall development layout presented in the *Cavalliere Ranch Sewer Master Plan*.


1.2 Project Scope

Kimley-Horn's design team performed the following services as part of this preliminary analysis:



- Review of existing and proposed water/wastewater information
- Prepare an overall wastewater drainage area map of the service area
- Identify the lift station site
- Identify pump sizing to convey the proposed interim and ultimate peak design flows
- Prepare site layout exhibits
- Prepare preliminary OPC



TOMS THUMB TRAILHEAD



PROJECT NO. 191089020 DRAWING NAME SITE LAYOUT	STORYROCK ENGINEER DESIGN REPORT STORYROCK VICINITY MAP SCOTTSDALE, ARIZONA	SCALE (H): 1"=500'		© 2016 KIMLEY-HORN AND ASSOCIATES, INC. 7740 North 16th Street, Suite 300 Phoenix, Arizona 85020 (602) 944-5500	NO.	REVISION	DATE
		DESIGNED BY: ZJH DRAWN BY: MRN CHECKED BY: REL DATE: SEPT 2016					



TOMS THUMB TRAILHEAD

PROJECT NO. 191089020	DRAWING NAME SITE LAYOUT	STORYROCK ENGINEER DESIGN REPORT STORYROCK VICINITY MAP SCOTTSDALE, ARIZONA	SCALE (H): 1"=500'		© 2016 KIMLEY-HORN AND ASSOCIATES, INC. 7740 North 16th Street, Suite 300 Phoenix, Arizona 85020 (602) 944-5500	NO.	REVISION	DATE
			SCALE (V): NONE			NO.	REVISION	DATE
DESIGNED BY: ZJH			DATE: SEPT 2016					
DRAWN BY: MRN								
CHECKED BY: REL								

2.0 Design Criteria

2.1 Lift Stations

See **Appendix A – City of Scottsdale Sewer Lift Station Design Criteria.**

The City of Scottsdale Design Guide, Chapter 7 “Wastewater” can be found in **Appendix B** and contains the following information regarding wastewater lift stations:

The City’s Water Operations maintains a separate document outlining the design, specifications and materials required for City owned and maintained wastewater lift station. This document may be viewed at www.ScottsdaleAZ.gov/bldgresources/counterresources/WaterFeePacket.

A. Site Selection

In selecting a site for the sewage lift station, considerations included accessibility, drainage patterns, visual impact, function and design constraints.

The station’s equipment must be protected from damage and remain operable during a 100-year flood plain. The proposed site is located outside the 100-year flood plain.

Unless otherwise agreed to in writing by the City’s rights-of-way agent, the tract or lot dedicated to the City will be conveyed by a general warranty deed and accompanied by a title policy in favor of the City, both to the satisfaction of the City.

B. Lift Station Design

Arizona Administrative Code, Title 18, Chapter 9, “Water Pollution Control,” contains minimum requirements for a wastewater lift station. At a minimum, telemetry, dual pumps, backup power supply, three-phase power, provisions for future odor control, and perimeter walls will be required. The site will also be large enough to contain all the equipment and service equipment for repairs.

A final design report prepared by a registered professional engineer, licensed in the State of Arizona, must accompany all pump station design drawings and specifications submitted to the City for review.

2.2 Force Main

City of Scottsdale staff has indicated that force mains smaller than 4 inches will require a parallel force main with interconnecting valves.

The City of Scottsdale Design Guide, Chapter 7 “Wastewater” can be found in **Appendix B** and contains the following information regarding Force Main Design:

Force mains will be located within a right-of-way, private street tract or utility easement. The line must be located under pavement where possible.

A. Velocity Requirements

The flow velocity in the force main must be between 3 and 6 feet per second (fps).

B. Materials of Construction

All pipe material used in design of the force mains must have established ASTM, ANSI, AWWA and NSF standards of manufacture or seals of approval and shall be designated as pressure sanitary sewer pipe. Force mains must be identified as such with marking tape 1 foot above the pipe. All ductile iron force mains shall be lined.

C. Air Release Valves

Air release valves designed for sewage must be provided on force mains at all peaks in elevation see City of Scottsdale (COS) Standard Detail No. 2405, www.ScottsdaleAZ.gov/design/COSMAGSupp.

D. Cleanouts

Two-way cleanouts shall be provided every 1,300 feet apart or 1-way cleanouts every 650 feet. Single cleanouts must be provided at all horizontal bends oriented in line with the downstream pipe. See COS Standard Detail No. 2403, www.ScottsdaleAZ.gov/design/COSMAGSupp.

E. Force Mains

Force mains will be constructed with 3" schedule 40 PVC pipe. Force mains will be constructed of restrained ductile iron pipe for the following conditions:

1. All locations where a vertical realignment is required;
2. Drainage wash crossings;
3. Air release assemblies;
4. Clean-out assemblies.

F. Line Separations

1. Where a force main crosses a water main or transmission line, protection must be provided as per ADEQ Engineering Bulletin No. 10 and the Arizona Administrative Code, Title 18, Chapter 9, "Water Pollution Control." At a minimum, the force main should be constructed of ductile iron pipe for a distance of 10 feet on each side of the water line.
2. See COS Standard Detail No. 2402 for details regarding discharge into a manhole from a force main.
3. The minimum separation between the force mains and water lines should be 2 feet wall-to-wall vertically and 6 feet horizontally under all conditions. Where a force main crosses above or less than 6 feet below a water line, the force main shall be encased in at least 6 inches of concrete for 10 feet on either side of the water line. Fittings should not fall within the encasement.

The engineer must evaluate the potential for odor to develop from a force main downstream of the receiving manhole. One-way valves on building service lines shall be specified where there is potential for gasses to strip from the waste stream. The valves should be located at or near the building

2.3 Lift Station Design

Preliminary pump design criteria has been developed for the proposed lift station. Pumps are required to convey the peak design flow rate at the total dynamic head calculated. In order to mitigate low design flow rates, the City has accepted the use of

supplementing demands with potable water that can be entered into the gravity sewer system upstream of the proposed lift station. The proposed lift station will need to meet the following calculated pump requirements:

	Peak Design Flow (gpd)	Peak Design Flow (gpm)	Static Head	Total Dynamic Head (ft)
Lift Station #2	100,147	70	106	150

*Assumes a Hazen-Williams C value of 130

Preliminary wet well sizes have been calculated for the proposed lift stations. Wet well volume calculations are based on the following criteria and assumptions:

- Minimum flow to lift station = 0 gpm
- Minimum pump running time = 2 minutes
- Minimum pump cycle time = 6 minutes
- Wet well diameter = 6 feet

Based on the above criteria wet well volumes are as follows:

	Lift Station #2
Wet Well Volume (ft³)	54
Operational Depth (ft)	2


3.0 Civil Analysis

3.1 Adjacent Sanitary Systems

The Sereno Canyon development is located directly west of the project. Wastewater generated by a large portion of Sereno Canyon is conveyed by gravity sewer to an existing lift station located on the east side of 128th Street approximately 350' north of Ranch Gate Road. This lift station is located on the western boundary of the proposed Cavalliere Ranch Development. From the lift station wastewater flows are conveyed through an existing 6-inch forcemain west along the Happy Valley Road alignment. This force main connects to an existing manhole along the Happy Valley Road alignment approximately 300 feet east of 122nd Street. Flows are then conveyed by gravity sewer through the existing Granite Ridge subdivision to an 8-inch line within Happy Valley Road. Flows are ultimately conveyed to the City of Scottsdale treatment facility located at Pima Road and Hualapai Drive. Two existing gravity sewer lines exist within Ranch Gate Road. Both lines are currently dry as no development has occurred to the north of Ranch Gate Road. The first line runs east from approximately 124th Street to the existing lift station. The second line runs west from approximately 122nd Street to 118th Street. The second line has not yet been connected to an active downstream system. See **Figure 3 – System Layout** for existing lift station location.



SCALE: 1" = 60'



TOTAL AREA = 152,250 SF
HYDRAULICALLY CONNECTED AREA = 25,000 SF
RTIMP = $25,000 / 152,250 = 16.4\%$ CALCULATED
= 21.0% DESIGN

STORYROCK - R1-35 RTIMP DETERMINATION

12. PLAN, DATE: 11/18/2010, DRAWN BY: J. W. HORN, CHECKED BY: J. W. HORN, PROJECT: STORYROCK - R1-35 RTIMP DETERMINATION, SHEET: 15, TOTAL SHEETS: 15, DATE: 11/18/2010






SCALE: 1" = 60'

TOTAL AREA = 123,750 SF

HYDRAULICALLY
CONNECTED AREA = 19,000 SF

RTIMP = $19,000 / 123,750 = 15.4\%$ CALCULATED
17.0% DESIGN



STORYROCK - R1-43 RTIMP
DETERMINATION

K:\NAV_CAD\Projects\Storyrock\Drawings\Phase 1A\Drawings\RTIMP\Storyrock - R1-43 RTIMP.dwg, May 02, 2017 10:48 AM



Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 ROUTING DATA
 Project Reference: **STORYROCK PH1A PROP**

Route ID	LOB N	Chan N	ROB N	Length (ft)	Slope (ft/ft)	Max Elev (ft)		1.	2.	3.	4.	5.	6.	7.	8.
NORMAL DEPTH															
Major Basin 01															
ON20	0.050	0.035	0.050	1,302.00	0.0280	-	X: Y:	- 4.00	7.00 2.00	9.00 1.00	11.00 -	12.00 -	14.00 1.00	16.00 2.00	18.00 4.00
RF45	0.050	0.035	0.050	980.00	0.0260	-	X: Y:	- 3.00	14.00 2.00	21.00 1.00	25.00 -	31.00 -	35.00 1.00	41.00 2.00	45.00 3.00
RF60A	0.050	0.035	0.050	1,076.00	0.0300	-	X: Y:	- 3.00	8.00 2.00	18.00 1.00	55.00 -	71.00 -	78.00 1.00	83.00 2.00	90.00 3.00
RF60B	0.050	0.035	0.050	1,200.00	0.0320	-	X: Y:	- 3.00	9.00 2.00	14.00 1.00	16.00 -	16.50 -	22.00 1.00	26.00 2.00	33.00 3.00
RF60C	0.050	0.035	0.050	650.00	0.0280	-	X: Y:	- 3.00	25.00 2.00	38.00 1.00	48.00 -	49.00 -	57.00 1.00	67.00 2.00	80.00 3.00
RO10A	0.050	0.035	0.050	522.00	0.0250	-	X: Y:	- 3.00	12.00 2.00	29.00 1.00	31.00 -	31.50 -	42.00 1.00	59.00 2.00	62.00 3.00
RO10B	0.050	0.035	0.050	675.00	0.0270	-	X: Y:	- 3.00	8.00 2.00	13.00 1.00	17.00 -	17.50 -	22.00 1.00	26.00 2.00	29.00 3.00
RO10C	0.050	0.035	0.050	621.00	0.0220	-	X: Y:	- 3.00	5.00 2.00	10.00 1.00	28.00 -	32.00 -	68.00 1.00	78.00 2.00	83.00 3.00
RO11	0.050	0.035	0.050	1,000.00	0.0220	-	X: Y:	- 3.00	5.00 2.00	10.00 1.00	28.00 -	32.00 -	68.00 1.00	78.00 2.00	83.00 3.00
RO21	0.050	0.035	0.050	865.00	0.0240	-	X: Y:	- 4.00	7.00 2.00	9.00 1.00	11.00 -	12.00 -	14.00 1.00	16.00 2.00	18.00 4.00
RO22	0.050	0.035	0.050	1,733.00	0.0240	-	X: Y:	- 4.00	7.00 2.00	9.00 1.00	11.00 -	12.00 -	14.00 1.00	16.00 2.00	18.00 4.00

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 ROUTING DATA
 Project Reference: STORYROCK PH1A PROP

Route ID	LOB N	Chan N	ROB N	Length (ft)	Slope (ft/ft)	Max Elev (ft)		1.	2.	3.	4.	5.	6.	7.	8.
RO22B	0.050	0.035	0.050	585.00	0.0240	-	X: Y:	- 4.00	7.00 2.00	9.00 1.00	11.00 -	12.00 -	14.00 1.00	16.00 2.00	18.00 4.00
RO45	0.050	0.035	0.050	611.00	0.0290	-	X: Y:	- 2.50	11.00 2.00	15.00 1.00	19.00 -	19.10 -	25.00 1.00	33.00 2.00	43.00 3.00
RO5A	0.050	0.035	0.050	380.00	0.0340	-	X: Y:	- 3.00	12.00 2.00	16.00 1.00	20.00 -	21.00 -	24.00 1.00	32.00 2.00	42.00 3.00
RO5B	0.050	0.035	0.050	490.00	0.0265	-	X: Y:	- 3.00	7.00 2.00	14.00 1.00	21.00 -	22.00 -	31.00 1.00	37.00 2.00	48.00 3.00
RO5C	0.050	0.035	0.050	630.00	0.0240	-	X: Y:	- 3.00	4.00 2.00	6.00 1.00	9.00 -	10.00 -	14.00 1.00	21.00 2.00	31.00 3.00
RO60	0.050	0.035	0.050	625.00	0.0220	-	X: Y:	- 3.00	6.00 2.00	10.00 1.00	14.00 -	27.00 -	38.00 1.00	57.00 2.00	83.00 3.00
RO65	0.050	0.035	0.050	756.00	0.0250	-	X: Y:	- 3.00	5.00 2.00	7.00 1.00	8.50 -	9.00 -	19.00 1.00	24.00 2.00	29.00 3.00
RO70	0.050	0.035	0.050	1,280.00	0.0250	-	X: Y:	- 3.00	14.00 2.00	27.00 1.00	31.50 -	32.00 -	36.00 1.00	40.00 2.00	46.00 3.00
RO75A	0.050	0.035	0.050	553.00	0.0240	-	X: Y:	- 3.00	18.00 2.00	20.00 1.00	23.00 -	34.00 -	38.00 1.00	41.00 2.00	44.00 3.00
RO75B	0.050	0.035	0.050	1,600.00	0.0260	-	X: Y:	- 2.00	15.00 1.50	26.00 1.00	32.00 -	43.00 -	46.00 1.00	50.00 2.00	55.00 3.00

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 STORAGE FACILITIES

Storage Basin ID: DB10			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)		0.1	0.3	0.4	0.6	0.7	0.9	0.9		
Spillway Length:	-NA-	Discharge (cfs)	0	0	0	1	1	2	2	2	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	0.5	1.0	1.5	2.0	2.5	3.0	3.0	-	-
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.26	0.00	0.41	0.00	0.00	0.73				
Length of Dam:	-NA-	Peak Stage (ft)	1.00	0.00	1.50	0.00	0.00	2.50				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	0.00	0.00	1.00	0.00	0.00	2.00				
Weir Coefficient:	-NA-											

Storage Basin ID: DB15			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)		0.1	0.3	0.4	0.6	0.8	1.0	1.0		
Spillway Length:	-NA-	Discharge (cfs)	0	0	1	1	1	2	2	13	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	0.5	1.0	1.5	2.0	2.5	3.0	3.0	-	-
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.26	0.00	0.26	0.00	0.00	0.96				
Length of Dam:	-NA-	Peak Stage (ft)	1.00	0.00	1.00	0.00	0.00	3.00				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	1.00	0.00	1.00	0.00	0.00	13.00				
Weir Coefficient:	-NA-											

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 STORAGE FACILITIES

2/20/2017

Page 2

Storage Basin ID: DB20			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)		0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.3
Spillway Length:	-NA-	Discharge (cfs)	0	3	7	10	12	14	15	16	18	20
Discharge Coefficient:	-NA-	Elevation (ft)	-	1.0	2.0	2.5	3.0	3.5	4.0	4.5	5.0	5.5
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	0.4	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	23	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	6.0	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.08	0.00	0.15	0.00	0.00	0.40				
Length of Dam:	-NA-	Peak Stage (ft)	1.50	0.00	3.00	0.00	0.00	6.00				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	5.00	0.00	12.00	0.00	0.00	23.00				
Weir Coefficient:	-NA-											

Storage Basin ID: DB24			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)		0.1	0.1	0.2	0.2	0.3	0.3	0.3		
Spillway Length:	-NA-	Discharge (cfs)	0	0	0	1	1	2	2	15	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	0.5	1.0	1.5	2.0	2.5	3.0	3.0	-	-
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.17	0.00	0.30	0.00	0.00	0.34				
Length of Dam:	-NA-	Peak Stage (ft)	1.50	0.00	2.50	0.00	0.00	3.00				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	1.00	0.00	2.00	0.00	0.00	15.00				
Weir Coefficient:	-NA-											

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 STORAGE FACILITIES

2/20/2017

Page 3

Storage Basin ID: DB30			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)	0.1	0.1	0.2	0.3	0.3	0.4	0.4			
Spillway Length:	-NA-	Discharge (cfs)	1	3	4	5	5	6	55	0	0	
Discharge Coefficient:	-NA-	Elevation (ft)	0.5	1.0	1.5	2.0	2.5	3.0	3.0			
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.25	0.00	0.42	0.00	0.00	0.42				
Length of Dam:	-NA-	Peak Stage (ft)	2.00	0.00	3.00	0.00	0.00	3.00				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	5.00	0.00	23.00	0.00	0.00	55.00				
Weir Coefficient:	-NA-											

Storage Basin ID: DB40			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)	0.2	0.3	0.5	0.7	1.0	1.2	1.2			
Spillway Length:	-NA-	Discharge (cfs)	1	2	3	4	5	6	18	0	0	
Discharge Coefficient:	-NA-	Elevation (ft)	0.5	1.0	1.5	2.0	2.5	3.0	3.0			
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.34	0.00	0.74	0.00	0.00	1.21				
Length of Dam:	-NA-	Peak Stage (ft)	1.00	0.00	2.00	0.00	0.00	3.00				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	2.00	0.00	4.00	0.00	0.00	18.00				
Weir Coefficient:	-NA-											

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 STORAGE FACILITIES

Storage Basin ID: DB58		<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)											
Spillway Crest Elevation:	-NA- Volume (ac-ft)		0.1	0.1							
Spillway Length:	-NA- Discharge (cfs)	0	1	1	0	0	0	0	0	0	0
Discharge Coefficient:	-NA- Elevation (ft)	-	0.5	1.0	-	-	-	-	-	-	-
Weir Coefficient:	-NA-										
Low-Level Outlet (SL)		<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA- Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA- Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA- Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-										
Top of Dam Overflow (ST)		<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA- Peak Volume (ac-ft)	0.06	0.00	0.06	0.00	0.00	0.06				
Length of Dam:	-NA- Peak Stage (ft)	0.50	0.00	0.50	0.00	0.00	0.50				
Discharge Coefficient:	-NA- Peak Discharge (cfs)	1.00	0.00	1.00	0.00	0.00	1.00				
Weir Coefficient:	-NA-										

Storage Basin ID: DB60		<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)											
Spillway Crest Elevation:	-NA- Volume (ac-ft)		0.1	0.1	0.2	0.3	0.4	0.5	0.5		
Spillway Length:	-NA- Discharge (cfs)	0	1	2	2	3	4	4	26	0	0
Discharge Coefficient:	-NA- Elevation (ft)	-	0.5	1.0	1.5	2.0	2.5	3.0	3.0	-	-
Weir Coefficient:	-NA-										
Low-Level Outlet (SL)		<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA- Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA- Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA- Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-										
Top of Dam Overflow (ST)		<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA- Peak Volume (ac-ft)	0.12	0.00	0.26	0.00	0.00	0.45				
Length of Dam:	-NA- Peak Stage (ft)	1.00	0.00	2.00	0.00	0.00	3.00				
Discharge Coefficient:	-NA- Peak Discharge (cfs)	2.00	0.00	3.00	0.00	0.00	13.00				
Weir Coefficient:	-NA-										

Flood Control District of Maricopa County
 Drainage Design Management System
 HEC-1 STORAGE FACILITIES

Storage Basin ID: DB61			<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>	<u>10</u>
Spillway Characteristics (SS)												
Spillway Crest Elevation:	-NA-	Volume (ac-ft)		0.1	0.1	0.2	0.2	0.3	0.3			
Spillway Length:	-NA-	Discharge (cfs)	0	0	1	1	1	2	2	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	0.5	1.0	1.5	2.0	2.5	3.0	-	-	-
Weir Coefficient:	-NA-											
Low-Level Outlet (SL)			<u>11</u>	<u>12</u>	<u>13</u>	<u>14</u>	<u>15</u>	<u>16</u>	<u>17</u>	<u>18</u>	<u>19</u>	<u>20</u>
Centerline Elevation:	-NA-	Volume (ac-ft)	-	-	-	-	-	-	-	-	-	-
Cross-Section Area:	-NA-	Discharge (cfs)	0	0	0	0	0	0	0	0	0	0
Discharge Coefficient:	-NA-	Elevation (ft)	-	-	-	-	-	-	-	-	-	-
Orifice Equation Exponent:	-NA-											
Top of Dam Overflow (ST)			<u>2 Yr</u>	<u>5 Yr</u>	<u>10 Yr</u>	<u>25 Yr</u>	<u>50 Yr</u>	<u>100 Yr</u>				
Elevation Top of Dam:	-NA-	Peak Volume (ac-ft)	0.09	0.00	0.09	0.00	0.00	0.26				
Length of Dam:	-NA-	Peak Stage (ft)	1.00	0.00	1.00	0.00	0.00	2.50				
Discharge Coefficient:	-NA-	Peak Discharge (cfs)	1.00	0.00	1.00	0.00	0.00	2.00				
Weir Coefficient:	-NA-											

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**

Designed by **ZJH**
 Checked by **JMB**

Date **2/5/2016**
 Date **2/5/2016**

Project No. **191069020**

Objective: to determine the storage-flow relationship for small detention basins

DB10 **Drains in 14.40 hours**

Outlet Diameter	0.50 ft	Outlet X-Sect Area	0.196 ft ²
Outlet Elevation	0 ft	No. of Outlet Barrels	1
		Outlet Pipe Slope	0.005 ft/ft

Elevation	Surface Storage Area	Surface Storage Area	Average Area	Δ Elev	Δ Vol	Σ Vol	Δ Time to Drain	Q _{pipe}	Q _{weir}	Total Q _{out}
[ft]	[ft ²]	[acre]	[acre]	[ft]	[ac-ft]	[ac-ft]	[hr]	[cfs]	[cfs]	[cfs]
0	10,558	0.24	0.26	1.0	0.26	0	7.79	0	0	0
1	12,394	0.28	0.31	1.0	0.31	0.26	3.59	1	0	1
2	14,330	0.33	0.35	1.0	0.35	0.57	3.03	1	0	1
3	16,367	0.38				0.92		2	0	2

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Kimley»Horn

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB15 **Drains in 12.09 hours**

Outlet Diameter 0.50 ft Outlet X-Sect Area 0.196 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	10,148	0.23	0.26	1.0	0.26	0	7.70	0	0	0
1	12,555	0.29	0.32	1.0	0.32	0.26	3.72	1	0	1
2	15,161	0.35	0.38	1.0	0.38	0.58	0.67	1	0	1
3	17,970	0.41				0.96		2	11	13

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB20 **Drains in 0.14 hours**

Outlet Diameter 1.50 ft Outlet X-Sect Area 1.767 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	25	0.00	0.00	1.0	0.00	0	0.04	0	0	0
1	400	0.01	0.02	1.0	0.02	0.00	0.05	3	0	3
2	1,237	0.03	0.04	1.0	0.04	0.02	0.05	7	0	7
3	2,295	0.05	0.07	1.0	0.07	0.06	0.06	12	0	12
4	3,855	0.09	0.11	1.0	0.11	0.13	0.08	15	0	15
5	6,130	0.14	0.17	1.0	0.17	0.25	0.10	18	0	18
6	8,972	0.21				0.42		23	0	23

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB24 **Drains in 4.17 hours**

Outlet Diameter 0.50 ft Outlet X-Sect Area 0.196 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	3,226	0.07	0.09	1.0	0.09	0	2.59	0	0	0
1	4,408	0.10	0.12	1.0	0.12	0.09	1.36	1	0	1
2	5,690	0.13	0.15	1.0	0.15	0.20	0.22	1	0	1
3	7,073	0.16				0.35		2	13	15

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**

Designed by **ZJH**
 Checked by **JMB**

Date **2/5/2016**
 Date **2/5/2016**

Project No. **191069020**

Objective: to determine the storage-flow relationship for small detention basins

DB30 **Drains in 1.58 hours**

Outlet Diameter 1.00 ft Outlet X-Sect Area 0.785 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	4,062	0.09	0.11	1.0	0.11	0	1.04	0	0	0
1	5,380	0.12	0.14	1.0	0.14	0.11	0.47	3	0	3
2	6,800	0.16	0.17	1.0	0.17	0.25	0.07	5	0	5
3	8,320	0.19				0.42		6	49	55

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB40 **Drains in 5.11 hours**

Outlet Diameter 1.00 ft Outlet X-Sect Area 0.785 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	13,468	0.31	0.34	1.0	0.34	0	3.25	0	0	0
1	16,049	0.37	0.40	1.0	0.40	0.34	1.35	3	0	3
2	18,831	0.43	0.47	1.0	0.47	0.74	0.50	5	0	5
3	21,814	0.50				1.21		6	12	18

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Kimley»Horn

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB58 **Drains in 4.05 hours**

Outlet Diameter 0.50 ft Outlet X-Sect Area 0.196 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	4,896	0.11	0.14	1.0	0.14	0	4.05	0	0	0
1	7,051	0.16				0.14		1	0	1

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Kimley»Horn

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**
 Designed by **ZJH** Date **2/5/2016** Project No. **191069020**
 Checked by **JMB** Date **2/5/2016**

Objective: to determine the storage-flow relationship for small detention basins

DB60 **Drains in 2.50 hours**

Outlet Diameter 0.80 ft Outlet X-Sect Area 0.503 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	4,368	0.10	0.12	1.0	0.12	0	1.49	0	0	0
1	5,719	0.13	0.15	1.0	0.15	0.12	0.73	2	0	2
2	7,170	0.16	0.18	1.0	0.18	0.26	0.28	3	0	3
3	8,722	0.20				0.45		4	9	13

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**
 Subject **Detention Basin Calculations**

Designed by **ZJH**
 Checked by **JMB**

Date **2/5/2016**
 Date **2/5/2016**

Project No. **191069020**

Objective: to determine the storage-flow relationship for small detention basins

DB61

Drains in 5.03 hours

Outlet Diameter 0.50 ft Outlet X-Sect Area 0.196 ft²
 Outlet Elevation 0 ft No. of Outlet Barrels 1
 Outlet Pipe Slope 0.005 ft/ft

Elevation [ft]	Surface Storage Area [ft ²]	Surface Storage Area [acre]	Average Area [acre]	Δ Elev [ft]	Δ Vol [ac-ft]	Σ Vol [ac-ft]	Δ Time to Drain [hr]	Q _{pipe} [cfs]	Q _{weir} [cfs]	Total Q _{out} [cfs]
0	3,218	0.07	0.09	1.0	0.09	0	2.54	0	0	0
1	4,269	0.10	0.11	1.0	0.11	0.09	1.30	1	0	1
2	5,421	0.12	0.14	1.0	0.14	0.20	1.19	1	0	1
3	6,673	0.15				0.34		2	0	2

Notes:

Q_{pipe} goes from Mannings Eqn to Orifice Eqn when water surface exceeds 1.2*(Outlet Diameter)
 per Linsley et al. *Water Resources Engineering* 4th Edition, pg 652.

Project **Storyrock Phase 1A**

Subject **Basin Summary Table**

Designed by **ZJH**

Date 2/5/2016

Project No. 191069020

Checked by **JMB**

Date 2/5/2016

Objective: Basin Summary Table

Basin ID	Volume (ac-ft)	Max Depth (ft)	Max Side Slope (ft, H:V)	100 Yr Peak Inflow Rate (cfs)	100 Yr Peak Outflow Rate (cfs)	100 Yr Peak Flow Attenuation (cfs)	Orifice Size (ft)	Drain Time (hr)	Type	2 Year Storage Volume (ac-ft)	10 Year Storage Volume (ac-ft)	100 Year Storage Volume (ac-ft)
DB10	0.92	3.00	4:1	22	2	20	0.50	14.40	Standard	0.26	0.41	0.73
DB15	0.96	3.00	4:1	32	13	19	0.50	12.09	Standard	0.26	0.26	0.96
DB20	0.42	6.00	*	31	23	8	1.50	0.14	In-line	0.08	0.15	0.37
DB24	0.16	3.00	4:1	17	15	2	0.50	4.17	Standard	0.17	0.30	0.34
DB30	0.42	3.00	4:1	55	55	0	1.00	1.58	Standard	0.25	0.42	0.42
DB40	1.21	3.00	4:1	46	18	28	1.00	5.11	Standard	0.34	0.74	1.21
DB58	0.14	1.00	4:1	4	1	3	0.50	4.05	Standard	0.11	0.14	0.14
DB60	0.45	3.00	4:1	22	13	9	0.80	2.50	Standard	0.12	0.26	0.45
DB61	0.34	3.00	4:1	11	2	9	0.50	5.03	Standard	0.09	0.09	0.26

Project **Storyrock Phase 1A**

Subject **First Flush Summary Table**

Designed by **ZJH**

Date **2/5/2016**

Project No. **191069020**

Checked by **JMB**

Date **2/5/2016**

Objective: First Flush Summary

First Flush Volume = $A \cdot C \cdot P / 12$

Contributing Sub Basin	First Flush Method	Contributing Developed Area (sf)	Contributing Developed Area (ac)	First Flush Volume Req. (ac-ft)	Basin Volume Prov. (ac-ft)
ON05	N/A*	N/A	N/A	N/A	N/A
ON11	Basin	261,956	6.01	0.24	0.92
ON15	Basin	322,589	7.41	0.29	0.96
ON20	N/A*	N/A	N/A	N/A	N/A
ON22	Stormceptor /Alternate First Flush Method	N/A	N/A	N/A	N/A
ON24	Basin	160,384	3.68	0.15	0.16
ON30	Basin	216,702	4.97	0.20	0.42
ON31	N/A*	N/A	N/A	N/A	N/A
ON40	Basin	482,822	11.08	0.44	1.21
ON50	N/A*	N/A	N/A	N/A	N/A
ON58	Basin	58,703	1.35	0.05	0.14
ON59	Basin	40,197	0.92	0.04	-
ON60	Basin	188,247	4.32	0.17	-
			Total	0.21	0.45
ON61	Basin	118,986	2.73	0.11	0.34

Note* Direct discharge of lot drainage only. No first flush required.


```

*****
* FLOOD HYDROGRAPH PACKAGE (HEC-1) *
*   JUN 1998                   *
*   VERSION 4.1                 *
* RUN DATE 17FEB17 TIME 17:16:58 *
*****
    
```

```

*****
* U.S. ARMY CORPS OF ENGINEERS *
* HYDROLOGIC ENGINEERING CENTER *
* 609 SECOND STREET             *
* DAVIS, CALIFORNIA 95616      *
* (916) 756-1104               *
*****
    
```

```

X   X XXXXXXXX XXXXX           X
X   X X           X   X       XX
X   X X           X           X
XXXXXXX XXXX   X           XXXXX X
X   X X           X           X
X   X X           X   X       X
X   X XXXXXXXX XXXXX           XXX
    
```

THIS PROGRAM REPLACES ALL PREVIOUS VERSIONS OF HEC-1 KNOWN AS HEC1 (JAN 73), HEC1GS, HEC1DB, AND HEC1KW.

THE DEFINITIONS OF VARIABLES -RTIMP- AND -RTIOR- HAVE CHANGED FROM THOSE USED WITH THE 1973-STYLE INPUT STRUCTURE. THE DEFINITION OF -AMSKK- ON RM-CARD WAS CHANGED WITH REVISIONS DATED 28 SEP 81. THIS IS THE FORTRAN77 VERSION. NEW OPTIONS: DAMBREAK OUTFLOW SUBMERGENCE, SINGLE EVENT DAMAGE CALCULATION, DSS:WRITE STAGE FREQUENCY, DSS:READ TIME SERIES AT DESIRED CALCULATION INTERVAL LOSS RATE:GREEN AND AMPT INFILTRATION KINEMATIC WAVE: NEW FINITE DIFFERENCE ALGORITHM

1

HEC-1 INPUT

PAGE 1

LINE	ID	1	2	3	4	5	6	7	8	9	10
1	ID	Flood Control District of Maricopa County									
2	ID	STORYROCK PH1A PROP - STORYROCK PHASE 1A PROP CONDITION									
3	ID	2 YEAR									
4	ID	6 Hour Storm									
5	ID	Unit Hydrograph: Clark									
6	ID	Storm: Multiple									
7	ID	02/17/2017									
	*DIAGRAM										
8	IT	5	1JAN99	0	2000						
9	ID	5									
10	IN	15									
	*										
11	JD	1.419	0.0001								
12	PC	0.000	0.008	0.016	0.025	0.033	0.041	0.050	0.058	0.066	0.074
13	PC	0.087	0.099	0.118	0.138	0.216	0.377	0.834	0.911	0.931	0.950
14	PC	0.962	0.972	0.983	0.991	1.000					
15	JD	1.410	0.5000								
16	PC	0.000	0.008	0.016	0.025	0.033	0.041	0.050	0.058	0.066	0.074
17	PC	0.087	0.099	0.118	0.138	0.216	0.377	0.834	0.911	0.931	0.950
18	PC	0.962	0.972	0.983	0.991	1.000					
19	JD	1.384	2.8								
20	PC	0.000	0.009	0.016	0.025	0.034	0.042	0.051	0.059	0.067	0.076
21	PC	0.087	0.100	0.120	0.163	0.252	0.451	0.694	0.837	0.900	0.938
22	PC	0.950	0.963	0.975	0.988	1.000					
	*										
23	KK	OFF05	BASIN								
24	BA	0.001									
25	LG	0.35	0.40	6.00	0.18	0					
26	UC	0.142	0.166								
27	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
28	UA	100									
	*										
29	KK	RO5A	ROUTE								
30	RS	1	FLOW								
31	RC	0.050	0.035	0.050	380	0.0340	0.00				
32	RX	0.00	12.00	16.00	20.00	21.00	24.00	32.00	42.00		
33	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		

34	KK	OFF10	BASIN								
35	BA	0.005									
36	LG	0.35	0.40	6.00	0.18	0					
37	UC	0.253	0.303								
38	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
39	UA	100									
	*										

40	KK	RO5B	ROUTE								
41	RS	1	FLOW								
42	RC	0.050	0.035	0.050	490	0.0265	0.00				
43	RX	0.00	7.00	14.00	21.00	22.00	31.00	37.00	48.00		
44	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

HEC-1 INPUT

1

LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

45	KK	COSA	COMBINE								
46	HC	2									
	*										
47	KK	RO5C	ROUTE								
48	RS	1	FLOW								
49	RC	0.050	0.035	0.050	630	0.0240	0.00				
50	RX	0.00	4.00	6.00	9.00	10.00	14.00	21.00	31.00		
51	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										
52	KK	ON05	BASIN								
53	BA	0.008									
54	LG	0.33	0.33	6.00	0.17	9					
55	UC	0.291	0.486								
56	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
57	UA	100									
	*										

58	KK	COSB	COMBINE								
59	HC	2									
	*										
60	KK	OFF15	BASIN								
61	BA	0.014									
62	LG	0.35	0.40	6.00	0.18	0					
63	UC	0.386	0.544								
64	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
65	UA	100									
	*										

66	KK	RO10A	ROUTE								
67	RS	1	FLOW								
68	RC	0.050	0.035	0.050	522	0.0250	0.00				
69	RX	0.00	12.00	29.00	31.00	31.50	42.00	59.00	62.00		
70	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

71	KK	OFF20	BASIN								
72	BA	0.005									
73	LG	0.35	0.40	6.00	0.18	0					
74	UC	0.257	0.328								
75	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
76	UA	100									
	*										

77	KK	RO10B	ROUTE								
78	RS	1	FLOW								
79	RC	0.050	0.035	0.050	675	0.0270	0.00				
80	RX	0.00	8.00	13.00	17.00	17.50	22.00	26.00	29.00		
81	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

HEC-1 INPUT

1

LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

82	KK	CO10A	COMBINE								
----	----	-------	---------	--	--	--	--	--	--	--	--

400 KK C075B COMBINE
 401 HC 2
 *
 402 ZZ

1

SCHEMATIC DIAGRAM OF STREAM NETWORK

INPUT LINE	(V) ROUTING	(--->) DIVERSION OR PUMP FLOW
NO.	(.) CONNECTOR	(<---) RETURN OF DIVERTED OR PUMPED FLOW
23	OFF05 V V	
29	RO5A	
34	OFF10 V V	
40	RO5B	
45	C05A..... V V	
47	RO5C	
52	ON05	
58	C05B.....	
60	OFF15 V V	
66	RO10A	
71	OFF20 V V	
77	RO10B	
82	C010A..... V V	
84	RO10C	
89	ON10	
95	ON11 V V	
101	DB10	
107	C010B..... V V	
109	RO11	
114	ON12	
120	C012.....	
122	ON15 V	

134 V
 V
 R022B
 139 ON20
 145 ON58
 V
 V
 151 DB58
 V
 V
 157 ON20
 162 CO20
 V
 V
 164 DB20
 V
 V
 173 R022
 178 ON22
 184 ON24
 V
 V
 190 DB24
 196 CO22
 198 ON35
 204 ON30
 V
 V
 210 DB30
 216 ON31
 222 ON40
 V
 V
 228 DB40
 234 CO45B
 237 ON50
 243 COEX1
 245 OFF30
 251 OFF35
 257 OFF40
 263 CF45A
 V
 V

270	.	OFF45	.	.
276	.	CF45B.....	.	.
	.	V	.	.
	.	V	.	.
278	.	R060	.	.
283	.	OFF50	.	.
	.	V	.	.
	.	V	.	.
289	.	RF60A	.	.
294	.		OFF55	.
	.		V	.
	.		V	.
300	.		RF60B	.
305	.	CF60A.....	.	.
	.	V	.	.
	.	V	.	.
307	.	RF60C	.	.
312	.		OFF60	.
318	.	CF60B.....	.	.
	.	V	.	.
	.	V	.	.
320	.	R065	.	.
325	.		ON65	.
331	.			ON60
337	.			ON59
343	.			C060.....
	.			V
	.			V
345	.			DB60
351	.	C065.....	.	.
	.	V	.	.
	.	V	.	.
353	.	R075A	.	.
358	.	OFF65	.	.
	.	V	.	.
	.	V	.	.
364	.	R070	.	.
369	.		ON70	.
375	.			ON61
	.			V
	.			V
381	.			DB61
387	.	C075A.....	.	.
	.	V	.	.
	.	V	.	.
389	.	R075B	.	.

0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00

19 JD INDEX STORM NO. 3
 STRM 1.38 PRECIPITATION DEPTH
 TRDA 2.80 TRANSPOSITION DRAINAGE AREA

20 PI PRECIPITATION PATTERN
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
 0.03 0.03 0.07 0.07 0.07 0.08 0.08 0.08 0.05 0.05
 0.05 0.02 0.02 0.02 0.01 0.01 0.01 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00

*** **

 * *
 101 KK * DB10 * STORAGE
 * *

102 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 128 KK * DB15 * STORAGE
 * *

129 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 151 KK * DB58 * STORAGE
 * *

152 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 164 KK * DB20 * STORAGE
 * *

165 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL

QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

```
*****
*          *
190 KK  *   DB24 *   STORAGE
*          *
*****
```

```
191 KO      OUTPUT CONTROL VARIABLES
          IPRNT      5  PRINT CONTROL
          IPLOT      0  PLOT CONTROL
          QSCAL      0. HYDROGRAPH PLOT SCALE
```

*** **

```
*****
*          *
210 KK  *   DB30 *   STORAGE
*          *
*****
```

```
211 KO      OUTPUT CONTROL VARIABLES
          IPRNT      5  PRINT CONTROL
          IPLOT      0  PLOT CONTROL
          QSCAL      0. HYDROGRAPH PLOT SCALE
```

*** **

```
*****
*          *
228 KK  *   DB40 *   STORAGE
*          *
*****
```

```
229 KO      OUTPUT CONTROL VARIABLES
          IPRNT      5  PRINT CONTROL
          IPLOT      0  PLOT CONTROL
          QSCAL      0. HYDROGRAPH PLOT SCALE
```

*** **

```
*****
*          *
234 KK  *   C045B *  COMBINE
*          *
*****
```

```
235 KO      OUTPUT CONTROL VARIABLES
          IPRNT      3  PRINT CONTROL
          IPLOT      0  PLOT CONTROL
          QSCAL      0. HYDROGRAPH PLOT SCALE
```

```
236 HC      HYDROGRAPH COMBINATION
          ICOMP      3  NUMBER OF HYDROGRAPHS TO COMBINE
```

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 0.0 SQ MI

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
 6.40 71.40 166.50

(CFS)
 + 7. 4.50 2. 1. 0. 0.
 (INCHES) 0.472 0.499 0.499 0.499
 (AC-FT) 1. 1. 1. 1.
 CUMULATIVE AREA = 0.04 SQ MI

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 0.5 SQ MI

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
 + (CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
 + 7. 4.50 (CFS) 2. 1. 0. 0.
 (INCHES) 0.466 0.493 0.493 0.493
 (AC-FT) 1. 1. 1. 1.
 CUMULATIVE AREA = 0.04 SQ MI

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 2.8 SQ MI

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
 + (CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
 + 4. 4.50 (CFS) 1. 0. 0. 0.
 (INCHES) 0.253 0.274 0.274 0.274
 (AC-FT) 1. 1. 1. 1.
 CUMULATIVE AREA = 0.04 SQ MI

*** **

INTERPOLATED HYDROGRAPH AT C045B

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
 + (CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
 + 7. 4.50 (CFS) 2. 1. 0. 0.
 (INCHES) 0.467 0.495 0.495 0.495
 (AC-FT) 1. 1. 1. 1.
 CUMULATIVE AREA = 0.04 SQ MI

345 KK *****
 * DB60 * STORAGE
 * *

346 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

381 KK * DB61 * STORAGE

*
*

382 KO OUTPUT CONTROL VARIABLES

IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

1

RUNOFF SUMMARY
FLOW IN CUBIC FEET PER SECOND
TIME IN HOURS, AREA IN SQUARE MILES

OPERATION	STATION	PEAK FLOW	TIME OF PEAK	AVERAGE FLOW FOR MAXIMUM PERIOD			BASIN AREA	MAXIMUM STAGE	TIME OF MAX STAGE
				6-HOUR	24-HOUR	72-HOUR			
HYDROGRAPH AT	OFF05	1.	4.08	0.	0.	0.	0.00		
ROUTED TO	R05A	1.	4.17	0.	0.	0.	0.00		
HYDROGRAPH AT	OFF10	2.	4.17	0.	0.	0.	0.00		
ROUTED TO	R05B	2.	4.25	0.	0.	0.	0.00		
2 COMBINED AT	C05A	2.	4.17	0.	0.	0.	0.01		
ROUTED TO	R05C	2.	4.25	0.	0.	0.	0.01		
HYDROGRAPH AT	ON05	3.	4.25	0.	0.	0.	0.01		
2 COMBINED AT	C05B	5.	4.25	1.	0.	0.	0.01		
HYDROGRAPH AT	OFF15	3.	4.25	0.	0.	0.	0.01		
ROUTED TO	R010A	3.	4.33	0.	0.	0.	0.01		
HYDROGRAPH AT	OFF20	2.	4.17	0.	0.	0.	0.00		
ROUTED TO	R010B	2.	4.25	0.	0.	0.	0.00		
2 COMBINED AT	C010A	5.	4.33	1.	0.	0.	0.02		
ROUTED TO	R010C	5.	4.42	1.	0.	0.	0.02		
HYDROGRAPH AT	ON10	6.	4.17	1.	0.	0.	0.01		
HYDROGRAPH AT	ON11	5.	4.17	1.	0.	0.	0.01		
ROUTED TO	DB10	0.	6.25	0.	0.	0.	0.01		
3 COMBINED AT	C010B	9.	4.25	1.	0.	0.	0.04		
ROUTED TO	R011	8.	4.42	1.	0.	0.	0.04		
HYDROGRAPH AT	ON12	3.	4.25	0.	0.	0.	0.01		

+	HYDROGRAPH AT	ON15	9.	4.08	1.	0.	0.	0.01
	ROUTED TO	DB15	1.	4.33	0.	0.	0.	0.01
+	ROUTED TO	RO22B	1.	4.50	0.	0.	0.	0.01
+	HYDROGRAPH AT	ON20	6.	4.25	1.	0.	0.	0.02
+	HYDROGRAPH AT	ON58	1.	4.08	0.	0.	0.	0.00
+	ROUTED TO	DB58	1.	4.50	0.	0.	0.	0.00
+	ROUTED TO	ON20	1.	4.67	0.	0.	0.	0.00
+	2 COMBINED AT	CO20	6.	4.25	1.	0.	0.	0.02
+	ROUTED TO	DB20	5.	4.42	1.	0.	0.	0.02
+	ROUTED TO	RO22	5.	4.58	1.	0.	0.	0.02
+	HYDROGRAPH AT	ON22	5.	4.25	1.	0.	0.	0.01
+	HYDROGRAPH AT	ON24	5.	4.08	0.	0.	0.	0.01
+	ROUTED TO	DB24	1.	4.58	0.	0.	0.	0.01
+	4 COMBINED AT	CO22	10.	4.50	2.	1.	0.	0.05
+	HYDROGRAPH AT	ON35	1.	4.00	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON30	11.	4.25	1.	0.	0.	0.03
+	ROUTED TO	DB30	5.	4.58	1.	0.	0.	0.03
+	HYDROGRAPH AT	ON31	2.	4.08	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON40	13.	4.08	1.	0.	0.	0.02
+	ROUTED TO	DB40	2.	4.50	1.	0.	0.	0.02
+	3 COMBINED AT	CO45B	7.	4.50	2.	1.	0.	0.04
+	HYDROGRAPH AT	ON50	1.	4.00	0.	0.	0.	0.00
+	5 COMBINED AT	COEX1	27.	4.42	6.	2.	1.	0.15
+	HYDROGRAPH AT	OFF30	28.	4.50	5.	1.	0.	0.15
+	HYDROGRAPH AT	OFF35	9.	4.25	1.	0.	0.	0.03
+	HYDROGRAPH AT	OFF40	2.	4.17	0.	0.	0.	0.00

+	3 COMBINED AT	CF45A	35.	4.50	6.	1.	0.	0.18
	ROUTED TO							
+		RF45	34.	4.50	6.	1.	0.	0.18
	HYDROGRAPH AT							
+		OFF45	7.	4.25	1.	0.	0.	0.03
	2 COMBINED AT							
+		CF45B	39.	4.50	7.	2.	1.	0.21
	ROUTED TO							
+		RO60	38.	4.50	7.	2.	1.	0.21
	HYDROGRAPH AT							
+		OFF50	10.	4.50	2.	1.	0.	0.06
	ROUTED TO							
+		RF60A	10.	4.58	2.	1.	0.	0.06
	HYDROGRAPH AT							
+		OFF55	1.	4.17	0.	0.	0.	0.00
	ROUTED TO							
+		RF60B	1.	4.25	0.	0.	0.	0.00
	2 COMBINED AT							
+		CF60A	10.	4.58	2.	1.	0.	0.07
	ROUTED TO							
+		RF60C	10.	4.67	2.	1.	0.	0.07
	HYDROGRAPH AT							
+		OFF60	4.	4.33	1.	0.	0.	0.02
	2 COMBINED AT							
+		CF60B	13.	4.58	3.	1.	0.	0.08
	ROUTED TO							
+		RO65	12.	4.67	3.	1.	0.	0.08
	HYDROGRAPH AT							
+		ON65	2.	4.25	0.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON60	5.	4.08	0.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON59	1.	4.08	0.	0.	0.	0.00
	2 COMBINED AT							
+		CO60	6.	4.08	1.	0.	0.	0.01
	ROUTED TO							
+		DB60	2.	4.33	1.	0.	0.	0.01
	4 COMBINED AT							
+		CO65	53.	4.58	10.	2.	1.	0.31
	ROUTED TO							
+		RO75A	53.	4.58	10.	2.	1.	0.31
	HYDROGRAPH AT							
+		OFF65	1.	4.17	0.	0.	0.	0.00
	ROUTED TO							
+		RO70	1.	4.33	0.	0.	0.	0.00
	HYDROGRAPH AT							
+		ON70	4.	4.25	0.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON61	3.	4.17	0.	0.	0.	0.00
	ROUTED TO							
+		DB61	1.	4.42	0.	0.	0.	0.00

+		C075A	57.	4.58	11.	3.	1.	0.33
	ROUTED TO							
+		R075B	55.	4.67	11.	3.	1.	0.33
	HYDROGRAPH AT							
+		ON75	6.	4.33	1.	0.	0.	0.02
	2 COMBINED AT							
+		C075B	59.	4.67	12.	3.	1.	0.35

*** NORMAL END OF HEC-1 ***

```

*****
* FLOOD HYDROGRAPH PACKAGE (HEC-1) *
* JUN 1998 *
* VERSION 4.1 *
* RUN DATE 17FEB17 TIME 17:17:08 *
*****
    
```

```

*****
* U.S. ARMY CORPS OF ENGINEERS *
* HYDROLOGIC ENGINEERING CENTER *
* 609 SECOND STREET *
* DAVIS, CALIFORNIA 95616 *
* (916) 756-1104 *
*****
    
```

```

X X XXXXXXX XXXXX X
X X X X X XX
X X X X X
XXXXXXXX XXXX X XXXXX X
X X X X X
X X X X X
X X XXXXXXX XXXXX XXX
    
```

THIS PROGRAM REPLACES ALL PREVIOUS VERSIONS OF HEC-1 KNOWN AS HEC1 (JAN 73), HEC1GS, HEC1DB, AND HEC1KW.

THE DEFINITIONS OF VARIABLES -RTIMP- AND -RTIOR- HAVE CHANGED FROM THOSE USED WITH THE 1973-STYLE INPUT STRUCTURE. THE DEFINITION OF -AMSKK- ON RM-CARD WAS CHANGED WITH REVISIONS DATED 28 SEP 81. THIS IS THE FORTRAN77 VERSION. NEW OPTIONS: DAMBREAK OUTFLOW SUBMERGENCE, SINGLE EVENT DAMAGE CALCULATION, DSS:WRITE STAGE FREQUENCY, DSS:READ TIME SERIES AT DESIRED CALCULATION INTERVAL LOSS RATE:GREEN AND AMPT INFILTRATION KINEMATIC WAVE: NEW FINITE DIFFERENCE ALGORITHM

1

HEC-1 INPUT

PAGE 1

LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

```

1 ID Flood Control District of Maricopa County
2 ID STORYROCK PH1A PROP - STORYROCK PHASE 1A PROP CONDITION
3 ID 10 YEAR
4 ID 6 Hour Storm
5 ID Unit Hydrograph: Clark
6 ID Storm: Multiple
7 ID 02/17/2017
  *DIAGRAM
8 IT 5 1JAN99 0 2000
9 IO 5
10 IN 15
  *
11 JD 2.105 0.0001
12 PC 0.000 0.008 0.016 0.025 0.033 0.041 0.050 0.058 0.066 0.074
13 PC 0.087 0.099 0.118 0.138 0.216 0.377 0.834 0.911 0.931 0.950
14 PC 0.962 0.972 0.983 0.991 1.000
15 JD 2.092 0.5000
16 PC 0.000 0.008 0.016 0.025 0.033 0.041 0.050 0.058 0.066 0.074
17 PC 0.087 0.099 0.118 0.138 0.216 0.377 0.834 0.911 0.931 0.950
18 PC 0.962 0.972 0.983 0.991 1.000
19 JD 2.052 2.8
20 PC 0.000 0.009 0.016 0.025 0.034 0.042 0.051 0.059 0.067 0.076
21 PC 0.087 0.100 0.120 0.163 0.252 0.451 0.694 0.837 0.900 0.938
22 PC 0.950 0.963 0.975 0.988 1.000
  *
23 KK OFF05 BASIN
24 BA 0.001
25 LG 0.35 0.40 6.00 0.18 0
26 UC 0.118 0.135
27 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
28 UA 100
  *
29 KK ROSA ROUTE
30 RS 1 FLOW
31 RC 0.050 0.035 0.050 380 0.0340 0.00
32 RX 0.00 12.00 16.00 20.00 21.00 24.00 32.00 42.00
33 RY 3.00 2.00 1.00 0.00 0.00 1.00 2.00 3.00
  *
    
```

84	KK	RO10C	ROUTE								
85	RS	1	FLOW								
86	RC	0.050	0.035	0.050	621	0.0220	0.00				
87	RX	0.00	5.00	10.00	28.00	32.00	68.00	78.00	83.00		
88	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										
89	KK	ON10	BASIN								
90	BA	0.014									
91	LG	0.32	0.30	6.00	0.18	7					
92	UC	0.239	0.294								
93	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
94	UA	100									
	*										
95	KK	ON11	BASIN								
96	BA	0.009									
97	LG	0.31	0.27	6.00	0.19	16					
98	UC	0.204	0.235								
99	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
100	UA	100									
	*										
101	KK	DB10	STORAGE								
102	KO										
103	RS	1	STOR								
104	SV		0.13	0.26	0.41	0.57	0.73	0.92	0.92		
105	SQ				1.00	1.00	2.00	2.00	2.00		
106	SE		0.50	1.00	1.50	2.00	2.50	3.00	3.01		
	*										
107	KK	CO10B	COMBINE								
108	HC	3									
	*										
109	KK	RO11	ROUTE								
110	RS	1	FLOW								
111	RC	0.050	0.035	0.050	1000	0.0220	0.00				
112	RX	0.00	5.00	10.00	28.00	32.00	68.00	78.00	83.00		
113	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										
114	KK	ON12	BASIN								
115	BA	0.008									
116	LG	0.33	0.34	6.00	0.17	6					
117	UC	0.278	0.447								
118	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
119	UA	100									
	*										

HEC-1 INPUT

PAGE 4

1
LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

120	KK	CO12	COMBINE								
121	HC	2									
	*										
122	KK	ON15	BASIN								
123	BA	0.012									
124	LG	0.30	0.25	6.00	0.19	19					
125	UC	0.164	0.164								
126	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
127	UA	100									
	*										
128	KK	DB15	STORAGE								
129	KO										
130	RS	1	STOR								
131	SV		0.13	0.26	0.42	0.58	0.77	0.96	0.96		
132	SQ			1.00	1.00	1.00	2.00	2.00	13.00		
133	SE		0.50	1.00	1.50	2.00	2.50	2.98	3.00		
	*										
134	KK	RO22B	ROUTE								
135	RS	1	FLOW								
136	RC	0.050	0.035	0.050	585	0.0240	0.00				

244	HC	5									
	*										
245	KK	OFF30	BASIN								
246	BA	0.150									
247	LG	0.35	0.40	6.00	0.18	0					
248	UC	0.548	0.569								
249	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
250	UA	100									
	*										

251	KK	OFF35	BASIN								
252	BA	0.031									
253	LG	0.35	0.40	6.00	0.18	0					
254	UC	0.317	0.338								
255	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
256	UA	100									
	*										

257	KK	OFF40	BASIN								
258	BA	0.001									
259	LG	0.35	0.40	6.00	0.18	0					
260	UC	0.159	0.293								
261	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
262	UA	100									
	*										

263	KK	CF45A	COMBINE								
264	HC	3									
	*										

265	KK	RF45	ROUTE								
266	RS	1	FLOW								
267	RC	0.050	0.035	0.050	980	0.0260	0.00				
268	RX	0.00	14.00	21.00	25.00	31.00	35.00	41.00	45.00		
269	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

HEC-1 INPUT

LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

270	KK	OFF45	BASIN								
271	BA	0.025									
272	LG	0.35	0.40	6.00	0.18	0					
273	UC	0.327	0.360								
274	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
275	UA	100									
	*										

276	KK	CF45B	COMBINE								
277	HC	2									
	*										

278	KK	R060	ROUTE								
279	RS	1	FLOW								
280	RC	0.050	0.035	0.050	625	0.0220	0.00				
281	RX	0.00	6.00	10.00	14.00	27.00	38.00	57.00	83.00		
282	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

283	KK	OFF50	BASIN								
284	BA	0.064									
285	LG	0.35	0.40	6.00	0.18	1					
286	UC	0.499	0.726								
287	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
288	UA	100									
	*										

289	KK	RF60A	ROUTE								
290	RS	1	FLOW								
291	RC	0.050	0.035	0.050	1076	0.0300	0.00				
292	RX	0.00	8.00	18.00	55.00	71.00	78.00	83.00	90.00		
293	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

294	KK	OFF55	BASIN								
295	BA	0.002									

1

400 KK C075B COMBINE
 401 HC 2
 *
 402 ZZ

1

SCHEMATIC DIAGRAM OF STREAM NETWORK

INPUT LINE NO.	(V) ROUTING	(--->) DIVERSION OR PUMP FLOW
NO.	(.) CONNECTOR	(<---) RETURN OF DIVERTED OR PUMPED FLOW
23	OFF05 V V	
29	R05A	
34	OFF10 V V	
40	R05B	
45	C05A.....	
47	R05C	
52	ON05	
58	C05B.....	
60	OFF15 V V	
66	R010A	
71	OFF20 V V	
77	R010B	
82	C010A.....	
84	R010C	
89	ON10	
95	ON11 V V	
101	DB10	
107	C010B.....	
109	R011	
114	ON12	
120	C012.....	
122	ON15 V V	

```

      V
      V
134   RO22B
      .
      .
139   .           ON20
      .
      .
145   .           ON58
      .           V
      .           V
151   .           DB58
      .           V
      .           V
157   .           ON20
      .
      .
162   .           CO20 .....
      .           V
      .           V
164   .           DB20
      .           V
      .           V
173   .           RO22
      .
      .
178   .           ON22
      .
      .
184   .           ON24
      .           V
      .           V
190   .           DB24
      .
      .
196   .           CO22 .....
      .
      .
198   .           ON35
      .
      .
204   .           ON30
      .           V
      .           V
210   .           DB30
      .
      .
216   .           ON31
      .
      .
222   .           ON40
      .           V
      .           V
228   .           DB40
      .
      .
234   .           CO45B .....
      .
      .
237   .           ON50
      .
      .
243   .           COEX1 .....
      .
      .
245   .           OFF30
      .
      .
251   .           OFF35
      .
      .
257   .           OFF40
      .
      .
263   .           CF45A .....
      .           V
      .           V

```

270
276
278
283
289
294
300
305
307
312
318
320
325
331
337
343
345
351
353
358
364
369
375
381
387
389

OFF45
CF45B
V
V
R060
OFF50
V
V
RF60A
OFF55
V
V
RF60B
CF60A
V
V
RF60C
OFF60
CF60B
V
V
R065
ON65
ON60
ON59
C060
V
V
DB60
C065
V
V
R075A
OFF65
V
V
R070
ON70
ON61
V
V
DB61
C075A
V
V
R075B

394 ON75

400 C075B.....

(***) RUNOFF ALSO COMPUTED AT THIS LOCATION

```

*****
*
* FLOOD HYDROGRAPH PACKAGE (HEC-1) *
*   JUN 1998                      *
*   VERSION 4.1                    *
*
* RUN DATE 17FEB17 TIME 17:17:08 *
*
*****

```

```

*****
*
* U.S. ARMY CORPS OF ENGINEERS *
* HYDROLOGIC ENGINEERING CENTER *
* 609 SECOND STREET            *
* DAVIS, CALIFORNIA 95616      *
* (916) 756-1104              *
*
*****

```

Flood Control District of Maricopa County
 STORYROCK PH1A PROP - STORYROCK PHASE 1A PROP CONDITION
 10 YEAR
 6 Hour Storm
 Unit Hydrograph: Clark
 Storm: Multiple
 02/17/2017

9 IO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

IT HYDROGRAPH TIME DATA
 NMIN 5 MINUTES IN COMPUTATION INTERVAL
 IDATE 1JAN99 STARTING DATE
 ITIME 0000 STARTING TIME
 NQ 2000 NUMBER OF HYDROGRAPH ORDINATES
 NDDATE 7JAN99 ENDING DATE
 NDTIME 2235 ENDING TIME
 ICENT 19 CENTURY MARK

COMPUTATION INTERVAL 0.08 HOURS
 TOTAL TIME BASE 166.58 HOURS

ENGLISH UNITS
 DRAINAGE AREA SQUARE MILES
 PRECIPITATION DEPTH INCHES
 LENGTH, ELEVATION FEET
 FLOW CUBIC FEET PER SECOND
 STORAGE VOLUME ACRE-FEET
 SURFACE AREA ACRES
 TEMPERATURE DEGREES FAHRENHEIT

11 JD INDEX STORM NO. 1
 STRM 2.11 PRECIPITATION DEPTH
 TRDA 0.00 TRANSPOSITION DRAINAGE AREA

12 PI PRECIPITATION PATTERN
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
 0.03 0.03 0.05 0.05 0.05 0.15 0.15 0.15 0.03 0.03
 0.03 0.01 0.01 0.01 0.01 0.01 0.01 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00

15 JD INDEX STORM NO. 2
 STRM 2.09 PRECIPITATION DEPTH
 TRDA 0.50 TRANSPOSITION DRAINAGE AREA

16 PI PRECIPITATION PATTERN
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
 0.03 0.03 0.05 0.05 0.05 0.15 0.15 0.15 0.03 0.03

0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00

19 JD INDEX STORM NO. 3
STRM 2.05 PRECIPITATION DEPTH
TRDA 2.80 TRANSPOSITION DRAINAGE AREA

20 PI PRECIPITATION PATTERN
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
0.03 0.03 0.07 0.07 0.07 0.08 0.08 0.08 0.08 0.05
0.05 0.02 0.02 0.02 0.01 0.01 0.01 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00

*** **

* *
101 KK * DB10 * STORAGE
* *

102 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
128 KK * DB15 * STORAGE
* *

129 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
151 KK * DB58 * STORAGE
* *

152 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
164 KK * DB20 * STORAGE
* *

165 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL

QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

```

*****
*
190 KK * DB24 * STORAGE
*
*****
    
```

```

211 KO OUTPUT CONTROL VARIABLES
      IPRNT 5 PRINT CONTROL
      IPLOT 0 PLOT CONTROL
      QSCAL 0. HYDROGRAPH PLOT SCALE
    
```

*** **

```

*****
*
210 KK * DB30 * STORAGE
*
*****
    
```

```

211 KO OUTPUT CONTROL VARIABLES
      IPRNT 5 PRINT CONTROL
      IPLOT 0 PLOT CONTROL
      QSCAL 0. HYDROGRAPH PLOT SCALE
    
```

*** **

```

*****
*
228 KK * DB40 * STORAGE
*
*****
    
```

```

229 KO OUTPUT CONTROL VARIABLES
      IPRNT 5 PRINT CONTROL
      IPLOT 0 PLOT CONTROL
      QSCAL 0. HYDROGRAPH PLOT SCALE
    
```

*** **

```

*****
*
234 KK * C045B * COMBINE
*
*****
    
```

```

235 KO OUTPUT CONTROL VARIABLES
      IPRNT 3 PRINT CONTROL
      IPLOT 0 PLOT CONTROL
      QSCAL 0. HYDROGRAPH PLOT SCALE
    
```

```

236 HC HYDROGRAPH COMBINATION
      ICOMP 3 NUMBER OF HYDROGRAPHS TO COMBINE
    
```

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 0.0 SQ MI

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
 6 HR 24 HR 72 HR 168 HR


```

(CFS)
+ 28. 4.25 4. 1. 0. 0.
(INCHES) 0.912 0.961 0.961 0.961
(AC-FT) 2. 2. 2. 2.

CUMULATIVE AREA = 0.04 SQ MI

```

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 0.5 SQ MI

```

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
(CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
+ 28. 4.25 4. 1. 0. 0.
(INCHES) 0.903 0.952 0.952 0.952
(AC-FT) 2. 2. 2. 2.

CUMULATIVE AREA = 0.04 SQ MI

```

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 2.8 SQ MI

```

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
(CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
+ 9. 4.58 3. 1. 0. 0.
(INCHES) 0.703 0.746 0.746 0.746
(AC-FT) 2. 2. 2. 2.

CUMULATIVE AREA = 0.04 SQ MI

```

*** **

INTERPOLATED HYDROGRAPH AT C045B

```

PEAK FLOW TIME MAXIMUM AVERAGE FLOW
(CFS) (HR) 6-HR 24-HR 72-HR 166.58-HR
+ 28. 4.25 4. 1. 0. 0.
(INCHES) 0.906 0.954 0.954 0.954
(AC-FT) 2. 2. 2. 2.

CUMULATIVE AREA = 0.04 SQ MI

```

```

*****
* *
345 KK * DB60 * STORAGE
* *
*****

```

```

346 KO OUTPUT CONTROL VARIABLES
      IPRNT 5 PRINT CONTROL
      IPLOT 0 PLOT CONTROL
      QSCAL 0. HYDROGRAPH PLOT SCALE

```

381 KK * DB61 * STORAGE

* *

382 KO OUTPUT CONTROL VARIABLES

IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

1

RUNOFF SUMMARY
 FLOW IN CUBIC FEET PER SECOND
 TIME IN HOURS, AREA IN SQUARE MILES

+	OPERATION	STATION	PEAK FLOW	TIME OF PEAK	AVERAGE FLOW FOR MAXIMUM PERIOD			BASIN AREA	MAXIMUM STAGE	TIME OF MAX STAGE
					6-HOUR	24-HOUR	72-HOUR			
+	HYDROGRAPH AT									
+		OFF05	1.	4.00	0.	0.	0.	0.00		
+	ROUTED TO									
+		R05A	1.	4.08	0.	0.	0.	0.00		
+	HYDROGRAPH AT									
+		OFF10	5.	4.08	0.	0.	0.	0.00		
+	ROUTED TO									
+		R05B	5.	4.17	0.	0.	0.	0.00		
+	2 COMBINED AT									
+		C05A	6.	4.17	0.	0.	0.	0.01		
+	ROUTED TO									
+		R05C	6.	4.17	0.	0.	0.	0.01		
+	HYDROGRAPH AT									
+		ON05	7.	4.17	1.	0.	0.	0.01		
+	2 COMBINED AT									
+		C05B	13.	4.17	1.	0.	0.	0.01		
+	HYDROGRAPH AT									
+		OFF15	10.	4.25	1.	0.	0.	0.01		
+	ROUTED TO									
+		R010A	10.	4.25	1.	0.	0.	0.01		
+	HYDROGRAPH AT									
+		OFF20	5.	4.17	0.	0.	0.	0.00		
+	ROUTED TO									
+		R010B	5.	4.17	0.	0.	0.	0.00		
+	2 COMBINED AT									
+		C010A	14.	4.25	1.	0.	0.	0.02		
+	ROUTED TO									
+		R010C	13.	4.33	1.	0.	0.	0.02		
+	HYDROGRAPH AT									
+		ON10	14.	4.17	1.	0.	0.	0.01		
+	HYDROGRAPH AT									
+		ON11	11.	4.08	1.	0.	0.	0.01		
+	ROUTED TO									
+		DB10	1.	4.58	0.	0.	0.	0.01		
+	3 COMBINED AT									
+		C010B	25.	4.25	3.	1.	0.	0.04		
+	ROUTED TO									
+		R011	23.	4.33	3.	1.	0.	0.04		
+	HYDROGRAPH AT									
+		ON12	6.	4.17	1.	0.	0.	0.01		

+	HYDROGRAPH AT	ON15	18.	4.08	1.	0.	0.	0.01
+	ROUTED TO	DB15	1.	4.67	1.	0.	0.	0.01
+	ROUTED TO	RO22B	1.	4.67	1.	0.	0.	0.01
+	HYDROGRAPH AT	ON20	14.	4.17	2.	0.	0.	0.02
+	HYDROGRAPH AT	ON58	3.	4.08	0.	0.	0.	0.00
+	ROUTED TO	DB58	1.	4.25	0.	0.	0.	0.00
+	ROUTED TO	ON20	1.	4.75	0.	0.	0.	0.00
+	2 COMBINED AT	CO20	14.	4.17	2.	0.	0.	0.02
+	ROUTED TO	DB20	12.	4.33	2.	0.	0.	0.02
+	ROUTED TO	RO22	12.	4.42	2.	0.	0.	0.02
+	HYDROGRAPH AT	ON22	11.	4.17	1.	0.	0.	0.01
+	HYDROGRAPH AT	ON24	9.	4.08	1.	0.	0.	0.01
+	ROUTED TO	DB24	2.	4.42	0.	0.	0.	0.01
+	4 COMBINED AT	CO22	22.	4.33	4.	1.	0.	0.05
+	HYDROGRAPH AT	ON35	2.	4.00	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON30	26.	4.17	2.	1.	0.	0.03
+	ROUTED TO	DB30	23.	4.25	2.	1.	0.	0.03
+	HYDROGRAPH AT	ON31	3.	4.00	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON40	26.	4.08	2.	0.	0.	0.02
+	ROUTED TO	DB40	4.	4.50	2.	0.	0.	0.02
+	3 COMBINED AT	CO45B	28.	4.25	4.	1.	0.	0.04
+	HYDROGRAPH AT	ON50	2.	4.00	0.	0.	0.	0.00
+	5 COMBINED AT	COEX1	77.	4.25	13.	3.	1.	0.15
+	HYDROGRAPH AT	OFF30	82.	4.42	12.	3.	1.	0.15
+	HYDROGRAPH AT	OFF35	25.	4.25	2.	1.	0.	0.03
+	HYDROGRAPH AT	OFF40	1.	4.00	0.	0.	0.	0.00

+	3 COMBINED AT	CF45A	100.	4.33	14.	4.	1.	0.18
	ROUTED TO							
+		RF45	99.	4.42	14.	4.	1.	0.18
	HYDROGRAPH AT							
+		OFF45	20.	4.25	2.	0.	0.	0.03
	2 COMBINED AT							
+		CF45B	112.	4.33	16.	4.	1.	0.21
	ROUTED TO							
+		RO60	113.	4.42	16.	4.	1.	0.21
	HYDROGRAPH AT							
+		OFF50	30.	4.33	5.	1.	0.	0.06
	ROUTED TO							
+		RF60A	29.	4.42	5.	1.	0.	0.06
	HYDROGRAPH AT							
+		OFF55	2.	4.08	0.	0.	0.	0.00
	ROUTED TO							
+		RF60B	2.	4.25	0.	0.	0.	0.00
	2 COMBINED AT							
+		CF60A	30.	4.42	5.	1.	0.	0.07
	ROUTED TO							
+		RF60C	30.	4.50	5.	1.	0.	0.07
	HYDROGRAPH AT							
+		OFF60	11.	4.25	1.	0.	0.	0.02
	2 COMBINED AT							
+		CF60B	37.	4.50	7.	2.	1.	0.08
	ROUTED TO							
+		RO65	37.	4.50	7.	2.	1.	0.08
	HYDROGRAPH AT							
+		ON65	6.	4.17	1.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON60	11.	4.08	1.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON59	1.	4.08	0.	0.	0.	0.00
	2 COMBINED AT							
+		CO60	12.	4.08	1.	0.	0.	0.01
	ROUTED TO							
+		DB60	3.	4.42	1.	0.	0.	0.01
	4 COMBINED AT							
+		CO65	155.	4.42	24.	6.	2.	0.31
	ROUTED TO							
+		RO75A	155.	4.42	24.	6.	2.	0.31
	HYDROGRAPH AT							
+		OFF65	4.	4.17	0.	0.	0.	0.00
	ROUTED TO							
+		RO70	3.	4.25	0.	0.	0.	0.00
	HYDROGRAPH AT							
+		ON70	10.	4.25	1.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON61	5.	4.08	1.	0.	0.	0.00
	ROUTED TO							
+		DB61	1.	4.08	0.	0.	0.	0.00

+		C075A	165.	4.42	26.	6.	2.	0.33
+	ROUTED TO	R075B	161.	4.50	26.	6.	2.	0.33
+	HYDROGRAPH AT	ON75	15.	4.25	2.	0.	0.	0.02
+	2 COMBINED AT	C075B	171.	4.50	28.	7.	2.	0.35

*** NORMAL END OF HEC-1 ***

```

*****
* FLOOD HYDROGRAPH PACKAGE (HEC-1) *
* JUN 1998 *
* VERSION 4.1 *
* RUN DATE: 17FEB17 TIME 17:17:15 *
*****
    
```

```

*****
* U.S. ARMY CORPS OF ENGINEERS *
* HYDROLOGIC ENGINEERING CENTER *
* 609 SECOND STREET *
* DAVIS, CALIFORNIA 95616 *
* (916) 756-1104 *
*****
    
```

```

X X XXXXXXX XXXXX X
X X X X X XX
X X X X X X
XXXXXXXX XXXX X XXXXX X
X X X X X X
X X X X X X
X X XXXXXXX XXXXX XXX
    
```

THIS PROGRAM REPLACES ALL PREVIOUS VERSIONS OF HEC-1 KNOWN AS HEC1 (JAN 73), HEC1G5, HEC1DB, AND HEC1KW.

THE DEFINITIONS OF VARIABLES -RTIMP- AND -RTIOR- HAVE CHANGED FROM THOSE USED WITH THE 1973-STYLE INPUT STRUCTURE. THE DEFINITION OF -AMSKK- ON RM-CARD WAS CHANGED WITH REVISIONS DATED 28 SEP 81. THIS IS THE FORTRAN77 VERSION
 NEW OPTIONS: DAMBREAK OUTFLOW SUBMERGENCE , SINGLE EVENT DAMAGE CALCULATION, DSS:WRITE STAGE FREQUENCY,
 DSS:READ TIME SERIES AT DESIRED CALCULATION INTERVAL LOSS RATE:GREEN AND AMPT INFILTRATION
 KINEMATIC WAVE: NEW FINITE DIFFERENCE ALGORITHM

LINE	ID	1	2	3	4	5	6	7	8	9	10
1	ID	Flood Control District of Maricopa County									
2	ID	STORYROCK PH1A PROP - STORYROCK PHASE 1A PROP CONDITION									
3	ID	100 YEAR									
4	ID	6 Hour Storm									
5	ID	Unit Hydrograph: Clark									
6	ID	Storm: Multiple									
7	ID	02/17/2017									
	*DIAGRAM										
8	IT	5	1JAN99	0	2000						
9	IO	5									
10	IN	15									
	*										
11	JD	3.174	0.0001								
12	PC	0.000	0.008	0.016	0.025	0.033	0.041	0.050	0.058	0.066	0.074
13	PC	0.087	0.099	0.118	0.138	0.216	0.377	0.834	0.911	0.931	0.950
14	PC	0.962	0.972	0.983	0.991	1.000					
15	JD	3.155	0.5000								
16	PC	0.000	0.008	0.016	0.025	0.033	0.041	0.050	0.058	0.066	0.074
17	PC	0.087	0.099	0.118	0.138	0.216	0.377	0.834	0.911	0.931	0.950
18	PC	0.962	0.972	0.983	0.991	1.000					
19	JD	3.095	2.8								
20	PC	0.000	0.009	0.016	0.025	0.034	0.042	0.051	0.059	0.067	0.076
21	PC	0.087	0.100	0.120	0.163	0.252	0.451	0.694	0.837	0.900	0.938
22	PC	0.950	0.963	0.975	0.988	1.000					
	*										
23	KK	OFF05	BASIN								
24	BA	0.001									
25	LG	0.35	0.40	6.00	0.18	0					
26	UC	0.089	0.099								
27	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
28	UA	100									
	*										
29	KK	RO5A	ROUTE								
30	RS	1	FLOW								
31	RC	0.050	0.035	0.050	380	0.0340	0.00				
32	RX	0.00	12.00	16.00	20.00	21.00	24.00	32.00	42.00		
33	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00		
	*										

84	KK	RO10C	ROUTE									
85	RS	1	FLOW									
86	RC	0.050	0.035	0.050	621	0.0220	0.00					
87	RX	0.00	5.00	10.00	28.00	32.00	68.00	78.00	83.00			
88	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00			
	*											
89	KK	ON10	BASIN									
90	BA	0.014										
91	LG	0.32	0.30	6.00	0.18	7						
92	UC	0.185	0.220									
93	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0	
94	UA	100										
	*											
95	KK	ON11	BASIN									
96	BA	0.009										
97	LG	0.31	0.27	6.00	0.19	16						
98	UC	0.160	0.180									
99	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0	
100	UA	100										
	*											
101	KK	DB10	STORAGE									
102	KO											
103	RS	1	STOR									
104	SV		0.13	0.26	0.41	0.57	0.73	0.92	0.92			
105	SQ				1.00	1.00	2.00	2.00	2.00			
106	SE		0.50	1.00	1.50	2.00	2.50	3.00	3.01			
	*											
107	KK	CO10B	COMBINE									
108	HC	3										
	*											
109	KK	RO11	ROUTE									
110	RS	1	FLOW									
111	RC	0.050	0.035	0.050	1000	0.0220	0.00					
112	RX	0.00	5.00	10.00	28.00	32.00	68.00	78.00	83.00			
113	RY	3.00	2.00	1.00	0.00	0.00	1.00	2.00	3.00			
	*											
114	KK	ON12	BASIN									
115	BA	0.008										
116	LG	0.33	0.34	6.00	0.17	6						
117	UC	0.213	0.333									
118	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0	
119	UA	100										
	*											

HEC-1 INPUT

PAGE 4

LINE	ID	1	2	3	4	5	6	7	8	9	10
120	KK	CO12	COMBINE								
121	HC	2									
	*										
122	KK	ON15	BASIN								
123	BA	0.012									
124	LG	0.30	0.25	6.00	0.19	19					
125	UC	0.130	0.126								
126	UA	0	3.0	5.0	8.0	12.0	20.0	43.0	75.0	90.0	96.0
127	UA	100									
	*										
128	KK	DB15	STORAGE								
129	KO										
130	RS	1	STOR								
131	SV		0.13	0.26	0.42	0.58	0.77	0.96	0.96		
132	SQ			1.00	1.00	1.00	2.00	2.00	13.00		
133	SE		0.50	1.00	1.50	2.00	2.50	2.98	3.00		
	*										
134	KK	RO22B	ROUTE								
135	RS	1	FLOW								
136	RC	0.050	0.035	0.050	500	0.0220	0.00				

244 HC 5
*
245 KK OFF30 BASIN
246 BA 0.150
247 LG 0.35 0.40 6.00 0.18 0
248 UC 0.412 0.415
249 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
250 UA 100
*

251 KK OFF35 BASIN
252 BA 0.031
253 LG 0.35 0.40 6.00 0.18 0
254 UC 0.239 0.247
255 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
256 UA 100
*

257 KK OFF40 BASIN
258 BA 0.001
259 LG 0.35 0.40 6.00 0.18 0
260 UC 0.119 0.213
261 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
262 UA 100
*

263 KK CF45A COMBINE
264 HC 3
*

265 KK RF45 ROUTE
266 RS 1 FLOW
267 RC 0.050 0.035 0.050 980 0.0260 0.00
268 RX 0.00 14.00 21.00 25.00 31.00 35.00 41.00 45.00
269 RY 3.00 2.00 1.00 0.00 0.00 1.00 2.00 3.00
*

HEC-1 INPUT

LINE ID.....1.....2.....3.....4.....5.....6.....7.....8.....9.....10

270 KK OFF45 BASIN
271 BA 0.025
272 LG 0.35 0.40 6.00 0.18 0
273 UC 0.246 0.263
274 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
275 UA 100
*

276 KK CF45B COMBINE
277 HC 2
*

278 KK R060 ROUTE
279 RS 1 FLOW
280 RC 0.050 0.035 0.050 625 0.0220 0.00
281 RX 0.00 6.00 10.00 14.00 27.00 38.00 57.00 83.00
282 RY 3.00 2.00 1.00 0.00 0.00 1.00 2.00 3.00
*

283 KK OFF50 BASIN
284 BA 0.064
285 LG 0.35 0.40 6.00 0.18 1
286 UC 0.376 0.530
287 UA 0 3.0 5.0 8.0 12.0 20.0 43.0 75.0 90.0 96.0
288 UA 100
*

289 KK RF60A ROUTE
290 RS 1 FLOW
291 RC 0.050 0.035 0.050 1076 0.0300 0.00
292 RX 0.00 8.00 18.00 55.00 71.00 78.00 83.00 90.00
293 RY 3.00 2.00 1.00 0.00 0.00 1.00 2.00 3.00
*

294 KK OFF55 BASIN
295 BA 0.000

400 KK C075B COMBINE
 401 HC 2
 *
 402 ZZ

1

SCHEMATIC DIAGRAM OF STREAM NETWORK

INPUT LINE	(V) ROUTING	(--->) DIVERSION OR PUMP FLOW
NO.	(.) CONNECTOR	(<---) RETURN OF DIVERTED OR PUMPED FLOW
23	OFF05 V V	
29	R05A	
34		OFF10 V V
40		R05B
45	C05A.....	
47	V V R05C	
52		ON05
58	C05B.....	
60		OFF15 V V
66	R010A	
71		OFF20 V V
77		R010B
82	C010A.....	
84	V V R010C	
89		ON10
95		ON11 V V
101		DB10
107	C010B.....	
109	V V R011	
114		ON12
120	C012.....	
122		ON15 V V

```

      V
      V
134   RO22B
      .
      .
139   ON20
      .
      .
145   ON58
      V
      V
151   DB58
      V
      V
157   ON20
      .
      .
162   CO20 .....
      V
      V
164   DB20
      V
      V
173   RO22
      .
      .
178   ON22
      .
      .
184   ON24
      V
      V
190   DB24
      .
      .
196   CO22 .....
      .
      .
198   ON35
      .
      .
204   ON30
      V
      V
210   DB30
      .
      .
216   ON31
      .
      .
222   ON40
      V
      V
228   DB40
      .
      .
234   CO45B .....
      .
      .
237   ON50
      .
      .
243   COEX1 .....
      .
      .
245   OFF30
      .
      .
251   OFF35
      .
      .
257   OFF40
      .
      .
263   CF45A .....
      V
      V
      .
      .

```

270	.	OFF45	.	.
276	.	CF45B.....	.	.
	.	V	.	.
	.	V	.	.
278	.	R060	.	.
283	.	OFF50	.	.
	.	V	.	.
	.	V	.	.
289	.	RF60A	.	.
294	.		OFF55	.
	.		V	.
	.		V	.
300	.		RF60B	.
	.		.	.
305	.	CF60A.....	.	.
	.	V	.	.
	.	V	.	.
307	.	RF60C	.	.
312	.		OFF60	.
	.		.	.
318	.	CF60B.....	.	.
	.	V	.	.
	.	V	.	.
320	.	R065	.	.
325	.		ON65	.
331	.			ON60
	.			.
337	.			ON59
	.			.
343	.			C060.....
	.			V
	.			V
345	.			DB60
	.			.
351	.	C065.....	.	.
	.	V	.	.
	.	V	.	.
353	.	R075A	.	.
358	.	OFF65	.	.
	.	V	.	.
	.	V	.	.
364	.	R070	.	.
369	.		ON70	.
375	.			ON61
	.			V
	.			V
381	.			DB61
	.			.
387	.	C075A.....	.	.
	.	V	.	.
	.	V	.	.
389	.	R075B	.	.

394

ON75

400

C075B.....

(***) RUNOFF ALSO COMPUTED AT THIS LOCATION

```

1*****
*
* FLOOD HYDROGRAPH PACKAGE (HEC-1)
*   JUN 1998
*   VERSION 4.1
*
* RUN DATE 17FEB17 TIME 17:17:15
*
*****
    
```

```

*****
*
* U.S. ARMY CORPS OF ENGINEERS
* HYDROLOGIC ENGINEERING CENTER
* 609 SECOND STREET
* DAVIS, CALIFORNIA 95616
* (916) 756-1104
*
*****
    
```

Flood Control District of Maricopa County
 STORYROCK PH1A PROP - STORYROCK PHASE 1A PROP CONDITION
 100 YEAR
 6 Hour Storm
 Unit Hydrograph: Clark
 Storm: Multiple
 02/17/2017

9 IO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

IT HYDROGRAPH TIME DATA
 NMIN 5 MINUTES IN COMPUTATION INTERVAL
 IDATE 1JAN99 STARTING DATE
 ITIME 0000 STARTING TIME
 NQ 2000 NUMBER OF HYDROGRAPH ORDINATES
 NDDATE 7JAN99 ENDING DATE
 NDTIME 2235 ENDING TIME
 ICENT 19 CENTURY MARK
 COMPUTATION INTERVAL 0.08 HOURS
 TOTAL TIME BASE 166.58 HOURS

ENGLISH UNITS
 DRAINAGE AREA SQUARE MILES
 PRECIPITATION DEPTH INCHES
 LENGTH, ELEVATION FEET
 FLOW CUBIC FEET PER SECOND
 STORAGE VOLUME ACRE-FEET
 SURFACE AREA ACRES
 TEMPERATURE DEGREES FAHRENHEIT

11 JD INDEX STORM NO. 1
 STRM 3.17 PRECIPITATION DEPTH
 TRDA 0.00 TRANSPOSITION DRAINAGE AREA

12 PI PRECIPITATION PATTERN
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
 0.03 0.03 0.05 0.05 0.05 0.15 0.15 0.15 0.03 0.03
 0.03 0.01 0.01 0.01 0.01 0.01 0.01 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00

15 JD INDEX STORM NO. 2
 STRM 3.15 PRECIPITATION DEPTH
 TRDA 0.50 TRANSPOSITION DRAINAGE AREA

16 PI PRECIPITATION PATTERN
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
 0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00

0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00

19 JD INDEX STORM NO. 3
STRM 3.10 PRECIPITATION DEPTH
TRDA 2.80 TRANSPOSITION DRAINAGE AREA

20 PI PRECIPITATION PATTERN
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00 0.00 0.01 0.01 0.01 0.01 0.01 0.01 0.03
0.03 0.03 0.07 0.07 0.07 0.08 0.08 0.08 0.05 0.05
0.05 0.02 0.02 0.02 0.01 0.01 0.01 0.00 0.00 0.00
0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
0.00 0.00

*** **

* *
101 KK * DB10 * STORAGE
* *

102 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
128 KK * DB15 * STORAGE
* *

129 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
151 KK * DB58 * STORAGE
* *

152 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL
IPLOT 0 PLOT CONTROL
QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

* *
164 KK * DB20 * STORAGE
* *

165 KO OUTPUT CONTROL VARIABLES
IPRNT 5 PRINT CONTROL

QSCAL 0. HYDROGRAPH PLOT SCALE
 WARNING EXCESS AT PONDING LESS THAN ZERO FOR PERIOD. EXCESS SET TO ZERO

*** **

 * *
 190 KK * DB24 * STORAGE
 * *

191 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 210 KK * DB30 * STORAGE
 * *

211 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 228 KK * DB40 * STORAGE
 * *

229 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

*** **

 * *
 234 KK * CO45B * COMBINE
 * *

235 KO OUTPUT CONTROL VARIABLES
 IPRNT 3 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

236 HC HYDROGRAPH COMBINATION
 ICOMP 3 NUMBER OF HYDROGRAPHS TO COMBINE

*** **

HYDROGRAPH AT STATION CO45B
 TRANSPOSITION AREA 0.0 SQ MI

MAXIMUM AVERAGE FLOW

+	(CFS)	(HR)	(CFS)				
+	65.	4.08	5.	1.	0.	0.	
			(INCHES)	1.111	1.112	1.112	1.112
			(AC-FT)	3.	3.	3.	3.
			CUMULATIVE AREA =	0.04 SQ MI			

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 0.5 SQ MI

PEAK FLOW	TIME		MAXIMUM AVERAGE FLOW				
			6-HR	24-HR	72-HR	166.58-HR	
+	(CFS)	(HR)	(CFS)				
+	65.	4.08	5.	1.	0.	0.	
			(INCHES)	1.073	1.074	1.074	1.074
			(AC-FT)	3.	3.	3.	3.
			CUMULATIVE AREA =	0.04 SQ MI			

*** **

HYDROGRAPH AT STATION C045B
 TRANSPOSITION AREA 2.8 SQ MI

PEAK FLOW	TIME		MAXIMUM AVERAGE FLOW				
			6-HR	24-HR	72-HR	166.58-HR	
+	(CFS)	(HR)	(CFS)				
+	38.	4.08	6.	2.	1.	0.	
			(INCHES)	1.301	1.387	1.387	1.387
			(AC-FT)	3.	3.	3.	3.
			CUMULATIVE AREA =	0.04 SQ MI			

*** **

INTERPOLATED HYDROGRAPH AT C045B

PEAK FLOW	TIME		MAXIMUM AVERAGE FLOW				
			6-HR	24-HR	72-HR	166.58-HR	
+	(CFS)	(HR)	(CFS)				
+	65.	4.08	5.	1.	0.	0.	
			(INCHES)	1.084	1.085	1.085	1.085
			(AC-FT)	3.	3.	3.	3.
			CUMULATIVE AREA =	0.04 SQ MI			

```

*****
*          *
345 KK  *   DB60 *   STORAGE
*          *
*****
    
```

```

346 KO      OUTPUT CONTROL VARIABLES
            IPRNT      5  PRINT CONTROL
            IPLOT      0  PLOT CONTROL
            QSCAL      0. HYDROGRAPH PLOT SCALE
    
```

381 KK * *
 * DB61 * STORAGE
 * *

382 KO OUTPUT CONTROL VARIABLES
 IPRNT 5 PRINT CONTROL
 IPLOT 0 PLOT CONTROL
 QSCAL 0. HYDROGRAPH PLOT SCALE

1

RUNOFF SUMMARY
 FLOW IN CUBIC FEET PER SECOND
 TIME IN HOURS, AREA IN SQUARE MILES

OPERATION	STATION	PEAK FLOW	TIME OF PEAK	AVERAGE FLOW FOR MAXIMUM PERIOD			BASIN AREA	MAXIMUM STAGE	TIME OF MAX STAGE
				6-HOUR	24-HOUR	72-HOUR			
HYDROGRAPH AT	OFF05	3.	4.00	0.	0.	0.	0.00		
ROUTED TO	R05A	3.	4.00	0.	0.	0.	0.00		
HYDROGRAPH AT	OFF10	11.	4.08	1.	0.	0.	0.00		
ROUTED TO	R05B	11.	4.08	1.	0.	0.	0.00		
2 COMBINED AT	C05A	13.	4.08	1.	0.	0.	0.01		
ROUTED TO	R05C	13.	4.17	1.	0.	0.	0.01		
HYDROGRAPH AT	ON05	15.	4.08	2.	0.	0.	0.01		
2 COMBINED AT	C05B	27.	4.08	3.	1.	0.	0.01		
HYDROGRAPH AT	OFF15	23.	4.17	2.	1.	0.	0.01		
ROUTED TO	R010A	23.	4.17	2.	1.	0.	0.01		
HYDROGRAPH AT	OFF20	11.	4.08	1.	0.	0.	0.00		
ROUTED TO	R010B	10.	4.17	1.	0.	0.	0.00		
2 COMBINED AT	C010A	34.	4.17	3.	1.	0.	0.02		
ROUTED TO	R010C	32.	4.17	3.	1.	0.	0.02		
HYDROGRAPH AT	ON10	31.	4.08	3.	1.	0.	0.01		
HYDROGRAPH AT	ON11	22.	4.08	2.	0.	0.	0.01		
ROUTED TO	DB10	2.	4.42	1.	0.	0.	0.01		
3 COMBINED AT	C010B	61.	4.17	7.	2.	1.	0.04		
ROUTED TO	R011	57.	4.25	7.	2.	1.	0.04		
HYDROGRAPH AT	ON12	14.	4.17	1.	0.	0.	0.01		

+		CO12	69.	4.17	8.	2.	1.	0.05
+	HYDROGRAPH AT	ON15	32.	4.00	3.	1.	0.	0.01
+	ROUTED TO	DB15	13.	4.25	1.	0.	0.	0.01
+	ROUTED TO	RO22B	11.	4.33	1.	0.	0.	0.01
+	HYDROGRAPH AT	ON20	31.	4.17	3.	1.	0.	0.02
+	HYDROGRAPH AT	ON58	4.	4.08	1.	0.	0.	0.00
+	ROUTED TO	DB58	1.	4.00	1.	0.	0.	0.00
+	ROUTED TO	ON20	1.	5.00	1.	0.	0.	0.00
+	2 COMBINED AT	CO20	32.	4.17	4.	1.	0.	0.02
+	ROUTED TO	DB20	23.	4.33	4.	1.	0.	0.02
+	ROUTED TO	RO22	22.	4.42	4.	1.	0.	0.02
+	HYDROGRAPH AT	ON22	23.	4.08	3.	1.	0.	0.01
+	HYDROGRAPH AT	ON24	17.	4.00	1.	0.	0.	0.01
+	ROUTED TO	DB24	15.	4.08	1.	0.	0.	0.01
+	4 COMBINED AT	CO22	53.	4.25	8.	2.	1.	0.05
+	HYDROGRAPH AT	ON35	3.	4.00	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON30	55.	4.08	5.	1.	0.	0.03
+	ROUTED TO	DB30	55.	4.08	4.	1.	0.	0.03
+	HYDROGRAPH AT	ON31	6.	4.00	0.	0.	0.	0.00
+	HYDROGRAPH AT	ON40	46.	4.08	4.	1.	0.	0.02
+	ROUTED TO	DB40	18.	4.25	1.	0.	0.	0.02
+	3 COMBINED AT	CO45B	65.	4.08	5.	1.	0.	0.04
+	HYDROGRAPH AT	ON50	3.	4.00	0.	0.	0.	0.00
+	5 COMBINED AT	COEX1	182.	4.17	21.	5.	2.	0.15
+	HYDROGRAPH AT	OFF30	206.	4.25	25.	6.	2.	0.15
+	HYDROGRAPH AT	OFF35	59.	4.17	5.	1.	0.	0.03

+	3 COMBINED AT	CF45A	254.	4.25	30.	8.	3.	0.18
	ROUTED TO							
+		RF45	250.	4.25	30.	8.	3.	0.18
	HYDROGRAPH AT							
+		OFF45	46.	4.17	4.	1.	0.	0.03
	2 COMBINED AT							
+		CF45B	288.	4.25	34.	9.	3.	0.21
	ROUTED TO							
+		RO60	285.	4.25	34.	9.	3.	0.21
	HYDROGRAPH AT							
+		OFF50	77.	4.25	11.	3.	1.	0.06
	ROUTED TO							
+		RF60A	74.	4.33	11.	3.	1.	0.06
	HYDROGRAPH AT							
+		OFF55	4.	4.08	0.	0.	0.	0.00
	ROUTED TO							
+		RF60B	4.	4.17	0.	0.	0.	0.00
	2 COMBINED AT							
+		CF60A	77.	4.33	11.	3.	1.	0.07
	ROUTED TO							
+		RF60C	76.	4.33	11.	3.	1.	0.07
	HYDROGRAPH AT							
+		OFF60	27.	4.17	3.	1.	0.	0.02
	2 COMBINED AT							
+		CF60B	97.	4.33	14.	4.	1.	0.08
	ROUTED TO							
+		RO65	97.	4.33	14.	4.	1.	0.08
	HYDROGRAPH AT							
+		ON65	15.	4.08	1.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON60	19.	4.00	1.	0.	0.	0.01
	HYDROGRAPH AT							
+		ON59	2.	4.08	0.	0.	0.	0.00
	2 COMBINED AT							
+		CO60	22.	4.00	2.	0.	0.	0.01
	ROUTED TO							
+		DB60	13.	4.17	1.	0.	0.	0.01
	4 COMBINED AT							
+		CO65	392.	4.25	51.	13.	4.	0.31
	ROUTED TO							
+		RO75A	391.	4.33	51.	13.	4.	0.31
	HYDROGRAPH AT							
+		OFF65	8.	4.08	1.	0.	0.	0.00
	ROUTED TO							
+		RO70	7.	4.17	1.	0.	0.	0.00
	HYDROGRAPH AT							
+		ON70	24.	4.17	2.	1.	0.	0.01
	HYDROGRAPH AT							
+		ON61	11.	4.08	1.	0.	0.	0.00
	ROUTED TO							
+		RF65	2.	4.17	1.	0.	0.	0.00

+	4 COMBINED AT	C075A	418.	4.25	55.	14.	5.	0.33
	ROUTED TO							
+		R075B	413.	4.33	55.	14.	5.	0.33
	HYDROGRAPH AT							
+		ON75	34.	4.17	4.	1.	0.	0.02
	2 COMBINED AT							
+		C075B	440.	4.33	59.	15.	5.	0.35

*** NORMAL END OF HEC-1 ***

Appendix C – Hydraulics

HEC-RAS Output (Existing and Proposed Conditions)

- Schematic Geometry
- Cross Sections
- Profiles
- Summary Table

HY-8 Output:

- Preliminary Culvert Calculations

First Flush Spillway/Dissipation Basin Design:

HEC-RAS Existing Condition

135

1.86


674.58

477.04

334.44


197.32

47.19



Storyrock Master Plan: Storyrock Master Ex

WASH10 WASH10




Legend

- WS 100-Yr
- Ground


Storyrock Master Plan: Storyrock Master Ex

WASH60 WASH60







Storyrock Master - - Plan: Storyrock Master Ex

WASH75 WASH75




Legend





- WS 100-Yr
- Lat Struct
- Ground










Storyrock Master Plan: Storyrock Master Ex





River = WASH10 Reach = WASH10 RS = 65.67



















Storyrock Master Plan: Storyrock Master Ex

River = WASH75 Reach = WASH75 RS = 1300.34


← .05 → .035 → .05 →



Storyrock Master Plan: Storyrock Master Ex

River = WASH75 Reach = WASH75 RS = 1178.46



← .035 → .05 →



Storyrock Master Plan: Storyrock Master Ex

River = WASH75 Reach = WASH75 RS = 1078.73


← .05 → .035 →









Storyrock Master Plan: Storyrock Master Ex

River = WASH75 Reach = WASH75 RS = 962.62

← .035 → .05 →







Plan: Ex-Revised WASH75 WASH75 RS: 1400 Lateral Structure Profile: 100-Yr

E.G. US (ft)	2568.93	Weir Sta US (ft)	0.00
W.S. US (ft)	2568.32	Weir Sta DS (ft)	401.82
E.G. DS (ft)	2557.31	Min El Weir Flow (ft)	2557.27
W.S. DS (ft)	2555.96	Wr Top Width (ft)	156.94
Q US (cfs)	432.00	Weir Max Depth (ft)	0.26
Q Leaving Total (cfs)	11.00	Weir Avg Depth (ft)	0.09
Q DS (cfs)	421.15	Weir Flow Area (sq ft)	14.72
Perc Q Leaving	2.53	Weir Coef (ft ^{1/2})	2.000
Q Weir (cfs)	11.00	Weir Submerg	0.00
Q Gates (cfs)		Q Gate Group (cfs)	
Q Culv (cfs)		Gate Open Ht (ft)	
Q Lat RC (cfs)		Gate #Open	
Q Outlet TS (cfs)	0.00	Gate Area (sq ft)	
Q Breach (cfs)		Gate Submerg	
Breach Avg Velocity (ft/s)		Gate Invert (ft)	
Breach Flow Area (sq ft)		Gate Weir Coef	
Breach WD (ft)			
Breach Top El (ft)			
Breach Bottom El (ft)			
Breach SSL (ft)			
Breach SSR (ft)			


Profile	Q Total	Min Ch El	W.S. Elev	Ch W.S.	E.G. Elev	E.G. Slope	Val Chnl	Flow Area	Top Width	Froude # CH
(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(sq ft)	(ft)	(ft)
WASH75	2245.45	407.00	2585.99	2587.68	2588.27	0.032926	9.47	43.00	43.49	1.68
WASH75	2159.03	407.00	2584.00	2586.20	2586.15	0.027037	4.46	91.27	120.68	0.90
WASH75	2026.17	407.00	2580.97	2583.21	2584.02	0.013327	7.21	56.42	35.21	1.00
WASH75	1888.63	407.00	2577.99	2579.22	2579.62	0.057903	9.41	43.23	60.10	1.96
WASH75	1791.75	407.00	2575.80	2577.67	2577.87	0.015741	6.73	60.47	43.46	1.01
WASH75	1687.13	407.00	2573.00	2574.24	2574.61	0.056474	8.80	49.11	60.11	1.72
WASH75	1590.58	432.00	2570.88	2572.69	2572.69	0.018004	5.78	74.70	73.92	1.01
WASH75	1445.56	432.00	2567.87	2569.13	2569.27	0.032492	6.40	67.54	81.64	1.24
WASH75	1400									
WASH75	1300.34	431.96	2564.42	2566.54	2566.54	0.013402	5.92	72.92	69.70	1.22
WASH75	1178.46	430.59	2561.07	2563.64	2564.19	0.048437	9.97	43.18	41.53	1.72
WASH75	1078.73	422.44	2558.71	2560.61	2560.70	0.016817	6.52	72.03	79.03	1.01
WASH75	962.82	421.15	2555.74	2556.76	2557.22	0.105680	10.23	41.17	63.96	2.25
WASH75	831.66	421.15	2551.98	2553.82	2554.45	0.016999	6.37	66.10	53.20	1.01
WASH75	674.58	421.15	2547.99	2549.49	2550.27	0.046556	7.09	59.42	58.70	1.24
WASH75	477.04	421.15	2542.98	2544.22	2544.62	0.021451	5.09	82.80	106.28	1.02
WASH75	334.44	421.15	2538.98	2539.98	2540.07	0.039411	6.06	69.48	80.59	1.15
WASH75	332.34	421.15	2535.00	2536.54	2536.54	0.019286	5.29	79.57	94.69	1.02
WASH75	47.19	421.15	2530.22	2531.67	2531.85	0.057321	6.58	64.05	100.80	1.45
WASH65	904.05	2610.99	2612.02	2612.02	2612.16	0.027402	5.99	16.19	22.74	1.25
WASH65	608.77	2603.95	2605.07	2605.07	2605.50	0.022758	5.23	18.54	22.18	1.01
WASH65	516.17	2600.94	2602.56	2602.56	2602.38	0.019186	4.44	21.86	22.72	0.80
WASH65	400.74	2597.92	2599.50	2599.50	2600.00	0.032755	5.67	17.32	17.63	1.01
WASH65	293.66	2594.98	2598.26	2598.26	2598.40	0.025243	6.44	15.07	17.63	1.23
WASH65	219.18	2592.96	2594.23	2594.23	2594.67	0.034257	5.33	18.21	23.94	1.08
WASH65	101.76	2589.95	2591.42	2591.42	2591.85	0.021076	5.24	18.50	21.86	1.01
WASH65	861.45	2607.89	2609.98	2609.98	2610.10	0.020599	6.40	46.23	44.69	1.11
WASH60	576.92	2600.91	2603.16	2603.16	2604.43	0.022484	9.06	32.66	20.74	1.27
WASH60	395.74	2596.00	2598.53	2598.53	2599.14	0.029771	8.84	33.49	30.05	1.48
WASH60	296.24	2594.28	2595.76	2595.94	2596.52	0.032422	6.99	42.33	48.14	1.31
WASH60	101.73	2592.12	2593.59	2593.66	2594.16	0.024249	6.03	49.08	56.08	1.14
WASH60	81.32	2588.99	2591.09	2591.09	2591.76	0.016737	6.58	44.98	33.82	1.01
WASH60	1350.01	2605.54	2608.53	2608.53	2608.55	0.020802	3.66	18.55	49.66	1.05
WASH60	1219.73	2602.68	2603.48	2603.48	2603.70	0.022379	3.77	18.30	37.53	0.95
WASH60	1055.37	2598.95	2599.75	2599.75	2599.96	0.023154	3.67	18.81	46.11	1.01
WASH60	894	2594.95	2592.90	2592.90	2596.84	0.016498	3.46	19.93	34.18	0.80
WASH60	755.3	2591.99	2592.90	2592.90	2593.11	0.029625	3.68	18.82	64.61	0.83
WASH60	584.44	2587.96	2588.74	2588.74	2588.99	0.019925	4.07	16.95	33.95	1.02
WASH10	435.39	2584.87	2585.59	2585.59	2585.46	0.016902	2.73	25.33	53.10	0.68
WASH10	243.3	2580.99	2581.86	2581.86	2581.86	0.019975	4.36	15.83	27.29	1.01
WASH10	65.67	2576.97	2578.18	2578.26	2578.60	0.019998	5.18	13.31	21.30	1.16

○ SITE BOUNDARY CROSS SECTION

HEC-RAS Proposed Condition

Storyrock Master Plan: Storyrock Master Encroachment


WASH10 WASH10



Legend	
WS 100-Yr	▲
WS 100-Yr_Encroache	■
Ground	■


Storyrock Master Plan: Storyrock Master Encroach

WASH60 WASH60



Storyrock Master Plan: Storyrock Master Encroachment

WASH65 WASH65




Legend

- WS 100-Yr_Encroache
- WS 100-Yr
- Ground

Storyrock Master Plan: Storyrock Master Encroachment


WASH75 WASH75



Legend	
WS 100-Yr_Encroache	▲
WS 100-Yr	■
Ground	●


Storyrock Master Plan: Storyrock Master Encroach

River = WASH10 Reach = WASH10 RS = 1350.01




Storyrock Master Plan: Storyrock Master Encroach

River = WASH10 Reach = WASH10 RS = 1219.73




Storyrock Master Plan: Storyrock Master Encroach





River = WASH10 Reach = WASH10 RS = 1055.37



Storyrock Master Plan: Storyrock Master Encroach


River = WASH10 Reach = WASH10 RS = 894














Storyrock Master Plan: Storyrock Master Encroach





River = WASH10 Reach = WASH10 RS = 65.67

































HEC-RAS Plan: Encroache Locations: User Defined

River	Reach	River Sta	Profile	Q Total (cfs)	Min Ch El (ft)	W.S. Elev (ft)	Crit W.S. (ft)	E.G. Elev (ft)	E.G. Slope (ft/ft)	Vel Cntrl (ft/s)	Flow Area (sq ft)	Top Width (ft)	Froude # CH
WASH10	WASH10	1350.01	100-Yr	61.00	2605.54	2606.48	2606.50	2606.69	0.020828	3.64	18.75	43.33	1.03
WASH10	WASH10	1350.01	100-Yr Encroache	61.00	2605.54	2606.48	2606.60	2606.69	0.020826	3.65	18.71	42.26	1.02
WASH10	WASH10	1219.73	100-Yr	69.00	2602.68	2603.42	2603.46	2603.70	0.031831	4.25	18.22	36.45	1.12
WASH10	WASH10	1219.73	100-Yr Encroache	69.00	2602.68	2603.42	2603.46	2603.70	0.022057	3.75	18.30	37.57	0.94
WASH10	WASH10	1055.37	100-Yr	69.00	2598.95	2599.75	2599.75	2599.98	0.023154	3.67	18.81	48.11	1.01
WASH10	WASH10	1055.37	100-Yr Encroache	69.00	2598.95	2599.74	2599.74	2599.98	0.023539	3.69	18.69	46.01	1.02
WASH10	WASH10	894	100-Yr	69.00	2594.95	2595.94	2595.94	2596.12	0.016498	3.46	19.93	34.18	0.80
WASH10	WASH10	894	100-Yr Encroache	69.00	2594.95	2595.94	2595.94	2596.12	0.016498	3.48	19.93	34.18	0.80
WASH10	WASH10	755.3	100-Yr	69.00	2591.99	2592.90	2592.83	2593.11	0.020625	3.68	18.82	64.81	0.93
WASH10	WASH10	755.3	100-Yr Encroache	69.00	2591.99	2592.90	2592.83	2593.11	0.020551	3.68	18.84	64.83	0.83
WASH10	WASH10	584.44	100-Yr	69.00	2587.96	2588.74	2588.74	2588.99	0.019925	4.07	18.95	33.95	1.02
WASH10	WASH10	584.44	100-Yr Encroache	69.00	2587.96	2588.74	2588.74	2588.99	0.019853	4.07	18.95	33.95	1.02
WASH10	WASH10	435.39	100-Yr	69.00	2584.87	2585.58	2585.46	2585.70	0.016902	2.73	25.33	53.10	0.86
WASH10	WASH10	435.39	100-Yr Encroache	69.00	2584.87	2585.61	2585.49	2585.73	0.017272	2.76	25.11	50.85	0.87
WASH10	WASH10	243.3	100-Yr	69.00	2580.99	2581.66	2581.66	2582.16	0.019975	4.36	15.63	27.29	1.01
WASH10	WASH10	243.3	100-Yr Encroache	69.00	2580.99	2581.66	2581.66	2582.16	0.019975	4.36	15.63	27.29	1.01
WASH10	WASH10	65.87	100-Yr	69.00	2578.97	2578.18	2578.26	2578.60	0.019998	5.18	13.31	21.30	1.16
WASH10	WASH10	65.87	100-Yr Encroache	69.00	2578.97	2578.18	2578.26	2578.60	0.019998	5.18	13.31	21.30	1.16
WASH60	WASH60	861.45	100-Yr	289.00	2607.89	2609.06	2610.08	2610.59	0.020580	6.38	45.30	43.96	1.11
WASH60	WASH60	861.45	100-Yr Encroache	289.00	2607.89	2609.06	2610.08	2610.59	0.020580	6.38	45.30	43.96	1.11
WASH60	WASH60	578.92	100-Yr	289.00	2600.91	2603.13	2603.58	2604.39	0.022938	6.02	32.05	20.14	1.26
WASH60	WASH60	578.92	100-Yr Encroache	289.00	2600.91	2603.13	2603.58	2604.39	0.022638	6.02	32.05	20.14	1.26
WASH60	WASH60	395.74	100-Yr	289.00	2596.89	2598.51	2598.88	2599.70	0.029578	8.76	32.98	29.77	1.47
WASH60	WASH60	395.74	100-Yr Encroache	289.00	2596.89	2598.51	2598.88	2599.70	0.029578	8.76	32.98	29.77	1.47
WASH60	WASH60	296.24	100-Yr	289.00	2594.28	2595.74	2595.91	2596.49	0.032485	6.94	41.67	48.03	1.31
WASH60	WASH60	296.24	100-Yr Encroache	289.00	2594.28	2595.74	2595.91	2596.49	0.032485	6.94	41.67	48.03	1.31
WASH60	WASH60	213.64	100-Yr	289.00	2592.12	2593.58	2593.65	2594.13	0.024156	5.98	48.36	55.89	1.13
WASH60	WASH60	213.64	100-Yr Encroache	289.00	2592.12	2593.58	2593.65	2594.13	0.024156	5.98	48.36	55.89	1.13
WASH60	WASH60	81.32	100-Yr	289.00	2588.89	2591.06	2591.06	2591.73	0.016870	6.56	44.05	33.47	1.01
WASH60	WASH60	81.32	100-Yr Encroache	289.00	2588.89	2591.06	2591.06	2591.73	0.016870	6.56	44.05	33.47	1.01
WASH65	WASH65	904.05	100-Yr	96.00	2610.89	2612.01	2612.15	2612.57	0.027420	5.98	18.06	22.58	1.25
WASH65	WASH65	904.05	100-Yr Encroache	96.00	2610.89	2612.01	2612.15	2612.57	0.027420	5.98	18.06	22.58	1.25
WASH65	WASH65	608.77	100-Yr	96.00	2603.95	2605.07	2605.07	2605.49	0.022432	5.19	18.49	22.14	1.00
WASH65	WASH65	608.77	100-Yr Encroache	96.00	2603.95	2605.07	2605.07	2605.49	0.022432	5.19	18.49	22.14	1.00
WASH65	WASH65	516.17	100-Yr	96.00	2600.84	2602.55	2602.37	2602.85	0.019153	4.43	21.69	22.63	0.80
WASH65	WASH65	516.17	100-Yr Encroache	96.00	2600.84	2602.55	2602.37	2602.85	0.019153	4.43	21.69	22.63	0.80
WASH65	WASH65	400.74	100-Yr	96.00	2597.82	2599.49	2599.49	2599.99	0.032877	5.66	18.96	17.25	1.01
WASH65	WASH65	400.74	100-Yr Encroache	96.00	2597.82	2599.49	2599.49	2599.99	0.032877	5.66	18.96	17.25	1.01
WASH65	WASH65	293.66	100-Yr	96.00	2594.88	2596.26	2596.40	2596.90	0.025148	6.41	14.98	17.57	1.22
WASH65	WASH65	293.66	100-Yr Encroache	96.00	2594.88	2596.26	2596.40	2596.90	0.025148	6.41	14.98	17.57	1.22
WASH65	WASH65	219.18	100-Yr	96.00	2592.88	2594.22	2594.26	2594.68	0.034604	5.35	17.94	23.68	1.08
WASH65	WASH65	219.18	100-Yr Encroache	96.00	2592.88	2594.22	2594.26	2594.68	0.034518	5.35	17.96	23.68	1.08
WASH65	WASH65	101.78	100-Yr	96.00	2589.95	2591.41	2591.41	2591.84	0.021132	5.24	18.31	21.68	1.01
WASH65	WASH65	101.78	100-Yr Encroache	96.00	2589.95	2591.41	2591.41	2591.84	0.021104	5.24	18.32	21.69	1.01
WASH75	WASH75	2245.45	100-Yr	409.00	2585.99	2587.70	2588.27	2588.06	0.038015	9.35	43.74	43.94	1.85
WASH75	WASH75	2245.45	100-Yr Encroache	409.00	2585.99	2587.70	2588.27	2588.06	0.038015	9.35	43.74	43.94	1.85
WASH75	WASH75	2159.03	100-Yr	409.00	2584.00	2586.20	2586.15	2586.51	0.026880	4.46	91.74	120.60	0.90
WASH75	WASH75	2159.03	100-Yr Encroache	409.00	2584.00	2586.20	2586.15	2586.51	0.026880	4.46	91.74	120.60	0.90
WASH75	WASH75	2028.17	100-Yr	409.00	2580.97	2583.21	2583.21	2584.03	0.013341	7.23	56.60	35.28	1.01
WASH75	WASH75	2028.17	100-Yr Encroache	409.00	2580.97	2583.21	2583.21	2584.03	0.013341	7.23	56.60	35.28	1.01
WASH75	WASH75	1868.63	100-Yr	409.00	2577.99	2579.22	2579.63	2580.61	0.058184	9.44	43.32	60.11	1.96
WASH75	WASH75	1868.63	100-Yr Encroache	409.00	2577.99	2579.22	2579.63	2580.61	0.058184	9.44	43.32	60.11	1.96
WASH75	WASH75	1781.75	100-Yr	409.00	2575.80	2577.67	2577.67	2578.38	0.015825	8.75	80.56	43.48	1.01
WASH75	WASH75	1781.75	100-Yr Encroache	409.00	2575.80	2577.67	2577.67	2578.38	0.015817	8.75	80.57	43.48	1.01
WASH75	WASH75	1687.13	100-Yr	409.00	2573.00	2574.19	2574.59	2575.41	0.081508	8.87	46.11	59.40	1.78
WASH75	WASH75	1687.13	100-Yr Encroache	409.00	2573.00	2574.19	2574.59	2575.41	0.081508	8.87	46.11	59.40	1.78
WASH75	WASH75	1590.58	100-Yr	409.00	2570.88	2572.65	2572.85	2573.15	0.018005	5.70	71.82	73.60	1.02
WASH75	WASH75	1590.58	100-Yr Encroache	409.00	2570.88	2572.67	2572.67	2573.24	0.018360	6.10	67.10	69.54	1.01

HEC-RAS Plan Encroach Locations User Defined (Continued)

River	Reach	River Sta	Profile	Q Total (cfs)	Min Ch El (ft)	W.S. Elev (ft)	Crit W.S. (ft)	E.G. Elev (ft)	E.G. Slope (ft/ft)	Vel Chnl (ft/s)	Flow Area (sq ft)	Top Width (ft)	Froude # Chl
WASH75	WASH75	1445.56	100-Yr	409.00	2567.87	2569.10	2569.23	2569.72	0.032571	6.30	64.92	80.92	1.24
WASH75	WASH75	1445.56	100-Yr Encroache	409.00	2567.87	2569.09	2569.22	2569.74	0.033326	6.47	63.21	74.73	1.24
WASH75	WASH75	1300.34	100-Yr	420.00	2564.42	2566.54	2566.54	2567.06	0.012839	5.79	72.51	69.67	1.00
WASH75	WASH75	1300.34	100-Yr Encroache	420.00	2564.42	2566.46	2566.46	2567.10	0.014810	6.43	65.29	52.03	1.01
WASH75	WASH75	1178.46	100-Yr	420.00	2561.07	2562.61	2563.08	2564.18	0.050592	10.06	41.73	41.16	1.76
WASH75	WASH75	1178.46	100-Yr Encroache	420.00	2561.07	2562.85	2563.08	2564.10	0.045262	9.66	43.46	41.60	1.67
WASH75	WASH75	1078.73	100-Yr	420.00	2558.71	2560.62	2560.70	2561.24	0.016422	6.45	72.38	79.05	1.00
WASH75	WASH75	1078.73	100-Yr Encroache	420.00	2558.71	2560.64	2560.66	2561.29	0.016645	6.55	66.19	56.13	1.00
WASH75	WASH75	962.62	100-Yr	420.00	2555.74	2556.75	2557.22	2558.40	0.108060	10.30	40.79	63.83	2.27
WASH75	WASH75	962.62	100-Yr Encroache	420.00	2555.74	2556.75	2557.22	2558.41	0.109577	10.34	40.61	63.77	2.29
WASH75	WASH75	831.86	100-Yr	420.00	2551.98	2553.81	2553.81	2554.44	0.017013	6.37	65.94	53.15	1.01
WASH75	WASH75	831.86	100-Yr Encroache	420.00	2551.98	2553.81	2553.81	2554.44	0.017013	6.37	65.94	53.15	1.01
WASH75	WASH75	674.58	100-Yr	420.00	2547.99	2549.49	2549.65	2550.27	0.046403	7.07	59.37	58.69	1.24
WASH75	WASH75	674.58	100-Yr Encroache	420.00	2547.99	2549.49	2549.65	2550.27	0.046403	7.07	59.37	58.69	1.24
WASH75	WASH75	477.04	100-Yr	420.00	2542.98	2544.22	2544.22	2544.62	0.021483	5.08	82.60	106.23	1.02
WASH75	WASH75	477.04	100-Yr Encroache	420.00	2542.98	2544.20	2544.20	2544.68	0.024085	5.59	75.20	78.47	1.01
WASH75	WASH75	334.44	100-Yr	420.00	2538.98	2539.98	2540.07	2540.55	0.039337	6.05	69.40	80.58	1.15
WASH75	WASH75	334.44	100-Yr Encroache	420.00	2538.98	2540.01	2540.07	2540.55	0.035476	5.86	71.71	80.86	1.10
WASH75	WASH75	197.32	100-Yr	420.00	2535.00	2536.54	2536.54	2536.97	0.019307	5.29	79.38	94.65	1.02
WASH75	WASH75	197.32	100-Yr Encroache	420.00	2535.00	2536.53	2536.54	2536.97	0.019708	5.33	78.81	94.53	1.03
WASH75	WASH75	47.19	100-Yr	420.00	2530.22	2531.67	2531.85	2532.33	0.056582	6.54	64.22	100.88	1.45
WASH75	WASH75	47.19	100-Yr Encroache	420.00	2530.22	2531.67	2531.85	2532.33	0.054916	6.47	64.91	101.23	1.42

○ SITE BOUNDARY CROSS SECTION

HY-8 Culvert Calculation Output

HY-8 Culvert Analysis Report

Culvert: On-10

Crossing Discharge Data

Discharge Selection Method: Specify Minimum, Design, and Maximum Flow

Minimum Flow: 0 cfs

Design Flow: 34 cfs

Maximum Flow: 76 cfs

Table 1 - Summary of Culvert Flows at Crossing: ON10

Headwater Elevation (ft)	Total Discharge (cfs)	Culvert 1 Discharge (cfs)	Roadway Discharge (cfs)	Iterations
2601.50	0.00	0.00	0.00	1
2601.80	7.60	7.60	0.00	1
2602.16	15.20	15.20	0.00	1
2602.43	22.80	22.80	0.00	1
2602.71	30.40	30.40	0.00	1
2602.83	34.00	34.00	0.00	1
2603.18	45.60	45.60	0.00	1
2603.39	53.20	53.20	0.00	1
2603.59	60.80	60.80	0.00	1
2603.79	68.40	68.40	0.00	1
2604.00	76.00	76.00	0.00	1
2604.00	76.05	76.05	0.00	Overtopping

Rating Curve Plot for Crossing: ON10

Total Rating Curve

Crossing: ON10




Table 2 - Culvert Summary Table: Culvert 1

Total Discharge (cfs)	Culvert Discharge (cfs)	Headwater Elevation (ft)	Inlet Control Depth (ft)	Outlet Control Depth (ft)	Flow Type	Normal Depth (ft)	Critical Depth (ft)	Outlet Depth (ft)	Tailwater Depth (ft)	Outlet Velocity (ft/s)	Tailwater Velocity (ft/s)
0.00	0.00	2601.50	0.000	0.500	0-NF	0.000	0.000	1.500	1.500	0.000	0.000
7.60	7.60	2601.80	0.802	0.506	1-JS1t	0.353	0.604	1.500	1.500	1.075	0.000
15.20	15.20	2602.16	1.159	0.526	1-JS1t	0.517	0.863	1.500	1.500	2.150	0.000
22.80	22.80	2602.43	1.434	0.558	1-S2n	0.628	1.065	0.702	1.500	8.976	0.000
30.40	30.40	2602.71	1.711	0.604	1-S2n	0.728	1.240	0.829	1.500	9.562	0.000
34.00	34.00	2602.83	1.834	0.630	1-S2n	0.776	1.317	0.884	1.500	9.742	0.000
45.60	45.60	2603.18	2.183	0.770	1-S2n	0.901	1.536	1.047	1.500	10.364	0.000
53.20	53.20	2603.39	2.390	0.982	1-S2n	0.977	1.664	1.147	1.500	10.689	0.000
60.80	60.80	2603.59	2.590	1.196	1-S2n	1.052	1.781	1.241	1.500	10.999	0.000
68.40	68.40	2603.79	2.790	1.421	1-S2n	1.122	1.896	1.332	1.500	11.278	0.000
76.00	76.00	2604.00	2.998	1.649	1-S2n	1.186	2.001	1.419	1.500	11.545	0.000

 Straight Culvert


Inlet Elevation (invert): 2601.00 ft, Outlet Elevation (invert): 2600.00 ft

Culvert Length: 40.01 ft, Culvert Slope: 0.0250

Culvert Performance Curve Plot: Culvert 1

Performance Curve


Culvert: Culvert 1



Water Surface Profile Plot for Culvert: Culvert 1

Crossing - ON10, Design Discharge - 34.0 cfs

Culvert - Culvert 1, Culvert Discharge - 34.0 cfs



Site Data - Culvert 1

Site Data Option: Culvert Invert Data

Inlet Station: 0.00 ft

Inlet Elevation: 2601.00 ft

Outlet Station: 40.00 ft

Outlet Elevation: 2600.00 ft

Number of Barrels: 2

Culvert Data Summary - Culvert 1

Barrel Shape: Circular

Barrel Diameter: 3.00 ft

Barrel Material: Concrete

Embedment: 0.00 in

Barrel Manning's n: 0.0120

Culvert Type: Straight

Inlet Configuration: Beveled Edge (1:1)

Inlet Depression: NONE

Table 3 - Downstream Channel Rating Curve (Crossing: ON10)

Flow (cfs)	Water Surface Elev (ft)	Depth (ft)
0.00	2601.50	1.50
7.60	2601.50	1.50
15.20	2601.50	1.50
22.80	2601.50	1.50
30.40	2601.50	1.50
34.00	2601.50	1.50
45.60	2601.50	1.50
53.20	2601.50	1.50
60.80	2601.50	1.50
68.40	2601.50	1.50
76.00	2601.50	1.50

Tailwater Channel Data - ON10

Tailwater Channel Option: Enter Constant Tailwater Elevation.

Constant Tailwater Elevation: 2601.50 ft

Roadway Data for Crossing: ON10

Roadway Profile Shape: Constant Roadway Elevation

Crest Length: 90.00 ft

Crest Elevation: 2604.00 ft

Roadway Surface: Paved

Roadway Top Width: 40.00 ft

HY-8 Culvert Analysis Report

Culvert: ON-20

Crossing Discharge Data

Discharge Selection Method: Specify Minimum, Design, and Maximum Flow

Minimum Flow: 0 cfs

Design Flow: 15 cfs

Maximum Flow: 33 cfs

Rating Curve Plot for Crossing: ON20

Total Rating Curve

Crossing: ON20




Table 2 - Culvert Summary Table: Culvert 1

Total Discharge (cfs)	Culvert Discharge (cfs)	Headwater Elevation (ft)	Inlet Control Depth (ft)	Outlet Control Depth (ft)	Flow Type	Normal Depth (ft)	Critical Depth (ft)	Outlet Depth (ft)	Tailwater Depth (ft)	Outlet Velocity (ft/s)	Tailwater Velocity (ft/s)
0.00	0.00	2588.00	0.000	0.000	0-NF	0.000	0.000	1.500	1.500	0.000	0.000
3.30	3.30	2588.96	0.959	0.0*	1-JS1f	0.382	0.692	1.500	1.500	1.956	0.000
6.60	6.60	2589.47	1.469	0.0*	1-S2n	0.552	0.991	0.589	1.500	10.298	0.000
9.90	9.90	2590.09	2.090	0.460	5-S2n	0.691	1.212	0.750	1.500	11.212	0.000
13.20	13.20	2590.95	2.955	1.208	5-S2n	0.819	1.358	0.896	1.500	11.992	0.000
15.00	15.00	2591.52	3.518	1.706	5-S2n	0.888	1.407	0.972	1.500	12.367	0.000
19.80	19.80	2593.38	5.380	3.344	5-S2n	1.081	1.500	1.211	1.500	12.966	0.000
23.10	23.10	2595.05	7.052	4.733	5-S2n	1.255	1.500	1.494	1.500	13.691	0.000
26.40	24.83	2596.03	8.032	5.547	4-FFf	1.500	1.500	1.500	1.500	14.717	0.000
29.70	24.89	2596.07	8.068	5.577	4-FFf	1.500	1.500	1.500	1.500	14.754	0.000
33.00	24.94	2596.10	8.096	5.600	4-FFf	1.500	1.500	1.500	1.500	14.782	0.000

* Full Flow Headwater elevation is below inlet invert.

Straight Culvert


Inlet Elevation (invert): 2588.00 ft, Outlet Elevation (invert): 2586.00 ft

Culvert Length: 50.04 ft, Culvert Slope: 0.0400

Culvert Performance Curve Plot: Culvert 1

Performance Curve


Culvert: Culvert 1



Water Surface Profile Plot for Culvert: Culvert 1

Crossing - ON20, Design Discharge - 15.0 cfs

Culvert - Culvert 1, Culvert Discharge - 15.0 cfs



Site Data - Culvert 1

Site Data Option: Culvert Invert Data

Inlet Station: 0.00 ft

Inlet Elevation: 2588.00 ft

Outlet Station: 50.00 ft

Outlet Elevation: 2586.00 ft

Number of Barrels: 1

Culvert Data Summary - Culvert 1

Barrel Shape: Circular

Barrel Diameter: 1.50 ft

Barrel Material: Concrete

Embedment: 0.00 in

Barrel Manning's n: 0.0120

Culvert Type: Straight

Inlet Configuration: Beveled Edge (1:1)

Inlet Depression: NONE

Table 3 - Downstream Channel Rating Curve (Crossing: ON20)

Flow (cfs)	Water Surface Elev (ft)	Depth (ft)
0.00	2587.50	1.50
3.30	2587.50	1.50
6.60	2587.50	1.50
9.90	2587.50	1.50
13.20	2587.50	1.50
15.00	2587.50	1.50
19.80	2587.50	1.50
23.10	2587.50	1.50
26.40	2587.50	1.50
29.70	2587.50	1.50
33.00	2587.50	1.50

Tailwater Channel Data - ON20

Tailwater Channel Option: Enter Constant Tailwater Elevation

Constant Tailwater Elevation: 2587.50 ft

Roadway Data for Crossing: ON20

Roadway Profile Shape: Constant Roadway Elevation

Crest Length: 90.00 ft

Crest Elevation: 2596.00 ft

Roadway Surface: Paved

Roadway Top Width: 40.00 ft

First Flush Spillway/Dissipation Basin Design

Project **Storyrock**

Subject **First Flush Spillway/Dissipation Basin Design**

Designed by **ZJH**

Date 2/5/2016

Project No: 191069020

Checked by **JMB**

Date 2/5/2016

Objective: Design First Flush Spillway & Dissipation Basin for Typical Area

First Flush Equivalent Design Storm: 2 Year

$Q_2 = 2-8$ cfs

Spillway Design:

Top Width	8 Feet
Side Slopes	4:1 H:V
Flow Depth (2 year Design Storm)	0.5 Feet
Capacity ⁽¹⁾ (2 year Design Storm)	5 CFS

Dissipation Basin Design:

V = Spillway Velocity ⁽¹⁾	5.25 ft/s
D = Equivalent Opening Width	4 Feet
Riprap $D_{50} = 0.0191 * V^2 * (0.61)^{(2)}$	6 Inches
Basin Length = $4xD^{(3)}$	16 Feet

Notes:

- (1) Refer to Attached Flowmaster Output for Spillway Hydraulic Design
- (2) Per Drainage Design Manual - Hydraulics Equation 6.36, Specific Weight of Stone = 165 lb/ft³
- (3) Per Drainage Design Manual - Hydraulics Table 8.6

Worksheet for First Flush Spillway

Project Description

Friction Method Manning Formula
Solve For Discharge

Input Data

Roughness Coefficient	0.055	
Channel Slope	0.25000	ft/ft
Normal Depth	0.50	ft
Left Side Slope	4.00	ft/ft (H:V)
Right Side Slope	4.00	ft/ft (H:V)
Bottom Width	0.00	ft

Results

Discharge	5.25	ft ³ /s
Flow Area	1.00	ft ²
Wetted Perimeter	4.12	ft
Hydraulic Radius	0.24	ft
Top Width	4.00	ft
Critical Depth	0.64	ft
Critical Slope	0.06711	ft/ft
Velocity	5.25	ft/s
Velocity Head	0.43	ft
Specific Energy	0.93	ft
Froude Number	1.85	
Flow Type	Supercritical	

GVF Input Data

Downstream Depth	0.00	ft
Length	0.00	ft
Number Of Steps	0	

GVF Output Data

Upstream Depth	0.00	ft
Profile Description		
Profile Headloss	0.00	ft
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	0.50	ft
Critical Depth	0.64	ft
Channel Slope	0.25000	ft/ft

Appendix D – Stormwater Storage
Waiver



Request for Stormwater Storage Waiver

City of Scottsdale Case Numbers:

- PA - - ZN - - UP - - DR - - PP - PC#

The applicant/developer must complete and submit this form to the city for processing and obtain approval of waiver request **before submitting improvement plans**. Denial of the waiver may require the developer to submit a revised site plan to the Development Review Board.

Date 10/26/2016 Project Name Storyrock
 Project Location 128th Street and Ranch Gate Road
 Applicant Contact Jason Burm, PE Company Name Kimley-Horn and Associates
 Phone 480-207-2667 Fax _____ E-mail jason.burm@kimley-horn.com
 Address 1855 W. Baseline Road, Suite 200 Mesa, AZ 85202

Waiver Criteria

A project must meet at least one of three criteria listed below for the city to consider waiving some or all required stormwater storage. **However, regardless of the criteria, a waiver will only be granted if the applicant can demonstrate that the effect of a waiver will not increase the potential for flooding on any property.** Check the applicable box and provide a signed engineering report and supporting engineering analysis that demonstrate the project meets the criteria and that the effect of a waiver will not increase the potential for flooding on any property.

If the runoff for the project has been included in a storage facility at another location, the applicant must demonstrate that the stormwater storage facility was specifically designed to accommodate runoff from the subject property and that the runoff will be conveyed to this location through an adequately designed conveyance facility.

- 1. The development is adjacent to a conveyance facility that an engineering analysis shows is designed and constructed to handle the additional runoff from the site as a result of development.
- 2. The development is on a parcel less than one-half acre in size.
- 3. Stormwater storage requirements conflict with requirements of the Environmentally Sensitive Lands Ordinance (ESLO).

For a full storage waiver, a conflict with ESLO is limited to:

- Property located in the hillside landform as defined in the city Zoning Ordinance
- Property in the upper desert landform that has a land slope steeper than 5% as defined in the city Zoning Ordinance
- Property within the ESL zoning overlay district where the only viable location for a stormwater storage basin requires blasting

This full waiver only applies to those portions of property meeting one of these three requirements.

Partial waivers are available for projects or portions of properties within the Environmentally Sensitive Lands Zoning Overlay District, not meeting any of the three full waiver criteria above, if post-development peak discharge rates do not exceed pre-development conditions, based on the 10- and 100-year storm events.

By signing below, I certify that the stated project meets the waiver criteria selected above as demonstrated by the attached documentation.



 Engineer

10.27.16

 Date

Planning, Neighborhood & Transportation Division

7447 E Indian School Road, Suite 105, Scottsdale, AZ 85251 • Phone: 480-312-2500 • Fax: 480-312-7781



Request for Stormwater Storage Waiver

City of Scottsdale Case Numbers:

- PA -

- ZN -

- UP -

- DR -

- PP -

PC#

CITY STAFF TO COMPLETE THIS PAGE

Project Name _____

Check Appropriate Boxes:

Meets waiver criteria (specify): 1 2 3

Recommend approve waiver.

Recommend deny waiver:

None of waiver criteria met.

Downstream conditions prohibit waiver of any storage.

Other:

Explain: _____

Return waiver request:

Insufficient data provided.

Other: _____

Explain: _____

Recommended Conditions of Waiver:

All storage requirements waived.

Post-development peak discharge rates do not exceed pre-development conditions.

Other:

Explain: _____

Waiver approved per above conditions.

Waiver denied.

Floodplain Administrator or Designee

Date

Planning, Neighborhood & Transportation Division

7447 E Indian School Road, Suite 105, Scottsdale, AZ 85251 • Phone: 480-312-2500 • Fax: 480-312-7781



Request for Stormwater Storage Waiver

City of Scottsdale Case Numbers:

- PA -

- ZN -

- UP -

- DR -

- PP -

PC#

In-Lieu Fee and In-Kind Contributions

In-lieu fees are only applicable to projects where post-development peak discharge rates exceed pre-development levels, based on the 10- and 100-year storm events. If the city grants a waiver, the developer is required to calculate and contribute an in-lieu fee based on what it would cost the city to provide a storage basin, sized as described below, including costs such as land acquisition, construction, landscaping, design, construction management, and maintenance over a 75-year design life. The fee for this cost is \$1.87 per cubic foot of stormwater storage for a virtual storage basin designed to mitigate the increase in runoff associated with the 100-year/2-hour storm event. The applicant may submit site-specific in-lieu fee calculations subject to the Floodplain Administrator's approval.

The Floodplain Administrator considers in-kind contributions on a case-by-case basis. An in-kind contribution can serve as part of or instead of the calculated in-lieu fee. In-kind contributions must be stormwater related and must constitute a public benefit. In-lieu fees and in-kind contributions are subject to the approval of the Floodplain Administrator or designee.

Project Name STARROCK

The waived stormwater storage volume is calculated using a simplified approach as follows:

V = ΔCRA; where

V = stormwater storage volume required, in cubic feet,

ΔC = increase in weighted average runoff coefficient over disturbed area ($C_{post} - C_{pre}$),

R = 100-year/2-hour precipitation depth, in feet (DSPM, Appendix 4-1D, page 11), and

A = area of disturbed ground, in square feet

Furthermore,

R = _____

ΔC = _____

$V_w = V - V_p$; where

A = _____

V_w = volume waived,

V = _____

V = volume required, and

V_p = _____

V_p = volume provided

V_w = _____

An in-lieu fee will be paid, based on the following calculations and supporting documentation:

In-lieu fee (\$) = V_w (cu. ft.) x \$1.87 per cubic foot = _____

An in-kind contribution will be made, as follows:

No in-lieu fee is required. Reason:

Approved by:

Floodplain Administrator or Designee


Date

Planning, Neighborhood & Transportation Division

7447 E Indian School Road, Suite 105, Scottsdale, AZ 85251 • Phone: 480-312-2500 • Fax: 480-312-7781

Appendix E – Preliminary Grading Plan

C:\w\19106902 - Storyrock\Reports\PCRA\Lit Station #1\Exhibits\EDR_SystemLayout.dwg Oct 18, 2016 Matt.Nelson
 19106902 - Storyrock\Reports\PCRA\Lit Station #1\Exhibits\EDR_SystemLayout.dwg Oct 18, 2016 Matt.Nelson
 19106902 - Storyrock\Reports\PCRA\Lit Station #1\Exhibits\EDR_SystemLayout.dwg Oct 18, 2016 Matt.Nelson



NO.	REVISION	DATE

Kimley»Horn
 © 2016 KIMLEY-HORN AND ASSOCIATES, INC.
 7740 North 16th Street, Suite 300
 Phoenix, Arizona 85020 (602) 944-5500

SCALE (H): 1"=500'
 SCALE (V): NONE
 DESIGNED BY: ZJH
 DRAWN BY: MRN
 CHECKED BY: REL
 DATE: OCT 2016

STORYROCK
 ENGINEER DESIGN REPORT
 LIFT STATION #2 SYSTEM MAP
 SCOTTSDALE, ARIZONA

PROJECT NO.
19106902
 DRAWING NAME
SITE LAYOUT

3.2 Existing Lift Station and Sereno Canyon Service Area

The development of the Sereno Canyon lift station at 128th Street and Ranch Gate Road was intended to serve the properties adjacent to Sereno Canyon as described by the Sereno Canyon sewer service area within the *Facility Payback Agreement for Sewer System Improvements in the Sereno Canyon Service Area*. All properties in the proposed development are within this service area and have been allocated a percentage of capacity based on the proposed zoning and 0.31 du/acre.

The approved *Conceptual Master Wastewater System Report for Sereno Canyon* provides detailed analysis of the proposed system, including analysis of downstream pipe capacities in existing and ultimate conditions. The Sereno Canyon Lift Station consists of a duplex pumping station in a single wet well with an overflow storage area. Two identical pumps are provided, with a design flow of 350 GPM at a total dynamic head (TDH) of 151 feet.

The Sereno Canyon Lift station can be seen on **Figure 3 – System Layout**.

3.3 Proposed System Layout

Lift Station #2 will be one of three lift stations to be constructed to service the proposed StoryRock development. Approximately 10,400 feet of gravity sewer will be installed within the development that will outfall to the lift station. The lift station will utilize a new force that will convey flows into a proposed gravity sewer line that will be installed along 128th Street. Flows to this gravity sewer will outfall to the existing Sereno Canyon lift station. The full system layout can be seen on **Figure 1 – Vicinity Map**.

3.4 Proposed Site Layout

The proposed site is laid out on a 100' by 100' piece of land, at the low point of the StoryRock development. The site will consist of a six-foot diameter wet well, valve vault, meter vault, electrical control pad, transformer, concrete pad for a future chemical feed system, and a gas powered generator . The full site layout can be seen on **Figure 4 – Site Layout**.

4.0 Hydraulic and Capacity Analysis of Proposed Lift Station

4.1 Sereno Canyon Lift Station Allocation

This Conceptual Master Wastewater Plan has been prepared for the proposed Cavalliere Ranch Master Planned Community. See *Cavalliere Ranch Sewer Master Plan* for further information.

4.2 Sereno Canyon Service Area

In addition to the StoryRock project area, the existing lift station is intended to serve a total service area of approximately 1,200 acres. The original zoning of the service area was R1-130 with an associated density of 0.31 dwelling units per acre. The *Sereno Canyon Amended Master Wastewater Report* addressed the rezoning of Sereno Canyon to a higher density. It is anticipated that other developments in the service area may rezone to a higher density similarly to StoryRock and Sereno Canyon. For the purpose of this report, it is assumed that the developments west of 128th Street will rezone to a density of 1 dwelling unit per acre. The state land north of Ranch Gate Road is not anticipated to rezone to a higher density due to its proximity to existing low density developments. The calculated peak wet weather flow of for the Sereno Canyon service area per this report is 320 GPM.

According to the Sereno Canyon Amended Master Wastewater Report the Sereno Canyon Lift Station has a design capacity of 350 GPM. The existing lift station has the capacity for the calculated peak flow of the service area. Additionally, the existing 6" forcemain has adequate capacity to convey this peak flow.

4.3 Site Required Capacity

The StoryRock project area has been divided into multiple phases for constructability purposes, with Lift Station #2 supporting phases 1A and 1B, which are shown in **Figure 1 – Vicinity Map**. Ultimate design flow is estimated at 70 GPM as shown in **Figure 5 – Design Flows**. With the project being constructed in phases, the initial phased flows were evaluated. While phasing order will be confirmed at a later date, Phase 1A is assumed to be the first constructed, and will have an initial peak wet weather flow of approximately 31 GPM.

Using the existing topography and proposed locations of both the gravity sewer, as well as Lift Station #2, we've determined the static head for the proposed force main to be as follows:

Pumps Off Elevation	2537.00
Flow Line of Force Main at High Point	2643.00
Calculated Static Head	106.00

4.4 Pump & Force Main Phasing

With the phasing schedule anticipated for the StoryRock community, it is anticipated that the interim design flow will be a less than half of the ultimate design flow. In order to mitigate low design flow rates, the City has accepted the use of supplementing initially phased low demands with potable water that can be entered into the gravity sewer system upstream of the proposed lift station. This will flush the gravity system with potable water and will allow daily flushing of the force main to prevent the settling of solids within the force main. This will also reduce the potential of odor issues as well as help ensure that downstream gravity sewers are adequately flushed. Analysis of the system under both the interim and ultimate conditions can be seen below and in **Figure 5 – Design Flows**. The ultimate pump and system curves can be found in **Figure 6 – MP 3127 HT 3-262 System & Pump Curve**. Further information regarding the pump, including specs, efficiencies, pump curve, etc., can be found in **Appendix C**.

Condition	Total # of Lots	Flow to Lift Station (GPM)	Force Main Size	Pump	Pump Flow (GPM)	Total Dynamic Head (ft)	Force Main Flow Velocity (fps)
Interim	76	31 + supplemented potable water	3"	MP 3127 HT3-262, 170mm Impeller	71	162.82	3.08
Ultimate	170	70					

Lift Station # 2 Design Flows							
Phase	AREA	DWELLING UNITS (DU)	POPULATION	AVERAGE FLOW (gpd)	AAC Peaking Factor ⁽¹⁾	AAC Pipe Peak Wet Weather Flow (gpd) ⁽²⁾	AAC Pipe Peak Wet Weather Flow (gpm) (Total)
Phase 1A	A1	10	22	1,720	2.74	5,891	31
	A2	21	45	3,612	2.74	12,371	
	A3	38	82	6,536	2.74	22,386	
	A4	5	11	860	2.74	2,946	
	A5	2	4	344	2.74	1,178	
Phase 1B	B1	16	34	2,752	2.74	9,426	20
	B2	18	39	3,096	2.50	9675	
	B3	17	37	2,924	2.74	10,015	
Exception	OS1	3	6	516	2.74	1,767	18
	OS2	40	86	6,880	2.74	23,564	
Total		170	366	29,240	2.74	100,147	
						GPM	70
						Pumped Flow	71

(1) Peaking factor per AAC Title 18 - Chapter 9

(2) Wet Weather Peak Flow = 125% Dry Weather Peak Flow

Job Number	191988002
Job Description	Storyrock LS #2
Date	10/12/2016
Designed By	MRN
Checked By	REL
Pump Type	MP 3127HT3-262

HAZEN-WILLIAMS EQUATION FOR TDH CALCULATIONS

System Elevations:

Pumps Off Elevation
 Flow Line of Force Main at High Point
 Calculated Static Head

	2537.00	ft
	2643.00	ft
$\Delta Z =$	106.00	ft

Hazen-Williams Parameters:

Dia. of Discharge Piping
 Length of Discharge Piping
 Dia. of Force Main
 Length of Force Main
 Hazen Williams Coefficients
 Minor Losses - Sum of Coefficients for Discharge Piping
 Minor Losses - Sum of Coefficients for Force Main


D =	3.069	inches
L =	10	ft
D =	3.07	inches
L =	3890	ft
C =	130	
$K_o =$	1	taken from Minor Losses tab
$K_{FM} =$	6.87	taken from Minor Losses tab

Flow Interval for Tables

10	gpm
----	-----

C = 130 for Discharge Piping, C = 130 for Proposed Force Main

Flow (GPM)	Friction Head (Discharge Piping) (ft.)	Minor Losses (Discharge Piping) (ft.)	Friction Head (Force Main) (ft.)	Minor Losses (Force Main) (ft.)	T.D.H. (ft.)	Force Main Flow Velocity (fps)	Pump Curve (ft.)
0	0.00	0.00	0.00	0.00	106.00	0.00	190
10	0.00	0.00	1.50	0.02	107.51	0.43	185
20	0.01	0.01	5.42	0.08	111.45	0.87	184
30	0.03	0.03	11.48	0.18	117.54	1.30	181
40	0.05	0.05	19.55	0.32	125.65	1.73	176
50	0.08	0.07	29.55	0.50	135.70	2.17	172
60	0.11	0.11	41.40	0.72	147.61	2.60	168
70	0.14	0.14	55.06	0.98	161.35	3.04	164
80	0.18	0.19	70.49	1.28	176.86	3.47	156
90	0.23	0.24	87.66	1.63	194.12	3.90	133
100	0.27	0.29	106.52	2.01	213.09	4.34	0
110	0.33	0.35	127.06	2.43	233.74	4.77	
120	0.38	0.42	149.25	2.89	256.06	5.20	
130	0.44	0.49	173.07	3.39	280.01	5.64	
140	0.51	0.57	198.51	3.93	305.59	6.07	
150	0.58	0.66	225.53	4.52	332.77	6.51	



Approximate Capacity at C = 130: 71 gpm

5.0 Sitework

5.0 Site Options

The StoryRock project is being developed with the intent of attracting high income families. With the resulting higher quality developments, it may be preferable to look at different alternatives for the lift station to prevent neighbors and area developments being obstructed by the various aspects of the lift station (e.g. how the site looks, controlling odors, noise, etc.). Options for the site development of the lift station are as follows:

- Develop a decorative wall high enough to shield immediate neighbors from both views of the lift station, as well as prevent excess noise. Wall articulation that matches the theme of the neighborhood would help maintain an attractive look to the neighborhood.
- Decorative sun shades could be utilized to shield the site from above. Shades could be constructed for both the individual pieces of equipment, as well as for the whole site.
- Landscaping could be utilized, including large trees and native vegetation, and/or well placed earth with retaining walls to give a more natural look and obstruct views of the station equipment.
- Depending on the topography of the area, parts of the lift station can be constructed into sunk areas with retaining walls, creating a larger difference between the top of the walls and the top of the equipment
- The developers could look at constructing a house or architectural building matching area homes. Examples of other buildings utilized on other lift station projects can be found in **Appendix D**.

5.1 Wall

Per Section 7-1.205 of the *City of Scottsdale Design Standards & Policies Manual*, a perimeter wall will be required to be constructed around the site, but maintaining enough room inside of the site that all equipment and service equipment will be easily accessible for repair. As such, a 10-foot block wall is proposed around the site, with gate access located on the northwest corner of the site. As discussed in the previous section, there are several different options available to improve the aesthetics of the wall.

5.2 Odor Control

Per discussions with the City, odor control is not typically installed at new lift station sites. However, provisions for odor control chemical additional shall be provided at the lift station site in case the City deems it necessary to have installed. Installation will include a concrete pad for a future chemical storage tank, as well as electrical hook ups for future installation.

The City will require an odor control system at the force main outfall into the gravity system. Various options for outfall odor control include:

- Installing a sealed manhole at the outfall with a 'blower' to send the air through a filter that absorbs the H₂S. See **Appendix E – Odor Control** for examples of a Hartzell Blower, as well as a both a Vapex and Ecoair filter.
- Installing a chemical feed at the lift station to help treat the sewage for H₂S. The bioxide chemical used in this process is non-toxic, which means secondary containment on-site is unnecessary and chemical refilling procedures are greatly simplified. The chemical would be added before the sewage enters the force main, allowing the chemical to work as it works its way towards the outfall.

5.3 Generator

We plan to supplement the site power with addition of a standby generator. Similar sites (using combined motor Hp under 100Hp) utilize generators in size from 60KVA to 150KVA. Currently we plan to use a 150KVA generator that is switched via ATS in an emergency condition. We will coordinate with Scottsdale utility personnel to account for error conditions and controls to the generator.

5.4 Controls

Per Scottsdale Sewer Lift Station Design Criteria (Revision 10/15/15) we will provide controls of the station pumps, and control its overall operation. Scottsdale design standards will dictate flow sensing, telemetry, alarm systems and safety precautions, and associated hardware to ensure reliable communication with existing radio systems. Overall functionality and sequence of lift station's operations will be confirmed with city personnel in cases of specific operations for this lift station.

5.5 Lighting

Perimeter lighting will be installed per applicable City of Scottsdale standards. We will first design lighting in accord with lift station design requirements. In absence of specific lighting requirements for lift stations, IES (Illuminating Engineering Society) suggestions will be supplemented. Site lighting will be placed in locations that maintenance personnel agree with, and will be controlled using a hierarchy that is dictated by site management. We will conduct a basic calculation (AGI32 or approved software) to determine light levels and provide verification of fixture number and positioning.

5.6 Pump Enclosure

Various options exist for the wet well on the Lift Station #2 development site, which will vary based on the required volume and maximum depth of the wet well. As stated in Section 2.3 – Lift Station Design, the size of the wet well will be 6' diameter with approximately a 2' operational depth. Additional vendor information regarding the layout of the wet well and associated piping can be found in **Appendix G**.

An additional option for the wet well construction would be a fiberglass wet well, which is pre-constructed to include pumps, valve box, and water meter all in the construction of the wet well itself. This particular wet well would have a smaller foot print, which would assist in minimizing the size of the overall lift station site. Example plans of the Fiberglass Wet Well can be found in **Appendix F**.

6.0 *Permits Required*

- 1) Project shall require submittal of an Approval to Construct (ATC) and Approval of Construction (AOC) to the Maricopa County Environmental Services Department (MCESD).
- 2) Project shall require submittal of a Building Permit to the City of Scottsdale Planning and Development Services Department.

7.0 Recommendations

- January 2016
- 1) Lift station site will be designed and constructed to include the following:
Electrical Control Pad, Transformer, Generator, 6-foot diameter wet well,
Chemical pad valve vault, and meter vault. *by Sereno Canyon Water Utility and
Associated Sewer District*
 - 2) Lift station site will be designed to aesthetically accommodate the surrounding
development through the use of either a decorative wall, landscaping, shading
structure(s), combination thereof, or an architectural building.
Facility Payment Agreement for Sewer System Improvements in the Sereno Canyon
 - 3) Wastewater flows will be collected via 8" sanitary sewer lines across the
StoryRock development area for Lift Station #2
 - 4) Site will be designed to accommodate an ultimate flow of 70 GPM. Interim lower
flows will be accommodated by introducing potable water into the gravity sewer
system upstream of the proposed lift station.
 - 5) Lift Station #2 will require the installation of two MP 3127 HT 3 – 262 Motors
 - 6) Odor control options will be required at the gravity sewer force main outfall
 - 7) Dual PVC force mains will be constructed. Both force mains will be constructed
as 3" PVC lines.
 - 8) Force main will tie in with a currently proposed gravity sewer line, which will take
flows to the existing Sereno Canyon Lift Station

CITY OF SCOTTSDALE
SEWER LIFT STATION DESIGN CRITERIA
Revised 10/15/15

The purpose of this Sewer Lift Station Design Criteria document is to provide direction for the design of sewer lift stations that will ultimately be owned and operated by the City of Scottsdale (City). It is also recommended that privately-owned lift stations follow this document in the event that the City is asked or required to assume responsibility. While this document provides additional guideline for the design of sewer lift stations, it is not comprehensive and additional criteria may be required by both the City and the client based on project specific needs. The reader is also referred to the City of Scottsdale Design Standards and Policies Manual (DS&PM) for additional wastewater system criteria, including lift stations. The criteria provided herein are organized into general categories as shown below.

1 GENERAL/DOCUMENTATION

- 1.1 Prior to final inspection and acceptance, three sets of the following documents shall be prepared and provided to the City Water Resources Department (WRD): (1) As-Built/Record Drawings, and (2) Operation and Maintenance manuals. Each set shall include 1 hard copy and 1 electronic copy of the provided materials. In addition, each control panel shall have a copy of the panel drawings located inside the panel itself.
- 1.2 The City shall be provided a copy of all Maricopa County Environmental Services Department (MCESD) Approval to Construct (ATC) and Approval of Construction (AOC) documentation. AOC shall be obtained after functional testing and prior to system start-up.
- 1.3 All equipment shall be provided with the manufacturer recommended spare parts.

2 PROCESS/MECHANICAL

- 2.1 Each sewer lift station shall include a minimum of 2 pumps sized in a 1 duty + 1 standby configuration (or n+1 for larger configurations). Design flows shall be calculated in accordance with the DS&PM and in consultation with City WRD. Each pump shall additionally include a 35 gpm flow allowance above the peak calculated flow to account for the draining of swimming pools in the service area.
- 2.2 The following list provides the submersible sewage pump requirements:
 - Pump shall be of submersible type and mounted on two (2) 304L stainless steel rails. Rail mounting hardware shall also be 304L stainless steel including the submersible cable for pump removal.
 - Motors shall be air cooled submersible type, totally enclosed, non-ventilated, constant speed, inverter duty (VFD rated), 480V/3PH/60Hz.
 - Pumps shall be capable of passing 2 1/2" solids.
 - Pump shall be equipped with stainless steel motor shafts.
 - Pump Manufacturer shall be Fairbanks Morris, Flygt ITT, or approved equal.
- 2.3 Provide ductile iron piping for the discharge forcemain to a point 10 feet outside of the lift station property boundary.
- 2.4 The wet well access hatch shall include a locking hasp and be construction of aluminum, stainless steel, or other non-corrosive material. Access hatch shall be H20 load rated if located within a vehicle pathway.
- 2.5 Check valves shall be the full-port solids handling ball-type and shall be located outside the wet well in a separate vault. Air release valves shall also be installed inside the vault upstream of the check valves and plug valves shall be installed downstream. All equipment shall be rated for sewer service.

- 2.6 A 1.5" metered water source shall be installed for wash-down and cleaning up. The meter and backflow prevention device will be located adjacent to but outside the walls of the facility (See City of Scottsdale Standard Detail 2354). At least one hose bib shall be provided and shall have an approved atmospheric vacuum breakers and installed in an above ground location. At no time shall there be a connection between domestic water and the wet well or waste water.
- 2.7 Wet well wall interior surface shall be coated with Raven 405, Neopoxy 5300 or approved Equal. The coating will be applied to a minimum thickness of 80 mils. A factory certified technician will install the coating. The coating will be guaranteed free of defects and workmanship for a five-year period. The warranty will cover material, coating replacement and or repair. After the protective coating has set hard to the touch it shall be inspected with high-voltage holiday detection equipment. An induced holiday shall be made on to the coated concrete surface and shall serve to determine the minimum/maximum voltage to be used to test the coating for holidays at that particular area. The spark tester shall be initially set at 100 volts per 1 mil (25 microns) of film thickness applied but may be adjusted as necessary to detect the induced holiday. All detected holidays shall be marked and repaired by abrading the coating surface with grit disk paper or other hand tooling method. After abrading and cleaning, additional protective coating material can be hand applied to the repair area. All touch-up/repair procedures shall follow the protective coating manufacturer's recommendations. The manhole that receives the sewer lift station fluids will also be coated per these details.

3 ODOR CONTROL

- 3.1 Odor generation at a lift station is a highly variable element of lift station design that is impacted by upstream dischargers, hydraulic turbulence, upstream odor control chemical use, etc. At a minimum, provisions for odor control chemical addition shall be provided, including a concrete pad for a future chemical storage tank. However, due to the variable nature of odor generation and odor mitigation alternatives, the City Water Resources shall be contacted for approval of the specific odor control concept.

4 ELECTRICAL

- 4.1 The electric utility service shall be 480V 3PH.
- 4.2 A main service entrance disconnect is required.
- 4.3 Electrical cabinets shall be NEMA 4.
- 4.4 Phase protection shall be provided for all three-phase motors and pumps.
- 4.5 An hour meter (i.e. run-time totalizer) with local display shall be provided for each pump.
- 4.6 A power monitor shall be provided for each pump and shall be a watt-hour transducer Sineax PQ502, or approved equal. Power monitoring shall detect electrical load balance with current transformers and shall produce a 4-20 mA signal to the RTU, proportional to power used at each pump.
- 4.7 Pumps shall be driven with a motor soft starter, Benshaw or approved equal. For "grandfathered" lift stations without 480V/3PH power, Toshiba Variable Frequency Drives shall be used to transform the site power to 3PH for the pumps.
- 4.8 Oversized conduits shall be provided for the pumps to facilitate future pump replacement. Additionally, a spare conduit shall be provided.

- 4.9 All conduits that penetrate the Class 1 Division 1 boundary shall include a conduit seal per NFPA 820.
- 4.10 A minimum of one (1) 20A, 120V, 1PH outdoor rated convenience receptacle shall be provided on a dedicated circuit.
- 4.11 A generator shall be provided for backup power. The generator shall be 4 cycle natural gas, or diesel if natural gas is not feasible. Generator shall be load tested at the site at full rated power for a minimum of 6 hours. Should the generator be diesel fueled the tank shall be topped off after the load test. (See Section 7.3 The wetwell shall be provided with the appropriate warning signage regarding confined space entry.
- 4.12 Sound Level Limits)
- 4.13 An Arc Flash and coordination study shall be completed on new or modified electrical equipment and the gear shall bear the appropriate Arc Flash labels.

5 INSTRUMENTATION/CONTROLS


- 5.1 The control panel shall be powered through a dedicated circuit breaker and shall be separate from the pump starters.
- 5.2 Pump failure indicator lights shall be provided on the control panel. An internal lamp will latch upon failure. The alarm shall be capable of being reset either locally or remotely.
- 5.3 The lift station discharge flow meter shall be an ultrasonic type Endress+Hauser Prosonic Flow C, or approved equal, and shall comply with the following requirements.
- 5.3.1 The ultrasonic flow meter must comply with the applicable provisions of AWWA C750-10.
- 5.3.2 The totalizer will feature a digital indicator and solid state transmitter. The totalizer-transmitter will provide a 4-20 mA current signal proportional to the rate of flow.
- 5.3.3 Meter shall be installed per manufacturer's specifications for upstream and downstream straight-run distances.
- 5.3.4 Meter shall be sized to accurately measure both high and low flow and in accordance with the manufacturer's published data.
- 5.4 Level transducer shall be Endress+Hauser Waterpilot FMX21 and shall be used to measure wet well water level for pump operation and alarms. Level transducer shall be Waterpilot model number FMX21-FE211HGK25A (FE: Class 1 Division 1 Groups A-D; 2: 4-20m; 1: 316L 22mm Probe tube; 1H: 33 ft H2O Sensor range; G: Standard accuracy; K: 0-20FT/H2O custom factory calibration; 25: 60-ft shorable PE cable; A: FKM Viton seal).
- 5.5 Level switches, Roto-float or approved equal, shall be provided as a secondary means of control and shall be powered from the Uninterruptable Power Supply (UPS). Floats shall be mounted using 316 stainless steel hanger(s), that provide a minimum separation distance of 8 inches.

6 TELEMETRY

- 6.1 The Remote Terminal Unit (RTU) shall be Bristol Babcock Control Wave and compatible with the City's existing telemetry system. The preferred DO card is CWM-SEG 60-Sel 11. The City shall be contacted to obtain the specific RTU requirements that apply to the project. The engineer shall provide the system design elements, including number of pumps, sequence of operation, etc. so that the number of digital inputs and outputs can be verified and included in the RTU specification. The RTU shall include a keypad.
- 6.2 As soon as the location for the lift station is identified, Water Resources will conduct a survey to check communication with a City repeater. The outcome of this survey will be to provide an antennae height requirement that shall be implemented in the project.
- 6.3 Microwave Data Systems 9710A "smart" data remote transceiver, TX ON: 928.18125 MHz, 12V, DC input power, 4800 and 9600 baud rate Asynch digital interface modem, RS 232 interface-direct, type "N" female antenna connector with loopback option.
 - 6.3.1 Scala TY-900 Yagi antenna, "N" female connector
 - 6.3.2 Polyphaser IS-50NX-C2 lightning arrestor
- 6.4 Helix coaxial cable 1/2" foam dielectric 50 OHM LDF 4-50A; number of feet to be determined by the design engineer.
 - 6.4.1 Two Andrew type L44PLU "N" male connectors
- 6.5 Hoffman enclosure - NEMA 4, 30" x 24" x 8", including panel, painted white, or approved equal.
 - 6.5.1 Hoffman Catalog #A30H24BLP
 - 6.5.2 Hoffman Catalog #A30P24, including lock kit.
- 6.6 Single output series power supply 12V, DC output, 3.4 Amp, 115VAC input. Newark Catalog #89F1271
 - 6.6.1 Single output series power supply 24V, DC output, 3.6 AMP, 115VAC input. Newark Catalog #89F1264
 - 6.6.2 Two gel-cell batteries, 12VDC, 6 AMP/hr operable to 140° F. Newark Stock #99F1805
- 6.7 RTU will be programmed by the City of Scottsdale personnel.
- 6.8 RTU will include keypad option.
- 6.9 RTU shall include an uninterruptable power supply, Liebert GXT3 with Micropod. Liebert model number shall be GXT3-1000RT120, 1000 VA / 900 Watt UPS System, configured with 120VAC input and output power and furnished complete.
- 6.10 A 120V, 15A service receptacle shall be installed in the RTU cabinet.
- 6.11 Add 2 DO's - 1 for P1 fault reset and 1 for P2 fault reset. Need the high level and tempo for each pump separated.

7 SAFETY, SECURITY, AND SIGNAGE

- 7.1 All lift station sites shall be secured by an eight-foot high block wall, with a minimum of two access points. Access shall be provided by a 36" wide passage door and a sliding gate, minimum of twelve feet wide for vehicular access (See City of Scottsdale Standard Detail 2165-1 and 2165-2). Each access will be electronically keyed to City specification. No equipment inside the site shall protrude above the fence line, except the emergency beacon and the RTU antenna.
- 7.2 A site sign mounted on the exterior wall will have a green background with 2" white reflective lettering. The sign will be made of aluminum. The sign will read:



- 7.3 The wetwell shall be provided with the appropriate warning signage regarding confined space entry.

8 SOUND LEVEL LIMITS

- 8.1 It shall be unacceptable for any pump station to cause noise by any means to the extent that any fifteen minute period average sound level exceed the applicable limit given in the following table, at any location in the City of Scottsdale on or beyond the boundaries of the property line of the pump station facility. The noise subject to these limits is that part of the total noise at the specified location that is due solely to the action of said pump station.

TABLE OF APPLICABLE LIMITS	
Land Use Zone	Fifteen-Minute Average Sound Level (decibels)
Residential	45
Commercial	60

GENERATOR MAXIMUM NOISE LEVEL WILL BE 85 DECIBELS

- 8.2 Average sound level measurements will consist of Leq (15) measurements performed with an ANSI-S1.4-1971 Type 1 or Type 2 Sound Level Meter using the A-weighting network. Instrument response shall be "slow". Leq means the constant sound level that, in a given situation and time period, conveys the same sound energy as the actual time-varying A-weighted sound. Measurements with sound level meters shall be made when the wind velocity at the time and place of such measurement is not more than five miles per hour.
- 8.3 The location for measuring exterior sound levels shall be at the property line of the pump station facility and four to five feet above ground level and at least four feet from walls and other reflective surfaces. If a wall is closer than the required four feet to the property line, move the required distance outside the property line. An exception occurs when the pump station shares a boundary with an affected property. In this case the location for measuring exterior sound levels shall be at least one foot inside the property line of the affected property and four to five feet above ground level and at least four feet from walls and other reflective surfaces.

8.4 Alternative sound level measurements. Compliance with these guidelines can be demonstrated if the maximum sound level caused by the operation of the pump station does not exceed the average sound level limits set forth in paragraph 1 when tested at the locations described in paragraph 3.

9 MISCELLANEOUS

9.1 Install reset button for each pump on control panel.

9.2 Install high level reset to control panel

9.3 Lead float turns on P1 and lag float turns on P2

9.4 City of Scottsdale requires a cover over the instrumentation reads – hard cover on the NEMA box and a canopy over the instrument cluster.

Appendix B – City of Scottsdale Wastewater Design Guide
