



Water Study

PRELIMINARY WATER CAPACITY REPORT

Braun Property – 20 acres
Scottsdale, AZ

Prepared For:



7525 E. Camelback Rd., Suite #104
Scottsdale, AZ 85251
P: 480.946.5020

*ACCEPTED AS PRELIMINARY
REPORT W/COMMENTS*

City of Scottsdale
Water Resources Administration
9379 E. San Salvador
Scottsdale, AZ 85258

Prepared by:

*RRahman
09/20/2017*



EXPIRES 8/30/2017

Sustainability Engineering Group

8280 E. Gelding Drive, Suite 101
Scottsdale, AZ 85260
480.588.7226 www.azSEG.com

Project Number: 170601

Original Submittal Date: August 3, 2017

Case No.: TBD

Plan Check No.: TBD

14-ZN-2017
9/1/2017



TABLE OF CONTENTS:

1. EXECUTIVE SUMMARY	1
2. INTRODUCTION	
2.1 PLAN OBJECTIVE	1
2.2 SITE LOCATION	1
2.3 PROPOSED DEVELOPMENT	2
2.3.1 Existing Site Description	2
2.3.2 Proposed Site Development	2
3. DESIGN CRITERIA	
3.1 UTILITY DEVELOPER GUIDE CRITERIA	2
4. DEMANDS	
4.1 PROJECT USE DESCRIPTION	3
4.2 ZONING	4
4.3 PHASING OF DEMANDS	4
4.4 SUMMARY NARRATIVE OF DEMANDS	4
5. EXISTING FACILITIES / CONDITIONS	
5.1 PREVIOUS MASTER PLANS	4
6. PROPOSED FACILITIES	
6.1 DISTRIBUTION SYSTEM PIPING	
6.1.1 Onsite	4
6.1.2 Offsite Infrastructure	5
7. WATER MODEL	
7.1 DESCRIPTION OF MODEL	5
7.2 ASSUMPTIONS	6
7.3 SUMMARY OF RESULTS	6
8. SUMMARY / CONCLUSIONS	6
8.1 CONFORMANCE TO DESIGN GOALS	6
8.2 REQUIRED FACILITIES AND PHASING	7
9. REFERENCES	7



LIST OF TABLES:

TABLE 1	-	Design Criteria by demand type
TABLE 2	-	Water Demand Calculations

LIST OF FIGURES:

FIGURE 1	-	Vicinity Map
FIGURE 2	-	Aerial
FIGURE 3	-	Quarter Section Water Map 50-59
FIGURE 4	-	Quarter Section Water Map 50-57

APPENDIX:

APPENDIX I	-	Addendum to Water BOD Report for Reata Ranch
APPENDIX II	-	Preliminary Utility Plan

1. EXECUTIVE SUMMARY

The subject property is a proposed residential development of +/- 20 acres of undeveloped land located within the City of Scottsdale. The site is located on the NWC 132nd Street and East Pinnacle Vista Rd. The parcels are currently zoned R1-70 ESL and will be developed as thirteen residential lots with associated open space and public roads. The purpose of this report is to support an application for a ESL Density Incentive in accordance with the City of Scottsdale zoning ordinance and the environmentally sensitive land ordinance.

City of Scottsdale Quarter Section water maps show there is currently no water infrastructure near the project. The site falls within Quarter Section 50-59. According to the Addendum to Water BOD Report for Reata Ranch, dated September 2014, and Quarter Section Map 50-57, the closest existing water main is located at approximately Rio Verde Drive (Dynamite Blvd.) and 122nd Street. An existing 20" transmission main and an existing 12" golf course irrigation line are located in the Rio Verde R/W at this location. The Reata Ranch BOD report discusses the proposed water infrastructure from the connection to these existing water mains. A proposed 16-inch water main is planned along Rio-Verde Drive from 120th Street (connecting into the existing main) to 128th Street feeding and existing PRV, and a 12-inch water main from 128th Street to 136th Street. A 12-inch water main is also proposed south from Rio Verde Drive, down 132nd street to E. Pinnacle Vista.

Future?

2. INTRODUCTION

2.1 PLAN OBJECTIVE:

The purpose of this report is to provide discussions defining the water system concepts necessary to comply with the requirements outlined in the City of Scottsdale Design Standards & Policy Manual. It is intended to describe the requirements of providing water service to the site. At detailed study (with flow testing and calculations) of the existing and proposed water system will be completed prior to submission of the improvement plans to the City of Scottsdale.

2.2 SITE LOCATION

The project property consists of one (1) parcel of land located on the NWC 132nd Street and East Pinnacle Vista Rd. It is further defined as being in the E ½ of the SE ¼ of the NW ¼ of Section 36, Township 5 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Scottsdale, Arizona; Parcel ID number is APN: 216-77-024C. Refer to **FIGURE 1 - Vicinity Map** for the project's location with respect to major cross streets.

The site is bounded by E. Pinnacle Vista to the south, N 132 Street to the east, and the Desert Estates at Pinnacle Peak subdivision to the north and the east. The site is located approximately ¼ of a mile south of Rio Verde Drive.

Desert Estates at Pinnacle Peak is a recorded residential subdivision adjacent to the property, that is currently in the process of re-platting, and re-approval for onsite and offsite infrastructure. We have used the Addendum to Water BOD Report for Reata Ranch, dated September 2014, is the basis of this study.

2.3 PROPOSED DEVELOPMENT

2.3.1 Existing Site Description:

Land ownership includes 20.05 +/- net acres (19.26+/- gross acres) of undeveloped land designated as R1-70 (Single Family Residential-Low Density) per City of Scottsdale Zoning Map 39.

The site slopes from west to east and contains average cross-slopes generally ranging from 2% to 15%. Predominantly, the buildable areas of the site contain slopes ranging from 2% to 10%. The Rio Verde Wash 10 Tributary 3 splits the center of the property. FIRM Map Number 04013C1331M dated November 4, 2015 indicates this site is designated as Zone "X" with a portion of the property zone AE where the Rio Verde Wash 10 Tributary 3 crosses the site. A CLOMR has been approved by FEMA for improvements along this tributary, but the improvements have yet to be completed. A recorded drainage easement along this tributary exists for installing these drainage improvements. Two thirds of the AE zone have base flood elevations determined while the western one third was not part of the detailed study. The layout of the residential lots is such that the developable envelopes are outside of the determined flood plain and the dedicated drainage easement. Finished floor elevations for the home sites will be set a minimum one (1) foot above the high-water elevations of this tributary. Refer to FIGURE 2 for an aerial of the overall project existing conditions.

The City of Scottsdale Water Quarter Section Map (QS 50-59) shows the project site with no water infrastructure in the area. Also included is Quarter Section Map (QS 50-57) showing the nearest point of connection at this time. Refer to Figures 3 and 4 for the COS Water Quarter Section Maps (QS 50-59 and 50-57).

Due to the lack of current water infrastructure in the area, the parcel will be developed subsequent to or concurrently with the Reata Ranch development which proposes a 12-inch water main fronting the property. This water main is proposed as part of the Reata Ranch – Offsite Improvement plans currently being process through the City of Scottsdale under Case #2-PP-2014 and Plan #5483-14. ?

2.3.2 Proposed Site Development:

The property is proposed to be developed with a lot configuration for thirteen residential units. The development will include two 24' wide cul-de-sac roadways entering from 132nd Street. Refer to Appendix II for the preliminary utility plan showing the proposed site layout. ✓

An 8" main is proposed at each roadway tying into the proposed 12" DIP water main per the Reata Ranch – Offsite Improvements (Plan #5483-14). Domestic and irrigation services to the units will be tapped off these new 8" mains. ?

3. DESIGN CRITERIA

3.1 UTILITY DEVELOPER GUIDE CRITERIA

This project is designed using 13 du / 19.26 gross acres = 0.67 du/ac. Refer to **Table 1** below for applicable "Design Criteria for Water Systems" based on Figure 6.1-2 (<2 du/ac) in accordance with the City of Scottsdale DS&PM. ✓

Table 1 - COS Design Criteria by demand type

Land Use	Average Day Demand (gal/day/unit)	Max Day Peaking Factor	Peak Hour Peaking Factor
Residential (<2 DU/ac)	485.6	2.0	3.5

The system pressures, velocities, head losses and fire flow are in accordance with the COS DS&PM as follows:

Minimum Pressures:

50 psi residual pressure at the highest delivery point and 30 psi @ max day + fire flow ✓

Maximum Pressures:

Maximum Pressure = 120 psi ✓

The City of Scottsdale operates its system such that pressures may exceed 80 psi. Therefore, the city requires all metered services to have a pressure-regulating valve installed on the private service line per DS&PM 6-1.402. 407. ✓

Velocity & Head loss:

- 10 ft. head loss maximum per 1,000 linear feet of pipe for pipes less than 16 inches in diameter.

Hazen-Williams Coefficient 130

Fire Flows:

This site is under the jurisdiction of the City of Scottsdale Fire Department. Fire flows must be in accordance with the 2015 International Fire Code which, for one- and two-family dwellings, is determined as follows:

- Dwellings having a fire-flow calculation area that does not exceed 3,600 s.f. that have automatic sprinklers shall be 500 gpm for 1/2 hour. ✓

Higher Fire flow demand for >3,600 s.f. Homes. Confirm Home Sizes, as this will govern the F.F. demand.

4. DEMANDS

4.1 PROJECT USE DESCRIPTION

Proposed demands for this project are based on a Residential Demand per Dwelling Unit for a density <2 DU/ac. Refer to **Table 2** below for the proposed water demand calculations based on the design criteria established in *Section 3.1* above

Table 2: Water Demand Calculations							
	Units	Avg. Day Flow (gpd/unit)	Max Day Peaking Factor	Peak Hour Peaking Factor	Avg. Day Demand (GPD)	Max. Day Demand (GPD)	Peak Hour (GPD)
Res. (<2 DU/ac)	13	485.6	2	3.5	6,312.8	12,625.6	22,094.8
TOTAL PROPOSED BLDG UNITS	9						
		TOTAL DEMANDS (GPD):			6,312.8	12,625.6	22,094.8
		TOTAL DEMANDS (gpm):			4.38	8.77	15.34

4.2 ZONING

This site is in Zone 11 according to Figure 6.1-3 Pressure Zone Map in DS&PM.

4.3 PHASING OF DEMANDS

This residential project may be phased as dictated by unit demand. The infrastructure will be built in a single phase.

4.4 SUMMARY NARRATIVE OF DEMANDS

The demand scenario that governs the design was the peak hour demand.

Include Max. Day + Fire Flow demand Scenario.

5. EXISTING FACILITIES / CONDITIONS

5.1 PREVIOUS MASTER PLANS

No existing master plan or water report is available from COS for this site. However, a copy of the Addendum to Water BOD Report for Reata Ranch, dated September 2014 has been included in Appendix I of this report.

6. PROPOSED FACILITIES

6.1 DISTRIBUTION SYSTEM PIPING

6.1.1 Onsite:

The proposed water supply will consist of two new 8" public water lines and two new fire hydrants. The proposed 8" pipe will be DIP in accordance with COS requirements.

Domestic service will be provided by 1" copper service connections to each lot. Irrigation will be tapped from the domestic service and require backflow prevention.

Irrigation for common areas will be provided by a separate system tapped from the 8" line and maintained by the Home Owners Association.

6.1.2 Offsite Infrastructure:

Assuming this development proceeds the development of Reata Ranch no offsite infrastructure is required to service this site. ✓

7. WATER MODEL

7.1 DESCRIPTION OF MODEL

The final model of the proposed water system will be designed to meet the criteria of COS Water, the Arizona Department of Environmental Quality ("ADEQ"), and Maricopa County Environmental Services Department ("MCESD").

Bentley WaterCAD® Version 8i will be used to model the water system.

Network analysis input parameters included the following:

1. Pipe diameters (inches)
2. Pipe lengths (feet)
3. Pipes invert elevations (feet)
4. General Purpose Valve to model Water Meter and Double Check Valve Assembly
5. A reservoir and a pump to model the fire flow test performed
6. System demands (gpm)
7. Fire flows (gpm)
8. Model piping is ductile iron pipe using Hazen-Williams frictional losses (C = 130)

Output parameters will include but not necessarily limited too:

1. Pressure (psig)
2. Flow rates (gpm)
3. Velocities (fps)
4. Head loss (feet)

Include the worst case scenario
→ which is Max Day + Fire Flow Demand

However, referencing the modeling results from the *Water BOD Report for Reata Ranch* during maximum day and peak hour conditions provides a pressure of roughly 77 psi within the waterline within 132nd street. (Refer to Appendix I at nodes 7 and 23). During Max Day and Peak hour the pressure in this line is constant (77 psi) at both of the proposed taps for this subdivision. The Hazen Williams headloss equation provides a negligible friction loss for the approximately 400 foot of 8-inch pipe providing service to the proposed subdivision.

$$S_{\text{psi per foot}} = \frac{P_d}{L} = \frac{4.52 Q^{1.852}}{C^{1.852} d^{4.8704}}$$

Where;

- $S_{\text{psi per foot}}$ = frictional resistance (pressure drop per foot of pipe) in psi/ft
- P_d = pressure drop over the length of pipe in
- L = length of pipe in feet
- Q = flow, gpm

- C = pipe roughness coefficient (130)
- d = inside pipe diameter, (inches)
- H_f = friction headloss

$$S \text{ (psi/ft)} = [4.52 \times (15 \text{ gpm})^{1.852}] / [(130)^{1.852} \times (8.38)^{4.8704}] = 2.640 \times 10^{-6} \text{ psi/ft}$$

At 400 lf of onsite pipe length;
H_f = 0.0011 psi

show headloss @ Max Day + F.F. Condⁿ
For, 500 gpm FF, ~ Headloss ~ 2'4"
For, 1000 gpm FF, ~ Headloss ~ 8'3"

Approximately 10 ft -15 ft (4.3 psi – 6.5 psi) of elevation head loss will occur at the highest proposed PAD elevation on site. Consequently, the minimum Max Day and Peak Hour pressure should be around;

Elv. for Node 7 (App-I) is 2506.47. From GIS Map, Approx. Highest Elv. @ Site is 2535. Resulting Approx. of 12.4 psi of Elv. headloss.

$$\text{Minimum site pressure} = 77 \text{ psi} - 0.0011 \text{ psi} - 6.5 \text{ psi} = 70.5 \text{ psi}$$

7.2 ASSUMPTIONS

Please refer to *Section 3.1* for the design criteria.

The general methodology that will be used to provide the final design of this water infrastructure will consist of modeling a network of water distribution mains to meet COS pressure, head loss, and water demand requirements during daily demands and fire events. The connection to the water system will be modeled as a reservoir and pump. The pump will simulate the pressure drop and the available flow from the existing water system as depicted by the fire flow test. ✓

7.3 SUMMARY OF RESULTS

Modeling of the water system will be completed in the final BOD water report for the subdivision.

8. SUMMARY / CONCLUSIONS

8.1 CONFORMANCE TO DESIGN GOALS

- The proposed water main will be designed in accordance with COS design standards and policies¹. The following summary is based on the above analysis summary.
- Minimum 50 psi residual @ highest delivery point required, 70.5 psi minimum provided (per standard headloss calculations). — show min available pressure for Max Day + F.F. Condⁿ.
- Minimum 30 psi @ max+ fire flow required.
- 10 ft of headloss per 1000 feet of pipe will not be exceeded during fire flow conditions.
- The system will be designed to support the minimum 500 gpm fire flow requirements.
- If homes exceed 3,600 sf a fireflow rate of 1500 gpm will be required. This can be reduced to 750 gpm with the installation of a fire sprinkler system. ✓

8.2 REQUIRED FACILITIES AND PHASING

- Proposed facility improvements for this project are limited to a two 8" mains (approximately 400 lf each), two new fire hydrants, and 1" domestic service connections. ✓



- This project will be constructed in a single phase. ✓

REFERENCES

1. *City of Scottsdale Design Standards & Policies Manual-Chapter 6, Water*
2. *Water BOD Report for Reata Ranch, dated September 2014*



"LEEDing and Developing Smart Projects"



PROJECT
LOCATION

FIGURE 1
VICINITY MAP

© 2017 Google

Imagery Date: 10/4/2016 33°43'28.30" N 111°48'39.16" W elev 2662 ft eye alt 25812 ft




FIGURE 2
AERIAL

* THE SECTION LINE BEARING AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTENED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS "CALCULATED" ON THE MAP.

Air Release Valve	
Non-potable Air Release Valve	
Blowoff	
Cap	
Cathodic Protection	
Fill Drain	
Fire Hydrant	
Non-GPS Point	
Pressure Reducing Valve	
Pump	
Reducer	
Sample Station	
Water Manhole	
Non-Potable Manhole	
Well	
Valve	
Non-potable Valve	
Vault	
Water Main	
Non-Potable Main	
Fire / Private Main	
Non-Scottsdale Main	



The map scale of 1" = 100' is based on a full size print of 30" x 36"

50-59

NW 1/4 SEC. 36 T5N R5E

FIGURE 3




**SCOTTSDALE GEOGRAPHIC
INFORMATION SYSTEMS**
3629 North Drinkwater Boulevard
Scottsdale, Arizona 85251

N O T I C E

THE DOCUMENT IS PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.

THE CITY OF SCOTTSDALE



GENERAL NOTES:

- THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE OR DEPARTMENT AT (480) 312-7702.
- THE SECTION LINE BEARINGS AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER, 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTERED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS CALCULATED ON THE MAP.

LEGEND:

- Air Release Valve
- Non-potable Air Release Valve
- Blowoff
- Cap
- Cathodic Protection
- Fill Drain
- Fire Hydrant
- Non-GPS Point
- Pressure Reducing Valve
- Pump
- Reducer
- Sample Station
- Water Manhole
- Non-Potable Manhole
- Well
- Valve
- Non-potable Valve
- Vault
- Water Main
- Non-Potable Main
- Fire / Private Main
- Non-Scottsdale Main

VICINITY MAP

120TH STREET
121ST STREET
122ND STREET
DYNAMITE BOULEVARD
PINNACLE VISTA DRIVE
N 1/4 COR. 28200 N
N 1/4 COR. 27400 N
CENTER
12000 E
12400 E

NORTH

SCALE: 1" = 100'

0 50 100 200

The map scale of 1" = 100' is based on a full size print of 30" x 36"

WATER
QUARTER SECTION MAP
50-57
NW 1/4 SEC. 35 T5N R5E

FIGURE 4

CITY OF SCOTTSDALE
SCOTTSDALE GEOGRAPHIC INFORMATION SYSTEMS
3629 North Drinkwater Boulevard
Scottsdale, Arizona 85251



"LEED®ing and Developing Smart Projects"

APPENDIX I

Addendum to Water BOD Report for Reata Ranch September 2014

8280 E. Gelding Drive, Suite 101
Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com


APPENDIX

ADDENDUM TO WATER BOD REPORT

For

REATA RANCH

City of Scottsdale project Number: 3902-12



Prepared for:
Land Development Services, L.L.C.
7525 E. Camelback Road, Suite 104
Scottsdale, AZ 85251
Phone (480) 946-5020
Fax (480) 946-5041

Accepted For:
City of Scottsdale
Water Resources Department
9379 E. San Salvador
Scottsdale, Arizona

By: Doug Mann
Date: 10.14.14



Prepared by:
SKG Enterprises, Inc.
9260 East Raintree Drive, Suite 140
Scottsdale, Arizona 85260
Phone (480) 998-5600
Fax (480) 998-5603



September 2014
SKG Project #30-11

2-PP-2014

4508-14


2014
9/25/14
Water
4508-14

ADDENDUM TO WATER BOD REPORT

For

REATA RANCH

City of Scottsdale project Number: 3902-12



Prepared for:

Land Development Services, L.L.C.
7525 E. Camelback Road, Suite 104
Scottsdale, AZ 85251
Phone (480) 946-5020
Fax (480) 946-5041



Prepared by:

SKG Enterprises, Inc.
9260 East Raintree Drive, Suite 140
Scottsdale, Arizona 85260
Phone (480) 998-5600
Fax (480) 998-5603

September 2014
SKG Project #30-11

2-PP-2014

4508-14

TABLE OF CONTENTS

	Page No.
1.0 INTRODUCTION	3
2.0 EXISTING INFRASTRUCTURE	4
3.0 ONSITE WATER DISTRIBUTION SYSTEM.....	4
3.1 ULTIMATE BUILDOUT.....	6
4.0 WATER SYSTEM DESIGN PARAMETERS	8
5.0 HYDRAULIC ANALYSIS	9
6.0 REFERENCE	12

EXHIBITS

Exhibit 1	Location Map
Exhibit 2	Parcel Configuration Layout
Exhibit 3	Key map – Ultimate Buildout Scenario
Exhibit 4	Hydraulic model computer run for Ultimate Buildout

TABLES

Table 1	Parcel Infrastructure Dependency
Table 2	Water demand calculation for Ultimate Buildout Scenario
Table 3	Pressure at tie in locations
Table 4	Summary of Water System Design Parameters
Table 5	Summary of Water Demand Calculation for Each parcel and Site
Table 6	Summary of Scour depth for Sewer Line Segment under Wash

LIST OF APPENDICES

APPENDIX A.....	Demand Computation for Ultimate Buildout Scenario
APPENDIX B.....	Copy of City Approved SKG Water Report, Case # 3902-12
APPENDIX C.....	Scour Depth Analysis Excerpts from REATA RANCH Drainage Report

1.0 INTRODUCTION

- **Purpose of Study and Relative History**

The master water distribution system basis of design report (BOD) for Reata Ranch was originally developed by SKG Enterprises, Inc. on August 24th, 2012 (Reference 1 and Appendix B). This Water BOD report was approved by the City of Scottsdale under case number 3902-12 on September of 2012. Further, the proposed offsite waterline, along Rio Verde Drive, was designed as a part of Water Master Plan (Hunn & Associates, Inc.) by GTA Engineering Inc. on April 25th, 2001 (Reference 2), which was also City approved. Since the approval of the Rio Verde waterline design and the SKG water BOD report, the proposed development of Reata Ranch has undergone slight lot layout configuration changes, while the intent of the original design is still maintained.

The purpose of this addendum is to present the most recent proposed onsite water system's layout within the Reata Ranch development as has recently been approved by the City of Scottsdale Development Review Board under case number 2-PP-2014 and to demonstrate that the development of Reach Ranch (with its new and revise lot configuration) still meets the water design standards in accordance with the City of Scottsdale's Design Standards and Policy Manual.

- **Location of Study**

Reata Ranch is a proposed master planned development bounded by 136th to 128th Streets (east-west-direction) and Rio Verde Drive to Pinnacle Vista Drive (north-south-direction) and is situated in a portion of the north half of Section 36, Township 5 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Scottsdale, Arizona (Exhibit 1).




Exhibit 1 – Location Map

2.0 EXISTING INFRASTRUCTURE

Currently, there is no existing water main along the perimeter of the site. The closest existing water line to Reata Ranch is located within the vicinity of Rio Verde Drive and 120th Street. A proposed 16-inch water main is planned along Rio-Verde Drive from 120th Street (connecting into the existing main) to 128th Street (Reference 2) and a 12-inch water main from 128th Street to 136th Street. In addition to the proposed Rio Verde water main, additional water lines are also proposed as follow:

- 12-inch water main along 128th Street,
- 12-inch water main along 132nd Street,
- 12-inch water main along 136th Street, and
- Pressure Reducing Valve (PRV) at 128th Street

3.0 ONSITE WATER DISTRIBUTION SYSTEM

The proposed water distribution infrastructure for the Reata Ranch development will consist of two components:

1. Offsite water main along Rio Verde Drive, 128th Street, 132nd Street and 136th Street, and
2. Onsite water distribution system

It is currently anticipated that entire Reata Ranch site grading and infrastructure activities be constructed at one time. This construction plan was a result of balancing earthwork grading activity to mitigate potential earthwork import or export. In order to maintain flexibility to close-out of some parcels while the rest of the parcels are still under construction, the design team has elected to submit improvement plans via seven separate cover sheets labeled as Parcels “A” through “G”. The final plat for the development is; however, planned to be submitted as one complete final plat document (as opposed to seven separate plats). It should be noted; however, that all seven parcels are planned to be submitted to the City of Scottsdale for review at the same time. Associated with seven separate plans submittals, this water BOD report was prepared as a one document (not seven separate documents) with the understanding that the entire water system will be constructed at one time. The water hydraulic model has been prepared as one complete system to be constructed at one time. However, in case where one parcel should be closed-out while the rest of the infrastructure is still being constructed, the following table has been prepared to demonstrate which parcel can be closed-out “as a standalone parcel” and which parcel is dependent on others relative to water, sewer, and access. It is implied that the offsite water distribution system will be constructed prior to any onsite line installation (See Exhibit 2). It should be noted herein that the intent of the table below is not to suggest the project will be phased, relative to infrastructure construction, but rather which parcel can be closed-out while others are still being under construction.

Table 1 – Parcel Infrastructure Dependency

Sequence Number	Activity	Description of Construction Work
1	CLOMR channel grading	Channelization grading of wash and area directly adjacent to wash. Installation of drainage structures within the wash to comply with the FEMA-CLOMR application. The only utility to be installed with this construction activity is water line and potentially dry-utility sleeves under the drainage structures. These plans will also include channel erosion protection and channel re-vegetation plans.

2	Offsite Improvements	Construction of offsite improvements will consist of: 1. 136th Street: roadway, 12" water, and 4" sewer force main 2. 132nd Street: roadway and 12" water 3. 128th Street: roadway and 12" water 4. Rio Verde Drive: right & left turn lanes 5. Rio Verde Drive: 12" & 16" water line 6. Rio Verde Drive: 4" sewer force main These plans will also include storm-drain related construction, re-vegetation plans, landscape & irrigation, and dry utilities.
3	Parcel "E"	Residential subdivision with access drive off Rio Verde Drive. Secondary access will be toward 132nd Street (north of Parcel "C") since the channel grading will be 100% completed prior to completion of Parcel "E"; therefore, a graded access will be available from Parcel; "E" to 132nd Street. Water will have 2 sources, the 1st is via Rio Verde Drive and the 2nd is via 6" water line parallel to the force main connecting into 136th Street. Sewer is available all the way to the lift station. <u>Parcel "E" is a "standalone parcel" that can be closed-out independent of any other parcel.</u>
4	Parcel "C"	Access is through Rio Verde and 132nd Street (2 access points). Water will have 3 sources (Rio Verde, 136th Street, and 132nd Street). Sewer is gravity through Parcel "E". <u>Parcel "C" depends on Parcel "E" for sewer outfall and therefore, cannot complete its "certificate of occupancy" status prior to Parcel "E" sewer line construction completion.</u>
5	Parcel "G"	Access is through Rio Verde and 136th Street (2 access points). Water will have 2 sources (Rio Verde and 136th Street). Sewer is gravity all the way to the lift station. <u>Parcel "G" is a "standalone" parcel that can be closed-out independent of any other parcel.</u>
6	Parcel "F"	Access is through Rio Verde and 136th Street (2 access points). Water will have 3 sources (Rio Verde, 136th Street, and 132nd Street). Sewer is gravity through Parcel "G". <u>Parcel "F" depends on Parcel "G" for sewer outfall and therefore, cannot complete its "certificate of occupancy: status prior to Parcel "G" sewer line construction completion.</u>
7	Parcel "B"	Access will be through 132nd Street and 128th Street (2 access points). Access to 128th Street will be through the graded portion of the CLOMR wash grading activity in sequence number 1 above. The channel grading will be 100% completed prior to completion of Parcel "B"; therefore a graded access will be available to 128th Street. Water will be via 2 sources (132nd Street and 128th Street) which means that Parcel "A" water line must be installed with Parcel "B" to create the 2nd water source for Parcel "B". Also Parcel "B" sewer outfall depends on Parcels "E" and "C". Therefore <u>Parcel "B" cannot be completed without Parcels "E", "C", and "A".</u> Parcel "B" & "A" will be submitted and constructed together.
8	Parcel "A"	Access will be through 132nd Street and 128th Street (2 access points). Water will have 2 sources (128th Street and 132nd Street). Sewer outfall will be through Parcels "B", "C", and "E". Therefore, Parcel "A" is depends on parcels "B", "C", and "E" to function. <u>Parcel "A" cannot be completed without Parcels "B", "C", and "E".</u> Parcel "B" & "A" will be submitted and constructed together.

9	Parcel "D"	Access is through Rio Verde, 136 th , and 132 nd Street (3 access points). Water will have 3 sources (Rio Verde, 136 th Street, and 132 nd Street). Sewer is gravity through Parcel "E". <u>Parcel "D" depends on Parcel "E" for sewer outfall and 2nd source water connection.</u> Therefore, cannot complete its "certificate of occupancy" status prior to Parcel "E" construction completion.
10	Final Plat	Final plat will be prepared is one complete documents and be submitted "as reference" with each parcel submittal.

See Exhibit 2 for parcel configuration layout

The onsite water distribution system facility will entail the installation of the following:

- Onsite water distribution system consisting of 8-inch and 12-inch, water lines.
- 6-inch water line to create looping system at two locations.
- All water line shall be of ductile iron pipe material.

The proposed onsite distribution system design intent is to maintain pressure to range from an upper limit of approximately 120 pounds-per-square-inch (psi) to a lower limit of 50 psi limit at the highest end of the development's pressure zone. The lower limit could drop to as low as 30 psi during fire flow demand.

The water distribution system described in this report consists of ultimate buildout scenario where the water system model considered the entire developments of the Reata Ranch. The water infrastructure sizes for Reata Ranch development were based on this "ultimate buildout" scenario.

3.1 ULTIMATE BUILDOUT

Ultimate build-out is a final build-out scenario and includes the entire development areas of all 7 parcels and all offsite infrastructure improvements. As such, the ultimate build-out water model was prepared to include the entire Reata Ranch developments.

The proposed 12" D.I.P. along East Running Deer Trail connecting 128th, 132nd, and 136th streets and 8" D.I.P. for the remaining streets within the master planned development of Reata Ranch project is to deliver potable water and fire protection to the farthest of the development. Exhibit 3 illustrates the general layout of the water system infrastructure for each of the parcel development.

The table below outlines the projected water demand for the proposed Reata Ranch Ultimate build-out scenario. It describes the water demand in terms of average daily demand, maximum day demand and peak hourly demand.

Table 2 – Water demand calculation for Ultimate Build-out Scenario

Type 1	Acres 2	DU/Ac 3	Units 4	Demand Per Unit 5	Ave. Daily Demand (gpd) 6	Max Daily Demand (gpd) 7	Peak Hourly Demand (gpd) 8
Parcel A	17.9	3.5	36	485.6	17,482	34,963	61,186
Parcel B	20.5	3.5	40	485.6	19,424	38,848	67,984
Parcel C	26.3	3.5	63	485.6	30,593	61,186	107,075
Parcel D	24.7	3.5	37	485.6	17,967	35,934	62,885
Parcel E	16.6	3.5	24	485.6	11,654	23,309	40,790
Parcel F	22.3	3.5	78	485.6	37,877	75,754	132,569
Parcel G	20.6	3.5	50	485.6	24,280	48,560	84,980
Equestrian Center & Club House	15.3	-	-	1,786	27,322	54,644	95,627
Offsite - South of Property	420	3	140	485.6	67,984	135,968	237,944
Offsite - East of 136th Street	420	3	142	485.6	68,955	137,910	241,343

Design Criteria:

1. Average Daily Demand for Residential = 485.6 gpd per unit
2. Average Daily Demand for Resort town homes = 485.6 gpd per unit
2. Average Daily Demand for Developed Open Space - Parks = 1786 gpd per acre
2. Max Day Demand = 2 X Avg Daily Flow
3. Peak Hour Demand = 3.5 X Avg Daily Flow
4. Fire Flow = 1000 gpm for single family residential
5. Fire Flow = 2500 gpm for Resort
6. Offsite Water Demand was computed assuming that the surrounding Parcels are zoned as R1-130. Since Reata Ranch is 220acres, the adjoining Parcels of 420 acres is expected to develop 140 potential residential lots. Parcel to the east (Wildcat Ridge/Scottsdale National/ Scottsdale Appendage) is expected to develop 142 lots.

The City of Scottsdale has approved the proposed water distribution system along Rio Verde Drive consisting of 16" and 12" mains (Ref. 1 and 2). This approved water system will be the main domestic and fire flow water sources for the proposed development of Reata Ranch. A hydraulic water model for this water system was also previously prepared and City approved on May 7, 2001 (Ref. 5). Excerpt from this water model report is included in Ref. 3 of this report. The available water flow and pressure are summarized in Table-3.

Table 3 – Pressure at tie in locations

Node #	Near	Flow (GPM)	Pressure (psi)
1	2	3	4
210	128 th Street	299.56	55.00
212	East of 128 th Street	299.56	63.46
220	West of 132 nd Street	299.56	80.45
224	136 th Street	299.56	91.11

In the Ultimate build-out scenario, all the parcels (Parcels “A” through “G”) are considered for Hydraulic Analysis, the results of which are included in Section 5.

Demand assigned at each of the junctions is summarized in Appendix A for Ultimate Build-out Scenario.

4.0 WATER SYSTEM DESIGN PARAMETERS

The design parameters used to calculate the water demand for this development are presented in the table below.

Table 4 - Summary of Water System Design Parameters

Criteria	Parameters
Average Single-family Residential Demand	485.6 GPD per dwelling unit
Resort Development Demand	485.6 GPD per unit
Residential Fire Flow	1,000 GPM, 4 hour Duration
Commercial Fire Flow (Resort)	2,500 GPM, 4 hour Duration
Velocity Range	0 to 5 foot-per-second
Water pipe material	Ductile Iron Pipe
Allowable pipe sizes (inches)	8” and 12”
Peak Day Peaking Factor	2.0 times average day demand
Maximum Hour Peaking Factor	3.5 times average day demand

GPM = gallon per minute

GPD = gallon per day

Water Design parameters obtained from City of Scottsdale, "Chapter 6 Potable Water System Design, Design Standards and Policies Manual", Dated August 2008.

5.0 HYDRAULIC ANALYSIS

This report provided the water hydraulic analysis for ultimate build-out development scenario. The model is analyzed for 4 independent demand scenarios:

- 1 Average Day Demand;
- 2 Maximum Day Demand;
- 3 Peak Hour Demand; and
- 4 Maximum Day + Fire Flow Demands

The hydraulic system is modeled for “steady state analysis” using Bentley WaterCAD V8i software. Fire flow analysis is performed for all the nodes to meet the fire demand. Based on the model results, the proposed water infrastructure is found to be adequate to meet ultimate buildout domestic and fire demands, and serve as a reliable source of water supply for the entire development. The hydraulic model analysis results and corresponding demand patterns, with the proposed water system diagram of the ultimate buildout scenario for steady state analysis is presented in Exhibit 4 of this report. The following summarizes the water distribution system design criteria under these four scenarios.

- ❑ The Hazen-Williams "C" for ductile iron pipe is 120.
- ❑ Minor losses are ignored.
- ❑ The overall head-loss through the piping networks is low at peak hour demand and at the maximum day+fire demand. The maximum and minimum pressures at each junction nodes are within the pressure zone range.
- ❑ The upper limit of water pressure shall be on the order of 120 psi.
- ❑ The lower limit of water pressure shall be on the order of 50 psi.
- ❑ The lower limit of water pressure shall be on the order of 30 psi with fire flow.
- ❑ On-site water system distribution will consist of adequate size to deliver the needed flows and pressures.
- ❑ Fire Flow analysis for all nodes were conducted based on 1,000-GPM for residential units, and 2,500-GPM flow for resort parcels, with pressure equal to or greater than 30 psi at all nodes.
- ❑ All pipe material shall be of ductile iron pipe.
- ❑ Hydraulic model output print out is presented in Exhibit 3 of this report.
- ❑ Digital copy of the hydraulic model is attached in a “CD” at the back of this report

Table 5 presents a summary of the water demand calculation for each parcel and that of the total site. Table 6 presents the calculated scour-depth for the proposed 6” water line segment that will be installed under the wash (see Exhibit 3 for water line segment to be installed within a wash).

Table 5 - Summary of Water Demand Calculation for Each Parcel and the Total Site

Parcel No.	Junction No.	No. of Units	Average Daily Flow (gpm)	Maximum Day Demand (gpm)	Peak Hour Demand (gpm)	Maximum Day + Fireflow (gpm)
A	2	18	6.07	12.14	21.25	1000
B	3	18	6.07	12.14	21.25	1000
	4	22	7.42	14.84	25.97	1000
	5	7	2.36	4.72	8.26	1000
	6	11	3.71	7.42	12.98	1000
C	7	-	-	-	-	1000
	8	5	1.69	3.37	5.90	1000
	9	8	2.70	5.40	9.44	1000
	10	17	5.73	11.47	20.06	1000
	11	9	3.04	6.07	10.62	1000
	12	11	3.71	7.42	12.98	1000
	13	5	1.69	3.37	5.90	1000
	14	5	1.69	3.37	5.90	1000
E	15	3	1.01	2.02	3.54	1000
	16	-	-	-	-	1000
	17	4	1.35	2.70	4.72	1000
	18	8	2.70	5.40	9.44	1000
	19	12	4.05	8.09	14.16	1000
	35	-	-	-	-	1000
	36	-	-	-	-	1000
	27	-	-	-	-	2500
	31		18.97	37.95	66.41	2500
	41	-	-	-	-	1000
D	20	7	2.36	4.72	8.26	1000
	21	5	1.69	3.37	5.90	1000
	22	3	1.01	2.02	3.54	1000
	23	5	1.69	3.37	5.90	1000
	24	-	-	-	-	1000
	25	3	1.01	2.02	3.54	1000
	26	14	4.72	9.44	16.52	1000
F	28	30	10.12	20.23	35.41	2500
	29	32	10.79	21.58	37.77	2500
	30	16	5.40	10.79	18.88	2500
	40	-	-	-	-	1000
	44	-	-	-	-	2500
	45	-	-	-	-	2500
G	32	25	8.43	16.86	29.51	2500
	33	25	8.43	16.86	29.51	2500
	34	-	-	-	-	2500
	42	-	-	-	-	1000

Continued....

Parcel No.	Junction No.	No. of Units	Average Daily Flow (gpm)	Maximum Day Demand (gpm)	Peak Hour Demand (gpm)	Maximum Day + Fireflow (gpm)
Offsite Demand	37	47	15.74	31.47	55.08	1000
	38	47	15.74	31.47	55.08	1000
	39	47	15.74	31.47	55.08	1000
	43	142	47.89	95.77	167.60	1000

Table 6 – Scour depth for the 6” Water Line Segment under Wash

Pipe ID	Pipe Size	Start Node	End Node	Scour Depth	Depth of Pipe below Proposed Channel Bottom
P-46	6”	J-35	J-36	5’	7’

6.0 REFERENCE

1. **Water Distribution System – Basis of Design Report for Reata Ranch, Case # 3902-12 by SKG Enterprises, Inc., City of Scottsdale, AZ, August 24th, 2012.**
City of Scottsdale approved on 09-19-2012.
2. **GTA Engineering, Inc., *Scottsdale National Water Supply System, Scottsdale. Arizona.* April 25, 2001. Project number GTA00145 (Approved by the City of Scottsdale on May 07, 2001).**
3. **City of Scottsdale, "*Chapter 6 Potable Water System Design, Design Standards and Policies Manual*", Dated August 2008.**
4. **Arizona Department of Environmental Quality, "*engineering bulletin 110.10 Guidelines for the Construction of Water, Minimum Requirements (or Design, Submission of Plans and Specifications of Sewage Works*". May, 1978.**
5. **2006 International Fire Code, International Code Council, dated 2006**

EXHIBIT 2





EXHIBIT 3



LEGEND

12" WATER LINE	12"W
8" WATER LINE	8"W
6" WATER LINE	6"W
NODE	
RESERVOIR	

DATE	REVISION	BY

SKG ENTERPRISES, INC.
CONSULTING CIVIL ENGINEERS
9280 E. RainTree Drive • Suite 140 • Scottsdale, Az. • 85260 • (480) 998-5600


DSN: JAR CKD: SKG	REATA RANCH WATER KEYMAP	JOB# 30-11 EXHIBIT 3
----------------------	-------------------------------------	-------------------------

Two months after before you dig
CALL FOR THE BLUE STAKES
602-263-1100
1-800-STAKE-IT
OUTSIDE MARICOPA COUNTY



EXHIBIT 4

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: AVG DAY



REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Scenario Summary			
ID	115		
Label	AVG DAY		
Notes			
Active Topology	Base Active Topology		
Physical	Base Physical		
Demand	Average Day Demand		
Initial Settings	Base Initial Settings		
Operational	Base Operational		
Age	Base Age		
Constituent	Base Constituent		
Trace	Base Trace		
Fire Flow	Base Fire Flow		
Energy Cost	Base Energy Cost		
Transient	Base Transient		
Pressure Dependent Demand	Base Pressure Dependent Demand		
Failure History	Base Failure History		
User Data Extensions	Base User Data Extensions		
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options		
Transient Solver Calculation Options	Base Calculation Options		
Hydraulic Summary			
Time Analysis Type	Steady State	Use simple controls during steady state?	True
Friction Method	Hazen-Williams	Is EPS Snapshot?	False
Accuracy	0.001	Start Time	00:00:00
Trials	40	Calculation Type	Hydraulics Only

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Title REATA RANCH - WATER MODEL
 Engineer
 Company
 Date 04-06-2014
 Notes

Scenario Summary

ID	115
Label	AVG DAY
Notes	
Active Topology	Base Active Topology
Physical	Base Physical
Demand	Average Day Demand
Initial Settings	Base Initial Settings
Operational	Base Operational
Age	Base Age
Constituent	Base Constituent
Trace	Base Trace
Fire Flow	Base Fire Flow
Energy Cost	Base Energy Cost
Transient	Base Transient
Pressure Dependent Demand	Base Pressure Dependent Demand
Failure History	Base Failure History
User Data Extensions	Base User Data Extensions
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options
Transient Solver Calculation Options	Base Calculation Options

Network Inventory

Pipes	53	PRV's	0
Junctions	44	PSV's	0
Hydrants	0	PBV's	0
Tanks	0	FCV's	0

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: AVG DAY

Network Inventory			
Reservoirs	1	TCV's	0
Pumps	0	GPV's	0
Pump Stations	0	Isolation Valves	0
Variable Speed Pump	0	Spot Elevations	0
Batteries			
Transient Network Inventory			
Turbines	0	Rupture Disks	0
Periodic Head-Flows	0	Discharges to Atmosphere	0
Air Valves	0	Orifices Between Pipes	0
Hydropneumatic Tanks	0	Valves With Linear Area	0
		Change	
Surge Valves	0	Surge Tanks	0
Check Valves	0		
Pressure Pipes Inventory			
6.0 (in)	1,140 ft	12.0 (in)	18,405 ft
8.0 (in)	13,796 ft	All Diameters	33,340 ft

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-2	2,568.27	2,686.91	51	118.64	6
J-3	2,524.09	2,686.83	70	162.74	6
J-4	2,537.19	2,686.83	65	149.64	7
J-5	2,512.73	2,686.82	75	174.09	2
J-6	2,520.42	2,686.82	72	166.40	4
J-7	2,506.47	2,686.82	78	180.35	0
J-8	2,506.36	2,686.82	78	180.46	2
J-9	2,503.28	2,686.81	79	183.53	3
J-10	2,497.23	2,686.81	82	189.58	6
J-11	2,501.59	2,686.81	80	185.22	3
J-12	2,590.86	2,686.81	42	95.95	4
J-13	2,491.74	2,686.80	84	195.06	2
J-14	2,487.20	2,686.80	86	199.60	2
J-15	2,486.56	2,686.80	87	200.24	1
J-16	2,482.41	2,686.80	88	204.39	0
J-17	2,480.84	2,686.80	89	205.96	1
J-18	2,482.82	2,686.80	88	203.98	3
J-19	2,472.71	2,686.79	93	214.08	4
J-20	2,493.38	2,686.80	84	193.42	2
J-21	2,506.54	2,686.81	78	180.27	2
J-22	2,507.93	2,686.81	77	178.88	1
J-23	2,510.78	2,686.81	76	176.03	2
J-24	2,492.32	2,686.80	84	194.48	0
J-25	2,489.07	2,686.80	86	197.73	1
J-26	2,467.25	2,686.80	95	219.55	5
J-27	2,480.42	2,686.80	89	206.38	0
J-28	2,485.63	2,686.79	87	201.16	10
J-29	2,504.36	2,686.80	79	182.44	11
J-30	2,513.02	2,686.80	75	173.78	5

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-31	2,477.85	2,686.79	90	208.94	19
J-32	2,474.60	2,686.79	92	212.19	8
J-33	2,469.66	2,686.79	94	217.13	8
J-34	2,464.99	2,686.79	96	221.80	0
J-35	2,473.14	2,686.79	92	213.65	0
J-36	2,458.52	2,686.79	99	228.27	0
J-37	2,572.61	2,686.91	49	114.30	16
J-38	2,514.21	2,686.81	75	172.60	16
J-39	2,455.97	2,686.79	100	230.82	16
J-40	2,520.01	2,686.82	72	166.81	0
J-41	2,490.35	2,686.80	85	196.45	0
J-42	2,476.80	2,686.79	91	209.99	0
J-43	2,476.20	2,686.79	91	210.59	48
J-44	2,513.05	2,686.80	75	173.75	0
J-45	2,516.89	2,686.82	74	169.93	0

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Current Time: 0.000 hours

Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-3	12.0	Open	R-1	J-2	415	117	0.33	2,686.93	2,686.91	0.000
P-4	12.0	Open	J-2	J-3	2,417	95	0.27	2,686.91	2,686.83	0.000
P-5	8.0	Open	J-3	J-4	999	7	0.05	2,686.83	2,686.83	0.000
P-6	12.0	Open	J-3	J-5	434	81	0.23	2,686.83	2,686.82	0.000
P-7	8.0	Open	J-5	J-6	392	4	0.02	2,686.82	2,686.82	0.000
P-8	12.0	Open	J-5	J-7	233	75	0.21	2,686.82	2,686.82	0.000
P-9	12.0	Open	J-7	J-8	6	103	0.29	2,686.82	2,686.82	0.000
P-12	12.0	Open	J-8	J-9	328	66	0.19	2,686.82	2,686.81	0.000
P-14	8.0	Open	J-9	J-11	786	13	0.08	2,686.81	2,686.81	0.000
P-16	8.0	Open	J-11	J-10	521	6	0.04	2,686.81	2,686.81	0.000
P-13	12.0	Open	J-10	J-9	517	51	0.14	2,686.81	2,686.81	0.000
P-17	12.0	Open	J-10	J-13	168	51	0.14	2,686.81	2,686.80	0.000
P-18	8.0	Open	J-13	J-14	547	2	0.01	2,686.80	2,686.80	0.000
P-15	8.0	Open	J-12	J-11	538	4	0.02	2,686.81	2,686.81	0.000
P-19	12.0	Open	J-13	J-15	545	48	0.13	2,686.80	2,686.80	0.000
P-20	8.0	Open	J-15	J-16	279	6	0.04	2,686.80	2,686.80	0.000
P-21	8.0	Open	J-16	J-20	829	7	0.04	2,686.80	2,686.80	0.000
P-28	8.0	Open	J-20	J-24	109	6	0.04	2,686.80	2,686.80	0.000
P-29	8.0	Open	J-24	J-25	102	1	0.01	2,686.80	2,686.80	0.000
P-25	8.0	Open	J-20	J-21	799	15	0.10	2,686.80	2,686.81	0.000
P-27	8.0	Open	J-21	J-23	301	18	0.11	2,686.81	2,686.81	0.000
P-30	8.0	Open	J-24	J-26	1,076	5	0.03	2,686.80	2,686.80	0.000
P-22	8.0	Open	J-16	J-17	211	13	0.09	2,686.80	2,686.80	0.000
P-23	8.0	Open	J-17	J-18	341	3	0.02	2,686.80	2,686.80	0.000
P-31	12.0	Open	J-15	J-27	624	40	0.11	2,686.80	2,686.80	0.000
P-32	8.0	Open	J-27	J-28	183	6	0.04	2,686.80	2,686.79	0.000
P-33	8.0	Open	J-28	J-29	919	2	0.01	2,686.79	2,686.80	0.000
P-35	8.0	Open	J-29	J-28	1,259	2	0.01	2,686.80	2,686.79	0.000

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: AVG DAY

Current Time: 0.000 hours


Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-36	12.0	Open	J-27	J-31	143	34	0.10	2,686.80	2,686.79	0.000
P-37	8.0	Open	J-31	J-41	1,034	14	0.09	2,686.79	2,686.80	0.000
P-42	12.0	Open	J-42	J-34	1,560	2	0.01	2,686.79	2,686.79	0.000
P-41	12.0	Open	J-34	J-33	269	13	0.04	2,686.79	2,686.79	0.000
P-40	8.0	Open	J-33	J-32	823	5	0.03	2,686.79	2,686.79	0.000
P-39	12.0	Open	J-32	J-33	748	16	0.05	2,686.79	2,686.79	0.000
P-38	12.0	Open	J-32	J-31	503	30	0.08	2,686.79	2,686.79	0.000
P-11	12.0	Open	J-8	J-23	1,355	35	0.10	2,686.82	2,686.81	0.000
P-26	8.0	Open	J-21	J-22	184	1	0.01	2,686.81	2,686.81	0.000
P-61	8.0	Open	J-17	J-35	904	9	0.06	2,686.80	2,686.79	0.000
P-62	8.0	Open	J-35	J-19	153	4	0.03	2,686.79	2,686.79	0.000
P-45	12.0	Open	J-34	J-36	228	10	0.03	2,686.79	2,686.79	0.000
P-46	6.0	Open	J-36	J-35	742	5	0.06	2,686.79	2,686.79	0.000
P-66	12.0	Open	R-1	J-40	2,633	108	0.31	2,686.93	2,686.82	0.000
P-67	12.0	Open	J-40	J-41	1,411	60	0.17	2,686.82	2,686.80	0.000
P-68	12.0	Open	J-41	J-42	1,245	46	0.13	2,686.80	2,686.79	0.000
P-69	12.0	Open	J-2	J-37	265	16	0.04	2,686.91	2,686.91	0.000
P-70	12.0	Open	J-23	J-38	205	16	0.04	2,686.81	2,686.81	0.000
P-71	12.0	Open	J-36	J-39	861	16	0.04	2,686.79	2,686.79	0.000
P-72	12.0	Open	J-42	J-43	187	48	0.14	2,686.79	2,686.79	0.000
P-73	8.0	Open	J-29	J-44	365	15	0.10	2,686.80	2,686.80	0.000
P-74	8.0	Open	J-44	J-30	141	5	0.03	2,686.80	2,686.80	0.000
P-77	12.0	Open	J-7	J-45	939	28	0.08	2,686.82	2,686.82	0.000
P-78	12.0	Open	J-45	J-40	166	48	0.14	2,686.82	2,686.82	0.000
P-80	6.0	Open	J-45	J-44	398	20	0.23	2,686.82	2,686.80	0.000

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: AVG DAY

Current Time: 0.000 hours

ID	Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
135	R-1	2,686.93	225	2,686.93

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY



REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Scenario Summary			
ID	116		
Label	MAX DAY		
Notes			
Active Topology	Base Active Topology		
Physical	Base Physical		
Demand	Max Day Demand		
Initial Settings	Base Initial Settings		
Operational	Base Operational		
Age	Base Age		
Constituent	Base Constituent		
Trace	Base Trace		
Fire Flow	Base Fire Flow		
Energy Cost	Base Energy Cost		
Transient	Base Transient		
Pressure Dependent Demand	Base Pressure Dependent Demand		
Failure History	Base Failure History		
User Data Extensions	Base User Data Extensions		
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options		
Transient Solver Calculation Options	Base Calculation Options		
Hydraulic Summary			
Time Analysis Type	Steady State	Use simple controls during steady state?	True
Friction Method	Hazen-Williams	Is EPS Snapshot?	False
Accuracy	0.001	Start Time	00:00:00
Trials	40	Calculation Type	Hydraulics Only

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Title REATA RANCH - WATER MODEL
 Engineer
 Company
 Date 04-06-2014
 Notes

Scenario Summary

ID	116
Label	MAX DAY
Notes	
Active Topology	Base Active Topology
Physical	Base Physical
Demand	Max Day Demand
Initial Settings	Base Initial Settings
Operational	Base Operational
Age	Base Age
Constituent	Base Constituent
Trace	Base Trace
Fire Flow	Base Fire Flow
Energy Cost	Base Energy Cost
Transient	Base Transient
Pressure Dependent Demand	Base Pressure Dependent Demand
Failure History	Base Failure History
User Data Extensions	Base User Data Extensions
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options
Transient Solver Calculation Options	Base Calculation Options

Network Inventory

Pipes	53	PRV's	0
Junctions	44	PSV's	0
Hydrants	0	PBV's	0
Tanks	0	FCV's	0

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY

Network Inventory			
Reservoirs	1	TCV's	0
Pumps	0	GPV's	0
Pump Stations	0	Isolation Valves	0
Variable Speed Pump	0	Spot Elevations	0
Batteries			
Transient Network Inventory			
Turbines	0	Rupture Disks	0
Periodic Head-Flows	0	Discharges to Atmosphere	0
Air Valves	0	Orifices Between Pipes	0
Hydropneumatic Tanks	0	Valves With Linear Area Change	0
Surge Valves	0	Surge Tanks	0
Check Valves	0		
Pressure Pipes Inventory			
6.0 (in)	1,140 ft	12.0 (in)	18,405 ft
8.0 (in)	13,796 ft	All Diameters	33,340 ft

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-2	2,568.27	2,686.86	51	118.59	12
J-3	2,524.09	2,686.58	70	162.49	12
J-4	2,537.19	2,686.57	65	149.38	15
J-5	2,512.73	2,686.54	75	173.81	5
J-6	2,520.42	2,686.54	72	166.12	7
J-7	2,506.47	2,686.52	78	180.05	0
J-8	2,506.36	2,686.52	78	180.16	3
J-9	2,503.28	2,686.50	79	183.22	5
J-10	2,497.23	2,686.48	82	189.25	11
J-11	2,501.59	2,686.49	80	184.90	6
J-12	2,590.86	2,686.48	41	95.62	7
J-13	2,491.74	2,686.48	84	194.74	3
J-14	2,487.20	2,686.48	86	199.28	3
J-15	2,486.56	2,686.46	86	199.90	2
J-16	2,482.41	2,686.46	88	204.05	0
J-17	2,480.84	2,686.45	89	205.61	3
J-18	2,482.82	2,686.45	88	203.63	5
J-19	2,472.71	2,686.44	92	213.73	8
J-20	2,493.38	2,686.46	84	193.08	5
J-21	2,506.54	2,686.48	78	179.94	3
J-22	2,507.93	2,686.48	77	178.55	2
J-23	2,510.78	2,686.50	76	175.72	3
J-24	2,492.32	2,686.46	84	194.14	0
J-25	2,489.07	2,686.46	85	197.39	2
J-26	2,467.25	2,686.46	95	219.21	9
J-27	2,480.42	2,686.44	89	206.02	0
J-28	2,485.63	2,686.44	87	200.81	20
J-29	2,504.36	2,686.44	79	182.08	22
J-30	2,513.02	2,686.45	75	173.43	11

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-31	2,477.85	2,686.44	90	208.59	38
J-32	2,474.60	2,686.43	92	211.83	17
J-33	2,469.66	2,686.43	94	216.77	17
J-34	2,464.99	2,686.43	96	221.44	0
J-35	2,473.14	2,686.44	92	213.30	0
J-36	2,458.52	2,686.43	99	227.91	0
J-37	2,572.61	2,686.86	49	114.25	31
J-38	2,514.21	2,686.49	75	172.28	31
J-39	2,455.97	2,686.43	100	230.46	31
J-40	2,520.01	2,686.54	72	166.53	0
J-41	2,490.35	2,686.47	85	196.12	0
J-42	2,476.80	2,686.43	91	209.63	0
J-43	2,476.20	2,686.42	91	210.22	96
J-44	2,513.05	2,686.45	75	173.40	0
J-45	2,516.89	2,686.53	73	169.64	0

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Current Time: 0.000 hours

Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-3	12.0	Open	R-1	J-2	415	233	0.66	2,686.93	2,686.86	0.000
P-4	12.0	Open	J-2	J-3	2,417	190	0.54	2,686.86	2,686.58	0.000
P-5	8.0	Open	J-3	J-4	999	15	0.09	2,686.58	2,686.57	0.000
P-6	12.0	Open	J-3	J-5	434	163	0.46	2,686.58	2,686.54	0.000
P-7	8.0	Open	J-5	J-6	392	7	0.05	2,686.54	2,686.54	0.000
P-8	12.0	Open	J-5	J-7	233	150	0.43	2,686.54	2,686.52	0.000
P-9	12.0	Open	J-7	J-8	6	206	0.58	2,686.52	2,686.52	0.000
P-12	12.0	Open	J-8	J-9	328	132	0.37	2,686.52	2,686.50	0.000
P-14	8.0	Open	J-9	J-11	786	26	0.16	2,686.50	2,686.49	0.000
P-16	8.0	Open	J-11	J-10	521	12	0.08	2,686.49	2,686.48	0.000
P-13	12.0	Open	J-10	J-9	517	101	0.29	2,686.48	2,686.50	0.000
P-17	12.0	Open	J-10	J-13	168	102	0.29	2,686.48	2,686.48	0.000
P-18	8.0	Open	J-13	J-14	547	3	0.02	2,686.48	2,686.48	0.000
P-15	8.0	Open	J-12	J-11	538	7	0.05	2,686.48	2,686.49	0.000
P-19	12.0	Open	J-13	J-15	545	95	0.27	2,686.48	2,686.46	0.000
P-20	8.0	Open	J-15	J-16	279	13	0.08	2,686.46	2,686.46	0.000
P-21	8.0	Open	J-16	J-20	829	14	0.09	2,686.46	2,686.46	0.000
P-28	8.0	Open	J-20	J-24	109	11	0.07	2,686.46	2,686.46	0.000
P-29	8.0	Open	J-24	J-25	102	2	0.01	2,686.46	2,686.46	0.000
P-25	8.0	Open	J-20	J-21	799	30	0.19	2,686.46	2,686.48	0.000
P-27	8.0	Open	J-21	J-23	301	35	0.23	2,686.48	2,686.50	0.000
P-30	8.0	Open	J-24	J-26	1,076	9	0.06	2,686.46	2,686.46	0.000
P-22	8.0	Open	J-16	J-17	211	27	0.17	2,686.46	2,686.45	0.000
P-23	8.0	Open	J-17	J-18	341	5	0.03	2,686.45	2,686.45	0.000
P-31	12.0	Open	J-15	J-27	624	80	0.23	2,686.46	2,686.44	0.000
P-32	8.0	Open	J-27	J-28	183	12	0.08	2,686.44	2,686.44	0.000
P-33	8.0	Open	J-28	J-29	919	5	0.03	2,686.44	2,686.44	0.000
P-35	8.0	Open	J-29	J-28	1,259	4	0.02	2,686.44	2,686.44	0.000

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY

Current Time: 0.000 hours


Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-36	12.0	Open	J-27	J-31	143	68	0.19	2,686.44	2,686.44	0.000
P-37	8.0	Open	J-31	J-41	1,034	29	0.18	2,686.44	2,686.47	0.000
P-42	12.0	Open	J-42	J-34	1,560	5	0.01	2,686.43	2,686.43	0.000
P-41	12.0	Open	J-34	J-33	269	25	0.07	2,686.43	2,686.43	0.000
P-40	8.0	Open	J-33	J-32	823	10	0.07	2,686.43	2,686.43	0.000
P-39	12.0	Open	J-32	J-33	748	32	0.09	2,686.43	2,686.43	0.000
P-38	12.0	Open	J-32	J-31	503	59	0.17	2,686.43	2,686.44	0.000
P-11	12.0	Open	J-8	J-23	1,355	70	0.20	2,686.52	2,686.50	0.000
P-26	8.0	Open	J-21	J-22	184	2	0.01	2,686.48	2,686.48	0.000
P-61	8.0	Open	J-17	J-35	904	19	0.12	2,686.45	2,686.44	0.000
P-62	8.0	Open	J-35	J-19	153	8	0.05	2,686.44	2,686.44	0.000
P-45	12.0	Open	J-34	J-36	228	21	0.06	2,686.43	2,686.43	0.000
P-46	6.0	Open	J-36	J-35	742	10	0.12	2,686.43	2,686.44	0.000
P-66	12.0	Open	R-1	J-40	2,633	216	0.61	2,686.93	2,686.54	0.000
P-67	12.0	Open	J-40	J-41	1,411	120	0.34	2,686.54	2,686.47	0.000
P-68	12.0	Open	J-41	J-42	1,245	91	0.26	2,686.47	2,686.43	0.000
P-69	12.0	Open	J-2	J-37	265	31	0.09	2,686.86	2,686.86	0.000
P-70	12.0	Open	J-23	J-38	205	31	0.09	2,686.50	2,686.49	0.000
P-71	12.0	Open	J-36	J-39	861	31	0.09	2,686.43	2,686.43	0.000
P-72	12.0	Open	J-42	J-43	187	96	0.27	2,686.43	2,686.42	0.000
P-73	8.0	Open	J-29	J-44	365	30	0.19	2,686.44	2,686.45	0.000
P-74	8.0	Open	J-44	J-30	141	11	0.07	2,686.45	2,686.45	0.000
P-77	12.0	Open	J-7	J-45	939	55	0.16	2,686.52	2,686.53	0.000
P-78	12.0	Open	J-45	J-40	166	96	0.27	2,686.53	2,686.54	0.000
P-80	6.0	Open	J-45	J-44	398	41	0.46	2,686.53	2,686.45	0.000

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY

Current Time: 0.000 hours

ID	Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
135	R-1	2,686.93	449	2,686.93

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: PEAK HOUR



REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Scenario Summary			
ID	117		
Label	PEAK HOUR		
Notes			
Active Topology	Base Active Topology		
Physical	Base Physical		
Demand	Peak Hour Demand		
Initial Settings	Base Initial Settings		
Operational	Base Operational		
Age	Base Age		
Constituent	Base Constituent		
Trace	Base Trace		
Fire Flow	Base Fire Flow		
Energy Cost	Base Energy Cost		
Transient	Base Transient		
Pressure Dependent Demand	Base Pressure Dependent Demand		
Failure History	Base Failure History		
User Data Extensions	Base User Data Extensions		
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options		
Transient Solver Calculation Options	Base Calculation Options		
Hydraulic Summary			
Time Analysis Type	Steady State	Use simple controls during steady state?	True
Friction Method	Hazen-Williams	Is EPS Snapshot?	False
Accuracy	0.001	Start Time	00:00:00
Trials	40	Calculation Type	Hydraulics Only

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Title REATA RANCH - WATER MODEL
 Engineer
 Company
 Date 04-06-2014
 Notes

Scenario Summary

ID	117
Label	PEAK HOUR
Notes	
Active Topology	Base Active Topology
Physical	Base Physical
Demand	Peak Hour Demand
Initial Settings	Base Initial Settings
Operational	Base Operational
Age	Base Age
Constituent	Base Constituent
Trace	Base Trace
Fire Flow	Base Fire Flow
Energy Cost	Base Energy Cost
Transient	Base Transient
Pressure Dependent Demand	Base Pressure Dependent Demand
Failure History	Base Failure History
User Data Extensions	Base User Data Extensions
Steady State/EPS Solver Calculation Options	Hydraulic SSA Calculation Options
Transient Solver Calculation Options	Base Calculation Options

Network Inventory

Pipes	53	PRV's	0
Junctions	44	PSV's	0
Hydrants	0	PBV's	0
Tanks	0	FCV's	0
Reservoirs	1	TCV's	0
Pumps	0	GPV's	0
Pump Stations	0	Isolation Valves	0
Variable Speed Pump	0	Spot Elevations	0
Batteries			

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: PEAK HOUR

Network Inventory			
Transient Network Inventory			
Turbines	0	Rupture Disks	0
Periodic Head-Flows	0	Discharges to Atmosphere	0
Air Valves	0	Orifices Between Pipes	0
Hydropneumatic Tanks	0	Valves With Linear Area Change	0
Surge Valves	0	Surge Tanks	0
Check Valves	0		
Pressure Pipes Inventory			
6.0 (in)	1,140 ft	12.0 (in)	18,405 ft
8.0 (in)	13,796 ft	All Diameters	33,340 ft

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-2	2,568.27	2,686.73	51	118.46	21
J-3	2,524.09	2,685.94	70	161.85	21
J-4	2,537.19	2,685.92	64	148.73	26
J-5	2,512.73	2,685.83	75	173.10	8
J-6	2,520.42	2,685.83	72	165.41	13
J-7	2,506.47	2,685.78	78	179.31	0
J-8	2,506.36	2,685.78	78	179.42	6
J-9	2,503.28	2,685.72	79	182.44	9
J-10	2,497.23	2,685.67	82	188.44	20
J-11	2,501.59	2,685.68	80	184.09	11
J-12	2,590.86	2,685.67	41	94.81	13
J-13	2,491.74	2,685.65	84	193.91	6
J-14	2,487.20	2,685.65	86	198.45	6
J-15	2,486.56	2,685.60	86	199.04	4
J-16	2,482.41	2,685.60	88	203.19	0
J-17	2,480.84	2,685.58	89	204.74	5
J-18	2,482.82	2,685.58	88	202.76	9
J-19	2,472.71	2,685.55	92	212.84	14
J-20	2,493.38	2,685.61	83	192.23	8
J-21	2,506.54	2,685.67	78	179.13	6
J-22	2,507.93	2,685.67	77	177.74	4
J-23	2,510.78	2,685.71	76	174.93	6
J-24	2,492.32	2,685.61	84	193.29	0
J-25	2,489.07	2,685.61	85	196.54	4
J-26	2,467.25	2,685.60	94	218.35	17
J-27	2,480.42	2,685.56	89	205.14	0
J-28	2,485.63	2,685.56	86	199.93	35
J-29	2,504.36	2,685.56	78	181.20	38
J-30	2,513.02	2,685.59	75	172.57	19

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Current Time: 0.000 hours

Label	Elevation (ft)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Demand (gpm)
J-31	2,477.85	2,685.55	90	207.70	66
J-32	2,474.60	2,685.53	91	210.93	30
J-33	2,469.66	2,685.52	93	215.86	30
J-34	2,464.99	2,685.52	95	220.53	0
J-35	2,473.14	2,685.55	92	212.41	0
J-36	2,458.52	2,685.52	98	227.00	0
J-37	2,572.61	2,686.73	49	114.12	55
J-38	2,514.21	2,685.70	74	171.49	55
J-39	2,455.97	2,685.51	99	229.54	55
J-40	2,520.01	2,685.83	72	165.82	0
J-41	2,490.35	2,685.63	84	195.28	0
J-42	2,476.80	2,685.52	90	208.72	0
J-43	2,476.20	2,685.50	91	209.30	168
J-44	2,513.05	2,685.59	75	172.54	0
J-45	2,516.89	2,685.81	73	168.92	0

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Current Time: 0.000 hours

Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-3	12.0	Open	R-1	J-2	415	408	1.16	2,686.93	2,686.73	0.000
P-4	12.0	Open	J-2	J-3	2,417	332	0.94	2,686.73	2,685.94	0.000
P-5	8.0	Open	J-3	J-4	999	26	0.17	2,685.94	2,685.92	0.000
P-6	12.0	Open	J-3	J-5	434	284	0.81	2,685.94	2,685.83	0.000
P-7	8.0	Open	J-5	J-6	392	13	0.08	2,685.83	2,685.83	0.000
P-8	12.0	Open	J-5	J-7	233	263	0.75	2,685.83	2,685.78	0.000
P-9	12.0	Open	J-7	J-8	6	360	1.02	2,685.78	2,685.78	0.000
P-12	12.0	Open	J-8	J-9	328	231	0.66	2,685.78	2,685.72	0.000
P-14	8.0	Open	J-9	J-11	786	45	0.29	2,685.72	2,685.68	0.000
P-16	8.0	Open	J-11	J-10	521	21	0.13	2,685.68	2,685.67	0.000
P-13	12.0	Open	J-10	J-9	517	177	0.50	2,685.67	2,685.72	0.000
P-17	12.0	Open	J-10	J-13	168	178	0.51	2,685.67	2,685.65	0.000
P-18	8.0	Open	J-13	J-14	547	6	0.04	2,685.65	2,685.65	0.000
P-15	8.0	Open	J-12	J-11	538	13	0.08	2,685.67	2,685.68	0.000
P-19	12.0	Open	J-13	J-15	545	166	0.47	2,685.65	2,685.60	0.000
P-20	8.0	Open	J-15	J-16	279	23	0.14	2,685.60	2,685.60	0.000
P-21	8.0	Open	J-16	J-20	829	24	0.15	2,685.60	2,685.61	0.000
P-28	8.0	Open	J-20	J-24	109	20	0.13	2,685.61	2,685.61	0.000
P-29	8.0	Open	J-24	J-25	102	4	0.02	2,685.61	2,685.61	0.000
P-25	8.0	Open	J-20	J-21	799	52	0.33	2,685.61	2,685.67	0.000
P-27	8.0	Open	J-21	J-23	301	62	0.40	2,685.67	2,685.71	0.000
P-30	8.0	Open	J-24	J-26	1,076	17	0.11	2,685.61	2,685.60	0.000
P-22	8.0	Open	J-16	J-17	211	47	0.30	2,685.60	2,685.58	0.000
P-23	8.0	Open	J-17	J-18	341	9	0.06	2,685.58	2,685.58	0.000
P-31	12.0	Open	J-15	J-27	624	140	0.40	2,685.60	2,685.56	0.000
P-32	8.0	Open	J-27	J-28	183	21	0.13	2,685.56	2,685.56	0.000
P-33	8.0	Open	J-28	J-29	919	8	0.05	2,685.56	2,685.56	0.000
P-35	8.0	Open	J-29	J-28	1,259	7	0.04	2,685.56	2,685.56	0.000

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: PEAK HOUR

Current Time: 0.000 hours


Label	Diameter (in)	Status (Initial)	Start Node	Stop Node	Length (Scaled) (ft)	Flow (Absolute) (gpm)	Velocity (ft/s)	Hydraulic Grade (Start) (ft)	Hydraulic Grade (Stop) (ft)	Headloss Gradient (ft/ft)
P-36	12.0	Open	J-27	J-31	143	120	0.34	2,685.56	2,685.55	0.000
P-37	8.0	Open	J-31	J-41	1,034	50	0.32	2,685.55	2,685.63	0.000
P-42	12.0	Open	J-42	J-34	1,560	8	0.02	2,685.52	2,685.52	0.000
P-41	12.0	Open	J-34	J-33	269	45	0.13	2,685.52	2,685.52	0.000
P-40	8.0	Open	J-33	J-32	823	18	0.12	2,685.52	2,685.53	0.000
P-39	12.0	Open	J-32	J-33	748	56	0.16	2,685.53	2,685.52	0.000
P-38	12.0	Open	J-32	J-31	503	104	0.29	2,685.53	2,685.55	0.000
P-11	12.0	Open	J-8	J-23	1,355	123	0.35	2,685.78	2,685.71	0.000
P-26	8.0	Open	J-21	J-22	184	4	0.02	2,685.67	2,685.67	0.000
P-61	8.0	Open	J-17	J-35	904	33	0.21	2,685.58	2,685.55	0.000
P-62	8.0	Open	J-35	J-19	153	14	0.09	2,685.55	2,685.55	0.000
P-45	12.0	Open	J-34	J-36	228	37	0.10	2,685.52	2,685.52	0.000
P-46	6.0	Open	J-36	J-35	742	18	0.21	2,685.52	2,685.55	0.000
P-66	12.0	Open	R-1	J-40	2,633	378	1.07	2,686.93	2,685.83	0.000
P-67	12.0	Open	J-40	J-41	1,411	210	0.60	2,685.83	2,685.63	0.000
P-68	12.0	Open	J-41	J-42	1,245	160	0.45	2,685.63	2,685.52	0.000
P-69	12.0	Open	J-2	J-37	265	55	0.16	2,686.73	2,686.73	0.000
P-70	12.0	Open	J-23	J-38	205	55	0.16	2,685.71	2,685.70	0.000
P-71	12.0	Open	J-36	J-39	861	55	0.16	2,685.52	2,685.51	0.000
P-72	12.0	Open	J-42	J-43	187	168	0.48	2,685.52	2,685.50	0.000
P-73	8.0	Open	J-29	J-44	365	53	0.34	2,685.56	2,685.59	0.000
P-74	8.0	Open	J-44	J-30	141	19	0.12	2,685.59	2,685.59	0.000
P-77	12.0	Open	J-7	J-45	939	97	0.27	2,685.78	2,685.81	0.000
P-78	12.0	Open	J-45	J-40	166	168	0.48	2,685.81	2,685.83	0.000
P-80	6.0	Open	J-45	J-44	398	72	0.81	2,685.81	2,685.59	0.001

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: PEAK HOUR

Current Time: 0.000 hours

ID	Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
135	R-1	2,686.93	786	2,686.93

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY + FIRE



REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY + FIRE

Scenario Summary			
ID	118		
Label	MAX DAY + FIRE		
Notes			
Active Topology	Base Active Topology		
Physical	Base Physical		
Demand	Max Day + Fire		
Initial Settings	Base Initial Settings		
Operational	Base Operational		
Age	Base Age		
Constituent	Base Constituent		
Trace	Base Trace		
Fire Flow	Automated Fire Flow		
Energy Cost	Base Energy Cost		
Transient	Base Transient		
Pressure Dependent Demand	Base Pressure Dependent Demand		
Failure History	Base Failure History		
User Data Extensions	Base User Data Extensions		
Steady State/EPS Solver Calculation Options	Automated Fire Calculation Options		
Transient Solver Calculation Options	Base Calculation Options		
Hydraulic Summary			
Time Analysis Type	Steady State	Use simple controls during steady state?	True
Friction Method	Hazen-Williams	Is EPS Snapshot?	False
Accuracy	0.001	Start Time	00:00:00
Trials	40	Calculation Type	Fire Flow

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY + FIRE

Title REATA RANCH - WATER MODEL
 Engineer
 Company
 Date 04-06-2014
 Notes

Scenario Summary

ID	118
Label	MAX DAY + FIRE
Notes	
Active Topology	Base Active Topology
Physical	Base Physical
Demand	Max Day + Fire
Initial Settings	Base Initial Settings
Operational	Base Operational
Age	Base Age
Constituent	Base Constituent
Trace	Base Trace
Fire Flow	Automated Fire Flow
Energy Cost	Base Energy Cost
Transient	Base Transient
Pressure Dependent Demand	Base Pressure Dependent Demand
Failure History	Base Failure History
User Data Extensions	Base User Data Extensions
Steady State/EPS Solver Calculation Options	Automated Fire Calculation Options
Transient Solver Calculation Options	Base Calculation Options

Network Inventory

Pipes	53	PRV's	0
Junctions	44	PSV's	0
Hydrants	0	PBV's	0
Tanks	0	FCV's	0

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY + FIRE

Network Inventory			
Reservoirs	1	TCV's	0
Pumps	0	GPV's	0
Pump Stations	0	Isolation Valves	0
Variable Speed Pump	0	Spot Elevations	0
Batteries			
Transient Network Inventory			
Turbines	0	Rupture Disks	0
Periodic Head-Flows	0	Discharges to Atmosphere	0
Air Valves	0	Orifices Between Pipes	0
Hydropneumatic Tanks	0	Valves With Linear Area Change	0
Surge Valves	0	Surge Tanks	0
Check Valves	0		
Pressure Pipes Inventory			
6.0 (in)	1,140 ft	12.0 (in)	18,405 ft
8.0 (in)	13,796 ft	All Diameters	33,340 ft

REATA RANCH - ULTIMATE BUILDOUT
Active Scenario: MAX DAY + FIRE

Current Time: 0.000 hours

Label	Elevation (ft)	Pressure (Calculated Residual @ Total Flow Needed) (psi)	Flow (Total Needed) (gpm)
J-2	2,568.27	51	1,012
J-3	2,524.09	69	1,012
J-4	2,537.19	55	1,015
J-5	2,512.73	74	1,005
J-6	2,520.42	67	1,007
J-7	2,506.47	76	1,000
J-8	2,506.36	76	1,003
J-9	2,503.28	77	1,005
J-10	2,497.23	80	1,011
J-11	2,501.59	77	1,006
J-12	2,590.86	34	1,007
J-13	2,491.74	82	1,003
J-14	2,487.20	80	1,003
J-15	2,486.56	84	1,002
J-16	2,482.41	85	1,000
J-17	2,480.84	85	1,003
J-18	2,482.82	82	1,005
J-19	2,472.71	85	1,008
J-20	2,493.38	79	1,005
J-21	2,506.54	74	1,003
J-22	2,507.93	72	1,002
J-23	2,510.78	73	1,003
J-24	2,492.32	79	1,000
J-25	2,489.07	79	1,002
J-26	2,467.25	81	1,009
J-27	2,480.42	80	2,500
J-28	2,485.63	73	2,520

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY + FIRE

Current Time: 0.000 hours

Label	Elevation (ft)	Pressure (Calculated Residual @ Total Flow Needed) (psi)	Flow (Total Needed) (gpm)
J-29	2,504.36	60	2,522
J-30	2,513.02	48	2,511
J-31	2,477.85	81	2,538
J-32	2,474.60	81	2,517
J-33	2,469.66	83	2,517
J-34	2,464.99	85	2,500
J-35	2,473.14	86	1,000
J-36	2,458.52	96	1,000
J-37	2,572.61	49	1,031
J-38	2,514.21	72	1,031
J-39	2,455.97	96	1,031
J-40	2,520.01	70	1,000
J-41	2,490.35	83	1,000
J-42	2,476.80	88	1,000
J-43	2,476.20	88	1,096
J-44	2,513.05	71	1,000
J-45	2,516.89	72	1,000

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY + FIRE

Current Time: 0.000 hours

Label	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (gpm)	Fire Flow (Available) (gpm)	Flow (Total Needed) (gpm)	Flow (Total Available) (gpm)	Pressure (Residual Lower Limit) (psi)	Pressure (Calculated Residual) (psi)	Junction w/ Minimum Pressure (Zone)	Is Fire Flow Run Balanced?
J-2	True	1,000	1,005	1,012	1,017	30	51	J-12	True
J-3	True	1,000	1,005	1,012	1,017	30	69	J-12	True
J-4	True	1,000	1,005	1,015	1,020	30	55	J-12	True
J-5	True	1,000	1,005	1,005	1,010	30	74	J-12	True
J-6	True	1,000	1,005	1,007	1,012	30	67	J-12	True
J-7	True	1,000	1,005	1,000	1,005	30	76	J-12	True
J-8	True	1,000	1,005	1,003	1,008	30	76	J-12	True
J-9	True	1,000	1,005	1,005	1,010	30	77	J-12	True
J-10	True	1,000	1,005	1,011	1,016	30	80	J-12	True
J-11	True	1,000	1,005	1,006	1,011	30	77	J-12	True
J-12	True	1,000	1,005	1,007	1,012	30	34	J-37	True
J-13	True	1,000	1,005	1,003	1,008	30	82	J-12	True
J-14	True	1,000	1,005	1,003	1,008	30	80	J-12	True
J-15	True	1,000	1,005	1,002	1,007	30	84	J-12	True
J-16	True	1,000	1,005	1,000	1,005	30	85	J-12	True
J-17	True	1,000	1,005	1,003	1,008	30	85	J-12	True
J-18	True	1,000	1,005	1,005	1,010	30	81	J-12	True
J-19	True	1,000	1,005	1,008	1,013	30	85	J-12	True
J-20	True	1,000	1,005	1,005	1,010	30	79	J-12	True
J-21	True	1,000	1,005	1,003	1,008	30	74	J-12	True
J-22	True	1,000	1,005	1,002	1,007	30	72	J-12	True
J-23	True	1,000	1,005	1,003	1,008	30	73	J-12	True
J-24	True	1,000	1,005	1,000	1,005	30	79	J-12	True
J-25	True	1,000	1,005	1,002	1,007	30	79	J-12	True
J-26	True	1,000	1,005	1,009	1,014	30	81	J-12	True
J-27	True	2,500	2,505	2,500	2,505	30	80	J-12	True
J-28	True	2,500	2,505	2,520	2,525	30	73	J-12	True

REATA RANCH - ULTIMATE BUILDOUT

Active Scenario: MAX DAY + FIRE

Current Time: 0.000 hours

Label	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (gpm)	Fire Flow (Available) (gpm)	Flow (Total Needed) (gpm)	Flow (Total Available) (gpm)	Pressure (Residual Lower Limit) (psi)	Pressure (Calculated Residual) (psi)	Junction w/ Minimum Pressure (Zone)	Is Fire Flow Run Balanced?
J-29	True	2,500	2,505	2,522	2,527	30	60	J-12	True
J-30	True	2,500	2,505	2,511	2,516	30	48	J-12	True
J-31	True	2,500	2,505	2,538	2,543	30	81	J-12	True
J-32	True	2,500	2,505	2,517	2,522	30	81	J-12	True
J-33	True	2,500	2,505	2,517	2,522	30	83	J-12	True
J-34	True	2,500	2,505	2,500	2,505	30	85	J-12	True
J-35	True	1,000	1,005	1,000	1,005	30	86	J-12	True
J-36	True	1,000	1,005	1,000	1,005	30	96	J-12	True
J-40	True	1,000	1,005	1,000	1,005	30	70	J-12	True
J-41	True	1,000	1,005	1,000	1,005	30	83	J-12	True
J-42	True	1,000	1,005	1,000	1,005	30	88	J-12	True
J-37	True	1,000	1,005	1,031	1,036	30	49	J-12	True
J-38	True	1,000	1,005	1,031	1,036	30	72	J-12	True
J-39	True	1,000	1,005	1,031	1,036	30	96	J-12	True
J-43	True	1,000	1,005	1,096	1,101	30	88	J-12	True
J-44	True	1,000	1,005	1,000	1,005	30	71	J-12	True
J-45	True	1,000	1,005	1,000	1,005	30	72	J-12	True

APPENDIX A

Reata Ranch - Water Demand Computation

Usage	No. of Units	Area (Sq. ft)	Demand (gallons/day/unit)	Average Daily Demand (gpd)	Average Daily Flow (gpm)	Maximum Day Demand (gpm)	Peak Hour Demand (gpm)
1	2	3	4	5 = 2 x 4 or 5 = 3 x 4	6 = 5 / 1440	7 = 6 X 2.0	8 = 6 X 3.5
Residential	200		485.6	97,120	67.44	134.89	236.06
Resort Town Homes	128		485.6	62,157	43.16	86.33	151.08
Equestrian & Club House		666,387	1786	27,322	18.97	37.95	66.41
Offsite - South of Property (3Nodes)	140		485.6	67,984	47.21	94.42	165.24
Offsite - East of 136 th Street (1Node)	142		485.6	68,955	47.89	95.77	167.60
Total	328	666,387		186,599	130	259	454

Design Criteria:

1. Average Daily Demand for Residential = 248.2 gpd per unit
2. Average Daily Demand for Resort town homes = 446.3 gpd per unit
2. Average Daily Demand for Developed Open Space - Parks = 1786 gpd per acre
2. Max Day Demand = 2 X Avg Daily Flow
3. Peak Hour Demand = 3.5 X Avg Daily Flow
4. Fire Flow = 1000 gpm for single family residential
5. Fire Flow = 2500 gpm for Resort
6. Offsite Water Demand was computed assuming that the surrounding Parcels are zoned as R1-130. Since Reata is 220 acres, the adjoining Parcels of 420 acres is expected to develop 140 potential residential lots. Parcel to the east (Wildcat Ridge/Scottsdale National/ Scottsdale Appendage) is expected to develop 142 lots.

APPENDIX B

Long Copy

8/31/12
PS

**WATER DISTRIBUTION SYSTEM
BASIS OF DESIGN REPORT
FOR
REATA RANCH**

Case # 3902-12


Prepared For:

Land Development Services
7525 East Camelback Road
Suite 104
Scottsdale, AZ 85251

Prepared By:



SKG ENTERPRISES, INC.
9260 E. Raintree Drive
Suite 140
Scottsdale, AZ 85260
Ph: (480) 998-5600
Fax: (480) 998-5603
www.skgaz.com
info@skgaz.com



Job # 30-11.2
Prepared: July 2012
Revised: August 2012

Accepted for
City of Scottsdale
Water Resources Administration
9379 E. San Salvador
Scottsdale, AZ 85258

Dina Mann
9.19.2012

Water Resource

3902-12

**WATER DISTRIBUTION SYSTEM
BASIS OF DESIGN REPORT
FOR
REATA RANCH**

Prepared For:

Land Development Services
7525 East Camelback Road
Suite 104
Scottsdale, AZ 85251

Prepared By:



SKG ENTERPRISES, INC.
9260 E. Raintree Drive, Suite 140
Scottsdale, AZ 85260
Ph: (480) 998-5600
Fax: (480) 998-5603
www.skgaz.com




Job # 30-11.2
Prepared: July 2012

TABLE OF CONTENTS

1.0	INTRODUCTION.....	1
2.0	EXISTING WATER DISTRIBUTION SYSTEM	1
3.0	PRESSURE ZONES	2
4.0	PROPOSED WATER DISTRIBUTION SYSTEM	3
5.0	HYDRAULIC ANALYSIS.....	5
6.0	RECOMMENDATIONS.....	7
7.0	CONCLUSIONS	7
8.0	REFERENCES.....	8

EXHIBITS

EXHIBIT	DESCRIPTION
1	Site Location Map
2	Conceptual Site Plan
3	Exerts from GTA Engineering Water System Model
4	Hydraulic model computer run



Expires 3-31-13

1.0 INTRODUCTION

Reata Ranch is a proposed master planned community located in Section 36 of Township 5 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. This site is located within the City of Scottsdale's Upper Desert Landform of the Environmentally Sensitive Lands Ordinance (E.S.L.O.) area. Reata Ranch consists of three separate parcels that are combined into one development totaling 220-acres in size. A site location map is included as Exhibit 1 in this report.

The land generally slopes from northwest to southeast at an average rate of 5 percent and is traversed by several well-defined washes. The site is currently platted as single family residential development with various lot sizes and will undergo a re-platting process as a planned community consisting of various residential parcels, ranch resort, and open space. The name and address of the developer's agent is:

Land Development Services, L.L.C.
7525 East Camelback Road, Suite 104
Scottsdale, AZ 85251
480-946-5020

2.0 EXISTING WATER DISTRIBUTION SYSTEM

At present, no domestic water system exists within the immediate project area. According to the City of Scottsdale water quarter section maps 50-57 through 50-60, an existing 20" Ductile Iron Pipe (DIP) City water line terminates at 122nd Street along Rio Verde Drive (Dynamite Boulevard), as shown on quarter section map number 50-57. However, there had been several previous projects that provided water line extension designs connecting into the existing 20"-line and extending it to 136th Street. These plans have previously been City approved but never constructed and have now expired.

One of the referenced expired water extension design plans were prepared by SKV Engineering, which proposed to construct a 16" water line from 122nd Street to 128th Street and continues with a 12" water line from 128th Street to 132nd Street along the Rio Verde Drive (Ref. 1). The other project was prepared by Evolution Engineering, which proposed to construct a 12" water line from 132nd to 136th Street along the Rio Verde Drive (Ref. 2).

This project will need to utilize the aforementioned City approved water extension design plans (Ref. 1 and 2) as its main water source. As the referenced water extension design plans have expired, this project should consider resurrecting the expired plans for re-approval and constructing the proposed water line from 122nd Street to 136th Street, as specified on the referenced expired design plans. Per the City of Scottsdale Design Standards and Procedures Manual (DS&PM), Section 6-1.103 the Developer intends to file for "Payback Agreements" for the proposed extension. As payback agreements are based upon construction cost, a completed package containing all required materials will be submitted with the final improvement plans with supplemental documentation provided by contractors bid documents and receipts.

3.0 PRESSURE ZONES

The ground elevation range of Reata Ranch is 2,455 to 2,565 in elevation, which is classified as pressure zone 11E (City of Scottsdale). City of Scottsdale Design Standard and Policies Manual for Potable Water System Design (Ref. 2) requires the maximum allowable pressure not exceed 120 pounds per square inch (psi) and the minimum residual pressure of 50 psi be maintained under all non-fire flow conditions at the highest finished floor elevation.

Table 1 Pressure Zone Service Elevations

Pressure Zone	Minimum Elevation	Maximum Elevation
11E	2,440	2,570

4.0 PROPOSED WATER DISTRIBUTION SYSTEM

The proposed water infrastructure for Reata Ranch shall be composed of eight (8) and twelve (12) inch diameter Ductile Iron (poly-wrapped) pipes. The 8-inch diameter pipes will be along the interior roadways within the development and the 12-inch diameter pipes will be along 128th, 132nd, and 136th Streets. A conceptual site plan depicting major infrastructure layout is presented on Exhibit 2 of this report. The on-site water distribution system will follow the roadway system shown in Exhibit 2.

There will be four points of connections into the 12" water main along Rio Verde Drive to serve the Reata Ranch development and they are:

1. At 128th Street
2. At Rio Verde Drive at the main development entrance, midway between 128th and 132nd Streets
3. At 132nd Street
4. At 136th Street

According to the offsite water line plans along Rio Verde (Ref. 1), there will be a Pressure Reducing Valve (PRV) directly to the west of 128th Street. This PRV is located at the water pressure zone 12E / 11E line. The offsite water distribution system, along Rio Verde Drive, shall follow the City approved plans prepared by SVK Engineering (Ref. 1) and Evolution Engineering (Ref. 2). The proposed 12" water line along 128th, 132nd, and 136th Street together with the interior onsite water distribution system shall be designed in accordance with Chapter 4 of the City of Scottsdale Water Distribution System design guidelines (Ref. 3), the Arizona Administrative Code R18-4-502, and Engineering Bulletin no. 10 (Ref. 4).

- **Demand**

The design parameters for the proposed water distribution system for Reata Ranch is presented in the table below

Table 3 Design Criteria

Criteria	Parameter
Average Daily Water Demand (gallon/day/unit)	485.6
Maximum Unit Count	330
Peaking Factor / Maximum day peaking factor	3.5 times average day demand
Peaking Factor / Maximum hour peaking factor	1.7 times peak day
⁽¹⁾ Fire Demand (gallon per minute)	1,000 gpm Residential, 2,500 gpm Commercial
Minimum pressure in the system during fire flow	40 psi
Water velocity range (foot per second) during fire flow	0 to 8

⁽¹⁾Commercial Fire Flow values assumed from 2006 International Fire Code, Appendix B "Fire-Flow Requirements for Buildings", Section B105 and Table B105.1 (Ref. 6).

The table below outlines the projected water demand for the proposed Reata Ranch development. It describes the water demand in terms of average daily demand, Peak demand, and peak demand with fire flow.

Table 3 Water demand calculation by development category

Type	Acres	DU/Ac	Units	Demand per unit	Ave. daily demand (GPD)	Peak daily demand (GPD)	Max Hourly demand (GPM)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Resort			75	485.6	36,420	127,470	150
Parcel A	5.7	3.5	20	485.6	9,712	33,992	40
Parcel B	5.9	3.5	21	485.6	10,198	35,692	42
Parcel C	8.3	3.5	29	485.6	14,082	49,288	58
Parcel D	9.6	3.5	34	485.6	16,510	57,786	68
Parcel E	5.9	3.5	21	485.6	10,198	35,692	42
Parcel F	8.4	3.5	30	485.6	14,568	50,988	60
Parcel G	10.1	3.5	35	485.6	16,996	59,486	70
Parcel H	8.1	3.5	26	485.6	12,626	44,190	52
Parcel I	10.4	3.5	36	485.6	17,482	61,186	72
TOTAL	-	-	330	-	158,791	555,769	656

Notes:

(6) = (4) x (5)

(7) = (6) x 3.5

(8) = {(7) x 1.7}/1,440 minutes/day

5.0 HYDRAULIC ANALYSIS

The City of Scottsdale has approved the proposed water distribution system along Rio Verde Drive consisting of 16" and 12" mains (Ref. 1 and 2). This approved water system will be the main domestic and fire flow water sources for the proposed development of Reata Ranch. A hydraulic water model for this water system was also previously prepared and City approved on May 7, 2001 (Ref. 5). Exerts from this water model report is included in Exhibit 3 of this report. According to the enclosed exert, the available water flow and pressure are as described in the table below.

Node	Near	Flow (GPM)	⁽¹⁾ Pressure (psi)
210	128 th Street	299.56	55.00
212	East of 128 nd Street	299.56	63.46
220	West of 132 nd Street	299.56	80.45
224	136 th Street	299.56	91.11

(1) Based upon Average Day Demand

A hydraulic model has been developed connecting into the water system along Rio Verde Drive with the flows and pressures provided in the table above. The purpose of this hydraulic model is to present the water demand for Reata Ranch development and for the single family residential parcels to the south of Reata Ranch relative to flow and pressure. The model is presented in Exhibit 4 of this report. The hydraulic model employed the following parameters:

- ✓ The water source (PRV at Rio Verde Road, east of 128th Street) is modeled at fixed grade node with a constant pressure head of 55 psig;
- ✓ The Hazen-Williams "C" for ductile iron pipe is 120;
- ✓ Ignore minor losses

The results of the computer runs are included in Exhibit 4 and are summarized below.

- ✓ The overall head-loss through the piping networks is low at peak day demand and also at maximum day + fire demands. The maximum and minimum pressures at each junction nodes are within the pressure zone range.
- ✓ The proposed piping network for this subdivision is adequate for peak and maximum day + fire flow demands.
- ✓ Fire flow is modeled at Node J14 to coincide with the Resort parcel and a fire flow demand of 2,500 gpm. Results, as shown prove the sustainability of the proposed system under modeled conditions.

6.0 RECOMMENDATIONS

- ✓ Construct the offsite water line from 122nd Street to 136th Street per City approved plans, project number 3357-04-4 and project number 3357-04-1 upon plans re-approval.
- ✓ Construct the onsite piping network consisting of 8-inch diameter pipe following the backbone roadway alignment s as shown in Exhibit 2 for the Reata Ranch development.


7.0 CONCLUSIONS

- ✓ The project is located in City of Scottsdale pressure zones 11E (El. 2,440-2,570).
- ✓ Fire hydrants shall be placed per requirements of City of Scottsdale Fire Department.
- ✓ A "Water Quality Sampling Station" shall be placed in Reata Ranch development. The water quality sampling station shall be constructed according the City of Scottsdale Standard Detail 2349.
- ✓ The proposed offsite piping improvement shall comply with the approved Water Distributions System Master Plan. (Ref. 1, 2, and 5).
- ✓ When the water line alignments cross natural washes they shall be protected from scouring by the use of a downstream cutoff wall in the flow area.

8.0 REFERENCES

1. SVK Engineering, Inc., "Rio Verde Estates offsite Water, Rio Verde / Dynamite Boulevard – Water Main Plans Phase 2", April 10, 2008, Plan number 23-PP-2004, 3357-04-4 (Approved by the City of Scottsdale on May 20, 2008).
2. Evolution Engineering, LLC, "Desert Estates Offsite, Rio Verde Drive Water Main Plans", September 26, 2007, Plan number 5-PP-03, 73-NP-2001, 1346-03-4 (Approved by the City of Scottsdale on May 20, 2008).
3. City of Scottsdale, "Chapter 6 Potable Water System Design, Design Standards and Policies Manual", Dated August 2008.
4. Arizona Department of Environmental Quality, "engineering bulletin no. 10 Guidelines for the Construction of Water, Minimum Requirements for Design, Submission of Plans and Specifications of Sewage Works", May, 1978.
5. GTA Engineering, Inc., Scottsdale National Water Supply System, Scottsdale, Arizona. April 25, 2001. Project number GTA00145 ((Approved by the City of Scottsdale on May 07, 2001).
6. 2006 International Fire Code, International Code Council, dated 2006

EXHIBIT 1



Site Location Map


EXHIBIT 2

RECREATION
FACILITIES
SUBDIVISION

RECREATION FACILITIES

RECREATION FACILITIES

RECREATION FACILITIES



DEVELOPMENT SUMMARY

RECREATION

COUNTRY LODGE AND LOUVER UNITS	12 UNITS
SOUTHERN LODGE UNITS	18 UNITS
COUNTRY RANCH UNITS	43 UNITS
HOUSEHOLD UNITS	18 UNITS
SUB-TOTAL:	75 UNITS
PARCEL A: 5.7 AC. 3.5 DU/AC	20 UNITS
PARCEL B: 5.9 AC. 3.5 DU/AC	21 UNITS
PARCEL C: 6.3 AC. 3.5 DU/AC	29 UNITS
PARCEL D: 5.5 AC. 3.5 DU/AC	34 UNITS
PARCEL E: 5.5 AC. 3.5 DU/AC	21 UNITS
PARCEL F: 8.4 AC. 3.5 DU/AC	29 UNITS
PARCEL G: 10.1 AC. 3.5 DU/AC	35 UNITS
PARCEL H: 8.1 AC. 3.5 DU/AC	28 UNITS
PARCEL I: 10.4 AC. 3.5 DU/AC	36 UNITS
SUB-TOTAL:	255 UNITS
TOTAL:	330 UNITS

DATE: 11/11/11

Travis Architecture Associates

REATA RANCH

11/11/11
CRAZY/PICTURE

EXHIBIT 3

**Scottsdale National
Water Supply System
Scottsdale, Arizona**

Water Master Plan

prepared for:
Hunn & Associates, Inc.



Accepted w/ Comments:

**CITY OF SCOTTSDALE
WATER RESOURCES DEPT
9388 E SAN SALVADOR DR.
SCOTTSDALE, AZ 85258**

prepared by


*by Doug Mann
5-7-2001*

GTA ENGINEERING, INC.
Consulting Engineers
1990 W. Camelback Rd., Suite 401
Phoenix, Arizona 85015
TEL (602) 246-7759 FAX (602) 246-7645
e-mail: gta@goldmantoy.com

Revised April, 2001

GTA00145

Scottsdale National Links Map



No P.V.

 * E P A N E T *
 * Hydraulic and Water Quality *
 * Analysis for Pipe Networks *
 * Version 2.0 *

Input File: SN3ADF.inp

Scottsdale National (w/o Map)

AVERAGE DAILY FLOW RUN

Map displays entire network w/o backdrop. To see partial network w/
backdrop, open: SNmap.net

Link - Node Table:

Link ID	Start Node	End Node	Length ft	Diameter in
1	R100	105	3300	24
2	105	110	1700	24
3	111	112	1100	20
4	112	114	1200	20
5	114	118	1200	12
6	116	118	1500	12
7	118	120	1000	12
8	121	210	500	12
9	210	212	1000	12
10	212	214	1300	12
11	214	220	1200	12
12	220	224	1300	12
13	224	228	200	12
14	228	230	500	12
15	230	232	500	12
P100	233	J100	551.79	12
P500	J100	J500	1789.21	12
P510	J500	J510	950.00	12
P120	J100	J120	420.01	8
P140	J120	J140	187.09	8
P160	J140	J160	272.99	8
P170	J160	PH170	489.42	8
P180	PH170	J180	83.32	8
P200	J180	J200	745.39	8
P210	J200	PH210	192.30	8
P220	PH210	J220	192.43	8
P240	J220	J240	474.89	8
P260	J240	J260	217.32	8
P280	J260	J280	161.15	8
P290	J280	PH290	32.26	8
P300	PH290	J300	307.32	8
P310	J300	J600	465.63	8
P520	J500	J520	411.75	8
P522	J520	PH522	66.51	8

16" Revised to 16" on 9.14.01 OK w/
GARY LANE after discussion.

Link - Node Table: (continued)

Link ID	Start Node	End Node	Length ft	Diameter in
P524	FH522	FH524	705.52	8
P526	FH524	FH526	849.87	8
P528	FH526	J600	60.79	8
P610	J600	FH610	772.03	8
P620	FH610	J620	69.46	8
P626	J620	FH626	535.35	8
P640	J620	J640	309.40	8
P145	J140	J145	121.59	6
P165	J160	J165	262.24	6
P185	J180	FH185	396.87	6
P190	FH185	J190	369.92	6
P205	J200	J205	254.73	6
P223	J220	FH223	130.60	6
P226	FH223	J226	313.79	6
P229	J220	J229	472.71	6
P245	J240	FH245	331.67	6
P250	FH245	J250	263.17	6
P265	J260	J265	324.30	6
P285	J280	J285	476.27	6
P305	J300	FH305	82.83	6
P320	FH305	J320	352.12	6
P323	J320	J323	203.66	6
P326	J320	FH326	379.38	6
P329	FH326	J329	70.13	6
P340	J320	J340	769.79	6
P343	J340	FH343	339.53	6
P346	FH343	J346	131.87	6
P350	J340	FH350	111.93	6
P360	FH350	J360	348.78	6
P363	J360	FH363	211.31	6
P366	FH363	J366	190.78	6
P369	J360	J369	258.68	6
P370	J360	FH370	299.99	6
P380	FH370	J380	205.82	6
P385	J380	J385	297.69	6
P400	J380	J400	167.31	6
P405	J400	J405	315.39	6
P410	J400	FH410	203.58	6
P420	FH410	J120	222.19	6
P540	J540	J540	963.88	6
P545	J540	J545	434.39	6
P550	J540	FH550	174.49	6
P560	FH550	J560	355.24	6
P563	J560	FH563	189.48	6
P566	FH563	J566	125.01	6
P570	J560	FH570	612.60	6
P580	FH570	J580	139.43	6

Link - Node Table: (continued)

Link ID	Start Node	End Node	Length ft	Diameter in
P600	J580	J600	309.74	6
P622	J620	FH622	575.20	6
P624	FH622	J624	135.33	6
P628	FH626	J628	544.80	6
PRV1	120	121	N/A	12 Valve
PRV2	232	233	N/A	12 Valve
PRV13	110	111	N/A	12 Valve

Node Results:

Node ID	Demand GPM	Head ft	Pressure psi	Quality
105	0.00	2814.60	53.99	0.00
110	572.00	2814.39	49.57	0.00
111	0.00	2814.39	49.57	0.00
112	0.00	2814.29	60.36	0.00
114	0.00	2814.20	71.15	0.00
116	0.00	2813.06	81.49	0.00
118	0.00	2811.69	98.22	0.00
120	235.00	2810.75	108.65	0.00
121	0.00	2686.93	55.00	0.00
210	0.00	2686.78	59.26	0.00
212	0.00	2686.46	63.46	0.00
214	0.00	2686.05	69.78	0.00
220	0.00	2685.67	80.45	0.00
224	0.00	2685.26	91.11	0.00
228	0.00	2685.20	91.00	0.00
230	251.00	2685.04	101.84	0.00
232	0.00	2685.04	101.84	0.00
233	0.00	2576.93	55.00	0.00
J100	0.00	2576.93	57.47	0.00
J120	0.00	2576.92	55.86	0.00
J140	0.00	2576.91	54.99	0.00
J145	1.01	2576.91	52.96	0.00
J160	0.67	2576.91	57.37	0.00
J165	1.01	2576.91	59.84	0.00
FH170	0.00	2576.91	59.32	0.00
J180	2.02	2576.91	57.50	0.00
FH185	0.00	2576.91	76.65	0.00
J190	2.36	2576.91	66.25	0.00
J200	1.35	2576.90	60.62	0.00
J205	1.35	2576.90	63.65	0.00
FH210	0.00	2576.90	62.35	0.00
J220	2.02	2576.90	64.52	0.00
FH223	0.00	2576.90	63.65	0.00
J226	1.35	2576.90	67.55	0.00

* 125th St./Rio Verde

Node Results: (continued)

Node ID	Demand GPM	Head ft	Pressure psi	Quality
J229	1.35	2576.90	64.74	0.00
J240	0.34	2576.90	71.76	0.00
FH245	0.00	2576.90	72.32	0.00
J250	1.69	2576.90	71.45	0.00
J260	0.34	2576.90	74.49	0.00
J265	1.01	2576.90	67.55	0.00
J280	0.67	2576.90	76.44	0.00
J285	1.35	2576.90	75.57	0.00
FH290	0.00	2576.90	76.65	0.00
J300	1.01	2576.90	72.75	0.00
FH305	0.00	2576.90	74.49	0.00
J320	1.01	2576.90	73.62	0.00
J323	1.69	2576.90	75.78	0.00
FH326	0.00	2576.90	70.15	0.00
J329	1.69	2576.90	67.99	0.00
J340	1.69	2576.90	71.45	0.00
FH343	0.00	2576.90	72.32	0.00
J346	1.69	2576.90	70.58	0.00
FH350	0.00	2576.90	68.72	0.00
J360	1.35	2576.90	66.69	0.00
FH363	0.00	2576.90	65.02	0.00
J366	1.35	2576.90	65.60	0.00
J369	0.67	2576.90	69.07	0.00
FH370	0.00	2576.91	63.65	0.00
J380	0.00	2576.91	61.92	0.00
J385	1.35	2576.91	62.79	0.00
J400	0.34	2576.91	60.19	0.00
J405	1.01	2576.91	62.36	0.00
FH410	0.00	2576.91	57.37	0.00
J500	0.00	2576.92	74.58	0.00
J510	0.00	2576.92	84.03	0.00
J520	1.35	2576.92	74.27	0.00
FH522	0.00	2576.91	73.62	0.00
FH524	0.00	2576.91	78.39	0.00
FH526	0.00	2576.90	78.39	0.00
J540	1.69	2576.91	81.85	0.00
J545	1.35	2576.91	77.52	0.00
FH550	0.00	2576.91	83.15	0.00
J560	1.01	2576.90	82.07	0.00
FH563	0.00	2576.90	83.15	0.00
J566	1.01	2576.90	85.75	0.00
FH570	0.00	2576.90	83.15	0.00
J580	2.02	2576.90	84.45	0.00
J600	0.67	2576.90	78.39	0.00
FH610	0.00	2576.90	78.73	0.00
J620	1.69	2576.90	77.52	0.00
FH622	0.00	2576.90	83.15	0.00

Node Results: (continued)

Node ID	Demand GPM	Head ft	Pressure psi	Quality
J624	2.02	2576.90	83.80	0.00
PH626	0.00	2576.90	72.32	0.00
J628	1.01	2576.90	71.45	0.00
J640	0.00	2576.90	78.08	0.00
R100	-1106.57	<u>2815.00</u>	0.00	0.00 Reservoir
VolCurve	0.00	2400.00	0.00	0.00 Reservoir

Will Establish Now @ 2830
w/ 2 1/2 Reservoir

Link Results:

Link ID	Flow GPM	Velocity fps	Headloss ft/Kft	Status
1	1106.57	0.78	0.12	Open
2	1106.57	0.78	0.12	Open
3	534.57	0.55	0.08	Open
4	534.57	0.55	0.08	Open
5	534.57	1.52	0.95	Open
6	534.57	1.52	0.92	Open
7	534.57	1.52	0.92	Open
8	299.56	0.85	0.32	Open
9	299.56	0.85	0.32	Open
10	299.56	0.85	0.32	Open
11	299.56	0.85	0.32	Open
12	299.56	0.85	0.32	Open
13	299.56	0.85	0.31	Open
14	299.56	0.85	0.32	Open
15	48.57	0.14	0.01	Open
P100	48.57	0.14	0.01	Open
P500	21.70	0.06	0.00	Open
P510	0.00	0.00	0.00	Open
P120	26.86	0.17	0.03	Open
P140	17.04	0.11	0.01	Open
P160	16.03	0.10	0.01	Open
P170	14.34	0.09	0.01	Open
P180	14.34	0.09	0.01	Open
P200	9.96	0.06	0.00	Open
P210	7.26	0.05	0.00	Open
P220	7.26	0.05	0.00	Open
P240	2.54	0.02	0.00	Open
P260	0.53	0.00	0.00	Open
P280	-0.83	0.01	0.00	Open
P290	-2.86	0.02	0.00	Open
P300	-2.86	0.02	0.00	Open
P310	-7.87	0.05	0.00	Open
P520	21.70	0.14	0.02	Open
P522	13.10	0.08	0.01	Open
P524	13.10	0.08	0.01	Open

Link Results: (continued)

Link ID	Flow GPM	Velocity fps	Headloss ft/Kft	Status
P526	13.10	0.08	0.01	Open
P528	13.10	0.08	0.01	Open
P610	4.72	0.03	0.00	Open
P620	4.72	0.03	0.00	Open
P626	1.01	0.01	0.00	Open
P640	0.00	0.00	0.00	Open
P145	1.01	0.01	0.00	Open
P165	1.01	0.01	0.00	Open
P185	2.36	0.03	0.00	Open
P190	2.36	0.03	0.00	Open
P205	1.35	0.02	0.00	Open
P223	1.35	0.02	0.00	Open
P226	1.35	0.02	0.00	Open
P229	1.35	0.02	0.00	Open
P245	1.69	0.02	0.00	Open
P250	1.69	0.02	0.00	Open
P265	1.01	0.01	0.00	Open
P285	1.35	0.02	0.00	Open
P305	4.00	0.05	0.00	Open
P320	4.00	0.05	0.00	Open
P323	1.69	0.02	0.00	Open
P326	1.69	0.02	0.00	Open
P329	1.69	0.02	0.00	Open
P340	-0.38	0.00	0.00	Open
P343	1.69	0.02	0.00	Open
P346	1.69	0.02	0.00	Open
P350	-3.75	0.04	0.00	Open
P360	-3.75	0.04	0.00	Open
P363	1.35	0.02	0.00	Open
P366	1.35	0.02	0.00	Open
P369	0.67	0.01	0.00	Open
P370	-7.13	0.08	0.01	Open
P380	-7.13	0.08	0.01	Open
P385	1.35	0.02	0.00	Open
P400	-8.47	0.10	0.01	Open
P405	1.01	0.01	0.00	Open
P410	-9.82	0.11	0.02	Open
P420	-9.82	0.11	0.02	Open
P540	7.25	0.08	0.01	Open
P545	1.35	0.02	0.00	Open
P550	4.21	0.05	0.00	Open
P560	4.21	0.05	0.00	Open
P563	1.01	0.01	0.00	Open
P566	1.01	0.01	0.00	Open
P570	2.19	0.02	0.00	Open
P580	2.19	0.02	0.00	Open
P600	0.17	0.00	0.00	Open

Link Results: (continued)

Link ID	Flow GPM	Velocity fps	Headloss ft/Kft	Status
P622	2.02	0.02	0.00	Open
P624	2.02	0.02	0.00	Open
P628	1.01	0.01	0.00	Open
PRV1	299.57	0.85	123.82	Active Valve
PRV2	48.56	0.14	108.10	Active Valve
PRV13	534.57	1.52	0.00	Open Valve

EXHIBIT 4

APPENDIX B

FIRE-FLOW REQUIREMENTS FOR BUILDINGS

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

SECTION B101 GENERAL

B101.1 Scope. The procedure for determining fire-flow requirements for buildings or portions of buildings hereafter constructed shall be in accordance with this appendix. This appendix does not apply to structures other than buildings.

SECTION B102 DEFINITIONS

B102.1 Definitions. For the purpose of this appendix, certain terms are defined as follows:

FIRE-FLOW. The flow rate of a water supply, measured at 20 pounds per square inch (psi) (138 kPa) residual pressure, that is available for fire fighting.

FIRE-FLOW CALCULATION AREA. The floor area, in square feet (m²), used to determine the required fire flow.

SECTION B103 MODIFICATIONS

B103.1 Decreases. The fire chief is authorized to reduce the fire-flow requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.

B103.2 Increases. The fire chief is authorized to increase the fire-flow requirements where conditions indicate an unusual susceptibility to group fires or conflagrations. An increase shall not be more than twice that required for the building under consideration.

B103.3 Areas without water supply systems. For information regarding water supplies for fire-fighting purposes in rural and suburban areas in which adequate and reliable water supply systems do not exist, the fire code official is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

SECTION B104 FIRE-FLOW CALCULATION AREA

B104.1 General. The fire-flow calculation area shall be the total floor area of all floor levels within the exterior walls, and under the horizontal projections of the roof of a building, except as modified in Section B104.3.

B104.2 Area separation. Portions of buildings which are separated by fire walls without openings, constructed in accordance with the *International Building Code*, are allowed to be considered as separate fire-flow calculation areas.

B104.3 Type IA and Type IB construction. The fire-flow calculation area of buildings constructed of Type IA and Type IB construction shall be the area of the three largest successive floors.

Exception: Fire-flow calculation area for open parking garages shall be determined by the area of the largest floor.

SECTION B105 FIRE-FLOW REQUIREMENTS FOR BUILDINGS

B105.1 One- and two-family dwellings. The ~~minimum fire-flow requirements~~ for one- and two-family dwellings having a fire-flow calculation area which does not exceed 3,600 square feet (344.5 m²) shall be 1,500 gallons per minute (3785.4 L/min). Fire-flow and flow duration for dwellings having a fire-flow calculation area in excess of 3,600 square feet (344.5 m²) shall not be less than that specified in Table B105.1.

✓ **Exception:** A ~~reduction~~ in required fire flow of 50 percent, as approved, is allowed when the building is provided with an approved ~~automatic sprinkler system~~.

B105.2 Buildings other than one- and two-family dwellings. The minimum fire-flow and flow duration for buildings other than one- and two-family dwellings shall be as specified in Table B105.1.

Exception: A reduction in required fire-flow of up to 75 percent, as approved, is allowed when the building is provided with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. The resulting fire-flow shall not be less than 1,500 gallons per minute (5678 L/min) for the prescribed duration as specified in Table B105.1.

SECTION B106 REFERENCED STANDARDS

ICC	IBC	International Building Code	B104.2, Table B105.1
ICC	IWUIC	International Wildland-Urban Interface Code	B103.3
NFPA	1142	Standard on Water Supplies for Suburban and Rural Fire Fighting	B103.3

TABLE B105.1
MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS^a

TYPICAL WOOD FRAME

FIRE-FLOW CALCULATION AREA (square feet)					FIRE-FLOW (gallons per minute) ^c	FLOW DURATION (hours)
Type IA and IB ^b	Type IIA and IIIA ^b	Type IV and V-A ^b	Type IIB and IIIB ^b	Type V-B ^b		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	3
83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	4
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-183,400	92,401-103,100	59,101-66,000	42,701-47,700	26,301-29,300	4,500	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750	
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000	
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250	
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500	
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750	
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000	
—	—	115,801-125,500	83,701-90,600	51,501-55,700	6,250	
—	—	125,501-135,500	90,601-97,900	55,701-60,200	6,500	
—	—	135,501-145,800	97,901-106,800	60,201-64,800	6,750	
—	—	145,801-156,700	106,801-113,200	64,801-69,600	7,000	
—	—	156,701-167,900	113,201-121,300	69,601-74,600	7,250	
—	—	167,901-179,400	121,301-129,600	74,601-79,800	7,500	
—	—	179,401-191,400	129,601-138,300	79,801-85,100	7,750	
—	—	191,401-Greater	138,301-Greater	85,101-Greater	8,000	

For SI: 1 square foot = 0.0929 m², 1 gallon per minute = 3.785 L/min, 1 pound per square inch = 6.895 kPa.

a. The minimum required fire flow shall be allowed to be reduced by 25 percent for Group R.

b. Types of construction are based on the *International Building Code*.

c. Measured at 20 psi.

DISREGARD per FP - Armstrong

THE CODE CONNECTION

Hosted by Terry Welker AIA

Construction Types

All buildings are classified according to their construction type. Type I is least combustible and Type V is most combustible. The more combustible a building is and the more hazardous the use is, the more the maximum allowable area is limited (in table 503). All construction types and use groups are allowed to have increased areas by using sprinklers.

Type I

I-A or I-B

Typically these are concrete frame buildings made of noncombustible materials. All of the building elements (structural frame, bearing walls, floors and roofs) are fire resistance rated according to Tables 601 and 602.

Type II

II-A or II-B

These buildings are constructed of noncombustible materials. Typically these are masonry bearing walls structures with steel studs for walls and steel bar joists for floor and roof structures. IIA has fire rated building elements (structural frame, bearing walls, floors and roofs). IIB is the most common construction type for commercial buildings because the building elements are not required to be fire resistance rated but still must be non-combustible.

Types I and II. (602.2)

Types I and II construction are those types of construction in which the building elements listed in Table 601 are of noncombustible materials.

Type III

III-A or III-B

Type III construction is that type of construction in which the exterior walls are of noncombustible materials and the interior building elements are of any material permitted by the code (combustible or non-combustible). This is typical of buildings with masonry bearing walls and wood roofs or floors.

Type III. (602.3)

Type III construction is that type of construction in which the exterior walls are of noncombustible materials and the interior building elements are of any material permitted by this code. Fire-retardant-treated wood framing complying with Section 2303.2 shall be permitted within exterior wall assemblies of a 2-hour rating or less.

Type IV

IV-A or IV-B

This is Heavy Timber construction which is not common in Ohio except perhaps in some worship facilities.

Type IV. (602.4)

Type IV construction (Heavy Timber, HT) is that type of construction in which the exterior walls are of noncombustible materials and the interior building elements are of solid or laminated wood without concealed spaces. The details of Type IV construction shall comply with the provisions of this section. Fire-retardant-treated wood framing complying with Section 2303.2 shall be permitted within exterior wall assemblies with a 2-hour rating or less.

Type V


V-A or V-B

Type V construction is typically wood frame construction. V-A requires fire rated assemblies for all building elements (structural frame, bearing walls, floors and roofs); this is often seen in older construction that predates sprinklers but still not commonly used. V-B is very common because it does not require any fire rating.

Type V. (602.5)

Type V construction is that type of construction in which the structural elements, exterior walls and interior walls are of

REATA RANCH - AVERAGE DAY DEMAND



```

*****
*                               E P A N E T                               *
*                               Hydraulic and Water Quality                 *
*                               Analysis for Pipe Networks                   *
*                               Version 2.0                                 *
*****

```

Input File: Reata Ranch Water System (AVG DAY)_7-11-2012.net

Link - Node Table:

Link ID	Start Node	End Node	Length ft	Diameter in
P1	J1	J2	455.3	12
P12	J12	J13	404	12
P11	J7	J12	2693	12
P10	J11	J8	1610	12
P2	J2	J3	19	8
P3	J2	J4	232.9	12
P6	J5	J7	1299	12
P5	J5	J6	50	8
P7	J8	J7	1053	12
P8	J9	J8	100	8
P9	J8	J10	100	12
P14	J13	J15	2220	12
P13	J13	J14	35	12
1	R1	J1	75	36
P4	J1	J5	1280	12

Node Results:


Node ID	Demand GPM	Head ft	Pressure psi	Quality
J1	0.00	2706.77	59.26	0.00
J2	0.00	2706.77	58.83	0.00
J12	0.00	2706.58	97.74	0.00
J13	0.00	2706.57	104.67	0.00
J7	0.00	2706.61	78.69	0.00
J11	0.00	2706.59	81.71	0.00
J8	0.00	2706.59	84.75	0.00
J3	6.74	2706.77	59.70	0.00
J4	0.00	2706.77	57.10	0.00
J5	0.00	2706.69	70.06	0.00
J6	0.00	2706.69	71.36	0.00
J9	16.86	2706.58	83.88	0.00
J10	43.16	2706.58	85.18	0.00
J15	0.00	2706.57	106.84	0.00
J14	43.84	2706.57	104.67	0.00
R1	-110.61	2706.77	0.00	0.00 Reservoir

128th / Rio Verde

Link Results:

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Status
P1	6.74	0.02	0.00	Open
P12	43.84	0.12	0.01	Open
P11	43.84	0.12	0.01	Open
P10	0.00	0.00	0.00	Open
P2	6.74	0.04	0.00	Open
P3	0.00	0.00	0.00	Open
P6	103.86	0.29	0.06	Open
P5	0.00	0.00	0.00	Open
P7	-60.02	0.17	0.02	Open
P8	-16.86	0.11	0.01	Open
P9	43.16	0.12	0.01	Open
P14	0.00	0.00	0.00	Open
P13	43.84	0.12	0.01	Open
1	110.61	0.03	0.00	Open
P4	103.87	0.29	0.06	Open

REATA RANCH - MAXIMUM DAY DEMAND




```

*****
*                               E P A N E T                               *
*                               Hydraulic and Water Quality                 *
*                               Analysis for Pipe Networks                   *
*                               Version 2.0                                 *
*****

```

Input File: Reata Ranch Water System (MAX DAY)_7-11-2012.NET

Link - Node Table:

Link ID	Start Node	End Node	Length ft	Diameter in
P1	J1	J2	455.3	12
P12	J12	J13	404	12
P11	J7	J12	2693	12
P10	J11	J8	1610	12
P2	J2	J3	19	8
P3	J2	J4	232.9	12
P6	J5	J7	1299	12
P5	J5	J6	50	8
P7	J8	J7	1053	12
P8	J9	J8	100	8
P9	J8	J10	100	12
P14	J13	J15	2220	12
P13	J13	J14	35	12
1	R1	J1	75	36
P4	J1	J5	1280	12

Node Results:


Node ID	Demand GPM	Head ft	Pressure psi	Quality
J1	0.00	2706.77	59.26	0.00 <i>128th / Rio Verde</i>
J2	0.00	2706.77	58.83	0.00
J12	0.00	2706.07	97.52	0.00
J13	0.00	2706.05	104.45	0.00
J7	0.00	2706.19	78.51	0.00
J11	0.00	2706.11	81.51	0.00
J8	0.00	2706.11	84.54	0.00
J3	13.49	2706.77	59.70	0.00
J4	0.00	2706.77	57.10	0.00
J5	0.00	2706.48	69.97	0.00
J6	0.00	2706.48	71.27	0.00
J9	33.72	2706.10	83.67	0.00
J10	86.33	2706.10	84.97	0.00
J15	0.00	2706.05	106.61	0.00
J14	87.68	2706.05	104.45	0.00
R1	-221.23	2706.77	0.00	0.00 Reservoir

Link Results:

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Status
P1	13.49	0.04	0.00	Open
P12	87.68	0.25	0.05	Open
P11	87.68	0.25	0.05	Open
P10	0.00	0.00	0.00	Open
P2	13.49	0.09	0.01	Open
P3	0.00	0.00	0.00	Open
P6	207.73	0.59	0.22	Open
P5	0.00	0.00	0.00	Open
P7	-120.05	0.34	0.08	Open
P8	-33.72	0.22	0.06	Open
P9	86.33	0.24	0.04	Open
P14	0.00	0.00	0.00	Open
P13	87.68	0.25	0.04	Open
1	221.23	0.07	0.00	Open
P4	207.74	0.59	0.22	Open

Reata Ranch

REATA RANCH - MAXIMUM DAY DEMAND (WITH FIRE FLOW)



 * E P A N E T *
 * Hydraulic and Water Quality *
 * Analysis for Pipe Networks *
 * Version 2.0 *

Input File: Reata Ranch Water System (MAX DAY-W_FIRE)_7-11-2012.NET

Link - Node Table:

Link ID	Start Node	End Node	Length ft	Diameter in
P1	J1	J2	455.3	12
P12	J12	J13	404	12
P11	J7	J12	2693	12
P10	J11	J8	1610	12
P2	J2	J3	19	8
P3	J2	J4	232.9	12
P6	J5	J7	1299	12
P5	J5	J6	50	8
P7	J8	J7	1053	12
P8	J9	J8	100	8
P9	J8	J10	100	12
P14	J13	J15	2220	12
P13	J13	J14	35	12
1	R1	J1	75	36
P4	J1	J5	1280	12

Node Results:


Node ID	Demand GPM	Head ft	Pressure psi	Quality
J1	0.00	2706.76	59.26	0.00
J2	0.00	2706.76	58.82	0.00
J12	0.00	2574.98	40.72	0.00
J13	0.00	2565.30	43.46	0.00
J7	0.00	2639.53	49.63	0.00
J11	0.00	2639.44	52.62	0.00
J8	0.00	2639.44	55.66	0.00
J3	13.49	2706.76	59.69	0.00
J4	0.00	2706.76	57.09	0.00
J5	0.00	2673.39	55.63	0.00
J6	0.00	2673.39	56.93	0.00
J9	33.72	2639.44	54.79	0.00
J10	86.33	2639.44	56.09	0.00
J15	0.00	2565.30	45.63	0.00
J14	2587.68	2564.46	43.10	0.00
R1	-2721.23	2706.77	0.00	0.00 Reservoir

128th / RIO VERDE

Link Results:

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Status
P1	13.49	0.04	0.00	Open
P12	2587.68	7.34	23.97	Open
P11	2587.68	7.34	23.97	Open
P10	0.00	0.00	0.00	Open
P2	13.49	0.09	0.01	Open
P3	0.00	0.00	0.00	Open
P6	2707.73	7.68	26.07	Open
P5	0.00	0.00	0.00	Open
P7	-120.05	0.34	0.08	Open
P8	-33.72	0.22	0.06	Open
P9	86.33	0.24	0.04	Open
P14	0.00	0.00	0.00	Open
P13	2587.68	7.34	23.97	Open
1	2721.23	0.86	0.12	Open
P4	2707.74	7.68	26.07	Open

REATA RANCH - PEAK HOUR DEMAND



 * E P A N E T *
 * Hydraulic and Water Quality *
 * Analysis for Pipe Networks *
 * Version 2.0 *

Input File: Reata Ranch Water System (PEAK HOUR)_7-11-2012.NET

Link - Node Table:

Link ID	Start Node	End Node	Length ft	Diameter in
P1	J1	J2	455.3	12
P12	J12	J13	404	12
P11	J7	J12	2693	12
P10	J11	J8	1610	12
P2	J2	J3	19	8
P3	J2	J4	232.9	12
P6	J5	J7	1299	12
P5	J5	J6	50	8
P7	J8	J7	1053	12
P8	J9	J8	100	8
P9	J8	J10	100	12
P14	J13	J15	2220	12
P13	J13	J14	35	12
1	R1	J1	75	36
P4	J1	J5	1280	12

Node Results:

Node ID	Demand GPM	Head ft	Pressure psi	Quality
J1	0.00	2706.77	59.26	0.00
J2	0.00	2706.77	58.83	0.00
J12	0.00	2704.79	96.97	0.00
J13	0.00	2704.74	103.88	0.00
J7	0.00	2705.14	78.05	0.00
J11	0.00	2704.90	80.98	0.00
J8	0.00	2704.90	84.02	0.00
J3	23.61	2706.77	59.69	0.00
J4	0.00	2706.77	57.09	0.00
J5	0.00	2705.96	69.74	0.00
J6	0.00	2705.96	71.04	0.00
J9	59.01	2704.88	83.14	0.00
J10	151.08	2704.88	84.44	0.00
J15	0.00	2704.74	106.05	0.00
J14	153.44	2704.74	103.88	0.00
R1	-387.15	2706.77	0.00	0.00 Reservoir


Link Results:

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Status
P1	23.61	0.07	0.00	Open
P12	153.44	0.44	0.13	Open
P11	153.44	0.44	0.13	Open
P10	0.00	0.00	0.00	Open
P2	23.61	0.15	0.03	Open
P3	0.00	0.00	0.00	Open
P6	363.54	1.03	0.63	Open
P5	0.00	0.00	0.00	Open
P7	-210.09	0.60	0.23	Open
P8	-59.01	0.38	0.16	Open
P9	151.08	0.43	0.12	Open
P14	0.00	0.00	0.00	Open
P13	153.44	0.44	0.13	Open
1	387.15	0.12	0.00	Open
P4	363.54	1.03	0.63	Open

SKG Enterprises, Inc.						
Junction Node Elevation and Demand						
Project: Reata Ranch (Scottsdale, Arizona)			Date:		7/11/2012	
			SKG Project No.		30-9	
Junction Number (node)	Elevation (feet)	Number of Units	Average Day Water Demand (gpm)	Maximum Day Water Demand (gpm)	Peak Hour Water Demand (gpm)	Notes
Res1	2706.77 ⁽⁴⁾	0	Units*485.6/1440	2*Avg. Day	3.5*Average Day	Base Parameters
J1 ⁽⁶⁾	2570.0 ft	0	0.00	0.00	0.00	
J2	2571.0 ft	0	0.00	0.00	0.00	
J3	2569.0 ft	20	6.74	13.49	23.61	Parcel A
4 ⁽¹⁾	2575.0 ft	0	0.00	0.00	0.00	
J5	2545.0 ft	0	0.00	0.00	0.00	
J6	2542.0 ft	0	0.00	0.00	0.00	
J7	2525.0 ft	0	0.00	0.00	0.00	
J8	2511.0 ft	0	0.00	0.00	0.00	
J9	2513.0 ft	50	16.86	33.72	59.01	Parcel B and Parcel C
J10	2510.0 ft	128	43.16	86.33	151.08	Parcels F, G, H and I
11 ⁽¹⁾	2518.0 ft	0	0.00	0.00	0.00	
J12	2481.0 ft	0	0.00	0.00	0.00	
J13	2465.0 ft	0	0.00	0.00	0.00	
J14 ⁽²⁾⁽³⁾	2465.0 ft	130	43.84	87.68	153.44	Parcels D, E and Resort (Fire Flow)
J15 ⁽¹⁾	2460.0 ft	0	0.00	0.00	0.00	
Total		328	110.61	221.22	387.13	Total
1 = Boundary node -- Future system expansion estimated based on adjacent zoning opportunity						
2 = Fire Flow Analysis (Use 2,500 gpm for Resort as Site Fire Flow control)						
3 = A daily demand of 485.6/unit was applied to the Resort and Guest Ranch facilities as units more closely resemble Single Family housing.						
4 = Elevation reflects required head + ground elevation.						
5 = Node J1 (this report) = Node 210 (approved GTA Engineering, Inc. report for the Scottsdale national Water Supply System (dated 4/25/01).						


SKG Enterprises, Inc.
9260 East Raintree Drive #140
Scottsdale, Arizona 85260
ph) 480.998.5600

APPENDIX C




RIVER	REACH	RIVER STATION	SCOUR DEPTH (FT)	MINIMUM TOE LENGTH REQUIRED (FT)	TOE LENGTH PROVIDED (FT)
RVW10T4	R1	0.310	3	4.5	6
RVW10T4	R1	0.222	3	4.5	6
RVW10T4	R1	0.210	3	4.5	6
RVW10T4	R1	0.145	6	9.0	9.0
RVW10T4	R1	0.034	5	7.5	7.5
RVW10T3	R1	0.520	3	4.5	6
RVW10T3	R1	0.438	2	3.0	6
RVW10T3	R1	0.411	3	4.5	6
RVW10T3	R1	0.357	2	3.0	6
RVW10T3	R1	0.356	3	4.5	6
RVW10T3	R1	0.290	4	6.0	6
RVW10T3	R1	0.289	4	6.0	6
RVW10T3	R1	0.259	3	4.5	6
RVW10T3	R13	0.200	4	6.0	6
RVW10T3	R13	0.123	3	4.5	6
RVW10T2	R1	0.843	3	4.5	6
RVW10T2	R1	0.747	3	4.5	6
RVW10T2	R1	0.711	2	3.0	6
RVW10T2	R1	0.684	2	3.0	6
RVW10T2	R1	0.663	2	3.0	6
RVW10T2	R1	0.581	5	7.5	7.5
RVW10T2	R1	0.540	4	6.0	6
RVW10T2	R1	0.530	4	6.0	6
RVW10T2	R1	0.520	5	7.5	7.5
RVW10T2	R1	0.450	5	7.5	7.5

RIVER	REACH	RIVER STATION	SCOUR DEPTH (FT)	MINIMUM TOE LENGTH REQUIRED (FT)	TOE LENGTH PROVIDED (FT)
RVW10	R1	9.104	3	4.5	6
RVW10	R1	9.012	3	4.5	6
RVW10	R1	8.937	3	4.5	6
RVW10	R1	8.826	2	3.0	6
RVW10	R2	8.740	3	4.5	6
RVW10	R2	8.586	3	4.5	6
RVW10	R2	8.467	4	6.0	6
RVW10	R2	8.354	4	6.0	6
RVW10	R2	8.353	5	7.5	7.5
RVW10	R2	8.135	6	9.0	9
RVW10	R2	8.134	5	7.5	7.5
RVW10	R3	7.984	4	6.0	6



ESTIMATE RIPRAP QUANTITY 222 CFT



SKG ENTERPRISES, INC.
9260 E. RAINTREE DRIVE
SUITE 140
SCOTTSDALE, AZ. 85260
PH) 480-998-5600
FAX) 480-998-5603
WWW.SKGAZ.COM



25970
SHAW K
GAHGARI
03/31/16
1-800-874-2117
OUT OF STATE COUNTY

PRELIMINARY
NOT FOR CONSTRUCTION
OR FOR RECORDING

REATA RANCH
EROSION PROTECTION EXHIBIT
CITY OF SCOTTSDALE, ARIZONA

job no.
design UP
approved G
date 02/20/16

revisions

EXHIBIT



Scour Analysis - Reata Ranch

						Neill's Equation					Lacey's Equation				Blench's Equation					
River	Reach	River Sta.	100-Year Peak Discharge (ft. ³ /sec.)	Top Width (ft.)	Unit Water Discharge (ft. ³ /sec./ft.)	Velocity (ft. ² /sec.)	Average Depth (ft.)	Bank Full Discharge (ft.)	Multiplying Factor	Neill's Equation Scour Depth (ft.)	Mean Grain Size (mm)	Lacey's Silt Factor	Multiplying Factor	Lacey's Equation Scour Depth (ft.)	Blench's Zero Bed Factor (ft./sec.)	Multiplying Factor	Blench's Equation Scour Depth (ft.)	Maximum Scour Depth (ft.)	Minimum Toe Length Req. (ft.)	Toe Length Provided (ft.)
RVW10T4	R1	0.373	990	401.99	2	5.94	0.4	990	0.5	0.2	0.6	1.36	0.5	2.6	2.2	0.6	1.4	3	4.5	6.0
RVW10T4	R1	0.31	990	319.65	3	4.58	0.7	990	0.5	0.3	0.6	1.36	0.5	2.6	2.2	0.6	1.7	3	4.5	6.0
RVW10T4	R1	0.222	2215	418.35	5	8.23	0.6	2215	0.5	0.3	0.6	1.36	0.5	3.4	2.2	0.6	2.4	3	4.5	6.0
RVW10T4	R1	0.21	2215	388.19	6	6.39	0.9	2215	0.5	0.4	0.6	1.36	0.5	3.4	2.2	0.6	2.5	3	4.5	6.0
RVW10T4	R1	0.205	Lat Struct																	
RVW10T4	R1	0.145	2215	118.29	19	10.25	1.8	2215	0.5	0.9	0.6	1.36	0.5	3.4	2.2	0.6	5.5	6	9.0	9.0
RVW10T4	R1	0.034	2215	132.37	17	7.16	2.3	2215	0.5	1.2	0.6	1.36	0.5	3.4	2.2	0.6	5.1	5	7.5	7.5
RVW10T3	R1	0.615	815	138.7	6	5.75	1.0	815	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	2.5	3	4.5	6.0
RVW10T3	R1	0.520	815	126.45	6	5.95	1.1	815	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	2.7	3	4.5	6.0
RVW10T3	R1	0.438	815	149.58	5	5.69	1.0	815	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	2.4	2	3.0	6.0
RVW10T3	R1	0.411	815	107.15	8	6.27	1.2	815	0.5	0.6	0.6	1.36	0.5	2.4	2.2	0.6	3.0	3	4.5	6.0
RVW10T3	R1	0.357	815	151.5	5	5.60	1.0	815	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	2.4	2	3.0	6.0
RVW10T3	R1	0.356	815	88.32	9	2.79	3.3	815	0.5	1.7	0.6	1.36	0.5	2.4	2.2	0.6	3.4	3	4.5	6.0
RVW10T3	R1	0.300	Culvert																	
RVW10T3	R1	0.290	815	72.75	11	6.51	1.7	815	0.5	0.9	0.6	1.36	0.5	2.4	2.2	0.6	3.9	4	6.0	6.0
RVW10T3	R1	0.289	815	81.04	10	5.58	1.8	815	0.5	0.9	0.6	1.36	0.5	2.4	2.2	0.6	3.6	4	6.0	6.0
RVW10T3	R1	0.259	815	135.76	6	5.80	1.0	815	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	2.6	3	4.5	6.0
RVW10T3	R13	0.200	1570	143.96	11	7.11	1.5	1570	0.5	0.8	0.6	1.36	0.5	3	2.2	0.6	3.8	4	6.0	6.0
RVW10T3	R13	0.123	1570	165.84	9	6.73	1.4	1570	0.5	0.7	0.6	1.36	0.5	3	2.2	0.6	3.5	3	4.5	6.0
RVW10T2	R1	0.845	755	189.03	4	6.01	0.7	755	0.5	0.3	0.6	1.36	0.5	2.4	2.2	0.6	2.0	2	3.0	6.0
RVW10T2	R1	0.843	755	107.66	7	6.10	1.1	755	0.5	0.6	0.6	1.36	0.5	2.4	2.2	0.6	2.9	3	4.5	6.0
RVW10T2	R1	0.747	755	97.65	8	7.17	1.1	755	0.5	0.5	0.6	1.36	0.5	2.4	2.2	0.6	3.1	3	4.5	6.0
RVW10T2	R1	0.711	755	429.89	2	5.08	0.3	755	0.5	0.2	0.6	1.36	0.5	2.4	2.2	0.6	1.1	2	3.0	6.0
RVW10T2	R1	0.684	755	282.05	3	5.54	0.5	755	0.5	0.2	0.6	1.36	0.5	2.4	2.2	0.6	1.5	2	3.0	6.0
RVW10T2	R1	0.663	755	325.25	2	5.04	0.5	755	0.5	0.2	0.6	1.36	0.5	2.4	2.2	0.6	1.4	2	3.0	6.0
RVW10T2	R1	0.581	755	48.46	16	7.80	2.0	755	0.5	1	0.6	1.36	0.5	2.4	2.2	0.6	4.9	5	7.5	7.5
RVW10T2	R1	0.540	755	60.96	12	7.35	1.7	755	0.5	0.8	0.6	1.36	0.5	2.4	2.2	0.6	4.2	4	6.0	6.0
RVW10T2	R1	0.530	755	54.62	14	7.84	1.8	755	0.5	0.9	0.6	1.36	0.5	2.4	2.2	0.6	4.5	4	6.0	6.0
RVW10T2	R1	0.520	755	42.99	18	8.31	2.1	755	0.5	1.1	0.6	1.36	0.5	2.4	2.2	0.6	5.3	5	7.5	7.5
RVW10T2	R1	0.450	755	42.01	18	8.39	2.1	755	0.5	1.1	0.6	1.36	0.5	2.4	2.2	0.6	5.4	5	7.5	7.5
RVW10	R1	9.689	735	235.93	3	4.74	0.7	735	0.5	0.3	0.6	1.36	0.5	2.3	2.2	0.6	1.7	2	3.0	6.0
RVW10	R1	9.564	735	345.95	2	3.03	0.7	735	0.5	0.4	0.6	1.36	0.5	2.3	2.2	0.6	1.3	2	3.0	6.0
RVW10	R1	9.429	1045	296.98	4	4.82	0.7	1045	0.5	0.4	0.6	1.36	0.5	2.6	2.2	0.6	1.8	3	4.5	6.0
RVW10	R1	9.252	1045	268.75	4	6.52	0.6	1045	0.5	0.3	0.6	1.36	0.5	2.6	2.2	0.6	1.9	3	4.5	6.0
RVW10	R1	9.176	1045	211.84	5	6.59	0.7	1045	0.5	0.4	0.6	1.36	0.5	2.6	2.2	0.6	2.3	3	4.5	6.0
RVW10	R1	9.175	Lat Struct																	
RVW10	R1	9.104	1045	298.07	4	7.23	0.5	1045	0.5	0.2	0.6	1.36	0.5	2.6	2.2	0.6	1.8	3	4.5	6.0
RVW10	R1	9.103	Lat Struct																	
RVW10	R1	9.102	880	152.01	6	7.25	0.8	880	0.5	0.4	0.6	1.36	0.5	2.5	2.2	0.6	2.5	3	4.5	6.0
RVW10	R1	9.011	Lat Struct																	
RVW10	R1	8.937	400	65.29	6	5.91	1.0	400	0.5	0.5	0.6	1.36	0.5	1.9	2.2	0.6	2.6	3	4.5	6.0
RVW10	R1	8.936	Lat Struct																	
RVW10	R1	8.826	170	47.74	4	2.12	1.7	170	0.5	0.8	0.6	1.36	0.5	1.4	2.2	0.6	1.8	2	3.0	6.0
RVW10	R2	8.740	2285	290.17	8	5.79	1.4	2285	0.5	0.7	0.6	1.36	0.5	3.4	2.2	0.6	3.1	3	4.5	6.0
RVW10	R2	8.586	2285	302.07	8	6.25	1.2	2285	0.5	0.6	0.6	1.36	0.5	3.4	2.2	0.6	3.0	3	4.5	6.0
RVW10	R2	8.467	2285	185.92	12	7.40	1.7	2285	0.5	0.8	0.6	1.36	0.5	3.4	2.2	0.6	4.2	4	6.0	6.2

						Neill's Equation					Lacey's Equation				Blench's Equation					
River	Reach	River Sta.	100-Year Peak Discharge (ft. ³ /sec.)	Top Width (ft.)	Unit Water Discharge (ft. ³ /sec./ft.)	Velocity (ft. ² /sec.)	Average Depth (ft.)	Bank Full Discharge (ft.)	Multiplying Factor	Neill's Equation Scour Depth (ft.)	Mean Grain Size (mm)	Lacey's Silt Factor	Multiplying Factor	Lacey's Equation Scour Depth (ft.)	Blench's Zero Bed Factor (ft./sec.)	Multiplying Factor	Blench's Equation Scour Depth (ft.)	Maximum Scour Depth (ft.)	Minimum Toe Length Req. (ft.)	Toe Length Provided (ft.)
RVW10	R2	8.354	2285	211.88	11	7.08	1.5	2285	0.5	0.8	0.6	1.36	0.5	3.4	2.2	0.6	3.8	4	6.0	6.0
RVW10	R2	8.353	2285	139.91	16	4.27	3.8	2285	0.5	1.9	0.6	1.36	0.5	3.4	2.2	0.6	5.0	5	7.5	7.5
RVW10	R2	8.300	Culvert																	
RVW10	R2	8.135	2285	101.42	23	9.02	2.5	2285	0.5	1.2	0.6	1.36	0.5	3.4	2.2	0.6	6.2	6	9.0	9.0
RVW10	R2	8.134	2285	161.08	14	7.72	1.8	2285	0.5	0.9	0.6	1.36	0.5	3.4	2.2	0.6	4.6	5	7.5	7.5
RVW10	R3	7.984	3925	654.17	6	7.94	0.8	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	2.6	4	6.0	6.0
RVW10	R3	7.886	3925	655.86	6	8.91	0.7	3925	0.5	0.3	0.6	1.36	0.5	4.1	2.2	0.6	2.6	4	6.0	6.0
RVW10	R3	7.784	3925	777.07	5	5.44	0.9	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	2.3	4	6.0	6.0
RVW10	R3	7.678	3925	591.39	7	8.91	0.7	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	2.8	4	6.0	6.0
RVW10	R3	7.611	3925	659.92	6	6.06	1.0	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	2.6	4	6.0	6.0
RVW10	R3	7.596	3925	430.97	9	8.87	1.0	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.4	4	6.0	6.0
RVW10	R3	7.541	3925	690.82	6	9.78	0.6	3925	0.5	0.3	0.6	1.36	0.5	4.1	2.2	0.6	2.5	4	6.0	6.0
RVW10	R3	7.491	3925	460.96	9	9.44	0.9	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.3	4	6.0	6.0
RVW10	R3	7.450	3925	576.08	7	8.56	0.8	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	2.8	4	6.0	6.0
RVW10	R3	7.382	3925	574.19	7	9.94	0.7	3925	0.5	0.3	0.6	1.36	0.5	4.1	2.2	0.6	2.8	4	6.0	6.0
RVW10	R3	7.331	3925	516.62	8	9.58	0.8	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	3.0	4	6.0	6.0
RVW10	R3	7.283	3925	458.96	9	10.62	0.8	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	3.3	4	6.0	6.0
RVW10	R3	7.240	3925	408.82	10	10.13	0.9	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.5	4	6.0	6.0
RVW10	R3	7.215	3925	501.65	8	10.35	0.8	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	3.1	4	6.0	6.0
RVW10	R3	7.193	3925	441.41	9	4.83	1.8	3925	0.5	0.9	0.6	1.36	0.5	4.1	2.2	0.6	3.3	4	6.0	6.0
RVW10	R3	7.174	3925	455.70	9	7.91	1.1	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.3	4	6.0	6.0
RVW10	R3	7.155	3925	492.95	8	8.10	1.0	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.1	4	6.0	6.0
RVW10	R3	7.076	3925	665.71	6	8.20	0.7	3925	0.5	0.4	0.6	1.36	0.5	4.1	2.2	0.6	2.5	4	6.0	6.0
RVW10	R3	6.982	3925	502.03	8	8.09	1.0	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	3.1	4	6.0	6.0
RVW10	R3	6.977	3925	501.11	8	6.54	1.2	3925	0.5	0.6	0.6	1.36	0.5	4.1	2.2	0.6	3.1	4	6.0	6.0
RVW10	R3	6.849	3925	539.10	7	7.82	0.9	3925	0.5	0.5	0.6	1.36	0.5	4.1	2.2	0.6	2.9	4	6.0	6.0
RVW10	R3	6.697	3925	462.10	8	3.22	2.6	3925	0.5	1.3	0.6	1.36	0.5	4.1	2.2	0.6	3.2	4	6.0	6.0

Notes:
 See Exhibit 5 for cross section location
 See Appendix C (HEC RAS Model) for channel velocity
 Assume mean grain size to be 0.6 mm

Regime Equation (Pemberton and Lara, 1984)			
Condition	Value of Z		
	Neill $d_s = Z d_f$	Lacey $d_s = Z d_m$	Blench $d_s = Z d_{fo}$
<u>Equation Types A and B</u>			
Straight reach	0.5	0.25	} <u>1/</u> 0.6 1.25
Moderate bend	0.6	0.5	
Severe bend	0.7	0.75	
Right angle bends		1.0	
Vertical rock bank or wall		1.25	



"LEED®ing and Developing Smart Projects"

APPENDIX II

Preliminary Utility Plan

8280 E. Gelding Drive, Suite 101
Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com

APPENDIX

OWNER:
BRAUN ROBERT W TR
3625 E. MEADOW BROOK AVE.
PHOENIX, AZ 85018

CIVIL ENGINEER:
SUSTAINABILITY ENGINEERING GROUP
8280 E GELDING DR., SUITE 101
SCOTTSDALE, AZ 85260
PHONE: 480-588-7226
ATTN: ALI FAKIH




PRELIMINARY UTILITY PLAN

BRAUN 20 ACRES

NWC 132ND ST. & PINNACLE VISTA RD., SCOTTSDALE, AZ 85259

LEGEND

- PROPOSED HYDRANT
- PROPOSED VALVE
- PROPOSED REDUCER
- PROPOSED WATER SERVICE



NOTE TO CONTRACTOR:
THIS SET OF DRAWINGS AND DOCUMENTS IS INTENDED AS A SET OF GUIDELINES FOR THE PROJECT AND ARE INTENDED TO BE USED IN CONJUNCTION WITH A SET OF CONSTRUCTION SPECIFICATIONS TO BE SUPPLIED BY OWNER. THEY MUST BE READ TO INCORPORATE ALL APPLICABLE FEDERAL, STATE, AND LOCAL CODES AND CONSTRUCTION SPECIFICATIONS. THE SET ASSUMES THAT THERE ARE NO UNUSUAL SOIL CONDITIONS OR WIND LOADS. THE FAILURE OF THIS CONSTRUCTION MAY REQUIRE REPAIRS AND CHANGES TO THESE DOCUMENTS. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COMPLY WITH ALL APPLICABLE CODES AND TO INFORM THE OWNER/ARCHITECTS OF ANY QUESTIONS OR CLARIFICATIONS WHICH ARE REQUIRED. CONTRACTORS SHALL ALSO VISIT THE SITE BEFORE BEGINNING. CONTRACTORS ARE REQUIRED TO KNOW ALL OBSERVABLE CONDITIONS AND APPLICABLE CODES.

NOT FOR
CONSTRUCTION

SUSTAINABILITY
ENGINEERING
GROUP

SEG



LAND DEVELOPMENT
SERVICES

PROJECT
BRAUN 131ST SCOTTSDALE
RESIDENTIAL DEVELOPMENT

LOCATION
NWC 132ND STREET AND PINNACLE
VISTA RD.
SCOTTSDALE, AZ 85259

DRAWN: TAPIA
DESIGNED: TAPIA
CHECKED: COUNSELL
PROJ. MGR: MALONEY

DATE: 07-27-17

ISSUED FOR: ZONING

REVISION NO.:	DATE:
1	
2	
3	

JOB NO.: 170601

SHEET TITLE:

PRELIMINARY
UTILITY PLAN

SHEET NO.: C4.00

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.