

Drainage Reports

Abbreviated Water & Sewer Need Reports

Water Study

Wastewater Study

Stormwater Waiver Application

**FINAL BASIS OF DESIGN REPORT
for
WATER AND SEWER SERVICE**

TSG FOUNDATION

SWC OF STAGECOACH PASS ROAD AND PIMA ROAD

Scottsdale, AZ

Prepared For:

**Orcutt Winslow
2929 N Central Ave,
Phoenix, AZ 85012
602.257.1764**



Prepared by:



**Sustainability Engineering Group
8280 E. Gelding Drive, Suite 101
Scottsdale, AZ 85260
480.588.7226 www.azSEG.com**

Project Number: 180333

Date Submitted: 04-08-2019

Pre-Ap No.: 513-PA-2017; 50-DR-2018

Plan Check No.: TBD

**50-DR-2018
4/8/2019**




Table of Contents

1. EXECUTIVE SUMMARY.....	1
2. INTRODUCTION	1
2.1 PLAN OBJECTIVE:	1
2.2 SITE LOCATION	1
2.3 PROPOSED DEVELOPMENT.....	2
3. DESIGN CRITERIA	2
3.1 DEVELOPMENT CRITERIA.....	2
4.1 PROPOSED DEMANDS	2
4.2 WATER ZONE	3
4.3 PHASING OF PROJECT.....	3
4.4 SUMMARY NARRATIVE OF DEMANDS.....	3
5. PROPOSED INFRASTRUCTURE	3
5.1 WATER DISTRIBUTION SYSTEM	3
5.2 SEWER COLLECTION SYSTEM.....	3
5.3 MAINTENANCE AND OWNERSHIP.....	4
6. WATER COMPUTATIONS	4
6.1 DESCRIPTION OF MODEL.....	4
7. SEWER COMPUTATIONS.....	4
7.1 DESCRIPTION	4
8. SUMMARY / CONCLUSIONS	4
9. REFERENCES	4
10. EXHIBITS:.....	4

1. EXECUTIVE SUMMARY

The proposed development consists of 13 acres of residential land located at the Southwest corner of Stagecoach Pass Road and Pima Road. The Site is bounded by:

- Adjoining neighboring property owners at the west and south boundaries
- North Pima Road to the east
- East Stagecoach Pass Road to the north

Refer to **EXHIBIT 1 – Vicinity Map.**

The property is presently zoned R1-35 ESL.

Located within the City of Scottsdale corporate boundary, this site will receive domestic water and fire service from the City of Scottsdale by connecting to a 12" PVC water line in East Stagecoach Pass, west of an existing PRV near the intersection with Pima Road.

Sanitary sewer service will be provided by a connection to the 21" PVC sewer line in Pima Road with a new manhole.

An existing well in the property will be utilized for domestic and supplemental irrigation water service. Water quality testing is presently being completed.

All water and sewer improvements will be designed and constructed to the most recent City of Scottsdale and MCESD design standards and policies.

2. INTRODUCTION

2.1 PLAN OBJECTIVE:

The purpose of this report is to provide information and calculations defining the water and sewer system design. Preparation of this report has been done in accordance with Chapters 6 and Chapter 7 of the City's Design Standards & Policies Manual.

2.2 SITE LOCATION

The 13.04 acres of the subject property consists of a public R.O.W and thirteen separate but contiguous parcels whose APN's are:

- 216-34-316 (Lot 1)
- 216-34-317 (Lot 2)
- 216-34-318 (Lot 3)
- 216-34-319 (Lot 4)
- 216-34-320 (Lot 5)
- 216-34-326 (Lot 11)
- 216-34-327 (Tract A)
- 216-34-328 (Lot B)
- 216-34-321 (Lot 6)
- 216-34-322 (Lot 7)
- 216-34-323 (Lot 8)
- 216-34-324 (Lot 9)
- 216-34-325 (Lot 10)

2.3 PROPOSED DEVELOPMENT

2.3.1 Existing Site Description:

This site is open desert land with one single structure and generally slopes from the northeast (elevation 2,564 +/-) to the southwest (elevation 2,531 +/-) at approximately 3.5% with a change in elevation of 33 feet.

The City of Scottsdale Water & Sewer Quarter Section Map (60-48) shows water mains and Sewer lines in East Stagecoach Pass and North Pima Rd as follows:

- A 12" PVC water main exists in East Stagecoach Pass, 32' South of the road center line.
- An 8" ACP in East Stagecoach Pass 4' north of the road centerline, owned by Carefree Water Company.
- A 10" TYP UNK in East Stagecoach Pass 12' south of the road centerline, owned by Carefree Water Company.
- An 8" TYP UNK RWDS Non-portable water line exists in East Stagecoach Pass, 25' south to the road centerline.
- A 16" TYP UNK potable water main exists to the east in North Pima Road, 20' west of the road centerline.
- A 24" SCP potable water line exists to the east in North Pima Road, 81' east of the road centerline.
- 12" DIP Non-portable water line, 12" TYP UNK Non-portable water line, and 16" TYP UNK Non-portable water line exist to the east in North Pima Road, 50', 32', and 15' east to the road centerline.
- A 21" PVC gravity sewer main exists to the east in North Pima Road, 48' east of the road centerline.

Refer to **EXHIBIT 2** for the COS Water Quarter Section Map (60-48).

2.3.2 Proposed Site Development:

The existing site will be re-platted and developed with a new building for office use and a parking lot. Refer to **EXHIBIT 3** for the Site Plan.

3. DESIGN CRITERIA

3.1 DEVELOPMENT CRITERIA

Proposed zoning: R1-35 ESL

Acreage: 13.04

Demands, system layout, system pressures, velocities, head losses for fire flow will all be in accordance with the City's DS&PM (References 2 and 3 in Sec. 11).

A 1,500 gpm system fire flow demand will be utilized in hydraulic calculations.4. DEMANDS

4.1 PROPOSED DEMANDS

Refer to the tables below for the proposed (R1-35 ESL PRD) water and sewer demand calculations in gallons per minute based on design criteria in the City's DS&PM.

Table 1: WATER DEMAND CALCULATIONS

	Area (sf)	Avg. Day Demand (GPM/SF)	Max Day Peaking Factor	Peak Hour Peaking Factor	Avg. Day Demand (GPM)	Max. Day Demand (GPM)	Peak Hour Demand (GPM)
Office	14,588	8.34E-04	2	3.5	12	24	43

Table 2 - SEWER DEMAND CALCULATIONS

	Area (sf)	Avg. Day Demand (gal/day/sf)	Avg. Day Demand (GPD)	Peaking Factor	Peak Flow (GPM)
Office	14,588	0.4	5,835	3	12

4.2 WATER ZONE

According to the City of Scottsdale DS&PM Sec. 6-1, the site is within Zone 11N.

4.3 PHASING OF PROJECT

Currently, the project is anticipated to be constructed in a single phase. Should this change, later reports will be updated and submitted for review. Final Basis of Design Reports must be accepted by the Water Resources Department prior to the submittal of improvement plans to the City's 1-Stop Shop.

4.4 SUMMARY NARRATIVE OF DEMANDS

- The max day + fire flow scenario will govern the water system design.
- No offsite sewer flow impacts this site.

5. PROPOSED INFRASTRUCTURE

5.1 WATER DISTRIBUTION SYSTEM

This project proposes to construct approximately 375 LF of 8" DIP connecting to the 12" line in East Stagecoach Pass. Refer to **EXHIBIT 3** for the proposed site and utility plan. A fire hydrant will terminate the extension. Metered service and the building fire line will be tapped off the new 8" water line.

5.2 SEWER COLLECTION SYSTEM

A 8"/6" sanitary sewer service will connect the building to the 21" PVC sewer main in Pima Road. A new manhole will need to be constructed over the existing sewer. The first reach of pipe will be 8" between two manholes to minimize any future impact to the desert floor. The service will be 6" under the drive with cleanouts at 100' on-center.

Falling topography does not support extension of public sewer along the site's Stagecoach Pass frontage. A public sewer to 8603 E. Stagecoach Pass has been extended to the southwest corner of that parcel which can provide future service.

5.3 MAINTENANCE AND OWNERSHIP

The water line is proposed as public to be owned and maintained by the City and is located within a 20-foot wide water easement. The sanitary sewer service is private and will be maintained by the owner. The new manhole will be public, owned and maintained by the City.

6. WATER COMPUTATIONS

6.1 DESCRIPTION OF MODEL

The new water system will be designed to meet the criteria of COS Water, the Arizona Department of Environmental Quality ("ADEQ"), and Maricopa County Environmental Services Department ("MCESD").

Bentley WaterCAD® Version 8i was used to model the water extension and demand scenarios. A current fire hydrant flow test is included in **EXHIBIT 4**. The results of water modeling are included in **EXHIBIT 5**.

7. SEWER COMPUTATIONS

7.1 DESCRIPTION

A 8" PVC sewer service at 1.5% grade will convey the peak 12 gpm flow to Pima Road at 1.6 fps with a normal depth of 0.7". The hydraulic radius is 0.47". At $d/D = 0.65$ the 8" service pipe has a capacity of 502.4 gpm at 4.7 fps. The full flow capacity is 664 gpm at 4.2 fps.

A 6" PVC sewer service at 2% grade will convey the peak 12 gpm flow to Pima Road at 1.9 fps with a normal depth of 0.8". The hydraulic radius is 0.47". At $d/D = 0.65$ the 6" service pipe has a capacity of 269 gpm at 4.4 fps. The full flow capacity is 356 gpm at 4.0 fps.

Reference **EXHIBIT 6**.

8. SUMMARY / CONCLUSIONS

- Sufficient city water supply is available to support the project's domestic and fire flow demand.
- Sufficient city sewer capacity is available to support the project.
- An existing onsite well will be utilized for irrigation service.

9. REFERENCES

1. COS QS numbers 60-48, 61-49
2. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 6 – Water).
3. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 7 – Wastewater)

10. EXHIBITS:

- | | | |
|-----------|---|-------------------------------|
| EXHIBIT 1 | - | VICINITY MAP – CONTEXT AERIAL |
| EXHIBIT 2 | - | Q-S MAPS 60-48, 61-49 |
| EXHIBIT 3 | - | Utility Plan |
| EXHIBIT 4 | - | Fire Hydrant Flow Test |
| EXHIBIT 5 | - | Water Modeling |
| EXHIBIT 6 | - | Sewer Service Calculation |



"LEED®ing and Developing Smart Projects"

EXHIBIT 1

Vicinity Map

*8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260*

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com



N.T.S

FIGURE 1
VICINITY MAP



"LEED®ing and Developing Smart Projects"


EXHIBIT 2

Q-S Map

*8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260*

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com



62-49

THE CITY OF SCOTTSDALE

N o t i c e

THIS DOCUMENT IS PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.

卷之三

21-OCT-18


61-48

60-49

LEGEND:

- | | |
|-------------------------------------|--|
| Water Valve | |
| Non-potable Water Valve | |
| Fire Hydrant | |
| Water Blowoff | |
| Water Main Reducer | |
| Water Sample Station | |
| Water Air Release Valve | |
| Non-potable Water Air Release Valve | |
| Water Pressure Reducing Valve | |
| Water Vault | |
| Water Manhole | |
| Non-Potable Water Manhole | |
| Water Pump | |
| Water Main | |
| Non-Potable Water Main | |
| Wire Line | |
| Water Service | |
| Non-Scottsdale Water Main | |
| Sewer Manhole | |
| Sewer Cleanout | |
| Sewer Lift Station | |
| Sewer Treatment Plant | |
| Sewer Main - Gravity | |
| Sewer Main - Force | |
| Non-Scottsdale Sewer Main | |
| Sewer Service | |

VICINITY MAP



WATER & SEWER

W 1/4 SEC. 31 T6N R5E

10.000-15.000 m²



"LEED®ing and Developing Smart Projects"




EXHIBIT 3

Preliminary Utility Plans

*8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260*

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com



45621
CERTIFICATE NO.
ALI SAMIH
FAKIH
Date Signed: 04-02-2019
ARIZONA, U.S.A.




orcutt|winslow

8280 E. GELDING DRIVE SUITE 101, SCOTTSDALE, ARIZONA 85260
WWW.AZSEG.COM TEL: 480.588.7228 FAX: 480.259.3534

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.

C4.11



VICINITY MAP
(NTS)



LEGEND:	
PROPERTY LINE	- - -
8"W WATER LINE	—
6"S SEWER LINE	—
-2250- EXISTING 5' CONTOUR	—
50 PROPOSED 5' CONTOUR	—
WATER EASEMENT	—
FIRE HYDRANT	●
WATER VALVE	○
WATER METER	■
REDUCER	▲
BACKFLOW PREVENTER	◆

SEWER CONSTRUCTION NOTES

- [1] FURNISH AND INSTALL 6" PVC-SDR 35 SEWER LINE CONNECTION PER M.A.G. STD. DET. 440-3. S=2% MINIMUM.
- [3] FURNISH AND INSTALL CLEAN-OUT PER C.O.S. STD. DTL 2403.

SEG SUSTAINABILITY
ENGINEERING GROUP



orcutt | winslow

8280 E. GELDING DRIVE SUITE 101, SCOTTSDALE, ARIZONA 85260
WWW.AZSEG.COM TEL: 480.588.7226 FAX: 480.289.3534



THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.

PROJECT	TSS FOUNDATION CENTER FOR SPIRITUAL DEVELOPMENT
LOCATION	SNC OF E. STAGECOACH PASS AND N. PINA RD.
DRAWN	BEGELL
DESIGNED	BEGELL
CHECKED	COUNSELL
PROJ. MGR.	FAKIH
DATE:	04/02/2019
ISSUED FOR:	DRB
REVISION NO.:	DATE:
JOB NO.:	180333
SHEET TITLE:	UTILITY PLAN 2
SHEET NO.:	C4.12



MATCHLINE REFER TO C4.11 SHEET 9

MATCHLINE REFER TO C4.12 SHEET #



SUSTAINABILITY
ENGINEERING
GROUP

82280 E. GELDING DRIVE SUITE 101, SCOTTSDALE, ARIZONA 85260
WWW. AZSEG.COM TEL. 480.588.7226 FAX 480.259.3534



orcutt | winslow

PROJECT			
TSG FOUNDATION CENTER FOR SPIRITUAL DEVELOPMENT		LOCATION	
DRAWN	BEGELL	SWC OF E. STAGECOACH PASS AND N. PIMA RD.	
DESIGNED	BEGELL		
CHECKED	COUNSELL		
PROJ. MGR.	FAKIH		
DATE:		04/02/2019	
SUED FOR:		DRB	
VISION NO.:		DATE:	
<input type="checkbox"/>			
JOB NO.:		180333	
SHEET TITLE:			
UTILITY PLAN 3			
SHEET NO.:			
C4.13			

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.



"LEED®ing and Developing Smart Projects"

EXHIBIT 4

Fire Hydrant Flow Test

*8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260*

Sustainability Engineering Group info@azSEG.com 480.588.7226 www.azSEG.com

Arizona Flow Testing LLC

HYDRANT FLOW TEST REPORT

Project Name: TSG
Project Address: Pima & Stagecoach Pass (SWC), Scottsdale, Arizona 85262
Arizona Flow Testing Project No.: 19051
Client Project No.: Not Provided
Flow Test Permit No.: C57398
Date and time flow test conducted: February 21, 2019 at 8:30 AM
Data is current and reliable until: August 21, 2019
Conducted by: Floyd Vaughan - Arizona Flow Testing, LLC (480-250-8154)
Witnessed by: Phil Cipolla - City of Scottsdale-Inspector (602-828-0847)

Raw Test Data

Static Pressure: **80.0 PSI**
(Measured in pounds per square inch)

Residual Pressure: **72.0 PSI**
(Measured in pounds per square inch)

Pitot Pressure: **23.0 PSI**
(Measured in pounds per square inch)

Diffuser Orifice Diameter: 4 Inch Hose Monster
(Measured in inches)

Coefficient of Diffuser: 0.7875

Flowing GPM: **1,803 GPM**
(Measured in gallons per minute)

GPM @ 20 PSI: **5,353 GPM**

Data with 10% Safety Factor

Static Pressure: **72.0 PSI**
(Measured in pounds per square inch)

Residual Pressure: **64.0PSI**
(Measured in pounds per square inch)

Distance between hydrants: Approx. 1,060 feet


Main size: Not Provided

Flowing GPM: **1,803 GPM**

GPM @ 20 PSI: **4,955 GPM**

Flow Test Location

North ↑





"LEED®ing and Developing Smart Projects"

EXHIBIT 5

Model Output

8280 E. Gelding Dr., Suite 101

Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com




EXHIBIT 5 – MODEL MAP

8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com

EXHIBIT

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,698.00	60
J-2	2,553.00	0	2,698.00	63
J-5	2,552.00	0	2,698.00	63
J-6	2,556.55	0	2,698.00	61
J-7	2,554.00	0	2,698.00	62
J-8	2,555.00	12	2,698.00	62
J-9	2,555.00	0	2,698.00	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	12	0.08
P-2	8.0	33	130.0	12	0.08
P-3	8.0	123	130.0	12	0.08
P-4	12.0	1,120	150.0	12	0.03
P-5	16.0	25	130.0	12	0.02
P-8	8.0	78	130.0	12	0.08
P-9	8.0	39	130.0	12	0.08
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,698.00	12	166.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	12	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,697.99	60
J-2	2,553.00	0	2,697.99	63
J-5	2,552.00	0	2,697.99	63
J-6	2,556.55	0	2,697.99	61
J-7	2,554.00	0	2,697.99	62
J-8	2,555.00	24	2,697.98	62
J-9	2,555.00	0	2,697.98	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	24	0.15
P-2	8.0	33	130.0	24	0.15
P-3	8.0	123	130.0	24	0.15
P-4	12.0	1,120	150.0	24	0.07
P-5	16.0	25	130.0	24	0.04
P-8	8.0	78	130.0	24	0.15
P-9	8.0	39	130.0	24	0.15
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,697.99	24	165.99

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	24	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,697.97	60
J-2	2,553.00	0	2,697.97	63
J-5	2,552.00	0	2,697.96	63
J-6	2,556.55	0	2,697.96	61
J-7	2,554.00	0	2,697.96	62
J-8	2,555.00	43	2,697.95	62
J-9	2,555.00	0	2,697.95	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	43	0.27
P-2	8.0	33	130.0	43	0.27
P-3	8.0	123	130.0	43	0.27
P-4	12.0	1,120	150.0	43	0.12
P-5	16.0	25	130.0	43	0.07
P-8	8.0	78	130.0	43	0.27
P-9	8.0	39	130.0	43	0.27
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,697.98	43	165.98

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	43	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD+Fire****Fire Flow Node FlexTable: Fire Flow Report**

Label	Needed Fire Flow (gpm)	MD + Needed Flow (gpm)	Calculated Pressure at Junction (psi)	Total Available Flow at 20 psi (gpm)	Junction w/ Minimum Pressure	Junction Pressure) (psi)	Pipe w/ Maximum Velocity	Pipe Velocity (ft/s)
J-1	1,500	1,500	51	1,501	J-6	53	P-4	4.33
J-2	1,500	1,500	52	1,501	J-6	51	P-3	9.73
J-5	1,500	1,500	52	1,501	J-6	50	P-3	9.73
J-6	1,500	1,500	49	1,501	J-9	50	P-3	9.73
J-7	1,500	1,500	49	1,501	J-9	49	P-8	9.73
J-8	1,500	1,524	48	1,525	J-9	48	P-9	9.73
J-9	1,500	1,500	47	1,501	J-8	48	P-9	9.73



"LEED®ing and Developing Smart Projects"

EXHIBIT 6

Sewer Service Calculation

8280 E. Gelding Dr., Suite 101

Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com

8" Pipe - Peak Flow

Project Description

Friction Method Manning Formula
 Solve For Normal Depth

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Diameter	8 in
Discharge	12.0 gal/min

Results

Normal Depth	0.74 in
Flow Area	0.02 ft ²
Wetted Perimeter	0.41 ft
Hydraulic Radius	0.47 in
Top Width	0.39 ft
Critical Depth	0.07 ft
Percent Full	9.3 %
Critical Slope	0.00743 ft/ft
Velocity	1.64 ft/s
Velocity Head	0.04 ft
Specific Energy	0.10 ft
Froude Number	1.40
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.00000 ft/ft
Flow Type	SuperCritical



8" Pipe - d/D = 0.65

Project Description

Friction Method Manning Formula
Solve For Discharge

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Normal Depth	5.20 in
Diameter	8 in

Results

Discharge	502.4 gal/min
Flow Area	0.24 ft ²
Wetted Perimeter	1.25 ft
Hydraulic Radius	0.31 in
Top Width	0.64 ft
Critical Depth	0.50 ft
Percent Full	65.0 %
Critical Slope	0.01023 ft/ft
Velocity	4.66 ft/s
Velocity Head	0.34 ft
Specific Energy	0.77 ft
Froude Number	1.34
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.00858 ft/ft
Flow Type	SuperCritical

8" Pipe - Full Flow Capacity

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Normal Depth	8.00 in
Diameter	8 in
Discharge	664.2 gal/min

Results

Discharge	664.2 gal/min
Normal Depth	8.00 in
Flow Area	0.35 ft ²
Wetted Perimeter	2.09 ft
Hydraulic Radius	2.00 in
Top Width	0.00 ft
Critical Depth	0.57 ft
Percent Full	100.0 %
Critical Slope	0.01402 ft/ft
Velocity	4.24 ft/s
Velocity Head	0.28 ft
Specific Energy	0.95 ft
Froude Number	0.00
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.01500 ft/ft
Flow Type	SubCritical



SEG

“LEED®ing and Developing Smart Projects”

6" Pipe - Peak Flow

Project Description

Friction Method **Manning Formula**
Solve For **Normal Depth**

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Diameter	6 in
Discharge	12.0 gal/min

Results

Normal Depth	0.75	in
Flow Area	0.01	ft ²
Wetted Perimeter	0.36	ft
Hydraulic Radius	0.47	in
Top Width	0.33	ft
Critical Depth	0.08	ft
Percent Full	12.6	%
Critical Slope	0.00760	ft/ft
Velocity	1.87	ft/s
Velocity Head	0.05	ft
Specific Energy	0.12	ft
Froude Number	1.59	
Maximum Discharge	383.10	gal/min
Discharge Full	356.1	gal/min
Slope Full	0.00002	ft/ft
Flow Type	SuperCritical	

6" Pipe - d/D = 0.65

Project Description

Friction Method Manning Formula
 Solve For Discharge

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Normal Depth	3.90 in
Diameter	6 in

Results

Discharge	269.4 gal/min
Flow Area	0.14 ft ²
Wetted Perimeter	0.94 ft
Hydraulic Radius	1.73 in
Top Width	0.48 ft
Critical Depth	0.39 ft
Percent Full	65.0 %
Critical Slope	0.01234 ft/ft
Velocity	4.44 ft/s
Velocity Head	0.31 ft
Specific Energy	0.63 ft
Froude Number	1.47
Maximum Discharge	383.10 gal/min
Discharge Full	356.1 gal/min
Slope Full	0.01144 ft/ft
Flow Type	SuperCritical

6" Pipe - Full Flow Capacity

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Normal Depth	6.00 in
Diameter	6 in
Discharge	356.1 gal/min

Results

Discharge	356.1 gal/min
Normal Depth	6.00 in
Flow Area	0.20 ft ²
Wetted Perimeter	1.57 ft
Hydraulic Radius	1.50 in
Top Width	0.00 ft
Critical Depth	0.44 ft
Percent Full	100.0 %
Critical Slope	0.01788 ft/ft
Velocity	4.04 ft/s
Velocity Head	0.25 ft
Specific Energy	0.75 ft
Froude Number	0.00
Maximum Discharge	383.10 gal/min
Discharge Full	356.1 gal/min
Slope Full	0.02000 ft/ft
Flow Type	SubCritical

**FINAL BASIS OF DESIGN REPORT
for
WATER AND SEWER SERVICE**


TSG FOUNDATION

SWC OF STAGECOACH PASS ROAD AND PIMA ROAD

Scottsdale, AZ

Prepared For:

**Orcutt Winslow
2929 N Central Ave,
Phoenix, AZ 85012
602.257.1764**



Prepared by:



**Sustainability Engineering Group
8280 E. Gelding Drive, Suite 101
Scottsdale, AZ 85260
480.588.7226 www.azSEG.com**

Project Number: 180333

Date Submitted: 04-08-2019

Pre-Ap No.: 513-PA-2017; 50-DR-2018

Plan Check No.: TBD

**50-DR-2018
4/8/2019**




Table of Contents

1. EXECUTIVE SUMMARY.....	1
2. INTRODUCTION	1
2.1 PLAN OBJECTIVE.....	1
2.2 SITE LOCATION.....	1
2.3 PROPOSED DEVELOPMENT.....	2
3. DESIGN CRITERIA.....	2
3.1 DEVELOPMENT CRITERIA.....	2
4.1 PROPOSED DEMANDS	2
4.2 WATER ZONE	3
4.3 PHASING OF PROJECT.....	3
4.4 SUMMARY/NARRATIVE OF DEMANDS.....	3
5. PROPOSED INFRASTRUCTURE.....	3
5.1 WATER DISTRIBUTION SYSTEM	3
5.2 SEWER COLLECTION SYSTEM.....	3
5.3 MAINTENANCE AND OWNERSHIP.....	4
6. WATER COMPUTATIONS	4
6.1 DESCRIPTION OF MODEL.....	4
7. SEWER COMPUTATIONS.....	4
7.1 DESCRIPTION.....	4
8. SUMMARY/ CONCLUSIONS	4
9. REFERENCES.....	4
10. EXHIBITS.....	4

1. EXECUTIVE SUMMARY

The proposed development consists of 13 acres of residential land located at the Southwest corner of Stagecoach Pass Road and Pima Road. The Site is bounded by:

- Adjoining neighboring property owners at the west and south boundaries
- North Pima Road to the east
- East Stagecoach Pass Road to the north

Refer to **EXHIBIT 1 – Vicinity Map.**

The property is presently zoned R1-35 ESL.

Located within the City of Scottsdale corporate boundary, this site will receive domestic water and fire service from the City of Scottsdale by connecting to a 12" PVC water line in East Stagecoach Pass, west of an existing PRV near the intersection with Pima Road.

Sanitary sewer service will be provided by a connection to the 21" PVC sewer line in Pima Road with a new manhole.

An existing well in the property will be utilized for domestic and supplemental irrigation water service. Water quality testing is presently being completed.

All water and sewer improvements will be designed and constructed to the most recent City of Scottsdale and MCESD design standards and policies.

2. INTRODUCTION

2.1 PLAN OBJECTIVE:

The purpose of this report is to provide information and calculations defining the water and sewer system design. Preparation of this report has been done in accordance with Chapters 6 and Chapter 7 of the City's Design Standards & Policies Manual.

2.2 SITE LOCATION

The 13.04 acres of the subject property consists of a public R.O.W and thirteen separate but contiguous parcels whose APN's are:

- 216-34-316 (Lot 1)
- 216-34-317 (Lot 2)
- 216-34-318 (Lot 3)
- 216-34-319 (Lot 4)
- 216-34-320 (Lot 5)
- 216-34-326 (Lot 11)
- 216-34-327 (Tract A)
- 216-34-328 (Lot B)
- 216-34-321 (Lot 6)
- 216-34-322 (Lot 7)
- 216-34-323 (Lot 8)
- 216-34-324 (Lot 9)
- 216-34-325 (Lot 10)

2.3. PROPOSED DEVELOPMENT

2.3.1 Existing Site Description:

This site is open desert land with one single structure and generally slopes from the northeast (elevation 2,564 +/-) to the southwest (elevation 2,531 +/-) at approximately 3.5% with a change in elevation of 33 feet.

The City of Scottsdale Water & Sewer Quarter Section Map (60-48) shows water mains and Sewer lines in East Stagecoach Pass and North Pima Rd as follows:

- A 12" PVC water main exists in East Stagecoach Pass, 32' South of the road centerline.
- An 8" ACP in East Stagecoach Pass 4' north of the road centerline, owned by Carefree Water Company.
- A 10" TYP UNK in East Stagecoach Pass 12' south of the road centerline, owned by Carefree Water Company.
- An 8" TYP UNK RWDS Non-portable water line exists in East Stagecoach Pass, 25' south to the road centerline.
- A 16" TYP UNK potable water main exists to the east in North Pima Road, 20' west of the road centerline.
- A 24" SCP potable water line exists to the east in North Pima Road, 81' east of the road centerline.
- 12" DIP Non-portable water line, 12" TYP UNK Non-portable water line, and 16" TYP UNK Non-portable water line exist to the east in North Pima Road, 50', 32', and 15' east to the road centerline.
- A 21" PVC gravity sewer main exists to the east in North Pima Road, 48' east of the road centerline.

Refer to EXHIBIT 2 for the COS Water Quarter Section Map (60-48).

2.3.2 Proposed Site Development:

The existing site will be re-platted and developed with a new building for office use and a parking lot. Refer to EXHIBIT 3 for the Site Plan.

3. DESIGN CRITERIA

3.1 DEVELOPMENT CRITERIA

Proposed zoning: R1-35 ESL

Acreage: 13.04

Demands, system layout, system pressures, velocities, head losses for fire flow will all be in accordance with the City's DS&PM (References 2 and 3 in Sec. 11).

A 1,500 gpm system fire flow demand will be utilized in hydraulic calculations.

4.1 PROPOSED DEMANDS

Refer to the tables below for the proposed (R1-35 ESL PRD) water and sewer demand calculations in gallons per minute based on design criteria in the City's DS&PM.

Table 1: WATER DEMAND CALCULATIONS

	Area (sf)	Avg. Day Demand (GPM/SF)	Max Day Peaking Factor	Peak Hour Peaking Factor	Avg. Day Demand (GPM)	Max. Day Demand (GPM)	Peak Hour Demand (GPM)
Office	14,588	8.34E-04	2	3.5	12	24	43

Table 2 - SEWER DEMAND CALCULATIONS

	Area (sf)	Avg. Day Demand (gal/day/sf)	Avg. Day Demand (GPD)	Peaking Factor	Peak Flow (GPM)
Office	14,588	0.4	5,835	3	12

4.2 WATER ZONE

According to the City of Scottsdale DS&PM Sec. 6-1, the site is within Zone 11N.

4.3 PHASING OF PROJECT

Currently, the project is anticipated to be constructed in a single phase. Should this change; later reports will be updated and submitted for review. Final Basis of Design Reports must be accepted by the Water Resources Department prior to the submittal of improvement plans to the City's 1-Stop Shop.

4.4 SUMMARY NARRATIVE OF DEMANDS

- The max day + fire flow scenario will govern the water system design;
- No offsite sewer flow impacts this site;

5. PROPOSED INFRASTRUCTURE

5.1 WATER DISTRIBUTION SYSTEM

This project proposes to construct approximately 375 LF of 8" DIP connecting to the 12" line in East Stagecoach Pass. Refer to EXHIBIT 3 for the proposed site and utility plan. A fire hydrant will terminate the extension. Metered service and the building fire line will be tapped off the new 8" water line.

5.2 SEWER COLLECTION SYSTEM

A 8"/6" sanitary sewer service will connect the building to the 21" PVC sewer main in Pima Road. A new manhole will need to be constructed over the existing sewer. The first reach of pipe will be 8" between two manholes to minimize any future impact to the desert floor. The service will be 6" under the drive with cleanouts at 100' on-center.

Falling topography does not support extension of public sewer along the site's Stagecoach Pass frontage. A public sewer to 8603 E. Stagecoach Pass has been extended to the southwest corner of that parcel which can provide future service.



5.3 MAINTENANCE AND OWNERSHIP

The water line is proposed as public to be owned and maintained by the City and is located within a 20-foot wide water easement. The sanitary sewer service is private and will be maintained by the owner. The new manhole will be public, owned and maintained by the City.

6. WATER COMPUTATIONS

6.1 DESCRIPTION OF MODEL

The new water system will be designed to meet the criteria of COS Water, the Arizona Department of Environmental Quality ("ADEQ"), and Maricopa County Environmental Services Department ("MCESD").

Bentley WaterCAD® Version 8i was used to model the water extension and demand scenarios. A current fire hydrant flow test is included in **EXHIBIT 4**. The results of water modeling are included in **EXHIBIT 5**.

7. SEWER COMPUTATIONS

7.1 DESCRIPTION

A 8" PVC sewer service at 1.5% grade will convey the peak 12 gpm flow to Pima Road at 1.6 fps with a normal depth of 0.7". The hydraulic radius is 0.47". At d/D = 0.65 the 8" service pipe has a capacity of 502.4 gpm at 4.7 fps. The full flow capacity is 664 gpm at 4.2 fps.

A 6" PVC sewer service at 2% grade will convey the peak 12 gpm flow to Pima Road at 1.9 fps with a normal depth of 0.8". The hydraulic radius is 0.47". At d/D = 0.65 the 6" service pipe has a capacity of 269 gpm at 4.4 fps. The full flow capacity is 356 gpm at 4.0 fps.

Reference **EXHIBIT 6**.

8. SUMMARY / CONCLUSIONS

- Sufficient city water supply is available to support the project's domestic and fire flow demand.
- Sufficient city sewer capacity is available to support the project.
- An existing onsite well will be utilized for irrigation service.

9. REFERENCES

1. COS QS numbers 60-48, 61-49
2. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 6 – Water).
3. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 7 – Wastewater)

10. EXHIBITS:

- | | |
|-----------|-------------------------------|
| EXHIBIT 1 | VICINITY MAP – CONTEXT AERIAL |
| EXHIBIT 2 | Q-S MAPS 60-48, 61-49 |
| EXHIBIT 3 | Utility Plan |
| EXHIBIT 4 | Fire Hydrant Flow Test |
| EXHIBIT 5 | Water Modeling |
| EXHIBIT 6 | Sewer Service Calculation |



"LEED®ing and Developing Smart Projects"

EXHIBIT 1

Vicinity Map

8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260

info@azSEG.com 480.588.7226 www.azSEG.com



N.T.S

FIGURE 1
VICINITY MAP



"LEED®ing and Developing Smart Projects"

EXHIBIT 2

Q-S Map

8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260


Sustainability Engineering Group info@azSEG.com 480.588.7226 www.azSEG.com

GENERAL NOTES:
 • THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE GIS DEPARTMENT AT (480) 312-7780.
 • THE SURVEY LINE BEARINGS AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER, 1991. BEARINGS ARE IN 3D GRID AND DISTANCES ARE FLATTENED TO GROUND WHERE NO CORNER WAS FOUND. THE DIMENTIONS ARE IN FEET AND ARE NOT TO SCALE. COORDINATES ARE NOTED AS CALCULATED ON THE MAP.

LEGEND:

Water Valve	⊗
Non-potable Water Valve	⊗
Fire Hydrant	⊗
Water Blowoff	⊗
Water Main Reducer	⊗
Water Sample Station	⊗
Water Air Release Valve	⊗
Non-potable Water Air Release Valve	⊗
Water Pressure Reducing Valve	⊗
Water Vault	⊗
Water Manhole	⊗
Non-Potable Water Manhole	⊗
Water Pump	⊗
Water Main	—
Non-Potable Water Main	—
Fire Line	—
Water Service	—
Non-Scottsdale Water Main	—
Sewer Manhole	⊗
Sewer Cleanout	⊗
Sewer Lift Station	⊗
Sewer Treatment Plant	⊗
Sewer Main - Gravity	—
Sewer Main - Force	—
Non-Scottsdale Sewer Main	—
Sewer Service	—

VICINITY MAP




SCALE: 1" = 100'
 The map scale of 1" = 100' is based on a full size print of 30" x 36".

WATER & SEWER QUARTER SECTION MAP

60-48

NE 1/4 SEC. 1 T5N R4E





SEG

"LEED®ing and Developing Smart Projects"

EXHIBIT 4

Fire Hydrant Flow Test

8280 E. Gelding Dr., Suite 101

Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com

62-49

61-48

60-49

NOTICE
PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF
SCOTTSDALE WARRANTS ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY
PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.

THE CITY OF SCOTTSDALE

N O T I C E

THIS DOCUMENT IS PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.

THE CITY OF SCOTTSDALE

100

卷之三


GENERAL NOTES:

- THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE GIS DEPARTMENT AT (480) 312-7792.
- THE SECTION LINE BEARING AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER, 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTENED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS 'CALCULATED' ON THE MAP.

LEGEND:

- | | |
|-------------------------|--|
| Water Valve | |
| nt | |
| off | |
| n Reducer | |
| ple Station | |
| Release Valve | |
| Water Air Release Valve | |
| sure Reducing Valve | |
| t | |
| hole | |
| Water Manhole | |
| p | |
| Water Main | |
| ice | |
| dale Water Main | |
| hole | |
| anout | |
| Station | |
| ment Plant | |
| n - Gravity | |
| n - Force | |
| dale Sewer Main | |

VICINITY MAP



NORTH

SCALE: 1" = 100'

50 100 200

Map scale of 1" = 100' is based



WATER & SEWER

QUARTER SECTION MAP

61-49

SW 1/4 SEC. 31 T6N R5E

The logo for Scottsdale Geographic Information Systems features a stylized illustration of a Native American man riding a dark horse. The man is depicted in a dynamic pose, holding a long staff or lance. The horse is shown in mid-gallop. Below the illustration, the word "SCOTTSDALE" is written in large, bold, serif capital letters. Underneath "SCOTTSDALE", the word "ARIZONA" is written in a smaller, all-caps sans-serif font. A small decorative flourish or star is positioned at the bottom right of the "A" in "ARIZONA".



SUSTAINABILITY ENGINEERING GROUP

8280 E. GELDING DRIVE SUITE 101 SCOTTSDALE, ARIZONA 85260
WWW.AZSEG.COM TEL: 480.588.7226 FAX: 480.299.3554



orcutt winslow

PROJECT	TSG FOUNDATION CENTER FOR SPIRITUAL DEVELOPMENT
LOCATION	SWC OF E. STAGECOACH PASS AND N. PIMA RD.
DRAWN	BEGELL
DESIGNED	BEGELL
CHECKED	COUNSELL
PROJ. MGR.	FAKIH
DATE:	04/02/2019
ISSUED FOR:	DRB
REVISION NO.:	DATE:
<input type="checkbox"/>	
JOB NO.:	180333
SHEET TITLE:	UTILITY PLAN 1
SHEET NO.:	C4.11


THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.




VICINITY MAP (NTS)



04.11








EXHIBIT 5 – MODEL MAP

8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260

Sustainability Engineering Group

info@azSEG.com 480.588.7226 www.azSEG.com

EXHIBIT

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,698.00	60
J-2	2,553.00	0	2,698.00	63
J-5	2,552.00	0	2,698.00	63
J-6	2,556.55	0	2,698.00	61
J-7	2,554.00	0	2,698.00	62
J-8	2,555.00	12	2,698.00	62
J-9	2,555.00	0	2,698.00	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	12	0.08
P-2	8.0	33	130.0	12	0.08
P-3	8.0	123	130.0	12	0.08
P-4	12.0	1,120	150.0	12	0.03
P-5	16.0	25	130.0	12	0.02
P-8	8.0	78	130.0	12	0.08
P-9	8.0	39	130.0	12	0.08
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,698.00	12	166.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: ADD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	12	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,697.99	60
J-2	2,553.00	0	2,697.99	63
J-5	2,552.00	0	2,697.99	63
J-6	2,556.55	0	2,697.99	61
J-7	2,554.00	0	2,697.99	62
J-8	2,555.00	24	2,697.98	62
J-9	2,555.00	0	2,697.98	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	24	0.15
P-2	8.0	33	130.0	24	0.15
P-3	8.0	123	130.0	24	0.15
P-4	12.0	1,120	150.0	24	0.07
P-5	16.0	25	130.0	24	0.04
P-8	8.0	78	130.0	24	0.15
P-9	8.0	39	130.0	24	0.15
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,697.99	24	165.99

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	24	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Junction Table**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,560.28	0	2,697.97	60
J-2	2,553.00	0	2,697.97	63
J-5	2,552.00	0	2,697.96	63
J-6	2,556.55	0	2,697.96	61
J-7	2,554.00	0	2,697.96	62
J-8	2,555.00	43	2,697.95	62
J-9	2,555.00	0	2,697.95	62

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Pipe Table**

Label	Diameter (in)	Length (ft)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)
P-1	8.0	59	130.0	43	0.27
P-2	8.0	33	130.0	43	0.27
P-3	8.0	123	130.0	43	0.27
P-4	12.0	1,120	150.0	43	0.12
P-5	16.0	25	130.0	43	0.07
P-8	8.0	78	130.0	43	0.27
P-9	8.0	39	130.0	43	0.27
P-10	8.0	42	130.0	0	0.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Pump Table**

Label	Elevation (ft)	Pump Status	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,530.00	On	2,532.00	2,697.98	43	165.98

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: PHD****FlexTable: Reservoir Table**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	2,532.00	43	2,532.00

2019-03-15 - TSG 1500 gpm FF with 8-in pipes.wtg**Active Scenario: MDD+Fire****Fire Flow Node FlexTable: Fire Flow Report**

Label	Needed Fire Flow (gpm)	MD + Needed Flow (gpm)	Calculated Pressure at Junction (psi)	Total Available Flow at 20 psi (gpm)	Junction w/ Minimum Pressure	Junction Pressure) (psi)	Pipe w/ Maximum Velocity	Pipe Velocity (ft/s)
J-1	1,500	1,500	51	1,501	J-6	53	P-4	4.33
J-2	1,500	1,500	52	1,501	J-6	51	P-3	9.73
J-5	1,500	1,500	52	1,501	J-6	50	P-3	9.73
J-6	1,500	1,500	49	1,501	J-9	50	P-3	9.73
J-7	1,500	1,500	49	1,501	J-9	49	P-8	9.73
J-8	1,500	1,524	48	1,525	J-9	48	P-9	9.73
J-9	1,500	1,500	47	1,501	J-8	48	P-9	9.73



"LEED®ing and Developing Smart Projects"

EXHIBIT 6

Sewer Service Calculation

8280 E. Gelding Dr., Suite 101
Scottsdale, AZ 85260

Sustainability Engineering Group info@azSEG.com 480.588.7226 www.azSEG.com

8" Pipe - Peak Flow

Project Description

Friction Method Manning Formula
 Solve For Normal Depth

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Diameter	8 in
Discharge	12.0 gal/min

Results

Normal Depth	0.74 in
Flow Area	0.02 ft ²
Wetted Perimeter	0.41 ft
Hydraulic Radius	0.47 in
Top Width	0.39 ft
Critical Depth	0.07 ft
Percent Full	9.3 %
Critical Slope	0.00743 ft/ft
Velocity	1.64 ft/s
Velocity Head	0.04 ft
Specific Energy	0.10 ft
Froude Number	1.40
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.00000 ft/ft
Flow Type	SuperCritical

8" Pipe - d/D = 0.65

Project Description

Friction Method Manning Formula
 Solve For Discharge

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Normal Depth	5.20 in
Diameter	8 in

Results

Discharge	502.4 gal/min
Flow Area	0.24 ft ²
Wetted Perimeter	1.25 ft
Hydraulic Radius	2.31 in
Top Width	0.64 ft
Critical Depth	0.50 ft
Percent Full	65.0 %
Critical Slope	0.01023 ft/ft
Velocity	4.66 ft/s
Velocity Head	0.34 ft
Specific Energy	0.77 ft
Froude Number	1.34
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.00858 ft/ft
Flow Type	SuperCritical

8" Pipe - Full Flow Capacity

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.013
Channel Slope	0.01500 ft/ft
Normal Depth	8.00 in
Diameter	8 in
Discharge	664.2 gal/min

Results

Discharge	664.2 gal/min
Normal Depth	8.00 in
Flow Area	0.35 ft ²
Wetted Perimeter	2.09 ft
Hydraulic Radius	2.00 in
Top Width	0.00 ft
Critical Depth	0.57 ft
Percent Full	100.0 %
Critical Slope	0.01402 ft/ft
Velocity	4.24 ft/s
Velocity Head	0.28 ft
Specific Energy	0.95 ft
Froude Number	0.00
Maximum Discharge	714.52 gal/min
Discharge Full	664.2 gal/min
Slope Full	0.01500 ft/ft
Flow Type	SubCritical

6" Pipe - Peak Flow

Project Description

Friction Method	Manning Formula
Solve For	Normal Depth

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Diameter	6 in
Discharge	12.0 gal/min

Results

Normal Depth	0.75 in
Flow Area	0.01 ft ²
Wetted Perimeter	0.36 ft
Hydraulic Radius	0.47 in
Top Width	0.33 ft
Critical Depth	0.08 ft
Percent Full	12.6 %
Critical Slope	0.00760 ft/ft
Velocity	1.87 ft/s
Velocity Head	0.05 ft
Specific Energy	0.12 ft
Froude Number	1.59
Maximum Discharge	383.10 gal/min
Discharge Full	356.1 gal/min
Slope Full	0.00002 ft/ft
Flow Type	SuperCritical

6" Pipe - d/D = 0.65

Project Description

Friction Method Manning Formula
 Solve For Discharge

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Normal Depth	3.90 in
Diameter	6 in

Results

Discharge	269.4 gal/min
Flow Area	0.14 ft ²
Wetted Perimeter	0.94 ft
Hydraulic Radius	1.73 in
Top Width	0.48 ft
Critical Depth	0.39 ft
Percent Full	65.0 %
Critical Slope	0.01234 ft/ft
Velocity	4.44 ft/s
Velocity Head	0.31 ft
Specific Energy	0.63 ft
Froude Number	1.47
Maximum Discharge	383.10 gal/min
Discharge Full	356.1 gal/min
Slope Full	0.01144 ft/ft
Flow Type	SuperCritical

6" Pipe - Full Flow Capacity

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.013
Channel Slope	0.02000 ft/ft
Normal Depth	6.00 in
Diameter	6 in
Discharge	356.1 gal/min

Results

Discharge	356.1 gal/min
Normal Depth	6.00 in
Flow Area	0.20 ft ²
Wetted Perimeter	1.57 ft
Hydraulic Radius	1.50 in
Top Width	0.00 ft
Critical Depth	0.44 ft
Percent Full	100.0 %
Critical Slope	0.01788 ft/ft
Velocity	4.04 ft/s
Velocity Head	0.25 ft
Specific Energy	0.75 ft
Froude Number	0.00
Maximum Discharge	383.10 gal/min
Discharge Full	356.1 gal/min
Slope Full	0.02000 ft/ft
Flow Type	SubCritical



"LEED®ing and Developing Smart Projects"

EXHIBIT 3

Preliminary Utility Plans

8280 E. Gelding Dr., Suite 101

Scottsdale, AZ 85260

info@azSEG.com 480.588.7226 www.azSEG.com

Sustainability Engineering Group