



Abbreviated Water and Sewer Needs

FINAL WATER BASIS OF DESIGN REPORT

Solitude

Southeast of Happy Valley Road and Pima Road
Scottsdale, Arizona

Prepared for:

Sonora West Development INC.
8937 East Bell Road
Suite 100
Scottsdale, Arizona 85260

Prepared by:

Kimley-Horn and Associates
1001 West Southern Avenue, Suite 131
Mesa, Arizona 85210
291203001
December 2020

FINAL Basis of Design Report


- ☒ APPROVED
☐ APPROVED AS NOTED
☐ REVISE AND RESUBMIT



Disclaimer: If approved; the approval is granted under the condition that the final construction documents submitted for city review will match the information herein. Any subsequent changes in the water or sewer design that materially impact design criteria or standards will require re-analysis, re-submittal, and approval of a revised basis of design report prior to the plan review submission.; this approval is not a guarantee of construction document acceptance. For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY scan

DATE 1/6/2021





FINAL WATER BASIS OF DESIGN REPORT

SOLITUDE
SOUTHEAST OF HAPPY VALLEY ROAD AND PIMA ROAD
SCOTTSDALE, ARIZONA

DECEMBER 2020

Prepared By:

Kimley»Horn

Contents

Introduction	2
Site Location	2
Project Size and Type	2
Purpose and Objectives.....	2
Water system description.....	4
Existing Water system.....	4
Proposed Water System.....	4
Basis of Design	6
Design Criteria	6
Water system analysis	7
Analysis Results.....	8

Figures

Figure 1: Vicinity Map.....	3
Figure 2: Water System Layout	5

Tables

Table 1. Water Design Criteria	6
Table 2. Water Demand Calculations	6
Table 3. WaterCAD Node Summary	7

Appendices

Appendix A – Fire Hydrant Flow Test Results

Appendix B – WaterCAD Output

INTRODUCTION

SITE LOCATION

This Final Water Basis of Design Report (WaterBOD) has been prepared for the proposed Solitude single family development located southeast of Happy Valley Road and Pima Road in Scottsdale, Arizona (development). The development is bound to the West by the 91st Street alignment, to the north by Happy Valley Road, to the south by undeveloped land, and to the west by the 92nd Street alignment. The development is located within Section 7 of Township 4 North, Range 5 East of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. Refer to **Figure 1** for the Vicinity Map.

PROJECT SIZE AND TYPE

The development is a proposed 17-unit single family residential subdivision. The proposed buildings are one-story units. The development is approximately 20 acres.

PURPOSE AND OBJECTIVES

This report presents the basis of design criteria that will be used for engineering design of the proposed development. This report establishes a water service plan for the development of the site.

- Demonstrate compliance with the City's Design Standards & Policies Manual (DSPM).
- Identify a water system layout for the proposed development.
- Determination of the water demand generated by the development.
- Modeling and Analysis of the proposed water system, including Fire service.

K:\EAV_Civil\291203001 - HV92\Reports\WaterBOD\Figures\V-MAP.dwg Sep 24, 2019 dan.recker
XREFs:




FIGURE 1
VICINITY MAP



WATER SYSTEM DESCRIPTION

EXISTING WATER SYSTEM

The existing site is primarily undeveloped natural desert with one existing house to be removed. The site slopes to the southwest and across the site. Existing grade elevations on the site range from approximately 2125-2080. The development falls entirely within pressure zone 8. Based on a review of the City Quarter Section Maps, there is an existing 12-inch water line in Happy Valley Road, an existing 12-inch water line in the 92nd Street alignment an existing 6-inch water line in the Whispering Wind alignment, and an existing 6-inch water line in the 91st Street alignment.


PROPOSED WATER SYSTEM

Directly to the west of the site is the HV91 development (CoS Plan Check #310-19), which is currently under construction. HV91 provide an 8-inch water stub at the eastern boundary along the Whispering Wind alignment. HV91 will be served by an 8-inch D.I.P. public water line which connects to the existing 12-inch water line in Happy Valley Road and the existing 6-inch water line in the 91st Street alignment.

The proposed solitude development consists of 17 single family residential units. The development will be served by a proposed 8"-D.I.P. public water line within private roadway tracts and/or easements within the development.

The proposed water system will be served by two connections into the HV91 system. The first connection is into the 8-inch stub provided at the Whispering Wind alignment, the second connection will be at the 8-inch line in 90th Way. Refer to **Figure 2** for the proposed water layout.

The existing 6-inch water line in the Whispering Wind Drive alignment will be abandoned.



BASIS OF DESIGN

DESIGN CRITERIA

The design criteria for the development is based on the City of Scottsdale Design Standards and Policies Manual (DS&PM). Average daily demands for the proposed use and peaking factors were used to determine the proposed peak flows generated on site. See **Table 1** below for a summary of the design criteria used.

Table 1. Water Design Criteria

WATER DESIGN CRITERIA		
Water Demands		
Land Use	Average Daily Flow (gpm)	
Prop. Development (<2 DU/ac Residential)	0.69	per unit
Water Design Criteria		
Peaking Factors		
Maximum Day	2.0	
Peak Hour	3.5	
Fire Flow		
Single Family Residential*	875	GPM
Pressure Requirements		
Residual @ Highest Finished Floor Elevation	50-120	PSI
Fire Flow @ Hydrant Tee or Riser	30	PSI

***Fire Flow requirement for one-story residential property, up to 4,800 sq-ft, Per IFC Table B105.1 with 50% reduction for interior fire sprinkler system.**

The proposed development generates a peak demand of approximately 41.1 gpm. See **Table 2** below for a summary of the existing and proposed flows generated on site.

Table 2. Water Demand Calculations

Water Demand Calculations					
Use	Units/ Rooms (#)	Unit Demand (gpm)	Average Daily Demand (gpm)	Max Day Demand (gpd)	Peak Hour Demand (gpm)
HV91	17	0.69	11.7	23.5	41.1
Solitude	17	0.69	11.7	23.5	41.1
Total	34	1.38	23.4	47	82.2

WATER SYSTEM ANALYSIS

The WaterCAD v8i water system modeling software distributed by Haestad Methods, Inc. was used to model the proposed water network. A fire hydrant flow test was performed to determine the residual and static pressures of the existing network. The test was performed on Happy Valley Road at the southeast corner of 92nd Street. Refer to **Appendix A – Fire Hydrant Flow Test Results**.

The proposed water distribution system is modeled under four design scenarios. Average Day, Max Day, Peak Hour, and Max Day plus Fire Flow. Domestic demands based on the calculated demands from **Table 2** were placed on the corresponding WaterCAD design Nodes. See **Table 3** below for WaterCAD Junction Demands.

Table 3. WaterCAD Node Summary

WaterCAD Node	Existing/Proposed Ground Elevation	WaterCAD Elevation	Units	Average Day Demand (gpm)	Max Day Demand (gpm)	Peak Hour Demand (gpm)	Fire Flow Demand (gpm)
J-1	2,131	2,131	0	0	0	0	875
J-2	2,099	2,099	0	0	0	0	875
J-3	2,097	2,097	0	0	0	0	875
J-4	2,107	2,107	0	0	0	0	875
J-5*	2,089.5	2,089.5	17	11.7	23.5	41.1	875
J-6	2,097	2,097	0	0	0	0	875
J-7	2,112	2,112	4	2.8	5.5	9.7	875
J-8	2,109	2,109	3	2.1	4.1	7.3	875
J-9	2,107.5	2,107.5	5	3.5	6.9	12.1	875
J-10	2,100	2,100	5	3.5	6.9	12.1	875
			34	23.5	46.9	82.1	

*17- unit demand at node J-5 represents the demand from HV91

Demands are placed at the highest finished floor of the proposed building (in this case, single-story), with an additional 23-feet of head (~10 PSI) to account for losses through the service, meter and PRV. For the Average Day, Max Day and Peak hour, the minimum residual pressure in the system should be maintained between above 50 PSI at the highest finished floor and below 120 PSI in the system. For the Fire Flow scenario, the required fire flow is applied to all nodes independently. In the Fire Flow scenario, the minimum residual pressure in the network should be maintained above 30 PSI at the hydrant tee and 15 psi at the highest finished floor.

ANALYSIS RESULTS

Results from the water model indicated the proposed system is able to provide the required domestic and fire flows at or above the minimum required pressures. On-site water pressure in the three modeled scenarios are approximately 80-95 psi at the highest finished floor of the proposed development. While the available Fire Flow in the Max Day is above 1,500 gpm at a residual pressure of 30 psi at hydrants and 15 psi at the highest finished floor. **See Appendix B – WaterCAD Output** complete analysis results.

Appendix A – Fire Hydrant Flow Test Results



Flow Test Summary

Project Name: EJFT 20334
Project Address: E Happy Valley Rd & N 92nd St, Scottsdale, AZ 85255
Date of Flow Test: 2020-12-14
Time of Flow Test: 7:40 AM
Data Reliable Until: 2021-06-14
Conducted By: Eder Cueva & Steven Saethre (EJ Flow Tests) 602.999.7637
Witnessed By: Sonny Schreiner (City of Scottsdale) 602.819.7718
City Forces Contacted: City of Scottsdale (602.819.7718)
Permit Number: C63921

Note Scottsdale requires a max static pressure of 72 psi for safety factor.

Raw Flow Test Data

Static Pressure: 90.0 PSI
Residual Pressure: 52.0 PSI
Flowing GPM: 1,062
GPM @ 20 PSI: 1,476


Data with a 18 PSI Safety Factor

Static Pressure: 72.0 PSI
Residual Pressure: 34.0 PSI
Flowing GPM: 1,062
GPM @ 20 PSI: 1,258

Hydrant F₁

Pitot Pressure (1): 40 PSI
Coefficient of Discharge (1): 0.9
Hydrant Orifice Diameter (1): 2.5 inches



 Static-Residual Hydrant

 Flow Hydrant

Distance Between F₁ and R
89 ft (measured linearly)

Static-Residual Elevation
2128 ft (above sea level)

Flow Hydrant (F₁) Elevation
2131 ft (above sea level)

Elevation & distance values are approximate

EJ Flow Tests, LLC

21505 North 78th Ave. | Suite 130 | Peoria, Arizona 85382 | (602) 999-7637 | www.ejengineering.com
John L. Echeverri | NICET Level IV 78493 SME | C-16 FP Contractor ROC 271705 AZ | NFPA CFPS 1915
www.flowtestsummary.com

Page 1

5-PP-2020_V2
12/29/20

Static-Residual Hydrant




Flow Hydrant (only hydrant F1 shown for clarity)



Approximate Project Site



Water Supply Curve N^{1.85} Graph



Appendix B – WaterCAD Output


- *Pump Supply Curve*
- *Average Day*
- *Max Day*
- *Peak Hour*
- *Max Day + Fire Flow*

Pump Definition Detailed Report: Fire Flow "1"

Active Scenario: Average Day

Element Details			
ID	55	Notes	
Label	Fire Flow "1"		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	78.54 ft
Shutoff Flow	0.0 gpm	Maximum Operating Flow	1,258.0 gpm
Shutoff Head	166.00 ft	Maximum Operating Head	46.00 ft
Design Flow	1,062.0 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0.0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft²	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True

Pump Definition Detailed Report: Fire Flow "1" **Active Scenario: Average Day**



FlexTable: Junction Table
Active Scenario: Average Day

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,131.00	0.0	2,296.93	72
J-2	2,099.00	0.0	2,296.93	86
J-3	2,097.00	0.0	2,296.92	86
J-4	2,107.00	0.0	2,296.93	82
J-5	2,089.50	11.7	2,296.92	90
J-6	2,097.00	0.0	2,296.93	86
J-7	2,112.00	2.8	2,296.93	80
J-8	2,109.00	2.1	2,296.92	81
J-9	2,107.50	3.5	2,296.92	82
J-10	2,100.00	3.5	2,296.92	85

FlexTable: Pipe Table
Active Scenario: Average Day

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-1	132	R-1	PMP-1	48.0	130.0	23.5	0.00	0.000
P-2	117	PMP-1	J-1	48.0	130.0	23.5	0.00	0.000
P-3	667	J-1	J-4	12.0	130.0	23.5	0.07	0.000
P-4	385	J-4	J-2	12.0	130.0	13.0	0.04	0.000
P-5	118	J-4	J-7	6.0	130.0	10.4	0.12	0.000
P-6	556	J-7	J-3	6.0	130.0	4.2	0.05	0.000
P-7	219	J-6	J-2	8.0	130.0	-13.0	0.08	0.000
P-8	679	J-6	J-5	8.0	130.0	8.9	0.06	0.000
P-9	334	J-5	J-3	8.0	130.0	-2.8	0.02	0.000
P-10	371	J-7	J-6	8.0	130.0	-4.1	0.03	0.000
P-11	579	J-8	J-7	8.0	130.0	-7.6	0.05	0.000
P-12	302	J-8	J-9	8.0	130.0	5.6	0.04	0.000
P-13	463	J-9	J-10	8.0	130.0	3.5	0.02	0.000
P-14	371	J-9	J-3	8.0	130.0	-1.3	0.01	0.000

FlexTable: Pump Table
Active Scenario: Average Day

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Design) (gpm)	Head (Design) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,131.00	2,131.00	2,296.93	1,062.0	78.54	23.5	165.93

FlexTable: Junction Table

Active Scenario: Max Day

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,131.00	0.0	2,296.74	72
J-2	2,099.00	0.0	2,296.74	86
J-3	2,097.00	0.0	2,296.72	86
J-4	2,107.00	0.0	2,296.74	82
J-5	2,089.50	23.5	2,296.72	90
J-6	2,097.00	0.0	2,296.73	86
J-7	2,112.00	5.5	2,296.73	80
J-8	2,109.00	4.1	2,296.72	81
J-9	2,107.50	6.9	2,296.72	82
J-10	2,100.00	6.9	2,296.72	85

FlexTable: Pipe Table
Active Scenario: Max Day

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-1	132	R-1	PMP-1	48.0	130.0	46.9	0.01	0.000
P-2	117	PMP-1	J-1	48.0	130.0	46.9	0.01	0.000
P-3	667	J-1	J-4	12.0	130.0	46.9	0.13	0.000
P-4	385	J-4	J-2	12.0	130.0	26.1	0.07	0.000
P-5	118	J-4	J-7	6.0	130.0	20.9	0.24	0.000
P-6	556	J-7	J-3	6.0	130.0	8.3	0.09	0.000
P-7	219	J-6	J-2	8.0	130.0	-26.1	0.17	0.000
P-8	679	J-6	J-5	8.0	130.0	17.8	0.11	0.000
P-9	334	J-5	J-3	8.0	130.0	-5.6	0.04	0.000
P-10	371	J-7	J-6	8.0	130.0	-8.2	0.05	0.000
P-11	579	J-8	J-7	8.0	130.0	-15.3	0.10	0.000
P-12	302	J-8	J-9	8.0	130.0	11.1	0.07	0.000
P-13	463	J-9	J-10	8.0	130.0	6.9	0.04	0.000
P-14	371	J-9	J-3	8.0	130.0	-2.7	0.02	0.000

FlexTable: Pump Table
Active Scenario: Max Day

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Design) (gpm)	Head (Design) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,131.00	2,131.00	2,296.74	1,062.0	78.54	46.9	165.74

FlexTable: Junction Table
Active Scenario: Peak Hour

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	2,131.00	0.0	2,296.27	72
J-2	2,099.00	0.0	2,296.25	85
J-3	2,097.00	0.0	2,296.21	86
J-4	2,107.00	0.0	2,296.25	82
J-5	2,089.50	41.1	2,296.21	89
J-6	2,097.00	0.0	2,296.23	86
J-7	2,112.00	9.7	2,296.23	80
J-8	2,109.00	7.2	2,296.22	81
J-9	2,107.50	12.1	2,296.21	82
J-10	2,100.00	12.1	2,296.21	85

FlexTable: Pipe Table
Active Scenario: Peak Hour

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-1	132	R-1	PMP-1	48.0	130.0	82.1	0.01	0.000
P-2	117	PMP-1	J-1	48.0	130.0	82.1	0.01	0.000
P-3	667	J-1	J-4	12.0	130.0	82.1	0.23	0.000
P-4	385	J-4	J-2	12.0	130.0	45.6	0.13	0.000
P-5	118	J-4	J-7	6.0	130.0	36.5	0.41	0.000
P-6	556	J-7	J-3	6.0	130.0	14.5	0.17	0.000
P-7	219	J-6	J-2	8.0	130.0	-45.6	0.29	0.000
P-8	679	J-6	J-5	8.0	130.0	31.2	0.20	0.000
P-9	334	J-5	J-3	8.0	130.0	-9.9	0.06	0.000
P-10	371	J-7	J-6	8.0	130.0	-14.4	0.09	0.000
P-11	579	J-8	J-7	8.0	130.0	-26.7	0.17	0.000
P-12	302	J-8	J-9	8.0	130.0	19.5	0.12	0.000
P-13	463	J-9	J-10	8.0	130.0	12.1	0.08	0.000
P-14	371	J-9	J-3	8.0	130.0	-4.7	0.03	0.000

FlexTable: Pump Table
Active Scenario: Peak Hour

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Design) (gpm)	Head (Design) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	2,131.00	2,131.00	2,296.27	1,062.0	78.54	82.1	165.27

Fire Flow Node FlexTable: Fire Flow Report

Active Scenario: Max Day + Fire Flow

Label	Elevation (ft)	Fire Flow (Needed) (gpm)	Fire Flow (Available) (gpm)	Pressure (Calculated Residual) (psi)	Satisfies Fire Flow Constraints?
J-1	2,131.00	875.0	1,273.3	15	True
J-2	2,099.00	875.0	1,273.3	27	True
J-3	2,097.00	875.0	1,273.3	25	True
J-4	2,107.00	875.0	1,273.3	24	True
J-5	2,089.50	875.0	1,273.3	28	True
J-6	2,097.00	875.0	1,273.3	27	True
J-7	2,112.00	875.0	1,273.3	20	True
J-8	2,109.00	875.0	1,273.3	19	True
J-9	2,107.50	875.0	1,273.3	20	True
J-10	2,100.00	875.0	1,273.2	17	True