

Wastewater Basis of Design Report

Happy Valley - 18

Prepared for:

Camelot Homes, Inc.
6607 North Scottsdale Road, Suite H-100
Scottsdale, AZ 85250

Prepared by:

Kimley-Horn & Associates, Inc.
7740 North 16th Street, Suite 300
Phoenix, AZ 85020

Kimley»»Horn

291104098
May 2020
Copyright © 2020, Kimley-Horn and Associates, Inc.

FINAL Basis of Design Report

- APPROVED
- APPROVED AS NOTED
- REVISE AND RESUBMIT



Disclaimer: If approved; the approval is granted under the condition that the final construction documents submitted for city review will match the information herein. Any subsequent changes in the water or sewer design that materially impact design criteria or standards will require re-analysis, re-submittal, and approval of a revised basis of design report prior to the plan review submission.; this approval is not a guarantee of construction document acceptance. For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY scan

DATE 6/1/2020



Jayme Thoma

Contents

1.0 Introduction	1
2.0 Wastewater Collection System.....	2
2.1 System Layout	2
2.2 System Analysis and Results.....	2
3.0 Conclusion	3
4.0 References.....	4



Appendices

Appendix A – Figures

Appendix B – Sewer Capacity Calculations

1.0 INTRODUCTION

Kimley-Horn and Associates, Inc. has prepared this wastewater basis of design report for the proposed residential development at the southwest corner of Alma School Road and Happy Valley Road in Scottsdale, Arizona. This report will demonstrate that the proposed project conforms to the City of Scottsdale design requirements.

Happy Valley 18, the “project”, encompasses approximately 29 acres and contains a total of 21 single family residential lots. The project lies within a portion of the southwest quarter of Section 8, Township 4 North, Range 5 East of the Gila and Salt River Base and Meridian in Maricopa County, Arizona. More specifically, the project is bounded by Alma School Road to the east, Happy Valley Road to the north, with single family residential subdivisions to the north, east, and west. The site slopes from the northeast to the southwest at approximately 4.0%. Refer to **Figure 1** in **Appendix A** for the project Vicinity Map.

2.0 WASTEWATER COLLECTION SYSTEM

2.1 SYSTEM LAYOUT

There is an existing 12" sanitary sewer main in Alma School Road that flows to the south towards Pinnacle Peak Road. A proposed 8" sewer main is proposed to connect to the existing 12" sewer in Alma School at the southeast portion of the project. The 8" line is aligned in Tract A until the southern leg where the 8" line turns south in the proposed water and sewer easement. From there, the proposed 8" sewer line tees in East Desert Vista Drive where it remains an 8" line. To the west the line terminates in the existing cul-de-sac in a proposed manhole. To the east, the proposed 8" sewer line continues until it taps into the existing 12" sewer main in Alma School Road. A new manhole will be required at the point of connection in Alma School Road. A majority of the sewer will be located within the private street tract, Tract A, with a blanket water and sewer facilities easement located over it. The portion of the sewer outside the private street tract will be within a 30-foot water and sewer facilities easement.

Due to odor issues in Alma School sewer a chemical dosing station will be required with site dimensions of 30 ft X 40 ft . The site will have access to a manhole for the chemical feed. Final determination of the design and location will be made at the time of preliminary plat and will be made as a stipulation of approval

All 8" sewer lines will be PVC SDR 35 at a minimum slope of 0.52%. Sewer Manhole sections and cones will be precast concrete as detailed in the MAG Standard Detail No. 420, without the manhole steps and/or cast in anchors for steps. Manholes shall be 4 feet in diameter, and for depths less than 10 feet. Manholes shall be 5 feet in diameter for all depths greater than 10 foot. Refer to **Figure 2** in **Appendix A** for the wastewater layout.

2.2 SYSTEM ANALYSIS AND RESULTS

To determine the capacity of the proposed onsite wastewater collection system, design flows were calculated and analyzed with minimum pipe design slopes. Design flows are calculated based on the criteria in Section 7-1.403 of **Reference 1**. For residential developments, the design flow is 100 gallons per capita per day (gpcd) with a peaking factor of 4. Residential densities are assumed to be 2.5 persons per dwelling unit. Average Day Flow (ADF) and Peak Day Flow (PDF) are summarized in Table 2 below:

Table 2: Wastewater Design Flows

# DUs	Density (persons/DU)	Design flow (gpcpd)	ADF (GPD)	Peaking Factor	PDF (GPD)	PDF (GPM)
21	2.5	100	5,250	4.0	21,000	14.59

Sanitary sewer lines will be designed to maintain a full flow velocity between 2.5 ft/sec – 10 ft/sec with a maximum depth to diameter ratio (d/D) of 0.65 in the ultimate peak flow condition. To achieve the velocity requirements, the minimum slope of 0.52% and maximum slope of 8.33% will be utilized. Using the peak flow calculated in **Table 2** and the minimum design slope, an 8" sewer main has the capacity to convey the proposed design flows with a flow depth of 1.08" and a d/D ratio of 0.14. Sewer pipe capacity calculations can be seen in **Appendix B**.

3.0 CONCLUSION

This project proposes a new 8" sanitary sewer main to serve the proposed development which will gravity flow into the existing 12" sanitary main in Alma School Road. Based on the analysis in this report, an 8" sewer main has the capacity to convey the proposed design flow for the development.

4.0 REFERENCES


1. City of Scottsdale, *Design Standards and Policies Manual*. 2018.
2. International Code Council, *2015 International Fire Code*. May 2014.

Appendix A – Figures

Figure 1 – Vicinity Map

Figure 2 – Wastewater Layout

NOTES:
 THIS DOCUMENT, TOGETHER WITH THE CONCEPTS AND DESIGNS PRESENTED HEREIN, AS AN INSTRUMENT OF SERVICE, IS INTENDED ONLY FOR THE SPECIFIC PURPOSE AND CLIENT FOR WHICH IT WAS PREPARED. REFUSE OF AND IMPROPER RELIANCE ON THIS DOCUMENT WITHOUT WRITTEN AUTHORIZATION AND ADAPTATION BY KIMLEY-HORN AND ASSOCIATES, INC. SHALL BE WITHOUT LIABILITY TO KIMLEY-HORN AND ASSOCIATES, INC.



PROJECT NO. 291104098
DRAWING NAME
1 OF 1

HAPPY VALLEY 18
FIGURE 1
VICINITY MAP


SCALE (H): NTS
SCALE (V): NTS
DESIGNED BY: MML
DRAWN BY: MML
CHECKED BY: MML
DATE: 5/30/2019

Kimley»Horn

© 2019 KIMLEY-HORN AND ASSOCIATES, INC.
 7740 North 16th Street, Suite 300
 Phoenix, Arizona 85020 (602) 944-5500

NO.	REVISION	DATE

K:_VHK_Civil\291104098 - Happy Valley & Alma School Reports\Wastewater\Exhibits\Utility Layout.dwg May 11, 2020 Joyme.Thoma
 XREFS: xref=291104098 xref=291104098 xref=291104098
 OF AND UNLESS OTHERWISE NOTED, THIS DOCUMENT IS THE PROPERTY OF KIMLEY-HORN AND ASSOCIATES, INC. NO PART OF THIS DOCUMENT IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT WRITTEN AUTHORIZATION AND ADAPTATION BY KIMLEY-HORN AND ASSOCIATES, INC. SHALL BE WITHOUT LIABILITY TO KIMLEY-HORN AND ASSOCIATES, INC.



<p>Kimley»Horn © 2020 KIMLEY-HORN AND ASSOCIATES, INC. 7740 North 16th Street, Suite 300 Phoenix, Arizona 85020 (602) 944-5500</p>	
<p>SCALE (H): 1"=60' SCALE (V): NONE DESIGNED BY: JRT DRAWN BY: JRT CHECKED BY: CLB DATE: 05/11/2020</p>	<p>HAPPY VALLEY 18 SCOTTSDALE, ARIZONA FIGURE 2 WASTEWATER LAYOUT</p>
<p>PROJECT NO.</p>	<p>OF</p>
<p>DRAWING NAME</p>	<p>BY DATE APPR.</p>

Appendix B – Sewer Capacity Calculations

Worksheet for 8" Capacity

Project Description	
Friction Method	Manning Formula
Solve For	Normal Depth
Input Data	
Roughness Coefficient	0.013
Channel Slope	0.00520 ft/ft
Diameter	8.0 in
Discharge	21,000.00 gpd
Results	
Normal Depth	1.1 in
Flow Area	0.0 ft ²
Wetted Perimeter	0.5 ft
Hydraulic Radius	0.7 in
Top Width	0.45 ft
Critical Depth	1.0 in
Percent Full	13.2 %
Critical Slope	0.00722 ft/ft
Velocity	1.19 ft/s
Velocity Head	0.02 ft
Specific Energy	0.11 ft
Froude Number	0.856
Maximum Discharge	606,286.92 gpd
Discharge Full	563,617.75 gpd
Slope Full	0.00001 ft/ft
Flow Type	Subcritical
GVF Input Data	
Downstream Depth	0.0 in
Length	0.0 ft
Number Of Steps	0
GVF Output Data	
Upstream Depth	0.0 in
Profile Description	
Profile Headloss	0.00 ft
Average End Depth Over Rise	0.0 %
Normal Depth Over Rise	13.5 %
Downstream Velocity	Infinity ft/s
Upstream Velocity	Infinity ft/s
Normal Depth	1.1 in
Critical Depth	1.0 in
Channel Slope	0.00520 ft/ft
Critical Slope	0.00722 ft/ft

Worksheet for 8" Full Flow Capacity

Project Description

Friction Method	Manning Formula
Solve For	Full Flow Capacity

Input Data

Roughness Coefficient	0.013	
Channel Slope	0.00520	ft/ft
Normal Depth	8.00	in
Diameter	8.00	in
Discharge	563617.75	gal/day

Results

Discharge	563617.75	gal/day
Normal Depth	8.00	in
Flow Area	0.35	ft ²
Wetted Perimeter	2.10	ft
Hydraulic Radius	2.00	in
Top Width	0.00	ft
Critical Depth	0.44	ft
Percent Full	100.0	%
Critical Slope	0.00857	ft/ft
Velocity	2.50	ft/s
Velocity Head	0.10	ft
Specific Energy	0.76	ft
Froude Number	0.00	
Maximum Discharge	0.94	ft ³ /s
Discharge Full	0.87	ft ³ /s
Slope Full	0.00520	ft/ft
Flow Type	SubCritical	

GVF Input Data

Downstream Depth	0.00	in
Length	0.00	ft
Number Of Steps	0	

GVF Output Data

Upstream Depth	0.00	in
Profile Description		
Profile Headloss	0.00	ft
Average End Depth Over Rise	0.00	%

Worksheet for 8" Full Flow Capacity

GVF Output Data

Normal Depth Over Rise	100.00	%
Downstream Velocity	Infinity	ft/s
Upstream Velocity	Infinity	ft/s
Normal Depth	8.00	in
Critical Depth	0.44	ft
Channel Slope	0.00520	ft/ft
Critical Slope	0.00857	ft/ft



Abbreviated Water and Sewer Needs

Water Basis of Design Report

Happy Valley - 18

Prepared for:

Camelot Homes, Inc.
6607 North Scottsdale Road, Suite H-100
Scottsdale, AZ 85250

Prepared by:

Kimley-Horn & Associates, Inc.
7740 North 16th Street, Suite 300
Phoenix, AZ 85020

Kimley»Horn

291104098
May 2020
Copyright © 2020, Kimley-Horn and Associates, Inc.

FINAL Basis of Design Report

- APPROVED
- APPROVED AS NOTED
- REVISE AND RESUBMIT



Disclaimer: If approved; the approval is granted under the condition that the final construction documents submitted for city review will match the information herein. Any subsequent changes in the water or sewer design that materially impact design criteria or standards will require re-analysis, re-submittal, and approval of a revised basis of design report prior to the plan review submission.; this approval is not a guarantee of construction document acceptance. For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY scan

DATE 6/1/2020



2-PP-2020
5/15/2020

Contents

1.0 Introduction	1
2.0 Existing Water Distribution System	1
3.0 Proposed Water Distribution System	1
4.0 Basis of Design	1
4.1 Domestic Water Demand	1
4.2 Fire Flow Demand	2
4.3 Design Parameters	2
4.4 Hydraulic Model	4
4.5 Hydraulic Model Results	4
5.0 Conclusion	4



Tables

Table 1 Domestic Water Demands	2
Table 2 Design Parameters	2

Appendices

- Appendix A: Exhibits
 - Exhibit 1 - Vicinity Map
 - Exhibit 2 – Water System Layout
 - Exhibit 3 – WaterCAD Network
- Appendix B: Average Day Demand Results
- Appendix C: Peak Hour Demand Results
- Appendix D: Maximum Day Demand + Fire Flow Results
- Appendix E: Fire Hydrant Flow Test Results

1.0 INTRODUCTION

Happy Valley 18, the “project”, is a proposed 21-lot single family residential subdivision located on approximately 29 acres at the southwest corner of Happy Valley Road and Alma School Road in Scottsdale, Arizona. The project lies within a portion of the northeast quarter of Section 8, Township 4 north, Range 5 east of the Gila and Salt River Base and Meridian, Maricopa County, Arizona. Refer to **Exhibit 1** for a Vicinity Map.

The purpose of this report is to calculate the project’s water demands, determine the available system capacity and proposed hydraulics of the planned water system while meeting the requirements of the City of Scottsdale and the 2015 International Fire Code (IFC). As a result of this analysis, it will be determined if the potable water infrastructure is capable of satisfying the projected fire flow and domestic water demands for the project.

2.0 EXISTING WATER DISTRIBUTION SYSTEM

There is an existing 8” water main in Happy Valley Road along the north boundary of the project. This existing water main transitions to a 12” main near the intersection of Alma School Road. There is also an existing 6” waterline in Alma School Road approximately 452’ south of the site. There is an existing stub provided in Alma School Road before the line jogs northeast into the North Greenman Road alignment.

3.0 PROPOSED WATER DISTRIBUTION SYSTEM

There is an existing 8” water line that runs from Happy Valley Road south through the site. In order to serve the project, the existing 8” water line will be cut at the northern leg of Tract A and tied into the proposed 8” waterline system with an 8” tee. The remainder of the existing 8” waterline will be abandoned. This proposed 8” water main will extend throughout the site and follow the roadway alignment to provide a domestic water service connection for each lot and fire hydrants spaced no more than 600’ apart. Refer to **Exhibit 2** for a water system layout.

The second connection for the site is provided approximately 452’ south of the site in the Alma School Road alignment. There is an existing 6” water line, with stub, that the proposed 8” waterline will tie into.

For more detail on the proposed connections see **Section 4.3**.

4.0 BASIS OF DESIGN

4.1 DOMESTIC WATER DEMAND

Per Figure 6-1.2 of the *City of Scottsdale Design Standards & Policies Manual*, the average day demand (ADD) for residential land use (<2 du/acre) is 0.69 gallons per minute per unit (gpm/du). Maximum Day Demand (MDD) is calculated as 2.0 times the ADD and Peak Hour Demand (PHD) is calculated as 3.5 times the ADD. Refer to **Table 1** below for a summary of domestic water demands.

Table 1 Domestic Water Demands

Land Use	ADD (gpm/du)	Dwelling units (du)	ADD (gpm)	MDD (gpm)	PHD (gpm)
Residential (<2 du/acre)	0.69	21	14.5	29	50.8

4.2 FIRE FLOW DEMAND

Per Table B105.1(1) of the 2015 IFC, the required fire flow for single family residential dwellings is 1,000 gpm for a 1-hour duration.

4.3 DESIGN PARAMETERS

The following design criteria will be utilized for this project:

Table 2 Design Parameters


Design Criteria	ADD	PHD	MDD + Fire Flow
Minimum Pressure (psi)	50	50	30
Maximum Pressure (psi)	100	100	100
Maximum Velocity (ft/sec)	5	5	10

The Happy Valley 18 project will connect in two places to the existing City of Scottsdale water system, one to the existing waterline stubbing south from Happy Valley Road and the second through East Desert Vista Drive, south of the Site. The first connection will require a tee to be cut into the existing 8" waterline with isolation valves per the DSPM. The 8" waterline off Happy Valley Road has sufficient valves located to isolate the waterline during construction. Refer to **Exhibit 2** for a water system layout.

For the second connection, the proposed 8" line is aligned in Tract A until the southern leg of Tract A where the 8" line turns south in the proposed water and sewer easement. From there, the proposed 8" water line tees in East Desert Vista Drive where it remains an 8" line. To the west the line terminates in the existing cul-de-sac in a proposed fire hydrant. To the east, the proposed 8" water line continues until it turns south in the Alma School Road alignment. The 8" water line continues approximately 452' south to the existing 6" water line stub where a proposed connection is made. A reducer is proposed to connect the proposed 8" waterline to the existing 6" waterline. A majority of the water line will be located within the private street tract, Tract A, with a blanket water and sewer facilities easement located over it. The portion of the water line outside the private street tract will be within a 30-foot water and sewer facilities easement. The waterline in Alma School Road has existing isolation valves north of the connection in North Greenman Road and south of the connection in Alma School Road (see QS 46-53). Refer to **Exhibit 2** for a water system layout.

All waterlines will be 8" DIP Class 350, with 3 foot of minimum cover. The ends of the proposed cul-de-sacs will have fire hydrants to allow for flushing the waterlines. The dip sections under the proposed

storm drains will be realigned per MAG STD DTL 404. All waterlines will be located within water/sewer facility easements. Thrust restraints will be located at horizontal and vertical bends and lateral branches per MAG Standard Detail 303-1 and 303-2. Thrust blocks will not be utilized. All restrained pipe lengths will be specified on the final Improvement Plans per the detail and table below.



RESTRAINED LENGTHS, LR, FOR DUCTILE IRON PIPE												
NOMINAL PIPE SIZE INCHES	HORIZONTAL BENDS			TEES		VERTICAL OFFSETS						DEAD ENDS
	90°	45°	22-1/2°	LRN=0'	LRN=10'	90° BEND FITTINGS		45° BEND FITTINGS		22-1/2° BEND FITTINGS		
						DOWN BEND	UP BEND	DOWN BEND	UP BEND	DOWN BEND	UP BEND	
4	18	7	4	30	8	31	18	13	7	6	3	31
6	25	10	5	43	20	44	25	18	10	9	5	44
8	32	13	6	56	34	58	32	24	13	11	6	58
10	38	16	8	68	45	69	38	29	16	14	8	69
12	45	19	9	80	57	81	45	34	19	16	9	81
14	51	21	10	91	68	92	51	38	21	18	10	92
16	57	24	11	103	79	104	57	43	24	21	11	104
18	62	26	12	113	90	115	62	48	26	23	12	115
20	68	28	14	125	100	126	68	52	28	25	14	126
24	79	33	16	145	121	147	79	61	33	29	16	147

RESTRAINED LENGTHS, LR, FOR DUCTILE IRON PIPE WITH POLYETHYLENE WRAP												
NOMINAL PIPE SIZE INCHES	HORIZONTAL BENDS			TEES		VERTICAL OFFSETS						DEAD ENDS
	90°	45°	22-1/2°	LRN=0'	LRN=10'	90° BEND FITTINGS		45° BEND FITTINGS		22-1/2° BEND FITTINGS		
						DOWN BEND	UP BEND	DOWN BEND	UP BEND	DOWN BEND	UP BEND	
4	26	11	5	69	18	72	26	30	11	14	5	72
6	36	15	7	99	47	102	36	42	15	20	7	102
8	47	19	9	130	78	133	47	55	19	26	9	133
10	56	23	11	157	103	159	56	66	23	32	11	159
12	65	27	13	185	131	187	65	77	27	37	13	187
14	74	31	15	211	156	214	74	89	31	42	15	214
16	82	34	16	238	183	241	82	100	34	48	16	241
18	90	37	18	263	207	266	90	110	38	53	18	266
20	98	41	20	289	233	292	98	121	41	58	20	292
24	113	47	22	337	280	340	113	141	47	68	22	340

NOTES:

- ALL JOINTS WITHIN THE SPECIFIED LENGTH LR MUST BE RESTRAINED. ALL LENGTHS ARE GIVEN IN FEET.
- THE MAXIMUM TEST PRESSURE SHALL NOT EXCEED 200 PSI
- THE MINIMUM DEPTH OF BURY SHALL BE 3' TO TOP OF PIPE.
- RESTRAINED LENGTHS MAY BE REDUCED WHEN SUPPORTED BY ENGINEERING CALCULATIONS.

DETAIL NO. 303-2

MARICOPA ASSOCIATION of GOVERNMENTS

STANDARD DETAIL ENGLISH

JOINT RESTRAINT FOR DUCTILE IRON AND POLYETHYLENE WRAPPED DUCTILE IRON WATER PIPES

REVISED 01-01-1998

DETAIL NO. 303-2

4.4 HYDRAULIC MODEL

A water model, using Bentley's WaterCAD V8i program, was used to analyze the proposed water system. To determine the existing and static and residual water pressures in the area, a fire hydrant flow test was completed using the adjacent fire hydrants near the project. The results from this test produced three different data points for static, residual, and maximum water pressures with associated flow rates. This data was then input into the water model and simulated as a reservoir and pump. Refer to **Appendix E** for Fire Hydrant Flow Test results.

The following scenarios were modeled to evaluate the existing and proposed water infrastructure to demonstrate compliance with the design parameters identified in this report:

- Average Day Demand
- Peak Hour Demand
- Maximum Day Demand + Fire Flow Demand

Refer to **Exhibit 3** for the WaterCAD network.

4.5 HYDRAULIC MODEL RESULTS

The results for Average Day Demand and Peak Hour Demand can be seen in **Appendix B** and **Appendix C**, respectively. All junctions maintained a minimum pressure of 72 psi or greater and all pipes maintained a velocity of 0.32 ft/sec or less.

The results for Maximum Day Demand + Fire Flow Demand can be seen in **Appendix D**. All proposed fire hydrants meet the minimum required fire flow of 1,000 gpm at a minimum pressure of 30 psi with a maximum velocity of 10 ft/sec.

5.0 CONCLUSION


Based on the results presented in this report, the existing water infrastructure has the capability to support the proposed development while conforming to the City of Scottsdale's design criteria. An 8" water main is proposed onsite which will connect to an existing 8" water main in Happy Valley Road.

APPENDIX A: Exhibits

Exhibit 1 – Vicinity Map

Exhibit 2 – Water System Layout

Exhibit 3 – WaterCAD Network



PROJECT NO. 291104098
DRAWING NAME
1 OF 1

**HAPPY VALLEY 18
 EXHIBIT 1
 VICINITY MAP**




SCALE (H): NTS
SCALE (V): NTS
DESIGNED BY: MML
DRAWN BY: MML
CHECKED BY: MML
DATE: 5/30/2019

Kimley»Horn

© 2019 KIMLEY-HORN AND ASSOCIATES, INC.
 7740 North 16th Street, Suite 300
 Phoenix, Arizona 85020 (602) 944-5500


2-PP-2020
 5/15/2020

K:\VHK_Civil\291104098 - Happy Valley & Alma School\Reports\Water\Exhibits\Water Layout.dwg May 11, 2020 Jayme.Thoma
 XREFS: xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098 xref=291104098
 OF AND W/PROPER RELIANCE ON THIS DOCUMENT WITHOUT WRITTEN AUTHORIZATION AND ADAPTATION BY KIMLEY-HORN AND ASSOCIATES, INC. SHALL BE WITHOUT LIABILITY TO KIMLEY-HORN AND ASSOCIATES, INC.



Kimley»Horn © 2020 KIMLEY-HORN AND ASSOCIATES, INC. 7740 North 16th Street, Suite 300 Phoenix, Arizona 85020 (602) 944-5500		NO.	REVISION	BY	DATE	APPR.
HAPPY VALLEY 18 SCOTTSDALE, ARIZONA EXHIBIT 2 WATER SYSTEM LAYOUT		SCALE (H): 1"=60' SCALE (V): NONE DESIGNED BY: JRT DRAWN BY: JRT CHECKED BY: CLB DATE: 05/11/2020				
PROJECT NO.		OF				
DRAWING NAME		2-PP-2020				
		5/15/2020				

Scenario: Average Day



APPENDIX B: Average Day Demand Results

Pipe Table

Junction Table

Hydrant Table

Reservoir Table

Pump Table

Pipe Table - Time: 0.00 hours

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-1	39	R-1	PMP-1	48.0	Ductile Iron	130.0	15	0.00	0.000
P-2	50	PMP-1	J-1	48.0	Ductile Iron	130.0	15	0.00	0.000
EX P-3	72	J-1	EX H-1	8.0	Ductile Iron	130.0	15	0.09	0.000
EX P-4	182	EX H-1	J-2	8.0	Ductile Iron	130.0	15	0.09	0.000
P-5	262	J-2	H-1	8.0	Ductile Iron	130.0	1	0.01	0.000
P-6	581	J-2	J-3	8.0	Ductile Iron	130.0	12	0.07	0.000
P-7	55	J-3	H-2	8.0	Ductile Iron	130.0	0	0.00	0.000
P-10	560	J-3	H-3	8.0	Ductile Iron	130.0	8	0.05	0.000
P-15	424	H-2	H-5	8.0	Ductile Iron	130.0	0	0.00	0.000
P-12	266	H-3	J-9	8.0	Ductile Iron	130.0	6	0.04	0.000
P-13	275	J-9	H-4	8.0	Ductile Iron	130.0	6	0.04	0.000
P-15	282	J-9	J-10	6.0	Ductile Iron	130.0	0	0.00	0.000
P-16	560	J-10	J-11	6.0	Ductile Iron	130.0	0	0.00	0.000
P-17	406	J-11	J-12	6.0	Ductile Iron	130.0	0	0.00	0.000
P-18	378	J-10	J-13	6.0	Ductile Iron	130.0	0	0.00	0.000
P-19	37	J-13	H-7	6.0	Ductile Iron	130.0	0	0.00	0.000
P-20	71	H-8	J-11	6.0	Ductile Iron	130.0	0	0.00	0.000

Junction Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
33	J-1	2,365.00	0	2,532.08	72
37	J-2	2,365.85	1	2,532.08	72
41	J-3	2,352.35	4	2,532.07	78
70	J-9	2,335.76	0	2,532.07	85
73	J-10	2,316.00	0	2,532.07	93
75	J-11	2,325.00	0	2,532.07	90
77	J-12	2,312.00	0	2,532.07	95
79	J-13	2,313.00	0	2,532.07	95

Hydrant Table - Time: 0.00 hours

ID	Label	Length (Hydrant Lateral) (ft)	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
35	EX H-1	20	2,365.51	0	2,532.08	72
39	H-1	20	2,366.54	1	2,532.08	72
43	H-2	20	2,347.39	0	2,532.07	80
47	H-3	20	2,342.69	2	2,532.07	82
53	H-4	20	2,328.61	6	2,532.07	88
60	H-5	20	2,352.89	0	2,532.07	78
81	H-7	20	2,314.00	0	2,532.07	94
83	H-8	20	2,324.00	0	2,532.07	90

Reservoir Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
30	R-1	2,366.00	<None>	15	2,366.00


Pump Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)
31	PMP-1	2,366.00	Flow Test	On	2,366.00	2,532.08	15

Pump Head (ft)
166.08

Pump Definition Detailed Report: Flow Test

Element Details			
ID	62	Notes	
Label	Flow Test		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	152.24 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	5,441 gpm
Shutoff Head	166.08 ft	Maximum Operating Head	46.13 ft
Design Flow	1,695 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft ²	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True



APPENDIX C: Peak Hour Demand Results

Pipe Table

Junction Table

Hydrant Table

Reservoir Table

Pump Table

Pipe Table - Time: 0.00 hours

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-1	39	R-1	PMP-1	48.0	Ductile Iron	130.0	51	0.01	0.000
P-2	50	PMP-1	J-1	48.0	Ductile Iron	130.0	51	0.01	0.000
EX P-3	72	J-1	EX H-1	8.0	Ductile Iron	130.0	51	0.32	0.000
EX P-4	182	EX H-1	J-2	8.0	Ductile Iron	130.0	51	0.32	0.000
P-5	262	J-2	H-1	8.0	Ductile Iron	130.0	5	0.03	0.000
P-6	581	J-2	J-3	8.0	Ductile Iron	130.0	41	0.26	0.000
P-7	55	J-3	H-2	8.0	Ductile Iron	130.0	0	0.00	0.000
P-10	560	J-3	H-3	8.0	Ductile Iron	130.0	27	0.17	0.000
P-15	424	H-2	H-5	8.0	Ductile Iron	130.0	0	0.00	0.000
P-12	266	H-3	J-9	8.0	Ductile Iron	130.0	19	0.12	0.000
P-13	275	J-9	H-4	8.0	Ductile Iron	130.0	19	0.12	0.000
P-15	282	J-9	J-10	6.0	Ductile Iron	130.0	0	0.00	0.000
P-16	560	J-10	J-11	6.0	Ductile Iron	130.0	0	0.00	0.000
P-17	406	J-11	J-12	6.0	Ductile Iron	130.0	0	0.00	0.000
P-18	378	J-10	J-13	6.0	Ductile Iron	130.0	0	0.00	0.000
P-19	37	J-13	H-7	6.0	Ductile Iron	130.0	0	0.00	0.000
P-20	71	H-8	J-11	6.0	Ductile Iron	130.0	0	0.00	0.000

Junction Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
33	J-1	2,365.00	0	2,532.06	72
37	J-2	2,365.85	5	2,532.04	72
41	J-3	2,352.35	14	2,532.01	78
70	J-9	2,335.76	0	2,532.00	85
73	J-10	2,316.00	0	2,532.00	93
75	J-11	2,325.00	0	2,532.00	90
77	J-12	2,312.00	0	2,532.00	95
79	J-13	2,313.00	0	2,532.00	95

Hydrant Table - Time: 0.00 hours

ID	Label	Length (Hydrant Lateral) (ft)	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
35	EX H-1	20	2,365.51	0	2,532.05	72
39	H-1	20	2,366.54	5	2,532.04	72
43	H-2	20	2,347.39	0	2,532.01	80
47	H-3	20	2,342.69	7	2,532.00	82
53	H-4	20	2,328.61	19	2,531.99	88
60	H-5	20	2,352.89	0	2,532.01	77
81	H-7	20	2,314.00	0	2,532.00	94
83	H-8	20	2,324.00	0	2,532.00	90

Reservoir Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
30	R-1	2,366.00	<None>	51	2,366.00


Pump Table - Time: 0.00 hours

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)
31	PMP-1	2,366.00	Flow Test	On	2,366.00	2,532.06	51

Pump Head (ft)
166.06

Pump Definition Detailed Report: Flow Test

Element Details			
ID	62	Notes	
Label	Flow Test		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	152.24 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	5,441 gpm
Shutoff Head	166.08 ft	Maximum Operating Head	46.13 ft
Design Flow	1,695 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft ²	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True



APPENDIX D: Maximum Day Demand + Fire Flow Results

Fire Flow Table

Fire Flow Node FlexTable: Fire Flow Report

Label	Elevation (ft)	Fire Flow (Needed) (gpm)	Pressure (Residual Lower Limit) (psi)	Pressure Head (ft)	Pressure (psi)
EX H-1	2,365.51	1,000	0	166.57	72
H-1	2,366.54	1,000	0	165.54	72
H-2	2,347.39	1,000	0	184.68	80
H-3	2,342.69	1,000	0	189.38	82
H-4	2,328.61	1,000	0	203.46	88
H-5	2,352.89	1,000	0	179.18	78
H-7	2,314.00	1,000	0	218.07	94
H-8	2,324.00	1,000	0	208.07	90
J-1	2,365.00	1,000	0	167.08	72
J-2	2,365.85	1,000	0	166.23	72
J-3	2,352.35	1,000	0	179.72	78
J-9	2,335.76	1,000	0	196.31	85
J-10	2,316.00	1,000	0	216.07	93
J-11	2,325.00	1,000	0	207.07	90
J-12	2,312.00	1,000	0	220.07	95
J-13	2,313.00	1,000	0	219.07	95

Alternative Summary Report

Alternative: Base Fire Flow

Base Fire Flow

Fire Flow (Needed)	1,000 gpm	Fire Flow Auxiliary Results Type	None
Fire Flow (Upper Limit)	3,500 gpm	Velocity (Upper Limit)	10.00 ft/s
Pressure (Residual Lower Limit)	0 psi	Pressure (System Lower Limit)	30 psi
Pressure (Zone Lower Limit)	0 psi	Pipe Velocity Greater Than Node Pressure Less Than	0.00 ft/s 0 psi
Use Minimum System Pressure Constraint?	True	Pipe Set	All Pipes
Use Velocity Constraint?	True	Fire Flow Nodes	All Fire Flow Nodes
Use Pipe Velocity Greater Than?	False	Fire Flow Auxiliary Results Type	None
Use Node Pressure Less Than?	False	Auxiliary Output Selection Set	<No Elements>
Apply Fire Flows By	Adding to Baseline Demand		

13: Base Fire Flow, Junction and Hydrant Alternative Report

*	ID	Label	Specify Local Fire Flow Constraints?	Fire Flow (Needed) (gpm)	Fire Flow (Upper Limit) (gpm)
True	35	EX H-1	False	1,000	3,500
True	39	H-1	False	1,000	3,500
True	43	H-2	False	1,000	3,500
True	47	H-3	False	1,000	3,500
True	53	H-4	False	1,000	3,500
True	60	H-5	False	1,000	3,500
True	81	H-7	False	1,000	3,500
True	83	H-8	False	1,000	3,500
True	33	J-1	False	1,000	3,500
True	37	J-2	False	1,000	3,500
True	41	J-3	False	1,000	3,500
True	70	J-9	False	1,000	3,500
True	73	J-10	False	1,000	3,500
True	75	J-11	False	1,000	3,500
True	77	J-12	False	1,000	3,500
True	79	J-13	False	1,000	3,500

Pressure (Residual Lower Limit) (psi)	Pressure (Zone Lower Limit) (psi)	Pressure (System Lower Limit) (psi)	Velocity (Upper Limit) (ft/s)
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00

Alternative Summary Report
Alternative: Base Fire Flow

13: Base Fire Flow, Junction and Hydrant Alternative Report

Pressure (Residual Lower Limit) (psi)	Pressure (Zone Lower Limit) (psi)	Pressure (System Lower Limit) (psi)	Velocity (Upper Limit) (ft/s)
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00
0	0	30	10.00

APPENDIX E: Fire Hydrant Flow Test Results



Flow Test Summary

Project Name: EJFT 19101
Project Address: 24770 N Alma School Rd, Scottsdale, AZ 85255
Date of Flow Test: 2019-05-08
Time of Flow Test: 7:36 AM
Data Reliable Until: 2019-11-08
Conducted By: Cesar Reyna & Austin Gourley (EJ Flow Tests) 602.999.7637
Witnessed By: Sonny Schreiner (City of Scottsdale) 602.819.7718
City Forces Contacted: City of Scottsdale (602.819.7718)
Permit Number: C58208

Note Scottsdale requires a max static pressure of 72 psi for safety factor

Raw Flow Test Data

Static Pressure: 116.0 PSI
Residual Pressure: 110.0 PSI
Flowing GPM: 1,695
GPM @ 20 PSI: 7,576

Data with a 44 PSI Safety Factor

Static Pressure: 72.0 PSI
Residual Pressure: 66.0 PSI
Flowing GPM: 1,695
GPM @ 20 PSI: 5,441

Hydrant F₁

Pitot Pressure (1): 25 PSI
Coefficient of Discharge (1): 0.9
Hydrant Orifice Diameter (1): 2.5 inches
Pitot Pressure (2): 26 PSI
Coefficient of Discharge (2): 0.9
Hydrant Orifice Diameter (2): 2.5 inches



- Project Site
 - Static-Residual Hydrant
 - Flow Hydrant
- Main Size
8 inches
- Distance Between F₁ and R
2619 ft (measured linearly)
- Static-Residual Elevation
2375 ft (above sea level)
- Flow Hydrant (F₁) Elevation
2316 ft (above sea level)
- Elevation & distance values are approximate

EJ Flow Tests, LLC

21505 North 78th Ave. | Suite 130 | Peoria, Arizona 85382 | (602) 999-7637 | www.ejengineering.com
John L. Echeverri | NICET Level IV 078493 SME | C-16 FP Contractor ROC 271705 AZ | NFPA CFPS 1915

www.flowtestsummary.com

Page 1

2-PP-2020
5/15/2020

Static-Residual Hydrant



Flow Hydrant (only hydrant F1 shown for clarity)



Approximate Project Site



Water Supply Curve N^{1.85} Graph

