

The proposed storage structure is 6,700 SF therefore per 2015 IPC the fire flow required is 2,250 GPM



METRO FIRE EQUIPMENT, INC.

63 S. Hamilton Place, Gilbert, AZ 85233 • 3851 N. Oracle Road, Tucson, AZ 85705
 Main (480) 464-0509 • Fax (480) 962-5372 • Tucson (520) 888-0694 • www.metrofireaz.com
 AZ ROC# C-16:111021 • CR-67:103313 • CR-5: 213027 • CR-80:295875 • R-16:166777

Hydrant Flow Test Report

LOCATION: 11420 East Shea Boulevard, Scottsdale, AZ DATE: 2/10/2021
 TEST BY: Metro Fire Equipment TIME: 7:00 AM
 WATER SUPPLIED BY: City of Scottsdale
 PURPOSE OF TEST: Water Curve Data

FLOW HYDRANT(S)	DATA	
	A1	A2
SIZE OPENING:	2.5	2.5
COEFFICIENT:	0.9	
PITOT READING:	57	0
GPM:	1267	0
TOTAL FLOW DURING TEST:	1267 GPM	
STATIC READING:	82 PSI	RESIDUAL: 72 PSI

ADJ. STATIC: 82 PSI RESIDUAL: 72 PSI
ADJ. FLOW: AT 20 PSI RESIDUAL 3393 GPM AT 0 PSI 3946 GPM

Results of this flow test identify water system characteristics for the date, time, and locations of this test only. Pressure and flows within the water system vary of time, it is expected and should be considered when preparing designs based upon fire flow test data. Numerous factors affect the water system, such as water level fluctuations in reservoirs, operating pressure ranges at booster pump stations, elevations at point of use, daily demand fluctuations, seasonal demands, emergency demands, water treatment plant availability, increased demands due to growth, operation/maintenance schedules, etc.



