

condition that the final construction documents submitted for city review will match the information herein. Any subsequent changes in the water or sewer design that materially impact design criteria or standards will require re-analysis, re-submittal, and approval of a revised basis of design report prior to the plan review submission; this approval is not a guarantee of construction document acceptance. For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY Idillon

DATE 6/1/2021

Address the following comments below and herein for plan submittal:

1.) **Stipulation**: Connection tees to the existing water mains on McDowell Rd and 70th St will require two isolation valves each. Refer to utility plan markups herein.

2.) Call out proposed riser room for each building. Are any FDC lines to be installed? If so indicate locations.
3.) Provide fully restrained joint pipe where required per MAG and City standards e.g. 90 degree bends.
4.) Stipulation: Proposed meter to be within meter vault as currently sized. Note that meter credit for existing meters to be removed/abandoned should be pursued/applied.

5.) Stipulation: meter and service line removal shall be removed back to the main, i.e. do not leave water service line(s) "stubbed out" at the property line.
6.) Address comments on utility plan.




3@engineering

lanning civil engineering

surveying

SOUTHDALE Final Water Basis of Design Report 3 engineering Job #: 1872 April 23, 2021





## SOUTHDALE

## FINAL WATER BASIS OF DESIGN REPORT

Prepared for:

Hawkins Companies LLC 4700 S. McClintock Drive #160 Scottsdale, Arizona 85257 Contact: Mark Mitchell Phone: (480) 223-8239



Daniel G. Mann, P.E.

April 23, 2021

### Submittal to:

City of Scottsdale 7447 E. Indian School Road, Suite 105 Scottsdale, AZ 85251

### Prepared by:

3 engineering, LLC 6370 E. Thomas Road, Suite #200 Scottsdale, Arizona 85251 Contact: Dan G. Mann, P.E.

### Job Number 1872





#### Table of Contents

#### Page

1.	Introduction	1
2.	Existing Conditions	1
3.	Proposed Conditions	1
4.	Required Computations & Hydraulic Modeling	1
5.	Summary	3

#### <u>Tables</u>

TABLE 1: On-Site Water	Demands	2

### **Appendices**

Vicinity Map	A
Fire Flow Test Results	
WaterCAD Results	C
Preliminary Water Plans	D

# engineerir

planning

civil engineering

#### 1. Introduction

The project site, Southdale, is located in the southeast quarter of Section 34, Township 2 North, Range 4 East of the Gila and Salt River Meridian, Maricopa County, Arizona within the City of Scottsdale. The project is located at 7000 E. McDowell Road, Scottsdale, AZ 85257. The site is bounded on the north by an apartment complex, on the east by a commercial development, on the south by McDowell Road, and on the west by 70<sup>th</sup> Street. See Appendix A for a site map.

The existing zoning is C-3. The land is currently used as a commercial development. The General Plan shows the site as a Mixed-Use Neighborhood. The proposed zoning is PUD. The site is a proposed 267-unit apartment complex with office and retail space.

#### 2. Existing Conditions

The existing zoning is C-3. The existing land is a commercial development. See Appendix A for a site map. The site is surrounded by existing multi-family residential development and commercial development.

The site currently has a 6" D.I.P. private fireline with fire hydrants. The fireline is tied into an existing 8" A.C.P. water main in 70th Street, west of the site. There is also an existing 12" A.C.P. waterline in McDowell Road, south of the site, and an existing 6" A.C.P. private waterline in APN 129-33-020A, east of the site. See Water Plans in Appendix D for existing waterline layout.

The certified flow test can be found in Appendix B. The static pressure of the existing system was 72.0 psi and the residual pressure was 54.0 psi at 2,392 gpm with a 16.0 psi factor of safety. The test was taken at two hydrants in 70<sup>th</sup> Street, west of the site.

#### 3. <u>Proposed Conditions</u>

The project consists of a 267-unit apartment complex with 3,300 s.f. of office space and 2,200 s.f. of retail space on 3.83 acres. The proposed building has a fire flow demand of 2,000 gpm based on Table B105.1 of the International Fire Code. This is using the total square footage of the building which is 285,240 s.f. and a construction type of V-B and a 75% reduction for automatic fire sprinklers. However, the minimum fire flow for high rise structures per the City of Scottsdale DSPM is 2,500 gpm. The existing private fire line and hydrants within the site will be removed and the proposed water system is to be public and is to be maintained by the City of Scottsdale. The system will connect to the existing 8" A.C.P. waterline in 70th Street and the existing 12" A.C.P. waterline in McDowell Road. The proposed water system includes four (4) new fire hydrants, connected by 8" D.I.P. waterline. Additionally, the water system will connect to the existing 6" ACP waterline stub in APN 129-33-020A at the northeast corner of the site. See Water Plans in Appendix D for proposed waterline layout, pipe sizes and material.

#### 4. <u>Required Computations & Hydraulic Modeling</u>

The purpose of this basis of design report is to verify that the existing City of Scottsdale water system is able to accommodate demands generated by the proposed project, Southdale. Demands were calculated using Figure 6.1-2 of the City of Scottsdale Design Standards and Policies Manual dated 2018. It is our opinion that this report is in accordance with the 2018 City of Scottsdale Design Standards and Policies Manual.

Page | 1



Not a high-rise per IBC, but OK conservative assumption

The following demand criteria were used in determining the system demands for the proposed site.

gpm

- 1. 267 proposed units
- 2. 3.83 acre site (70 du/ac)
- 3. 0.27 gallons per minute per unit (per Figure 6.2 of D.S.&P.M. 2018 for Residential Demand, High density Condo)
- 4. 3,300 s.f. proposed Office Space
- 5. 0.000834 gallons per day per square foot (Per DSPM, Office)
- 6. 2,200 s.f. proposed Retail Space
- 7. 0.0011 gallons per day per square foot (Per DSPM, Commercial/Retail)
- 8. Proposed Building = 285,240 s.f., Building type V-B, per Table B105.1 of the 2015 International Fire Code the fire flow = 8,000 gpm, 75% reduction based on fully sprinklered buildings is 2,000 gpm, The minimum fire flow is 2,500 gpm for High Rise structures per City of Scottsdale DSPM section 6-1.501. Fire Flow = 2,500 gpm.
- 9. Max day flow = 2.0 x average day demand
- 10. Peak hour flow = 3.5 x average day demand

TABLE 1: ON-SITE WATER DEMANDS						
Avg. daily demand	77.28 gpm					
Max day demand	154.56 gpm					
Peak hour flow rate	270.48 gpm					
Fire flow	2,500 gpm					
Fire flow + Max Day	2,654.56 gpm					

Average Daily Demand Residential: 267-units x 0.27 gpmpu = 72.09 gpm

Average Daily Demand Office: 3,300 s.f. x 0.000834 gpmpsf = 2.75 gpm

Average Daily Demand Retail: 2,200 s.f. x 0.00111 gpmpsf = 2.44 gpm

Total Average Daily Demand = 77.28 gpm

Max Day Demand =  $2.0 \times 77.28 \text{ gpm} = 154.56 \text{ gpm}$ 

Peak Hour Flow rate = 3.5 x 77.28 gpm = 270.48 gpm

Bentley WaterCAD V8i was used to model the proposed water system. The WaterCAD system was modeled with a connection to the existing public water system in the 12" waterline in McDowell Road using a reservoir and a pump with a curve determined from the flow test results. The Fire Flow + Max Day demand for the site is 2,654.56 gpm. At this flow, the minimum pressure in the system exceeds the City of Scottsdale Requirement of 30 psi minimum under fire flow conditions. The proposed pipes have velocities less than 10 fps. Therefore, the proposed water system is adequate to support the proposed improvements for the site. See WaterCAD Results in Appendix C.





5. Summary

The Peak Hourly Flow for the proposed site is 270.48 gpm.

The fire flow for the Proposed building is 2,500 gpm based on the minimum fire flow for high rise structures per City of Scottsdale DSPM.

The system meets minimum pressure requirements at Fire Flow + Max Day demand.


Page | 3 17-DR-2021 5/6/2021

3 engineering surveying planning

## APPENDIX A

# Vicinity Map

Page | A1



N.T.S.

<u>3®engineering</u> civil engineering planning surveying

## APPENDIX B

## Fire Flow Test Results

Page | A2 17-DR-2021 5/6/2021

## HYDRANT FLOW TEST REPORT

Project Name: Project Address: Client Project No.: Arizona Flow Testing Proje Flow Test Permit No.: Date and time flow test con Data is current and reliable Conducted by: Coordinated by:	70th Street & Not Provided ct No.: 20109 C61639 ducted: March 20, 20 until: September 20 Floyd Vaugha				
Raw Test Data		Data with 16 PSI Safety	y Factor Scottsdale requires a maximum Static		
Static Pressure: (Measured in pounds per se	<b>88.0 PSI</b> quare inch)	Static Pressure: (Measured in pounds pe	72.0 PSI Pressure of 72 PSI		
Residual Pressure: (Measured in pounds per se	<b>70.0 PSI</b> quare inch)	Residual Pressure: (Measured in pounds pe	<b>54.0 PSI</b> er square inch)		
Pitot Pressure:	31.0 PSI				
(Measured in pounds per se	quare inch)				
Diffuser Orifice Diameter: ( (Measured in inches)	One 4-inch Pollard Diffuser	Distance between hydra Main size: Not Provide			
Coefficient of Diffuser: 0.9					
Flowing GPM: (Measured in gallons per m	<b>2,392 GPM</b> inute)	Flowing GPM:	2,392 GPM		
GPM @ 20 PSI:	4,904 GPM	GPM @ 20 PSI:	4,243 GPM		
Flow Test Location	Nort	.њ 🕇			
Flow Fire Hydrant			Project Site 70th Street & McDowell (NEC) East McDowell Road		

Arizona Flow Testing LLC 480-250-8154 <u>www.azflowtest.com</u> floyd@azflowtest.com

<u>3@engineering</u> civil engineering planning surveying


## APPENDIX C

## WaterCAD Results

Page | A3 17-DR-2021 5/6/2021

Element Details			
ID	67	Notes	
Label	2020_05_20_ Flow_Test		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	124.74 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	4,243 gpm
Shutoff Head	166.32 ft	Maximum Operating Head	46.20 ft
Design Flow	2,392 gpm		
Pump Efficiency			
· ·····[· =·······			
Pump Efficiency	Best Efficiency Point	Motor Efficiency	100.0 %
	Efficiency	Motor Efficiency Is Variable Speed Drive?	100.0 % False
Pump Efficiency	Efficiency Point		
Pump Efficiency BEP Efficiency	Efficiency Point 100.0 %		
Pump Efficiency BEP Efficiency BEP Flow	Efficiency Point 100.0 %		


#### Pump Definition Detailed Report: 2020\_05\_20\_Flow\_Test



Pump Definition Detailed Report: 2020\_05\_20\_Flow\_Test

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 2 of 2





1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Hydrant Table (1872\_with\_pump.wtg)

I	D	Label	Hydrant Status	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
	28	H-1	Closed	45.27	0	200.82	67.3
	53	H-6	Closed	44.85	0	200.82	67.5
	54	H-7	Closed	44.48	0	200.83	67.6
	29	H-2	Closed	44.30	0	200.82	67.7
	31	H-4	Closed	42.50	77	200.81	68.5
	30	H-3	Closed	42.50	0	200.81	68.5

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

### FlexTable: Junction Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
50	J-3	38.26	<none></none>	0	200.82	70.3
49	J-2	37.17	<none></none>	0	200.83	70.8
48	J-1	34.58	<none></none>	0	200.83	71.9

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pipe Table (1872\_with\_pump.wtg)

ID	Label	Length (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
65	P-14	1	J-1	PMP-1	48.0	Ductile Iron	130.0	-77	0.01	0.000
66	P-15	1	PMP-1	R-4	48.0	Ductile Iron	130.0	-77	0.01	0.000
59	P-10	398	J-2	J-1	12.0	Asbestos Cement	140.0	-20	0.06	0.000
35	P-1	62	J-3	H-1	8.0	Ductile Iron	130.0	20	0.13	0.000
36	P-2	321	H-1	H-2	8.0	Ductile Iron	130.0	20	0.13	0.000
37	P-3	409	H-2	H-3	8.0	Ductile Iron	130.0	20	0.13	0.000
38	P-4	432	H-3	H-4	8.0	Ductile Iron	130.0	20	0.13	0.000
56	P-7	71	J-3	H-6	8.0	Asbestos Cement	140.0	-20	0.13	0.000
57	P-8	157	H-6	H-7	8.0	Asbestos Cement	140.0	-20	0.13	0.000
58	P-9	108	H-7	J-2	8.0	Asbestos Cement	140.0	-20	0.13	0.000
39	P-5	215	H-4	J-1	8.0	Ductile Iron	130.0	-58	0.37	0.000

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pump Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
64	PMP-1	34.58	2020_05_20_Flow_T est	On	34.58	200.83	77	166.25

#### Current Time: 0.000 hours


1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1


### FlexTable: Reservoir Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
52	R-4	34.58	<none></none>	77	34.58

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1





1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Hydrant Table (1872\_with\_pump.wtg)

ID	Label	Hydrant Status	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
28	H-1	Closed	45.27	0	200.62	67.2
53	H-6	Closed	44.85	0	200.63	67.4
54	H-7	Closed	44.48	0	200.63	67.6
29	H-2	Closed	44.30	0	200.61	67.6
31	H-4	Closed	42.50	155	200.57	68.4
30	H-3	Closed	42.50	0	200.59	68.4

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

### FlexTable: Junction Table (1872\_with\_pump.wtg)

ID	Label	(ft)		Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	
50	J-3	38.26	<none></none>	0	200.62	70.2	
49	J-2	37.17	<none></none>	0	200.64	70.7	
48	J-1	34.58	<none></none>	0	200.64	71.8	

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pipe Table (1872\_with\_pump.wtg)

ID	Label	Length (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
66	P-15	1	PMP-1	R-4	48.0	Ductile Iron	130.0	-155	0.03	0.000
65	P-14	1	J-1	PMP-1	48.0	Ductile Iron	130.0	-155	0.03	0.000
59	P-10	398	J-2	J-1	12.0	Asbestos Cement	140.0	-39	0.11	0.000
35	P-1	62	J-3	H-1	8.0	Ductile Iron	130.0	39	0.25	0.000
36	P-2	321	H-1	H-2	8.0	Ductile Iron	130.0	39	0.25	0.000
37	P-3	409	H-2	H-3	8.0	Ductile Iron	130.0	39	0.25	0.000
38	P-4	432	H-3	H-4	8.0	Ductile Iron	130.0	39	0.25	0.000
56	P-7	71	J-3	H-6	8.0	Asbestos Cement	140.0	-39	0.25	0.000
57	P-8	157	H-6	H-7	8.0	Asbestos Cement	140.0	-39	0.25	0.000
58	P-9	108	H-7	J-2	8.0	Asbestos Cement	140.0	-39	0.25	0.000
39	P-5	215	H-4	J-1	8.0	Ductile Iron	130.0	-115	0.74	0.000

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pump Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
64	PMP-1	34.58	2020_05_20_Flow_T est	On	34.58	200.64	155	166.06

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1


### FlexTable: Reservoir Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
52	R-4	34.58	<none></none>	155	34.58

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1





1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Hydrant Table (1872\_with\_pump.wtg)

ID	Label	Hydrant Status	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
28	H-1	Closed	45.27	0	200.11	67.0
53	H-6	Closed	44.85	0	200.13	67.2
54	H-7	Closed	44.48	0	200.15	67.3
29	H-2	Closed	44.30	0	200.07	67.4
31	H-4	Closed	42.50	270	199.96	68.1
30	H-3	Closed	42.50	0	200.02	68.2

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

### FlexTable: Junction Table (1872\_with\_pump.wtg)

ID	Label	(ft)		Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	
50	J-3	38.26	<none></none>	0	200.12	70.0	
49	J-2	37.17	<none></none>	0	200.16	70.5	
48	J-1	34.58	<none></none>	0	200.16	71.6	

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pipe Table (1872\_with\_pump.wtg)

ID	Label	Length (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
65	P-14	1	J-1	PMP-1	48.0	Ductile Iron	130.0	-270	0.05	0.000
66	P-15	1	PMP-1	R-4	48.0	Ductile Iron	130.0	-270	0.05	0.000
59	P-10	398	J-2	J-1	12.0	Asbestos Cement	140.0	-69	0.20	0.000
35	P-1	62	J-3	H-1	8.0	Ductile Iron	130.0	69	0.44	0.000
36	P-2	321	H-1	H-2	8.0	Ductile Iron	130.0	69	0.44	0.000
37	P-3	409	H-2	H-3	8.0	Ductile Iron	130.0	69	0.44	0.000
38	P-4	432	H-3	H-4	8.0	Ductile Iron	130.0	69	0.44	0.000
56	P-7	71	J-3	H-6	8.0	Asbestos Cement	140.0	-69	0.44	0.000
57	P-8	157	H-6	H-7	8.0	Asbestos Cement	140.0	-69	0.44	0.000
58	P-9	108	H-7	J-2	8.0	Asbestos Cement	140.0	-69	0.44	0.000
39	P-5	215	H-4	J-1	8.0	Ductile Iron	130.0	-202	1.29	0.001

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pump Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
64	PMP-1	34.58	2020_05_20_Flow_T est	On	34.58	200.16	270	165.58

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1


### FlexTable: Reservoir Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
52	R-4	34.58	<none></none>	270	34.58

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

Scenario: Max Day + Fire Flow



1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Hydrant Table (1872\_with\_pump.wtg)

ID	Label	Hydrant Status	Elevation (ft)	Demand (gpm)		$\sim$	ic Grade t)	Press (ps		
29	H-2	Closed	44.30	<mark>&gt; 1</mark>	,327	2	129.36		36.8	
30	H-3	Closed	42.50	1 ک	,327	2	129.38		37.6	
28	H-1	Closed	45.27	<u> </u>	<del>ro</del>	$\prec$	138.71		40.4	
53	H-6	Closed	44.85		0		142.34		42.2	
31	H-4	Closed	42.50		0		143.48		43.7	
54	H-7	Closed	44.48		0		146.33		44.1	
							: worse s, good			

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

### FlexTable: Junction Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
50	J-3	38.26	<none></none>	0	140.52	44.2
49	J-2	37.17	<none></none>	0	149.08	48.4
48	J-1	34.58	<none></none>	0	150.48	50.1

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pipe Table (1872\_with\_pump.wtg)

ID	Label	Length (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
37	P-3	409	H-2	H-3	8.0	Ductile Iron	130.0	-40	0.26	0.000
65	P-14	1	J-1	PMP-1	48.0	Ductile Iron	130.0	-2,655	0.47	0.000
66	P-15	1	PMP-1	R-4	48.0	Ductile Iron	130.0	-2,655	0.47	0.000
59	P-10	398	J-2	J-1	12.0	Asbestos Cement	140.0	-1,287	3.65	0.004
35	P-1	62	J-3	H-1	8.0	Ductile Iron	130.0	1,287	8.22	0.029
36	P-2	321	H-1	H-2	8.0	Ductile Iron	130.0	1,287	8.22	0.029
56	P-7	71	J-3	H-6	8.0	Asbestos Cement	140.0	-1,287	8.22	0.025
57	P-8	157	H-6	H-7	8.0	Asbestos Cement	140.0	-1,287	8.22	0.025
58	P-9	108	H-7	J-2	8.0	Asbestos Cement	140.0	-1,287	8.22	0.025
38	P-4	432	H-3	H-4	8.0	Ductile Iron	130.0	-1,367	8.73	0.033
39	P-5	215	H-4	J-1	8.0	Ductile Iron	130.0	-1,367	8.73	0.033

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

#### FlexTable: Pump Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
64	PMP-1	34.58	2020_05_20_Flow_T est	On	34.58	150.48	2,655	115.90

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

### FlexTable: Reservoir Table (1872\_with\_pump.wtg)

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
52	R-4	34.58	<none></none>	2,655	34.58

#### Current Time: 0.000 hours

1872\_with\_pump.wtg 6/26/2020 Bentley Systems, Inc. Haestad Methods Solution Center 27 Siemon Company Drive Suite 200 W Watertown, CT 06795 USA +1-203-755-1666 Bentley WaterCAD V8i (SELECTseries 3) [08.11.03.17] Page 1 of 1

<u>3@engineering</u> civil engineering planning surveying

## APPENDIX D

## Preliminary Water Plans

Page | A4 **17-DR-2021** 5/6/2021

## LEGAL DESCRIPTION:

THAT PORTION OF THE SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER OF SECTION 34, TOWNSHIP 2 NORTH, RANGE 4 EAST OF THE GILA AND SALT RIVER BASE AND MERIDIAN, MARICOPA COUNTY, ARIZONA, MORE PARTICULARLY DESCRIBED AS FOLLOWS:

BEGINNING AT A POINT ON THE NORTH LINE OF THE SOUTH HALF OF SAID SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER, A DISTANCE OF 380.00 FEET EAST OF THE WEST LINE OF SAID SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER:

THENCE WEST ALONG SAID NORTH LINE TO A POINT ON THE EAST LINE OF A NORTH-SOUTH ALLEY AS SHOWN ON THE PLAT OF WONDERLAND, ACCORDING TO BOOK 100 OF MAPS, PAGE 19, RECORDS OF MARICOPA COUNTY. ARIZONA:

THENCE SOUTH ALONG THE EAST LINE OF AFORESAID ALLEY TO AN ANGLE POINT THEREON;

THENCE WEST ALONG THE SOUTH LINE OF AN EAST-WEST ALLEY AS SHOWN ON AFORESAID PLAT OF WONDERLAND, TO A POINT ON THE EAST LINE OF 70TH STREET AS SHOWN ON AFORESAID PLAT:

THENCE SOUTH ALONG SAID EAST LINE, A DISTANCE OF 253.88 FEET TO THE BEGINNING OF A CURVE TO THE LEFT HAVING A CENTRAL ANGLE OF 91 DEGREES 14 MINUTES 49 SECONDS AND A TANGENT OF 20.00 FEET;

THENCE SOUTHEASTERLY ALONG SAID CURVE TO THE LEFT, AN ARC DISTANCE OF 31.17 FEET;

THENCE SOUTH PARALLEL WITH THE WEST LINE OF THE SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER OF SAID SECTION 34, A DISTANCE OF 65.00 FEET TO A POINT ON THE SOUTH LINE OF THE SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER OF SAID SECTION 34, FROM WHICH THE SOUTHWEST CORNER THEREOF BEARS WEST, A DISTANCE OF 52.42 FEET; THENCE EAST ALONG THE SOUTH LINE OF THE SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER OF SAID SECTION 34, TO A POINT 380.00 FEET EAST OF THE SOUTHWEST CORNER OF SAID SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER;


THENCE NORTH ALONG A LINE PARALLEL TO AND 380.00 FEET EAST OF THE WEST LINE OF SAID SOUTHEAST QUARTER OF THE SOUTHEAST QUARTER TO THE POINT OF BEGINNING;


EXCEPT THE SOUTH 65.00 FEET THEREOF.

## GENERAL NOTES FOR PUBLIC WORKS CONSTRUCTION:

- 1. ALL CONSTRUCTION IN THE PUBLIC RIGHTS-OF-WAY OR IN EASEMENTS GRANTED FOR PUBLIC USE MUST CONFORM TO THE LATEST MARICOPA ASSOCIATION OF GOVERNMENTS (MAG) UNIFORM STANDARD SPECIFICATIONS AND UNIFORM STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION AS AMENDED BY THE LATEST VERSION OF THE CITY OF SCOTTSDALE STANDARD SPECIFICATIONS AND SUPPLEMENTAL STANDARD DETAILS. IF THERE IS A CONFLICT, THE CITY'S SUPPLEMENTAL STANDARD DETAILS WILL GOVFRN.
- 2. THE CITY ONLY APPROVES THE SCOPE, NOT THE DETAIL OF ENGINEERING DESIGNS; THEREFORE IF CONSTRUCTION QUANTITIES ARE SHOWN ON THESE PLANS, THEY ARE NOT VERIFIED BY THE CITY.
- 3. THE APPROVAL OF PLANS IS VALID FOR SIX (6) MONTHS. IF ASSOCIATED PERMIT HAS NOT BEEN ISSUED WITHIN THIS TIME FRAME, THE PLANS MUST BE RESUBMITTED TO THE CITY FOR RE-APPROVAL.
- 4. A CITY INSPECTOR WILL INSPECT ALL WORKS WITHIN THE CITY OF SCOTTSDALE. NOTIFY INSPECTION SERVICES 72 HOURS BEFORE BEGINNING WORK.
- 5. WHENEVER EXCAVATION IS NECESSARY, CALL THE BLUE STAKE CENTER, 811. TWO WORKING DAYS BEFORE EXCAVATION BEGINS.
- 6. PERMISSION TO WORK IN THE RIGHT-OF-WAY (PWR) PERMITS ARE REQUIRED FOR ALL WORKS WITHIN THE RIGHTS-OF-WAY AND EASEMENTS GRANTED FOR PUBLIC PURPOSES. COPIES OF ALL PERMITS MUST BE RETAINED ON-SITE AND BE AVAILABLE FOR INSPECTION AT ALL TIMES. FAILURE TO PRODUCE THE REQUIRED PERMITS WILL RESULT IN IMMEDIATE SUSPENSION OF ALL WORK UNTIL THE PROPER PERMIT DOCUMENTATION IS OBTAINED.

UTILITY	UTILITY COMPANY	NAME OF COMPANY REPRESENTATIVE	TELEPHONE NUMBER	DATE SIGNED	
ELECTRIC	APS				
TELEPHONE	CENTURY LINK				
NATURAL GAS	SOUTHWEST GAS				
CABLE TV	COX COMMUNICATIONS				
OTHER	A.T.&T.				
OTHER					
ENGINEER'S CERTIFICATION					
I <u>DANIEL G. MANN</u> , AS THE ENGINEER OF RECORD FOR THIS DEVELOPMENT, HEREBY CERTIFY THAT ALL UTILITY COMPANIES LISTED ABOVE HAVE BEEN PROVIDED FINAL IMPROVEMENT PLANS FOR REVIEW, AND THAT ALL CONFLICTS IDENTIFIED BY THE UTILITIES HAVE BEEN RESOLVED. IN ADDITION "NO CONFLICT" FORMS HAVE BEEN OBTAINED FROM EACH UTILITY COMPANY AND ARE INCLUDED IN THIS SUBMITTAL.					





COMMUNITY NUMBER	PANEL NUMB				
045012	2235				

ENGINEER'S CERTIFICATION: THE LOWEST FINISH FLOOR ELEVATION(S) AND/OR FLOOD PROOFING ELEVATION(S) ON THIS PLAN ARE SUFFICIENTLY HIGH TO PROVIDE PROTECTION FROM FLOODING CAUSED BY A 100-YEAR STORM, AND ARE IN ACCORDANCE WITH SCOTTSDALE REVISED CODE, CHAPTER 37 - FLOODPLAIN AND STORMWATER REGULATION.

SIGNATURE

DATE

# PRELIMINARY UTILITY PLAN FOR SOUTHDALE 7000 E. MCDOWELL ROAD, SCOTTSDALE, ARIZONA 85257 LOCATED IN A PORTION OF THE SOUTHEAST QUARTER OF SECTION 34, TOWNSHIP 2 NORTH, RANGE 4 EAST

OF THE GILA AND SALT RIVER MERIDIAN, MARICOPA COUNTY, ARIZONA

INDEX OF SHEETS				
SHEET NO.	DESCRIPTION			
PUTL101	COVER SHEET - PRELIMINARY UTILITY PLAN			
PUTL102	PRELIMINARY UTILITY PLAN			
PUTL103	PRELIMINARY UTILITY PLAN			

## FLOOD INSURANCE RATE MAP (FIRM) INFORMATION:

BER	PANEL DATE	SUFFIX	FIRM DATE	FIRM ZONE	BASE FLOOD ELEVATION
	OCTOBER 16,2013	L	OCTOBER 16,2013	х	NZA

	• ]
	— ]
58	- ]
TC: 59.13 <i>t</i> G: 58.64	I
	I
+ 62.52 + P: 60.11	I
+ C: 56.69	J
× 15.9	J
<u> </u>	I
<b>♦</b> GB	I
GB P=	]
<u>C=</u>	I
G=	Ι
LF <sub>88</sub> =	Ι
WW	- I
S	- I
	I
•	Ι
	T
	I = I
• • •	
	= I
0	= I I
0 &	= I I I I
<b>0</b> & FH <b>@</b>	= I I I I I
● FH ⊕ 24" SD	= I I I I I
● <i>FH</i> ● 24" SD <i>8</i> " S 	= I I I I I I
● <i>FH</i> ● 24" SD 	= I I I I I I I
● <i>FH</i> ● 24" SD <i>8</i> " S 	= I I I I I I
● <i>FH</i> ● <i>−24" SD</i> <i>−12" W</i> ( <i>ACP</i> ) <i>WV</i> <i>−E</i> <i>G</i> <i>−OHE</i>	= I I I I I I I I I I
● FH ● 24" SD 	I = I I I I I I I I I I
● FH ● -24" SD -24" SD -12" W (ACP) WV E -12" W (ACP) WV 	= I I I I I I I I I I
	I = I I I I I I I I I I I I I I I I I
● FH ● -24" SD -24" SD -12" W (ACP) WV E -12" W (ACP) WV 	= I I I I I I I I I I I I
	I = I I I I I I I I I I I I I I I I I

INDICATES	PROPERTY	r / Bour
INDICATES	EXISTING	CONTOU
INDICATES	PROPOSED	) CONTOL
INDICATES	EXISTING	TOP OF
INDICATES	EXISTING	GUTTER
INDICATES	EXISTING	GROUND
INDICATES INDICATES	EXISTING EXISTING	PAVEMEI CONCRE <sup>-</sup>
INDICATES	PROPOSE	
INDICATES	DIRECTIO	N OF FL(
INDICATES	GRADE BF	REAK
INDICATES	PROPOSED	) PAVEM
INDICATES	PROPOSED	) TOP OF
INDICATES	PROPOSED	) GUTTEF
INDICATES	LOWEST F	TINISH FL
INDICATES	PROPOSED	WATERL
INDICATES	PROPOSED	SEWERL
INDICATES	PROPOSED	METER
INDICATES	PROPOSED	SEWER
INDICATES	PROPOSED	САТСН
INDICATES	PROPOSED	STORM
INDICATES	PROPOSED	STORM
INDICATES	PROPOSED	FIRE H
INDICATES	EXISTING	FIRE HY
INDICATES	EXISTING	STORM
INDICATES	EXISTING	SEWER L
INDICATES	EXISTING	WATER L
INDICATES	EXISTING	BURIED
INDICATES	EXISTING	GAS LIN
INDICATES	EXISTING	OVERHEA
INDICATES	EXISTING	POWER F
INDICATES	EXISTING	LIGHT P
INDICATES	EXISTING	ELECTRI
INDICATES	EXISTING	ELECTRI
INDICATES	EXISTING	WATER M
INDICATES	EXISTING	BACKFLC



5/6/2021

