

From: Jeff Fordyce <jfordyce@calpool.com>
Sent: Thursday, August 5, 2021 9:54 AM
To: Chantel Kimmins
Subject: Southdale - Filter Backwash Flow Restriction

Chantel

The only way we could slow it down to that slow of a GPM is to do a holding tank, I'd recommend a 500 gallon (or closest to this so we don't have to worry about a custom size). We'd run the backwash line over to the tank, the valve at the bottom would have a short piece of plumbing with a ball valve and flow meter so the GPM's could be monitored visually

Thanks,

Jeff Fordyce, Commercial Project Manager

4320 W Chandler Blvd Ste #1
Chandler, AZ, 85226
480-756-5617 Office
480-349-8915 Mobile
480-756-7088 Fax

