

FINAL SEWER BASIS OF DESIGN REPORT FOR WESTERN TECH OFFICE

Scottsdale, Arizona

January 19th, 2022

DEVELOPER

Capital Project Management
7447 East Indian School Road, #205
Scottsdale, Arizona 85251

SITE ADDRESS

1395 North Hayden Road
Scottsdale, Arizona 85257

PREPARED BY



4450 north 12th street, #228
phoenix, arizona 85014
CYPRESS # 21.148



TABLE OF CONTENTS

INTRODUCTION	1
EXISTING CONDITIONS	1
PROPOSED CONDITIONS	1
REQUIRED COMPUTATIONS	1
CONCLUSION	2
APPENDICES	
A	City of Scottsdale Sewer Quarter Section Map
B	Sewer Flow Calculation

INTRODUCTION: PROJECT DESCRIPTION AND LOCATION

The Project is known as 'Western Tech Office' and is located at 1395 North Hayden Road in Scottsdale, Arizona. The proposed project consists of the renovation and remodel of the existing office building and parking area.

The utility provider for sewer facilities is the City of Scottsdale.

EXISTING CONDITIONS

Per available utility maps and as-built records, an existing 8" PVC sewer main is located in the dedicated private roadway northwest of the Project. The existing building is 42,440 sf and is connected to the said main for sewer service via a 6" sewer lateral. The new building expansion area is 6,200 sf. Refer to Appendix A for City of Scottsdale Sewer Quarter Section Map.

PROPOSED CONDITIONS

The existing building is intended to maintain its current office use. An addition of approximately 6,200 sf of building at the northeast corner of the Project as part of the redevelopment. The redeveloped building will have 48,640 square feet. The design team intends to retain the existing sewer service connection for the redeveloped building. The sewer service is anticipated to provide adequate sizing to service the expanded office.

REQUIRED COMPUTATIONS

EXISTING SEWER DEMAND:

Average Day Demand (Bar/Restaurant): $0.4 \text{ GPD/SF} \times 42,440 \text{ SF} = 16,976 \text{ GPD}$

Peak Demand(Bar/Restaurant): $3 \times 16,976 = 50,928 \text{ GPD}$

PROPOSED SEWER DEMAND:

Average Day Demand (Bar/Restaurant): $0.4 \text{ GPD/SF} \times 48,640 \text{ SF} = 19,456 \text{ GPD}$

Peak Demand (Bar/Restaurant): $3 \times 19,456 = 58,368 \text{ GPD}$

The proposed demand will increase from the existing condition. A sewer flow calculation demonstrates that the capacity in the sewer service connection is an order of magnitude larger than the projected flows. See Appendix B for Sewer Flow Calculation.

CONCLUSION

CYPRESS respectfully submits this report as the Final Wastewater Design Report for the proposed the Western Tech Office Development. The proposed wastewater system shall be designed in accordance with ADEQ, International Building Code, and the City of Scottsdale standards.

Appendix A
City of Scottsdale Sewer Quarter Section Map

sewer

87/030627

(1435)

N.F.
N.F.

1218.43
1+69

N.F.
N.F.

N.F.
N.F.

N.F.
N.F.

N COMMERCE CT

16' 16"

1219.05
0+85

1218.95
0+81

131-09-002L
91/156441

(1395)

D2K
27

1218.29
0+86

1218.49
0+70

8" VCP

8" VCP



MCDOWELL ROAD

MOTOROLA ACCESS DRIVE



Sewer Cleanout
MAG Det. 441
(Typical) AB

FOR SANITARY SEWER
PROFILE SEE SHEET 7

6" FIRE LINE
2" WATER SERV.
6" SEWER SERV.
(TYP)

75% Pvm & Replmnt.
MAG Det. 200 Type "B" AB

5' Dia. Precast M.H.
MAG Det. 420
Break Into Exist. 36" Line
Drop Sewer Conn. AB
MAG Det. 426 Type "B"

Bench Mark = Rebar in H.H. @ Intersection of Hayden Rd.
& McDowell Rd. ELEV. = 1219.56
Bench Mark = B.C. on S.E. Cor. of Irr. Structure
S.W. Cor. of Intersection of Hayden Rd.
& McDowell Rd. ELEV. = 1220.80

NOTE: Survey Data Supplied by P.C.I. Assoc.
April 13, 1983

AB = "As-Built"
AS = "As-Stamped"



9374

SCOTTSDALE COMMERCE CENTRE

ON-SITE SEWER PLAN

DESIGN	J.R.W.	SCALE	1" = 40'	JOB NO.	6513	DATE	3-3-84	SHEET	6 OF 8
DRAWN	J.R.W.	CHECK	R.B.A.						

ellis-murphy
SURVEYING ENGINEERS / LAND SURVEYORS

CAUTION - High Pressure
Gas Line in This Area

Revision:
Added Future 48" Water Line 5-16-84 L.S.

532P84

Appendix B
Sewer Flow Calculation



Sewer Design Report Calculations

Western Tech Office

Sewage Flow Per Day (From DSPM 7-1.403)

Total Flow (GPD)	19,456
Dry Peaking Factor	3.000
Dry Peak Flow (GPD)	58,368

$$Q = \frac{1.49}{n} AR^{2/3} S^{1/2}$$

Where:

Q = flow in cfs

n = Manning's Roughness Coefficient

A = Cross sectional area of flow

SYSTEM MINIMUM SLOPE

n =	0.013
Pipe diameter (in) =	6
Pipe Slope (ft/ft) =	0.005

SYSTEM MAXIMUM SLOPE

n =	0.013
Pipe diameter (in) =	6
Pipe Slope (ft/ft) =	0.02

Full Flow*

Depth of flow (in) =	4.50
φ (radian) =	4.19
Area (in ²) =	22.75
Wetted Perimeter (in) =	12.57
Hydraulic Radius (in) =	1.81
Velocity (ft/sec) =	2.30
d/D ratio =	0.75
Pipe Capacity (GPD)	234,450

Full Flow*

Depth of flow (in) =	4.50
φ (radian) =	4.19
Area (in ²) =	22.75
Wetted Perimeter (in) =	12.57
Hydraulic Radius (in) =	1.81
Velocity (ft/sec) =	4.59
d/D ratio =	0.75
Pipe Capacity (GPD)	468,899

Design Flow

Depth of flow (in) =	3.79
φ (radian) =	3.68
Area (in ²) =	18.84
Wetted Perimeter (in) =	11.03
Hydraulic Radius (in) =	1.71
Velocity (ft/sec) =	2.21
d/D ratio =	0.63

Design Flow

Depth of flow (in) =	2.60
φ (radian) =	2.87
Area (in ²) =	11.74
Wetted Perimeter (in) =	8.62
Hydraulic Radius (in) =	1.36
Velocity (ft/sec) =	3.80
d/D ratio =	0.43

*Full Flow refers to d/D of 0.75 per AAC R18-9-E301.4.01.D.2.e