

# FINAL WATER BASIS OF DESIGN REPORT FOR WESTERN TECH OFFICE

Scottsdale, Arizona

January 19<sup>th</sup>, 2022

## DEVELOPER

Capital Project Management  
7447 East Indian School Road, #205  
Scottsdale, Arizona 85251

## SITE ADDRESS

1395 North Hayden Road  
Scottsdale, Arizona 85257

PREPARED BY



4450 north 12<sup>th</sup> street, #228  
phoenix, arizona 85014  
CYPRESS # 21.148



## TABLE OF CONTENTS

---

INTRODUCTION	1
EXISTING CONDITIONS	1
FIRE FLOW REQUIREMENTS	1
PROPOSED CONDITIONS	1
REQUIRED COMPUTATIONS	2
CONCLUSION	2
APPENDICES	
A	City of Scottsdale Water Quarter Section Map & Offsite Improvement Plan
B	Fire Flow Results

## **INTRODUCTION: PROJECT DESCRIPTION AND LOCATION**

The Project is known as 'Western Tech Office' and is located at 1395 North Hayden Road in Scottsdale, Arizona. The proposed project consists of the renovation and remodel of the existing office building and parking area.

The utility provider for water facilities is the City of Scottsdale.

## **EXISTING CONDITIONS**

Per available utility maps and as-built records, an existing 8" ACP water main is located in the dedicated private roadway northwest of the Project. The existing building is 42,440 sf and is connected to the said main for domestic service via a 2" meter. The new building expansion area is 6,200 sf. Refer to Appendix A for City of Scottsdale Water Quarter Section Map & Offsite Improvement Plan.

## **FIRE FLOW REQUIREMENTS**

The total building area after the redevelopment will be 48,640 square feet. The building is type VB construction. Per the International Fire Code, Table B105.1, the existing building with the new expansion requires a minimum fire flow of 6,000 GPM for a 5-hour duration. Per Table B105.2, the redeveloped building will have automatic sprinklers installed resulting in an allowable 75% reduction in fire flow requirements. Required fire flow will be 2,000 GPM for a 2-hour duration. A flow test was completed on October 5<sup>th</sup>, 2021 on the existing fire hydrant immediately west of the existing office building. 3,959 GPM is available at the existing fire hydrant after accounting for City of Scottsdale required PSI and Safety Factor adjustments. Refer to Appendix B for Fire Flow Results.

## **PROPOSED CONDITIONS**

The existing building is intended to maintain its current office use. An addition of approximately 6,200 sf of building at the northeast corner of the Project as part of the redevelopment. The redeveloped building will have 48,640 square feet. The design team intends to retain and reuse the existing 2" water service connection east of the redeveloped building. This is anticipated to provide adequate sizing and pressure to supply the intended domestic service to the building.

## **REQUIRED COMPUTATIONS**

### **EXISTING WATER DEMAND:**

**Average Day Demand (Office unit):**  $0.000834/\text{SF} \times 42,440 \text{ SF} = 35.56 \text{ GPM}$

**Peak Hour Demand:**  $3.5 \times 35.56 = 124.47 \text{ GPM}$

**Maximum Day Demand + Fire Flow Demand:**  $2 \times (35.56 \text{ GPM}) + 2,000 \text{ GPM} = 2,071.12 \text{ GPM}$

### **PROPOSED WATER DEMAND:**

**Average Day Demand (Bar/Restaurant unit):**  $0.000834/\text{SF} \times 48,640 \text{ SF} = 40.57 \text{ GPM}$

**Peak Hour Demand:**  $3.5 \times 40.57 = 141.98 \text{ GPM}$

**Maximum Day Demand + Fire Flow Demand:**  $2 \times (40.57 \text{ GPM}) + 2,000 \text{ GPM} = 2,081.14 \text{ GPM}$


Per the City of Scottsdale Design Standards & Policies Manual, Section 6-1.416 –M, minimum meter size is 2". The existing 2" water service from the west will be sufficient to support the minimum meter requirement.

## **CONCLUSION**

CYPRESS respectfully submits this report as the Final Water Design Report for the proposed Western Tech Office Development. The proposed water system shall be designed in accordance with ADEQ, International Building Code, and the City of Scottsdale standards.

Appendix A  
City of Scottsdale Water & Offsite Improvement Plan

water




131-09-002L  
91/156441  
(1395)



MCDOWELL ROAD

MOTOROLA ACCESS DRIVE



Sewer Cleanout  
MAG Det. 441  
(Typical)

FOR SANITARY SEWER  
PROFILE SEE SHEET 7

6" FIRE LINE  
2" WATER SERV.  
6" SEWER SERV.  
(TYP)

75% Pvm't Replcmnt.  
MAG Det. 200 Type "B"

5' Dia. Precast M.H.  
MAG Det. 420  
Break Into Exist. 36" Line  
Drop Sewer Conn. AB  
MAG Det. 426 Type "B"

Bench Mark = Rebar in H.W. @ Intersection of Hayden Rd.  
& McDowell Rd. ELEV. = 1219.56  
Bench Mark = B.C. on S.E. Cor. of Irr. Structure  
S.W. Cor. of Intersection of Hayden Rd.  
& McDowell Rd. ELEV. = 1220.80

NOTE: Survey Data Supplied by P.C.I. Assoc.  
April 13, 1983

AB = "As-Built"  
AS = "As-Shown"

263-1100

9374

HAYDEN ROAD

CAUTION-High Pressure  
Gas Line in This Area

SCOTTSDALE COMMERCE CENTRE					
ON-SITE SEWER PLAN					
DESIGN	J.R.W.	SCALE	JOB NO.	DATE	SHEET
DRAWN	J.R.W.	1"=40'	6513	3-3-84	7
CHECK	R.R.A.				6 OF 3
ellis-murphy civil engineering / land surveyors					

522P84

## Appendix B

### Fire Flow Test Results



# Arizona Flow Testing LLC

## HYDRANT FLOW TEST REPORT

Project Name:	Not Provided
Project Address:	1395 North Hayden Road, Scottsdale, Arizona, 85257
Client Project No.:	Not Provided
Arizona Flow Testing Project No.:	21535
Flow Test Permit No.:	C66449
Date and time flow test conducted:	October 5, 2021 at 7:20 AM
Data is current and reliable until:	April 5, 2022
Conducted by:	Floyd Vaughan – Arizona Flow Testing, LLC (480-250-8154)
Witnessed by:	Ray Padilla – City of Scottsdale-Inspector (602-541-0586)

### Raw Test Data

Static Pressure: **98.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **80.0 PSI**  
(Measured in pounds per square inch)

Pitot Pressure: **27.0 PSI**  
(Measured in pounds per square inch)

Diffuser Orifice Diameter: One 4-inch Pollard Diffuser  
(Measured in inches)

Coefficient of Diffuser: .9

Flowing GPM: **2,233 GPM**  
(Measured in gallons per minute)

GPM @ 20 PSI: **4,929 GPM**

### Data with 26 PSI Safety Factor

Static Pressure: **72.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **54.0 PSI**  
(Measured in pounds per square inch)

Distance between hydrants: Approx.: 360 Feet

Main size: Not Provided

Flowing GPM: **2,233 GPM**

GPM @ 20 PSI: **3,959 GPM**

Scottsdale requires a maximum Static Pressure of 72 PSI for AFES Design.

### Flow Test Location

North ↑

