

# Optima McDowell Mountain Village

Scottsdale, Arizona

## PRELIMINARY WATER BASIS OF DESIGN REPORT

### PRELIMINARY Basis of Design Report

- ACCEPTED
- ACCEPTED AS NOTED
- REVISE AND RESUBMIT



Disclaimer: If accepted; the preliminary approval is granted under the condition that a final basis of design report will also be submitted for city review and approval (typically during the DR or PP case). The final report shall incorporate further water or sewer design and analysis requirements as defined in the city design standards and policy manual and address those items noted in the preliminary review comments (both separate and included herein). The final report shall be submitted and approved prior to the plan review submission.

For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY apritchard

DATE 9/21/2022



*Michael L. Delmarter*

EXP: 12/31/2023

SEPTEMBER 2022

Prepared By:

Kimley » Horn

## CONTENTS

Contents .....	2
Appendices .....	2
1.0 Introduction .....	3
2.0 Domestic Water Analysis .....	3
2.1 Intent and Scope.....	3
2.2 General Theory .....	3
2.3 Domestic Water Supply.....	3
2.4 International Fire Code, 2018 .....	4
2.5 Water Demands.....	5
3.0 Conclusion .....	10
4.0 References.....	10

## APPENDICES

- Appendix A: Vicinity Map
- Appendix B: Flow Test
- Appendix C: IFC Fire Flow Requirements
- Appendix D: Layout Exhibit and WaterCAD Model Reports
- Appendix E: Demand Summation Tables
- Appendix F: Preliminary Utility Plan
- Appendix G: Water Feature Areas
- Appendix H: Private Vs Public Utility Line Exhibit

## 1.0 INTRODUCTION

Kimley-Horn and Associates, Inc. has prepared this Preliminary Water Basis of Design Report for the proposed Optima McDowell Mountain Village, a multi-family development at the northeast corner of Scottsdale Road and Mayo Boulevard in Scottsdale, Arizona. Refer to **Appendix A** for a Vicinity Map of the project area discussed. This report will demonstrate that the proposed project conforms to the City of Scottsdale design requirements.

Optima McDowell Mountain Village, the “project”, encompasses approximately 15.637+/- net acres and 21.88 gross acres of currently undeveloped land with sparse desert vegetation. The proposed development will include (3) 10-story and (3) 9-story standalone mix-use buildings, with 1,390 multi-family units total ( $1,390\text{DU}/15.637\text{ AC} = 88.89\text{DU}/\text{AC}$ ), and 36,000 SF of designated as Commercial Space. In addition to the buildings there will be a two-level underground parking structure below the development. The Commercial space is further broken down as Restaurant = 11,515 SF, Office = 17,935 SF, Loading = 6,550 SF with the loading area located in the garage with no additional water demands. All structures will adhere to fire codes and contain an approved sprinkler system. The Project will be developed in phases that will be determined during plan development.

The project lies within a portion of the Southwest Quarter of Section 26, Township 4 North, Range 4 East of the Gila and Salt River Base and Meridian in Maricopa County, Arizona. More specifically, the parcel is bounded by the Loop 101 Freeway to the north, vacant State Land to the east, a car dealership to the south, and Scottsdale Road to the west. The site generally slopes from the northeast to the southwest at approximately 1.5%. See **Appendix A** for the Vicinity Map.

## 2.0 DOMESTIC WATER ANALYSIS

### 2.1 INTENT AND SCOPE

The intent of this section is to evaluate the potable water infrastructure for the proposed development. As a result of this analysis, it will be determined if the potable water infrastructure can satisfy the projected water demands for the proposed development in accordance with the City of Scottsdale Design Standards & Policies Manual and the 2018 International Fire Code for fire prevention.

### 2.2 GENERAL THEORY

The water system modeling program Water CAD, developed by Haestad Methods, is used to model the water system servicing the proposed development. The program uses the fluid mechanic head loss theory known as the Hazen-Williams method. This is the typical method used to evaluate water distribution systems.

### 2.3 DOMESTIC WATER SUPPLY

A 16” ductile iron water main and a 12” ductile iron non-potable water main exists in Mayo Boulevard to the south of the site. The 12” non-potable water main stops near the end of the Mayo Boulevard pavement, and the 16” water main changes material to asbestos cement pipe and continues to the east across the state land. There are existing fire hydrants located along the project side of the street with one on the west and two on the south side of the site. Additionally, a 12” ductile iron water main and a 16” water main exists

in Scottsdale Road which both extend past the length of the project site. The 16" water main services the hydrants located on the project side of the road west of the site.

A certified Fire Hydrant Flow Test was conducted by EJ Flow Tests LLC on June 10, 2022, at the fire hydrant southeast of the site along Mayo Boulevard. Per the Fire Flow Report included in **Appendix B**, the static water pressure is 57.6 psi, the residual pressure is 50.6 psi at 2,110 GPM with a 10% safety factor, with an available flow at 20 psi of 4,666 GPM. The flowing gpm has been reduced per the DSMP Section 6-1.405.B.

The proposed domestic water system layout for this site consists of two 8" domestic connections fed through proposed 6" meters and 8" backflow preventors that tie into proposed 12" feeder mains that connect at two points each to the existing 16" mains in Mayo Boulevard and Scottsdale Road to comply with DSMP 6-1.416.K and 6-1.504.D. See **Appendix F** – Preliminary Utility Plan for the layout of the feeder mains and this site's proposed connections. The commercial portion of the site will also have a 4" water meter that is tapped into the proposed 12" feeder main in Mayo Boulevard. The water system will loop within the site/garage and connect to 3 separate domestic pump rooms which will each feed two buildings and their amenities. Additionally, there will be two 2" irrigation lines connecting to the proposed 12" feeder main in Mayo Boulevard to service the onsite vegetation. All pumps will be designed with Final Improvement Plans and included in Final Basis of Design Report.

The proposed fire system layout consists of two 12" connections through double detector check valves connecting to the same proposed 12" feeder mains in Mayo Boulevard and in Scottsdale Road. The onsite private fire line will be designed as a loop system through the garage. This loop will extend around the perimeter of the site and connect to three private hydrants near the north and eastern property lines and provide a connection to the fire pump room. The fire pump will connect to a fire riser loop which will provide fire flow to all the buildings for a single source. The fire pump design and pump curves will be provided during final design of the site with the Fire Life Safety Plans. Refer to **Appendix F** for the Preliminary Utility Plan layout, additionally **Appendix H** contains an exhibit that shows the separation of private and public utility lines proposed for the site. This report only analyzes the water systems to the connection point of the pump room and the onsite private hydrants.

## 2.4 INTERNATIONAL FIRE CODE, 2018

According to the City of Scottsdale Fire Department, the 2018 International Fire Code (IFC) with City of Scottsdale Amendments is currently the governing code with respect to fire protection requirements. Per the 2018 IFC and the Phoenix Fire department, a maximum 50% reduction of the required fire flow is allowed for the buildings, provided that the building is equipped with an approved interior fire suppression sprinkler system. In addition, remote Fire Department Connections (FDC'S) will be provided in accordance with City of Scottsdale Fire Code. Per the Scottsdale DSMP Section 6-1. 501.E, these buildings are classified as high rise and will therefore be required to have a minimum of 2500 gpm fire flow. See **Table 1** for required building fire flows.

The site has three existing fire hydrants along the southern frontage of the site along Mayo Boulevard, and an additional fire hydrant along the western frontage along Scottsdale Road. Additionally, three private hydrants will be installed along the north and east sides of the project site and an additional public hydrant is proposed along the southern property line at Mayo Boulevard. These hydrants will ensure proper coverage is provided for the site. This layout has been reviewed with the City of Scottsdale Fire Department.

The proposed buildings and structures will be equipped with sprinkler systems approved by the City of Scottsdale Fire Department.

The minimum fire flow requirements per the IFC 2018 for the proposed buildings are shown in Table 1. Table 1 also shows the required building fire flow based upon a maximum fire flow reduction of 50% allowed by the IFC 2018. Per Section B104.3, the building area used for the fire flow calculation is the sum of the three largest successive floors on each building. See **Appendix C** for IFC 2018 fire flow requirements. However, a minimum of 2,500 GPM was utilized in modeling per DSPM 6-1.502 because the buildings proposed have occupied floors over 75 feet classifying them as high-rise buildings.

The IFC evaluates the building construction type, occupancy descriptions, and square footage to set minimum fire flow requirements. The proposed buildings are categorized as Construction Type I-A in the garage through the first floor and Type 1-B through the second floor and above.

**Table 1: Required Building Fire Flows**

Building	Building Construction Type	Building Area (sf)	Required Fire Flow per IFC 2018 (gpm)	Reduction	Minimum Required Fire Flow with Reduction (gpm)*	Building Heights
Building 1	I-A	114,384	3,750	50%	2,500	133'-0"
Building 2	I-A	107,004	3,500	50%	2,500	133'-0"
Building 3	I-A	110,304	3,500	50%	2,500	123'-0"
Building 4	I-A	108,129	3,500	50%	2,500	123'-0"
Building 5	I-A	99,144	3,500	50%	2,500	123'-0"
Building 6	I-A	100,284	3,500	50%	2,500	133'-0"
Commercial/Retail	I-A	11,515	1,500		1,500	N/A
Office Space	I-A	17,935	1,500		1,500	N/A

## 2.5 WATER DEMANDS

According to the guidelines provided in Figure 6-1.2 of The City of Scottsdale Design Standards and Policies Manual, the proposed development will add the following demands to the existing water system for, Average Daily Flow (ADF), Maximum Daily Demand (MDD), and Peak Hour Demand (PHD):

Per the City of Scottsdale Design Standard and Policies Manual, the Max Daily Demand is produced by adding a 2.0 peaking factor to the Average Daily Flow. The Peak Hour Demand is produced by adding a 3.5 peaking factor to the Average Daily Flow. A peaking factor of 6 was used for the restaurant demands per DSPM 6-1.404. B.3. See **Table 2** below with the resulting demands for each scenario.

Demands for the vertical planter systems, water features/pools and landscape are also provided in **Table 2** below.

Please note that the proposed building cooling system does not utilize water and therefore does not generate a water demand. Refer to **Appendix D** for the WaterCad Model layout and data analysis reports.

**Table 2: Domestic Water Demands**

Building	Dwelling Units	ADD (gpm/du)	ADF (gpm)	MDD (gpm)	PHD (gpm)
Building 1	278	0.27	75.06	150.12	262.71
Building 2	238	0.27	64.26	128.52	224.91
Building 3	209	0.27	56.43	112.86	197.51
Building 4	211	0.27	56.97	113.94	199.40
Building 5	209	0.27	56.43	112.86	197.51
Building 6	245	0.27	66.15	132.30	231.53
Restaurant	11,515 SF	0.00181/SF	20.84	41.68	125.04
Office Space	17,935 SF	0.000834/SF	14.96	29.92	52.35
Vertical Planter Boxes*	24,833 LF	150 gal/lf/yr	7.09x4=28.36	28.36	28.36
Roof Top Pools/Water Features**	20,268 SF	1"/day evaporation	1.16	1.16	1.16
Ground Level Landscape***	229,600 SF	2.2 gal/mo./SF	11.53x4=46.12	46.12	46.12
<b>Total</b>			486.74	897.84	1,566.60

Include makeup water due to backwashing pools/spas. DSPM Figure 6-1.2 Note 2.

\*Vertical Planter Boxes and Ground Level Landscape water use demand is based on actual meter readings at other Arizona Optima projects. Linear footage and location of the Vertical planter boxes is shown in **Appendix F**. Irrigation will occur over a 6-hour period on a daily basis. The irrigation demand calculation takes into account the peaking factor of four, this is why the value remains constant with the ADF, MDD, and PHF values.

\*\*Calculations for the pool/water feature demand has been estimated using the known cumulative water surface area and a 1" daily evaporation rate that will need to be replenished with the domestic line. The demand for this element encompasses the pools, cold plunges, and spas which will only be filled initially and not on a regular basis. A breakdown of the different amenities areas per building is provided in **Appendix G**. For the demands, these numbers are split up equally between each of the three domestic pumps as the differences in water feature areas for each group of building is negligible.

\*\*\*Landscape area excludes building area, hardscape, and artificial turf areas. This is also based on a 6-hour watering schedule similar to the Vertical Planter System. For the demands, these numbers are split up equally between each of the three domestic pumps as the differences in landscape areas for each group of building is negligible.

The domestic demands were split up into three nodes. Each of the nodes represents one of the domestic pumps that is provided for each pair of buildings (Buildings 2 & 3, Buildings 1 & 6, and Buildings 4 & 5). The demand for the pools, spas, cold plunges, vertical landscaping, etc were all broken up into equal thirds. Refer to **Table 3 and 4** for the breakdown in demands for each building group.

Per the Scottsdale DSPM 6-1.202, four water scenarios are required for the Final Basis of Design Report which this site was stipulated to per the city comments. However, the fourth scenario (Minimum domestic service pressure at the worst-case demand node under normal daily operating flow conditions) was not performed. Per a discussion with the City of Scottsdale, this scenario will not be completed because this site will be providing domestic pumps to provide the required flows and pressures at the worst-case demand nodes and the pumps will be designed during the final design phase of the project. Therefore, the other three scenarios were completed providing the required flows and pressures to each of the domestic pumps. From that point forward, the pumps and the internal routing of the domestic water systems will take over. The three scenarios that were performed are listed below.

1. Model Scenario 1 (6-.202. G.6.a): Average Daily Demand – Per the City of Scottsdale Design Standards and Policies Manual. The demand and resulting pressure for each group of buildings, office space, restaurant space, and irrigation is shown in **Table 3**. The demand for each building group includes the Average Daily Flow for both buildings, 1/3 of the total rooftop water feature demand, and 1/3 of the total vertical planter box demand. The demand for the office and restaurant spaces are each split to their own nodes. The demand for the irrigation is split in half between each meter.
2. Model Scenario 2 (6-.202. G.6.b): Peak Hour – Per the City of Scottsdale Design Standards and Policies Manual. The demand and resulting pressure for each group of buildings, office space, restaurant space, and irrigation is shown in **Table 3**. The demand for each building group includes the Peak Hour Flow for both buildings, 1/3 of the total rooftop water feature demand, and 1/3 of the total vertical planter box demand. The demand for the office and restaurant spaces are each split to their own nodes. The demand for the irrigation is split in half between each meter.
3. Model Scenario 3 (6-.202. G.6.c): Max Day + Fire Demand – Per the City of Scottsdale Design Standards and Policies Manual, a minimum pressure of 30 psi must be maintained at the worst-

case hydrant and a minimum of 15 psi must be maintained at the worst-case location in the domestic system during the Max Day Demand with Worst Case Fire Flow. The three domestic pumps, the irrigation connection points, the restaurant connection point, and the office space connection points are all checked as the “worst case location” to ensure pressure within the whole system is maintained. This analysis was performed for each of the three proposed private hydrants and one proposed public hydrant.

See **Appendix B** for the Fire Flow Test Results used to model the WaterCAD system and **Appendix D** for the WaterCAD System Layout Exhibit and the detailed reports of the full results of each of the scenarios described above. A summary of the results of the three water scenarios are shown below:

**Table 3** below shows the resulting pressures that are at each domestic building pump, irrigation connection point, office connection point, and restaurant connection point for both the Average Daily Demand and Peak Hour Demand (Scenarios 1 and 2 described above). These pressures are compared to the required pressures in the City of Scottsdale Design Standard and Policies Manual.

The breakdown of the demand summations can be found in **Appendix E**. This appendix can be used to help further break down the calculation of the combined demands in Tables 3 and 4 if the explanation in the scenario description above is not clear enough.

**Table 3: Resulting Pressure for Combined Building Demand Nodes**

Scenarios	Scenario 1 – ADF (gpm)		Scenario 2 – PHD (gpm)	
	Demand	Resulting Pressure	Demand	Resulting Pressure
<b>Building 1&amp;6</b>	151.05	64	504.08	45
<b>Building 2&amp;3</b>	130.53	56	432.26	47
<b>Building 4&amp;5</b>	123.24	61	406.75	45
<b>Irrigation 1</b>	23.06	55	23.06	50
<b>Irrigation 2</b>	23.06	54	23.06	50
<b>Commercial (Office)</b>	14.96	60	52.35	37
<b>Commercial (Restaurant)</b>	20.84	60	125.04	27

**Table 4** below shows the resulting pressures for each domestic building pump, irrigation connection point, office connection point, and restaurant connection point for the Maximum Daily Demand and Fire Flow for each of the four proposed hydrants (Scenario 3 described above). These pressures are compared to the required pressures in the City of Scottsdale Design Standard and Policies Manual.

Update tables to include water demand from backwashing pools. DSPM Figure 6-1.2 Note 2.



The breakdown of the demand summations can be found in **Appendix E**. This appendix can be used to help further break down the calculation of the combined demands in **Tables 3 and 4** if the explanation in the Scenario description above is not clear enough.

**Table 4: Scenario 3 - Max Day Demand with Worst Case Fire Flow**

Scenario	Buildings 1 & 6			Building 2 & 3		
	Max Day Demand	Required Pressure	Provided Pressure	Max Day Demand	Required Pressure	Provided Pressure
Fire Flow at H-7	292.26	15	31	251.22	15	32
Fire Flow at H-8	292.26	15	31	251.22	15	32
Fire Flow at H-9	292.26	15	31	251.22	15	32
Fire Flow at H-10	292.26	15	33	251.22	15	32

Scenario	Buildings 4 & 5			Fire Flow to Hydrant		
	Max Day Demand	Required Pressure	Provided Pressure	Fire Flow Demand	Required Pressure	Provided Pressure
Fire Flow at H-7	236.64	15	31	2500	30	31
Fire Flow at H-8	236.64	15	31	2500	30	30
Fire Flow at H-9	236.64	15	31	2500	30	33
Fire Flow at H-10	236.64	15	33	2500	30	37

Scenario	Irrigation 1			Irrigation 2		
	Max Day Demand	Required Pressure	Provided Pressure	Max Day Demand	Required Pressure	Provided Pressure
Fire Flow at H-7	23.06	15	33	23.06	15	33
Fire Flow at H-8	23.06	15	33	23.06	15	33
Fire Flow at H-9	23.06	15	33	23.06	15	33
Fire Flow at H-10	23.06	15	33	23.06	15	33

Update tables to include water demand from backwashing pools.  
 DSPM Figure 6-1.2 Note 2.

Scenario	Commercial (Office)			Commercial (Restaurant)		
	Max Day Demand	Required Pressure	Provided Pressure	Max Day Demand	Required Pressure	Provided Pressure
Fire Flow at H-7	29.92	15	33	41.68	15	31
Fire Flow at H-8	29.92	15	33	41.68	15	31
Fire Flow at H-9	29.92	15	32	41.68	15	31
Fire Flow at H-10	29.92	15	35	41.68	15	34

### 3.0 CONCLUSION

The proposed and existing on-site water system as outlined by this analysis appears adequate to meet the required fire flow demand and peak domestic water demand for the proposed Optima McDowell Mountain Village development per the requirements of the Scottsdale Design Standards and Policies Manual. All Fire and domestic pump design will be provided with final engineering/building plans. Refer to **Appendix D** for the results of the water system analysis.


### 4.0 REFERENCES

1. City of Scottsdale, *Design Standards and Policies Manual*. 2018.
2. International Code Council, *2018 International Fire Code*. May 2018

Update table to include water demand from backwashing pools. DSPM Figure 6-1.2 Note 2.

# Appendices

## Appendix A: Vicinity Map



## VICINITY MAP

N.T.S

# Appendix B: Flow Test



# Flow Test Summary

Project Name: EJFT 22276 - 101 Scottsdale  
 Project Address: N Scottsdale Rd & E Mayo Blvd, Scottsdale, AZ 85255  
 Date of Flow Test: 2022-06-10  
 Time of Flow Test: 6:35 AM  
 Data Reliable Until: 2022-12-10  
 Conducted By: Eder Cueva & Caleb Crabbs (EJ Flow Tests) 602.999.7637  
 Witnessed By: Sonny Schreiner (City of Scottsdale) 602.819.7718  
 City Forces Contacted: City of Scottsdale (602.819.7718)  
 Permit Number: C69081

**Note** Static pressure on the flow hydrant was 64 PSI.

### Raw Flow Test Data

Static Pressure: 64.0 PSI  
 Residual Pressure: 57.0 PSI  
 Flowing GPM: 2,110  
 GPM @ 20 PSI: 5,694


### Data with a 10 % Safety Factor

Static Pressure: 57.6 PSI  
 Residual Pressure: ~~50.6~~ PSI **57\*0.9=51.3**  
 Flowing GPM: 2,110 **1899**  
 GPM @ 20 PSI: 5,230 **4666**

### Hydrant F<sub>1</sub>

Pitot Pressure (1): 35 PSI  
 Coefficient of Discharge (1): 0.9  
 Hydrant Orifice Diameter (1): 4 inches  
 Additional Coefficient 0.83 on orifice #1

Values reduced per DSPM  
 Section 6-1.405.B



Static-Residual Hydrant  
 Flow Hydrant  
 Distance Between F<sub>1</sub> and R  
 369 ft (measured linearly)  
 Static-Residual Elevation  
 1592 ft (above sea level)  
 Flow Hydrant (F<sub>1</sub>) Elevation  
 1590 ft (above sea level)  
 Elevation & distance values are approximate

### Static-Residual Hydrant




### Flow Hydrant (only hydrant F1 shown for clarity)



### Approximate Project Site



### Water Supply Curve N<sup>1.85</sup> Graph



39psi

$2500 + 897.84 = 3398 \text{ GPM}$

# Appendix C: IFC Fire Flow Requirements



## APPENDIX B

# FIRE-FLOW REQUIREMENTS FOR BUILDINGS

### User note:

**About this appendix:** Appendix B provides a tool for the use of jurisdictions in establishing a policy for determining fire-flow requirements in accordance with Section 507.3. The determination of required fire flow is not an exact science, but having some level of information provides a consistent way of choosing the appropriate fire flow for buildings throughout a jurisdiction. The primary tool used in this appendix is a table that presents fire flow based on construction type and building area based on the correlation of the Insurance Services Office (ISO) method and the construction types used in the International Building Code

### SECTION B101 GENERAL

**B101.1 Scope.** The procedure for determining fire-flow requirements for buildings or portions of buildings hereafter constructed shall be in accordance with this appendix. This appendix does not apply to structures other than buildings.

### SECTION B102 DEFINITIONS

**B102.1 Definitions.** For the purpose of this appendix, certain terms are defined as follows:

**FIRE-FLOW.** The flow rate of a water supply, measured at 20 pounds per square inch (psi) (138 kPa) residual pressure, that is available for firefighting.

**FIRE-FLOW CALCULATION AREA.** The floor area, in square feet (m<sup>2</sup>), used to determine the required fire flow.

### SECTION B103 MODIFICATIONS

**B103.1 Decreases.** The *fire code official* is authorized to reduce the fire-flow requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.

**B103.2 Increases.** The *fire code official* is authorized to increase the fire-flow requirements where conditions indicate an unusual susceptibility to group fires or conflagrations. An increase shall **be** not more than twice that required for the building under consideration.

**B103.3 Areas without water supply systems.** For information regarding water supplies for fire-fighting purposes in rural and suburban areas in which adequate and reliable water supply systems do not exist, the *fire code official* is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

**B103.4 Outside storage use.** The fire code is authorized to require a fire-flow of no less than 2,000 gpm (7571 L/min) where combustible materials, *hazardous materials* and other items are stored or used outside.

### SECTION B104 FIRE-FLOW CALCULATION AREA

**B104.1 General.** The fire-flow calculation area shall be the total floor area of all floor levels within the *exterior walls*, and under the horizontal projections of the roof of a building,

**B104.2 Area separation.** Portions of buildings **that** are separated by *fire walls* without openings, constructed in accordance with the *International Building Code*, are allowed to be considered as separate fire-flow calculation areas.

**B104.3 Type IA and Type IB construction.** The fire-flow calculation area of buildings constructed of Type IA and Type IB construction shall be the area of the three largest successive floors.

**Exception:** Fire-flow calculation area for open parking garages shall be determined by the area of the largest floor.

### SECTION B105 FIRE-FLOW REQUIREMENTS FOR BUILDINGS

**B105.1 One- and two-family dwellings, Group R-3 and R-4 buildings and townhouses.** The minimum *fire-flow* and flow duration requirements for one- and two-family *dwellings*, Group R-3 and R-4 buildings and *townhouses* shall be as specified in Tables B105.1(1) and B105.1(2).

**B105.2 Buildings other than one- and two-family dwellings, Group R-3 and R-4 buildings and townhouses.** The minimum *fire-flow* and flow duration for buildings other than one- and two-family *dwellings*, Group R-3 and R-4 buildings and *townhouses* shall be as specified in Tables B105.2 and B105.1(2).

**Exception:** A reduction in required fire-flow of up to 50 percent, as *approved*, is allowed when the building is provided with an *approved NFPA 13 automatic sprinkler system* installed in accordance with Section 903.3.1.1. The resulting fire-flow shall not be less than 1,500 gallons per minute (5678 L/min) for the prescribed duration as specified in Table B105.1. No reductions are allowed for NFPA 13D or 13R systems other than Group R-3 single-family homes.

**B105.3 Water supply for buildings equipped with an automatic sprinkler system.** For buildings equipped with an *approved automatic sprinkler system*, the water supply shall be capable of providing the greater of:

1. The *automatic sprinkler system* demand, including hose stream allowance.
2. The required *fire flow*.

**TABLE B105.1(1)  
REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

FIRE-FLOW CALCULATION AREA	AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE FLOW (gallons per minute)	FLOW DURATION (hours)
0-3,600	No automatic sprinkler system	1,000	1
3,601 and greater	No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2) at the required fire-flow rate
0 - 3,600	Section 903.3.1.3 of the <i>International Fire Code</i> or Section P2904 of the <i>International Residential Code</i>	500	B105.1(2)
3,601 and greater	Section 903.3.1.3 of the <i>International Fire Code</i> or Section P2904 of the <i>International Residential Code</i>	1/2 value in Table B105.1(2)	Duration in Table B105.1(2)

**TABLE B105.1(2)  
MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS**

FIRE-FLOW CALCULATION AREA (square feet)					FIRE-FLOW (gallons per minute) <sup>b</sup>	FLOW DURATION (hours)
Type IA and IB <sup>a</sup>	Type IIA and IIIA <sup>a</sup>	Type IV and V-A <sup>a</sup>	Type IIB and IIIB <sup>a</sup>	Type V-B <sup>a</sup>		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	3
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	
83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	4
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-183,400	92,401-103,100	59,101-66,000	42,701-47,700	26,301-29,300	4,500	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750	
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000	
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250	
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500	
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750	
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000	
—	—	115,801-125,500	83,701-90,600	51,501-55,700	6,250	
—	—	125,501-135,500	90,601-97,900	55,701-60,200	6,500	
—	—	135,501-145,800	97,901-106,800	60,201-64,800	6,750	
—	—	145,801-156,700	106,801-113,200	64,801-69,600	7,000	
—	—	156,701-167,900	113,201-121,300	69,601-74,600	7,250	
—	—	167,901-179,400	121,301-129,600	74,601-79,800	7,500	
—	—	179,401-191,400	129,601-138,300	79,801-85,100	7,750	
—	—	191,401-Greater	138,301-Greater	85,101-Greater	8,000	

For SI: 1 square foot = 0.0929 m<sup>2</sup>, 1 gallon per minute = 3.785 L/m, 1 pound per square inch = 6.895 kPa.

a. Types of construction are based on the *International Building Code*.

b. Measured at 20 psi residual pressure.

**TABLE B105.2**  
**REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND**  
**TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE FLOW (gallons per minute)	FLOW DURATION (hours)
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the <i>International Fire Code</i>	25% of the value in Table B105.1(2) <sup>a</sup>	Duration in Table B105.1(2) at the reduced flow rate
Section 903.3.1.2 of the <i>International Fire Code</i>	25% of the value in Table B105.1(2) <sup>b</sup>	Duration in Table B105.1(2) at the reduced flow rate

For SI: 1 gallon per minute = 3.785 L/m.


- a. The reduced fire flow shall be not less than 1,000 gallons per minute.
- b. The reduced fire flow shall be not less than 1,500 gallons per minute.

**SECTION B106**  
**REFERENCED STANDARDS**

ICC	IBC—18	International Building Code	B104.2
ICC	IWUIC—18	International Wildland-Urban Interface Code	B103.3
ICC	IRC—18	International Residential Code	Table 105.1(1)
NFPA	1142—17	Standard on Water Supplies for Suburban and Rural Fire Fighting	

**B106.1 Additional requirements.** See Chapter 5 of this code for additional requirements.

# Appendix D: Layout Exhibit and WaterCAD Model Reports



Per DSPM 6-1.405,  
service line velocities  
more than 7.5 ft/s are  
not allowed.


LABELS BELOW NODE J-8  
LINE ARE ONLY SHOWN  
FOR MODELING PURPOSES

## FlexTable: Pipe Table

### Active Scenario: Aveage Daily Demand

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-487	0.78	0.05
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	-5,350	8.54	1.48
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	4,831	13.71	5.49
P-25	121	12.0	517	1.47	1.28
P-26	813	12.0	288	0.82	1.28
P-28	24	5,000.0	-487	0.00	0.00
P-29	33	5,000.0	-487	0.00	0.00
P-33	20	6.0	151	1.71	0.04
P-34	14	6.0	123	1.40	0.02
P-35	27	6.0	131	1.48	0.05
P-36	319	8.0	78	0.50	3.33
P-37	1,115	8.0	209	1.33	11.53
P-39	871	8.0	332	2.12	8.40
P-40	3	12.0	2,357	6.69	0.06
P-42	3	12.0	537	1.52	0.10
P-43	3	12.0	-4,295	12.18	0.06
P-45	100	8.0	483	3.08	0.79
P-47	99	12.0	4,831	13.71	10.90
P-48	12	12.0	4,831	13.71	1.36
P-49	100	4.0	36	0.91	0.11
P-50	75	2.0	-21	2.13	0.90
P-51	18	2.0	15	1.53	0.12
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	78	0.50	0.08
P-54	48	8.0	-78	0.50	0.51
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	517	1.47	6.30
P-60	651	8.0	483	3.08	5.17
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	-5,350	8.54	3.10
P-64	12	12.0	-1,020	2.89	0.23
P-65	246	16.0	-5,350	8.54	4.70
P-66	118	16.0	-5,350	8.54	2.24
P-67	19	12.0	-2,311	6.56	0.39
P-68	19	12.0	2,553	7.24	0.52
P-69	15	16.0	3,039	4.85	0.08
P-70	12	16.0	-4,330	6.91	0.05
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	4,330	12.28	0.21

Per DSPM 6-1.405,  
service line velocities  
more than 7.5 ft/s are  
not allowed.



FlexTable: Pipe Table  
Active Scenario: Aveage Daily Demand

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	36	0.91	0.01
P-75	3	12.0	2,279	6.46	0.10
P-76	155	16.0	-487	0.78	0.03
P-77	3	12.0	-2,334	6.62	0.06
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	36	0.91	0.19
P-81	487	12.0	-229	0.65	2.24
P-81	11	6.0	483	5.48	0.37
P-82	311	12.0	-4,314	12.24	17.44
P-83	7	12.0	-4,831	13.71	0.76
P-84	48	12.0	-4,831	13.71	5.30
P-85	457	12.0	517	1.47	4.83
P-86	614	12.0	288	0.82	0.96
P-87	264	12.0	517	1.47	2.79
P-88	17	12.0	4,831	13.71	1.91

**FlexTable: Junction Table**  
**Active Scenario: Aveage Daily Demand**

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	54	1,718.72	1,593.00
J-3	0	67	1,748.94	1,593.00
J-5	0	58	1,727.74	1,593.00
J-6	0	58	1,727.74	1,593.00
J-7	0	58	1,727.74	1,593.00
J-8	0	58	1,727.79	1,593.00
J-9	0	58	1,727.79	1,593.00
J-10	0	58	1,727.79	1,593.00
J-13	0	63	1,739.37	1,593.00
J-15	0	61	1,734.62	1,593.00
J-16	0	61	1,733.14	1,593.00
J-20	0	57	1,724.10	1,593.00
J-25	0	67	1,747.15	1,593.00
J-26	0	56	1,722.05	1,593.00
J-27	131	56	1,722.01	1,593.00
J-28	0	61	1,733.59	1,593.00
J-29	123	61	1,733.56	1,593.00
J-30	0	64	1,741.98	1,593.00
J-31	151	64	1,741.94	1,593.00
J-35	0	63	1,739.59	1,593.00
J-36	0	63	1,739.64	1,593.00
J-37	0	63	1,739.54	1,593.00
J-38	0	58	1,727.35	1,593.00
J-39	0	58	1,727.29	1,593.00
J-40	0	58	1,727.19	1,593.00
J-41	0	60	1,731.89	1,593.00
J-42	15	60	1,731.77	1,593.00
J-43	21	60	1,730.98	1,593.00
J-44	23	54	1,718.93	1,593.00
J-50	0	63	1,739.37	1,593.00
J-51	0	63	1,739.37	1,593.00
J-52	0	63	1,739.32	1,593.00
J-53	0	58	1,727.80	1,593.00
J-54	0	58	1,727.71	1,593.00
J-55	0	58	1,727.41	1,593.00
J-56	23	55	1,718.99	1,593.00
J-57	0	67	1,747.03	1,593.00
J-59	0	59	1,729.59	1,593.00
J-60	0	60	1,732.08	1,593.00
J-61	0	64	1,742.00	1,593.00
J-62	0	65	1,744.24	1,593.00



FlexTable: Hydrant Table  
Active Scenario: Aveage Daily Demand

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,739.37	64
H-2	1,590.00	0	1,727.74	60
H-3	1,592.00	0	1,727.79	59
H-4	1,593.00	0	1,727.79	58
H-7	1,596.00	0	1,740.72	63
H-8	1,596.00	0	1,742.96	64
H-9	1,592.36	0	1,734.42	61
H-10	1,593.70	0	1,730.04	59

## FlexTable: Pump Table

### Active Scenario: Aveage Daily Demand

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,727.79	487	131.79

## FlexTable: GPV Table

### Active Scenario: Aveage Daily Demand

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	-78	9.15
GPV-7	1,591.51	12.0	12" 2000 SS Watts	4,831	27.81
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	36	7.38
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	-4,831	27.81
GPV-8	0.00	8.0	8" FEBCO	483	8.77

## FlexTable: Pipe Table

### Active Scenario: Peak Hour Demand

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-1,567	2.50	0.47
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	-17,407	27.78	1.01
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	16,794	47.64	0.96
P-25	121	12.0	1,764	5.00	0.79
P-26	813	12.0	623	1.77	0.79
P-28	24	5,000.0	-1,567	0.00	0.00
P-29	33	5,000.0	-1,567	0.00	0.00
P-33	20	6.0	504	5.72	0.42
P-34	14	6.0	407	4.62	0.20
P-35	27	6.0	432	4.90	0.42
P-36	319	8.0	-908	5.79	4.70
P-37	1,115	8.0	-476	3.04	4.47
P-39	871	8.0	-69	0.44	0.60
P-40	3	12.0	11,028	31.28	0.06
P-42	3	12.0	13,106	37.18	0.14
P-43	3	12.0	-3,689	10.46	0.03
P-45	100	8.0	435	2.78	0.34
P-47	99	12.0	16,794	47.64	1.91
P-48	12	12.0	16,794	47.64	0.24
P-49	100	4.0	177	4.53	2.16
P-50	75	2.0	-125	12.77	24.92
P-51	18	2.0	52	5.35	1.18
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	-908	5.79	0.11
P-54	48	8.0	908	5.79	0.71
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	1,764	5.00	3.87
P-60	651	8.0	435	2.78	2.18
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	-17,407	27.78	2.12
P-64	12	12.0	-13,541	38.41	0.06
P-65	246	16.0	-17,407	27.78	3.21
P-66	118	16.0	-17,407	27.78	1.53
P-67	19	12.0	-10,981	31.15	0.33
P-68	19	12.0	4,859	13.78	0.57
P-69	15	16.0	6,425	10.25	0.04
P-70	12	16.0	-3,866	6.17	0.03
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	3,866	10.97	0.14

It is difficult to read the network diagram for the pipes on this table. However, pipe velocities in this table are extremely high. Based on values in this BOD, the PHD is 1566 gpm. Update table.

## FlexTable: Pipe Table

### Active Scenario: Peak Hour Demand

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	177	4.53	0.26
P-75	3	12.0	11,935	33.86	0.17
P-76	155	16.0	-1,567	2.50	0.22
P-77	3	12.0	-11,005	31.22	0.05
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	177	4.53	3.74
P-81	487	12.0	-1,141	3.24	1.39
P-81	11	6.0	435	4.94	0.16
P-82	311	12.0	-15,030	42.64	10.72
P-83	7	12.0	-16,794	47.64	0.13
P-84	48	12.0	-16,794	47.64	0.93
P-85	457	12.0	1,764	5.00	2.96
P-86	614	12.0	623	1.77	0.60
P-87	264	12.0	1,764	5.00	1.71
P-88	17	12.0	16,794	47.64	0.33

**FlexTable: Junction Table**  
**Active Scenario: Peak Hour Demand**

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	49	1,706.56	1,593.00
J-3	0	49	1,706.76	1,593.00
J-5	0	54	1,717.31	1,593.00
J-6	0	54	1,717.31	1,593.00
J-7	0	54	1,717.31	1,593.00
J-8	0	54	1,717.78	1,593.00
J-9	0	54	1,717.78	1,593.00
J-10	0	54	1,717.78	1,593.00
J-13	0	50	1,709.13	1,593.00
J-15	0	52	1,712.38	1,593.00
J-16	0	52	1,713.39	1,593.00
J-20	0	54	1,718.78	1,593.00
J-25	0	46	1,698.97	1,593.00
J-26	0	47	1,701.86	1,593.00
J-27	432	47	1,701.44	1,593.00
J-28	0	45	1,697.39	1,593.00
J-29	407	45	1,697.20	1,593.00
J-30	0	45	1,696.79	1,593.00
J-31	504	45	1,696.37	1,593.00
J-35	0	50	1,709.00	1,593.00
J-36	0	50	1,708.97	1,593.00
J-37	0	50	1,709.11	1,593.00
J-38	0	54	1,717.43	1,593.00
J-39	0	54	1,717.49	1,593.00
J-40	0	54	1,717.65	1,593.00
J-41	0	38	1,680.84	1,593.00
J-42	52	37	1,679.66	1,593.00
J-43	125	27	1,655.92	1,593.00
J-44	23	50	1,709.01	1,593.00
J-50	0	50	1,709.13	1,593.00
J-51	0	50	1,709.13	1,593.00
J-52	0	50	1,709.17	1,593.00
J-53	0	54	1,717.04	1,593.00
J-54	0	54	1,717.08	1,593.00
J-55	0	54	1,717.37	1,593.00
J-56	23	50	1,708.96	1,593.00
J-57	0	49	1,707.09	1,593.00
J-59	0	54	1,717.82	1,593.00
J-60	0	40	1,684.58	1,593.00
J-61	0	51	1,710.20	1,593.00
J-62	0	50	1,708.81	1,593.00

# FlexTable: Hydrant Table

## Active Scenario: Peak Hour Demand

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,709.13	51
H-2	1,590.00	0	1,717.31	55
H-3	1,592.00	0	1,717.78	54
H-4	1,593.00	0	1,717.78	54
H-7	1,596.00	0	1,710.98	50
H-8	1,596.00	0	1,709.60	49
H-9	1,592.36	0	1,714.85	53
H-10	1,593.70	0	1,715.51	53

## FlexTable: Pump Table

### Active Scenario: Peak Hour Demand

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,717.78	1,567	121.78



## FlexTable: GPV Table

### Active Scenario: Peak Hour Demand

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	908	10.10
GPV-7	1,591.51	12.0	12" 2000 SS Watts	16,794	11.95
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	177	22.00
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	-16,794	11.95
GPV-8	0.00	8.0	8" FEBCO	435	9.65

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-3,398	5.42	1.97
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	-1,512	2.41	0.10
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	1,110	3.15	0.15
P-25	121	12.0	-1,438	4.08	0.60
P-26	813	12.0	-516	1.46	0.61
P-28	24	5,000.0	-3,398	0.00	0.00
P-29	33	5,000.0	-3,398	0.00	0.00
P-33	20	6.0	292	3.32	0.15
P-34	14	6.0	237	2.69	0.07
P-35	27	6.0	251	2.85	0.16
P-36	319	8.0	-450	2.88	1.33
P-37	1,115	8.0	-199	1.27	1.03
P-39	871	8.0	37	0.24	0.04
P-40	3	12.0	-615	1.74	0.00
P-42	3	12.0	482	1.37	0.00
P-43	3	12.0	-628	1.78	0.00
P-45	100	8.0	330	2.10	0.23
P-47	99	12.0	1,110	3.15	0.31
P-48	12	12.0	1,110	3.15	0.04
P-49	100	4.0	72	1.83	0.40
P-50	75	2.0	-42	4.26	3.26
P-51	18	2.0	30	3.06	0.42
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	-450	2.88	0.03
P-54	48	8.0	450	2.88	0.20
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	1,062	3.01	1.69
P-60	651	8.0	330	2.10	1.52
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	-1,512	2.41	0.22
P-64	12	12.0	-812	2.30	0.02
P-65	246	16.0	-1,512	2.41	0.33
P-66	118	16.0	-1,512	2.41	0.16
P-67	19	12.0	661	1.87	0.02
P-68	19	12.0	-1,226	3.48	0.07
P-69	15	16.0	2,172	3.47	0.04
P-70	12	16.0	-700	1.12	0.00
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	700	1.99	0.02

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	72	1.83	0.05
P-75	3	12.0	-164	0.47	0.00
P-76	155	16.0	-3,398	5.42	0.93
P-77	3	12.0	638	1.81	0.00
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	72	1.83	0.70
P-81	487	12.0	922	2.62	1.06
P-81	11	6.0	330	3.74	0.11
P-82	311	12.0	-49	0.14	0.00
P-83	7	12.0	1,390	3.94	0.03
P-84	48	12.0	1,390	3.94	0.22
P-85	457	12.0	1,062	3.01	1.29
P-86	614	12.0	-516	1.46	0.46
P-87	264	12.0	-1,438	4.08	1.31
P-88	17	12.0	-1,390	3.94	0.08

## FlexTable: Junction Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	33	1,668.19	1,593.00
J-3	0	34	1,670.70	1,593.00
J-5	0	37	1,679.09	1,593.00
J-6	0	37	1,679.09	1,593.00
J-7	0	37	1,679.09	1,593.00
J-8	0	38	1,681.06	1,593.00
J-9	0	38	1,681.06	1,593.00
J-10	0	38	1,681.06	1,593.00
J-13	0	36	1,677.30	1,593.00
J-15	0	37	1,677.64	1,593.00
J-16	0	37	1,677.74	1,593.00
J-20	0	34	1,670.78	1,593.00
J-25	0	32	1,667.40	1,593.00
J-26	0	32	1,666.86	1,593.00
J-27	251	32	1,666.71	1,593.00
J-28	0	32	1,665.84	1,593.00
J-29	237	31	1,665.76	1,593.00
J-30	0	32	1,665.87	1,593.00
J-31	292	31	1,665.72	1,593.00
J-35	0	36	1,677.29	1,593.00
J-36	0	36	1,677.28	1,593.00
J-37	0	36	1,677.28	1,593.00
J-38	0	37	1,678.09	1,593.00
J-39	0	37	1,678.09	1,593.00
J-40	0	37	1,678.09	1,593.00
J-41	0	33	1,668.54	1,593.00
J-42	30	33	1,668.12	1,593.00
J-43	42	31	1,665.28	1,593.00
J-44	23	33	1,669.67	1,593.00
J-50	0	36	1,677.30	1,593.00
J-51	0	36	1,677.30	1,593.00
J-52	0	36	1,677.30	1,593.00
J-53	0	37	1,678.11	1,593.00
J-54	0	37	1,678.16	1,593.00
J-55	0	37	1,678.09	1,593.00
J-56	23	33	1,669.68	1,593.00
J-57	0	34	1,670.62	1,593.00
J-59	0	34	1,670.62	1,593.00
J-60	0	33	1,669.24	1,593.00
J-61	0	33	1,668.24	1,593.00
J-62	0	33	1,669.31	1,593.00

## FlexTable: Hydrant Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,677.30	37
H-2	1,590.00	0	1,679.09	39
H-3	1,592.00	0	1,681.06	39
H-4	1,593.00	0	1,681.06	38
H-7	1,596.00	2,500	1,667.64	31
H-8	1,596.00	0	1,668.70	31
H-9	1,592.36	0	1,669.33	33
H-10	1,593.70	0	1,677.96	36

## FlexTable: Pump Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,681.06	3,398	85.06

## FlexTable: GPV Table

### Active Scenario: Maximum Daily Demand + Fire FH7

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	450	9.66
GPV-7	1,591.51	12.0	12" 2000 SS Watts	1,110	6.16
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	72	7.60
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	1,390	7.13
GPV-8	0.00	8.0	8" FEBCO	330	9.55

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-3,398	5.42	1.97
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	-1,505	2.40	0.10
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	1,103	3.13	0.15
P-25	121	12.0	831	2.36	0.22
P-26	813	12.0	-1,194	3.39	2.86
P-28	24	5,000.0	-3,398	0.00	0.00
P-29	33	5,000.0	-3,398	0.00	0.00
P-33	20	6.0	292	3.32	0.15
P-34	14	6.0	237	2.69	0.07
P-35	27	6.0	251	2.85	0.16
P-36	319	8.0	-450	2.87	1.33
P-37	1,115	8.0	-199	1.27	1.02
P-39	871	8.0	38	0.24	0.04
P-40	3	12.0	-619	1.76	0.00
P-42	3	12.0	478	1.36	0.00
P-43	3	12.0	-625	1.77	0.00
P-45	100	8.0	330	2.11	0.23
P-47	99	12.0	1,103	3.13	0.30
P-48	12	12.0	1,103	3.13	0.04
P-49	100	4.0	72	1.83	0.40
P-50	75	2.0	-42	4.26	3.26
P-51	18	2.0	30	3.06	0.42
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	-450	2.87	0.03
P-54	48	8.0	450	2.87	0.20
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	831	2.36	1.07
P-60	651	8.0	330	2.11	1.53
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	-1,505	2.40	0.22
P-64	12	12.0	-808	2.29	0.02
P-65	246	16.0	-1,505	2.40	0.33
P-66	118	16.0	-1,505	2.40	0.16
P-67	19	12.0	665	1.89	0.02
P-68	19	12.0	-1,228	3.48	0.07
P-69	15	16.0	2,170	3.46	0.04
P-70	12	16.0	-697	1.11	0.00
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	697	1.98	0.02



## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	72	1.83	0.05
P-75	3	12.0	-169	0.48	0.00
P-76	155	16.0	-3,398	5.42	0.93
P-77	3	12.0	642	1.82	0.00
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	72	1.83	0.70
P-81	487	12.0	475	1.35	0.31
P-81	11	6.0	330	3.74	0.11
P-82	311	12.0	-272	0.77	0.07
P-83	7	12.0	1,397	3.96	0.03
P-84	48	12.0	1,397	3.96	0.23
P-85	457	12.0	831	2.36	0.82
P-86	614	12.0	1,306	3.70	2.55
P-87	264	12.0	-1,669	4.74	1.73
P-88	17	12.0	-1,397	3.96	0.08

## FlexTable: Junction Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	33	1,668.19	1,593.00
J-3	0	34	1,670.67	1,593.00
J-5	0	37	1,679.09	1,593.00
J-6	0	37	1,679.09	1,593.00
J-7	0	37	1,679.09	1,593.00
J-8	0	38	1,681.06	1,593.00
J-9	0	38	1,681.06	1,593.00
J-10	0	38	1,681.06	1,593.00
J-13	0	36	1,677.31	1,593.00
J-15	0	37	1,677.64	1,593.00
J-16	0	37	1,677.74	1,593.00
J-20	0	34	1,670.81	1,593.00
J-25	0	32	1,667.40	1,593.00
J-26	0	32	1,666.86	1,593.00
J-27	251	32	1,666.71	1,593.00
J-28	0	32	1,665.84	1,593.00
J-29	237	31	1,665.77	1,593.00
J-30	0	32	1,665.88	1,593.00
J-31	292	31	1,665.72	1,593.00
J-35	0	36	1,677.29	1,593.00
J-36	0	36	1,677.29	1,593.00
J-37	0	36	1,677.29	1,593.00
J-38	0	37	1,678.09	1,593.00
J-39	0	37	1,678.09	1,593.00
J-40	0	37	1,678.09	1,593.00
J-41	0	33	1,668.55	1,593.00
J-42	30	33	1,668.13	1,593.00
J-43	42	31	1,665.29	1,593.00
J-44	23	33	1,669.67	1,593.00
J-50	0	36	1,677.31	1,593.00
J-51	0	36	1,677.31	1,593.00
J-52	0	36	1,677.31	1,593.00
J-53	0	37	1,678.12	1,593.00
J-54	0	37	1,678.16	1,593.00
J-55	0	37	1,678.09	1,593.00
J-56	23	33	1,669.68	1,593.00
J-57	0	34	1,670.59	1,593.00
J-59	0	34	1,670.66	1,593.00
J-60	0	33	1,669.24	1,593.00
J-61	0	33	1,668.55	1,593.00
J-62	0	33	1,668.86	1,593.00

## FlexTable: Hydrant Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,677.31	37
H-2	1,590.00	0	1,679.09	39
H-3	1,592.00	0	1,681.06	39
H-4	1,593.00	0	1,681.06	38
H-7	1,596.00	0	1,668.77	31
H-8	1,596.00	2,500	1,666.00	30
H-9	1,592.36	0	1,669.84	34
H-10	1,593.70	0	1,677.96	36

## FlexTable: Pump Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,681.06	3,398	85.06

## FlexTable: GPV Table

### Active Scenario: Maximum Daily Demand + Fire FH8

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	450	9.66
GPV-7	1,591.51	12.0	12" 2000 SS Watts	1,103	6.14
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	72	7.60
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	1,397	7.15
GPV-8	0.00	8.0	8" FEBCO	330	9.55

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-3,398	5.42	1.97
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	-1,529	2.44	0.11
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	1,128	3.20	0.16
P-25	121	12.0	-951	2.70	0.28
P-26	813	12.0	-341	0.97	0.28
P-28	24	5,000.0	-3,398	0.00	0.00
P-29	33	5,000.0	-3,398	0.00	0.00
P-33	20	6.0	292	3.32	0.15
P-34	14	6.0	237	2.69	0.07
P-35	27	6.0	251	2.85	0.16
P-36	319	8.0	-451	2.88	1.33
P-37	1,115	8.0	-200	1.28	1.03
P-39	871	8.0	37	0.24	0.04
P-40	3	12.0	-604	1.71	0.00
P-42	3	12.0	491	1.39	0.00
P-43	3	12.0	-636	1.81	0.00
P-45	100	8.0	329	2.10	0.23
P-47	99	12.0	1,128	3.20	0.31
P-48	12	12.0	1,128	3.20	0.04
P-49	100	4.0	72	1.83	0.40
P-50	75	2.0	-42	4.26	3.26
P-51	18	2.0	30	3.06	0.42
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	-451	2.88	0.03
P-54	48	8.0	451	2.88	0.20
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	-951	2.70	1.38
P-60	651	8.0	329	2.10	1.52
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	-1,529	2.44	0.22
P-64	12	12.0	-820	2.33	0.02
P-65	246	16.0	-1,529	2.44	0.34
P-66	118	16.0	-1,529	2.44	0.16
P-67	19	12.0	650	1.84	0.02
P-68	19	12.0	-1,219	3.46	0.07
P-69	15	16.0	2,179	3.48	0.04
P-70	12	16.0	-708	1.13	0.00
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	708	2.01	0.02

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	72	1.83	0.05
P-75	3	12.0	-153	0.43	0.00
P-76	155	16.0	-3,398	5.42	0.93
P-77	3	12.0	627	1.78	0.00
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	72	1.83	0.70
P-81	487	12.0	610	1.73	0.49
P-81	11	6.0	329	3.73	0.11
P-82	311	12.0	421	1.19	0.16
P-83	7	12.0	1,372	3.89	0.03
P-84	48	12.0	1,372	3.89	0.22
P-85	457	12.0	1,549	4.39	2.60
P-86	614	12.0	-341	0.97	0.21
P-87	264	12.0	-951	2.70	0.61
P-88	17	12.0	-1,372	3.89	0.08

## FlexTable: Junction Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	33	1,668.19	1,593.00
J-3	0	34	1,670.77	1,593.00
J-5	0	37	1,679.09	1,593.00
J-6	0	37	1,679.09	1,593.00
J-7	0	37	1,679.09	1,593.00
J-8	0	38	1,681.06	1,593.00
J-9	0	38	1,681.06	1,593.00
J-10	0	38	1,681.06	1,593.00
J-13	0	36	1,677.28	1,593.00
J-15	0	37	1,677.62	1,593.00
J-16	0	37	1,677.73	1,593.00
J-20	0	34	1,670.69	1,593.00
J-25	0	32	1,667.38	1,593.00
J-26	0	32	1,666.86	1,593.00
J-27	251	32	1,666.70	1,593.00
J-28	0	32	1,665.83	1,593.00
J-29	237	31	1,665.75	1,593.00
J-30	0	32	1,665.86	1,593.00
J-31	292	31	1,665.71	1,593.00
J-35	0	36	1,677.27	1,593.00
J-36	0	36	1,677.26	1,593.00
J-37	0	36	1,677.27	1,593.00
J-38	0	37	1,678.09	1,593.00
J-39	0	37	1,678.09	1,593.00
J-40	0	37	1,678.09	1,593.00
J-41	0	33	1,668.52	1,593.00
J-42	30	32	1,668.10	1,593.00
J-43	42	31	1,665.26	1,593.00
J-44	23	33	1,669.67	1,593.00
J-50	0	36	1,677.28	1,593.00
J-51	0	36	1,677.28	1,593.00
J-52	0	36	1,677.29	1,593.00
J-53	0	37	1,678.11	1,593.00
J-54	0	37	1,678.15	1,593.00
J-55	0	37	1,678.09	1,593.00
J-56	23	33	1,669.68	1,593.00
J-57	0	34	1,670.69	1,593.00
J-59	0	34	1,670.53	1,593.00
J-60	0	33	1,669.22	1,593.00
J-61	0	33	1,669.58	1,593.00
J-62	0	33	1,670.08	1,593.00



## FlexTable: Hydrant Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,677.28	37
H-2	1,590.00	0	1,679.09	39
H-3	1,592.00	0	1,681.06	39
H-4	1,593.00	0	1,681.06	38
H-7	1,596.00	0	1,669.30	32
H-8	1,596.00	0	1,669.80	32
H-9	1,592.36	2,500	1,667.93	33
H-10	1,593.70	0	1,677.95	36

## FlexTable: Pump Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,681.06	3,398	85.06

## FlexTable: GPV Table

### Active Scenario: Maximum Daily Demand + Fire FH9

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	451	9.66
GPV-7	1,591.51	12.0	12" 2000 SS Watts	1,128	6.22
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	72	7.60
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	1,372	7.07
GPV-8	0.00	8.0	8" FEBCO	329	9.55

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-6	42	6.0	0	0.00	0.00
P-7	38	6.0	0	0.00	0.00
P-8	328	16.0	-3,398	5.42	1.97
P-9	39	6.0	0	0.00	0.00
P-10	164	16.0	0	0.00	0.00
P-11	34	6.0	0	0.00	0.00
P-12	48	16.0	0	0.00	0.00
P-13	39	6.0	0	0.00	0.00
P-16	78	16.0	4,024	6.42	0.53
P-22	24	6.0	0	0.00	0.00
P-23	50	12.0	-4,619	13.10	1.08
P-25	121	12.0	-2,793	7.92	0.08
P-26	813	12.0	-506	1.43	1.13
P-28	24	5,000.0	-3,398	0.00	0.00
P-29	33	5,000.0	-3,398	0.00	0.00
P-33	20	6.0	292	3.32	0.15
P-34	14	6.0	237	2.69	0.07
P-35	27	6.0	251	2.85	0.16
P-36	319	8.0	-256	1.64	0.34
P-37	1,115	8.0	-5	0.03	0.55
P-39	871	8.0	231	1.48	0.64
P-40	3	12.0	-1,179	3.35	0.03
P-42	3	12.0	-2,307	6.55	0.02
P-43	3	12.0	2,312	6.56	0.02
P-45	100	8.0	524	3.34	0.51
P-47	99	12.0	-4,619	13.10	2.14
P-48	12	12.0	-4,619	13.10	0.27
P-49	100	4.0	72	1.83	0.40
P-50	75	2.0	-42	4.26	3.26
P-51	18	2.0	30	3.06	0.42
P-52	48	2.0	23	2.36	0.70
P-53	8	8.0	-256	1.64	0.01
P-54	48	8.0	256	1.64	0.05
P-58	7	2.0	23	2.35	0.10
P-59	596	12.0	-2,793	7.92	0.38
P-60	651	8.0	524	3.34	3.33
P-62	151	16.0	0	0.00	0.00
P-63	162	16.0	4,024	6.42	1.12
P-64	12	12.0	1,784	5.06	0.10
P-65	246	16.0	4,024	6.42	1.69
P-66	118	16.0	1,524	2.43	1.41
P-67	19	12.0	1,225	3.48	0.21
P-68	19	12.0	-3,697	10.49	0.27
P-69	15	16.0	-299	0.48	0.06
P-70	12	16.0	2,241	3.58	0.02
P-71	89	6.0	0	0.00	0.00
P-72	12	12.0	-2,241	6.36	0.08

## FlexTable: Pipe Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Length (Scaled) (ft)	Diameter (in)	Flow (gpm)	Velocity (ft/s)	Headloss (ft)
P-73	12	4.0	72	1.83	0.05
P-75	3	12.0	-923	2.62	0.04
P-76	155	16.0	-3,398	5.42	0.93
P-77	3	12.0	1,202	3.41	0.03
P-78	48	2.0	23	2.36	0.70
P-79	7	2.0	23	2.35	0.10
P-80	172	4.0	72	1.83	0.70
P-81	487	12.0	2,287	6.49	1.98
P-81	11	6.0	524	5.94	0.24
P-82	311	12.0	1,827	5.18	2.88
P-83	7	12.0	4,619	13.10	0.15
P-84	48	12.0	4,619	13.10	1.04
P-85	457	12.0	-2,793	7.92	0.29
P-86	614	12.0	-506	1.43	0.85
P-87	264	12.0	-2,793	7.92	0.17
P-88	17	12.0	-4,619	13.10	0.38

## FlexTable: Junction Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Demand (gpm)	Pressure (psi)	Hydraulic Grade (ft)	Elevation (ft)
J-2	0	33	1,668.40	1,593.00
J-3	0	39	1,683.26	1,593.00
J-5	0	37	1,679.09	1,593.00
J-6	0	37	1,679.09	1,593.00
J-7	0	37	1,679.09	1,593.00
J-8	0	38	1,681.06	1,593.00
J-9	0	38	1,681.06	1,593.00
J-10	0	38	1,681.06	1,593.00
J-13	0	39	1,682.98	1,593.00
J-15	0	38	1,681.27	1,593.00
J-16	0	38	1,680.73	1,593.00
J-20	0	37	1,678.92	1,593.00
J-25	0	34	1,672.58	1,593.00
J-26	0	32	1,668.06	1,593.00
J-27	251	32	1,667.90	1,593.00
J-28	0	33	1,668.61	1,593.00
J-29	237	33	1,668.53	1,593.00
J-30	0	33	1,669.25	1,593.00
J-31	292	33	1,669.10	1,593.00
J-35	0	39	1,683.06	1,593.00
J-36	0	39	1,683.08	1,593.00
J-37	0	39	1,683.06	1,593.00
J-38	0	37	1,677.96	1,593.00
J-39	0	37	1,677.93	1,593.00
J-40	0	37	1,677.89	1,593.00
J-41	0	35	1,674.31	1,593.00
J-42	30	35	1,673.89	1,593.00
J-43	42	34	1,671.05	1,593.00
J-44	23	33	1,669.55	1,593.00
J-50	0	39	1,682.98	1,593.00
J-51	0	39	1,682.98	1,593.00
J-52	0	39	1,682.96	1,593.00
J-53	0	37	1,678.21	1,593.00
J-54	0	37	1,678.16	1,593.00
J-55	0	37	1,678.00	1,593.00
J-56	23	33	1,669.58	1,593.00
J-57	0	39	1,682.89	1,593.00
J-59	0	38	1,680.00	1,593.00
J-60	0	35	1,675.01	1,593.00
J-61	0	38	1,680.74	1,593.00
J-62	0	39	1,682.72	1,593.00

## FlexTable: Hydrant Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
H-1	1,592.00	0	1,682.98	39
H-2	1,590.00	0	1,679.09	39
H-3	1,592.00	0	1,681.06	39
H-4	1,593.00	0	1,681.06	38
H-7	1,596.00	0	1,680.66	37
H-8	1,596.00	0	1,681.59	37
H-9	1,592.36	0	1,680.29	38
H-10	1,593.70	2,500	1,679.62	37

## FlexTable: Pump Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Elevation (ft)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-3	1,596.00	1,596.00	1,681.06	3,398	85.06



## FlexTable: GPV Table

### Active Scenario: Maximum Daily Demand + Fire FH10

Label	Elevation (ft)	Diameter (Valve) (in)	General Purpose Valve Headloss Curve	Flow (gpm)	Headloss (ft)
GPV-3	1,594.00	8.0	8" FEBCO	256	9.48
GPV-7	1,591.51	12.0	12" 2000 SS Watts	-4,619	6.56
GPV-9	1,594.00	2.0	2" FEBCO	23	7.62
GPV-11	1,591.50	2.0	2" FEBCO	72	7.60
GPV-12	1,594.00	2.0	2" FEBCO	-23	7.62
GPV-6	1,594.00	12.0	12" 2000 SS Watts	4,619	6.56
GPV-8	0.00	8.0	8" FEBCO	524	9.73

# Appendix E: Demand Summation Tables

Building 1 & 6				
Demands	ADF	MDD	PHD	Node
Building 1	75.06	150.12	262.71	J-31
Building 6	66.15	132.3	231.53	J-31
Vertical Planter Boxes*	9.45	9.45	9.45	J-31
Roof Top Pools/Water Features**	0.39	0.39	0.39	J-31
Total Demands	151.05	292.26	504.08	J-31

Building 2 & 3				
Demands	ADF	MDD	PHD	Node
Building 2	64.26	128.52	224.91	J-27
Building 3	56.43	112.86	197.51	J-27
Vertical Planter Boxes*	9.45	9.45	9.45	J-27
Roof Top Pools/Water Features**	0.39	0.39	0.39	J-27
Total Demands	130.53	251.22	432.26	J-27



Building 4 & 5				
Demands	ADF	MDD	PHD	Node
Building 4	56.97	113.94	199.4	J-29
Building 5	56.43	112.86	197.51	J-29
Vertical Planter Boxes*	9.45	9.45	9.45	J-29
Roof Top Pools/Water Features**	0.39	0.39	0.39	J-29
Total Demands	123.24	236.64	406.75	J-29

Additional Demands				
Demands	ADF	MDD	PHD	Node
Irrigation 1	23.06	23.06	23.06	J-56
Irrigation 2	23.06	23.06	23.06	J-44
Commercial (Office)	14.96	29.92	52.35	J-42
Commercial (Restaurant)	20.84	41.68	125.04	J-43

\*Note: All Vertical Planter Box demands divided by three and split up across each of the three groups of buildings.

\*\*Note: All Roof Top Pool/Water Features demands are produced by dividing the total Roof Top Pool/Water Features demand by 3 to equally split it amongst the three building groups. The differences in surface area for the water is negligible.

# Appendix F: Preliminary Utility Plan




**PRELIMINARY DOMESTIC WATER NOTES**

- ① PROPOSED 8"x12" TEE AND VALVE.
- ② PROPOSED 8" BACKFLOW PREVENTER.
- ③ PROPOSED 8" POLYWRAPPED CLASS 350 DIP WATERLINE.
- ④ PROPOSED 6" DOMESTIC WATER METER WITH 8"x6" REDUCERS MINIMUM 3' TO EITHER SIDE OF METER.
- ⑤ PROPOSED CONNECTION TO GARAGE.
- ⑥ PROPOSED 8" POLYWRAPPED CLASS 350 DIP WATERLINE.
- ⑦ PROPOSED 8" WATER LOOP.
- ⑧ PROPOSED DOMESTIC PUMP.
- ⑨ PROPOSED 2"x12" TEE AND VALVE.
- ⑩ PROPOSED 2" WATER METER.
- ⑪ PROPOSED 2" SCH 40 PVC WATER LINE.
- ⑫ PROPOSED 2" BACKFLOW PREVENTER
- ⑬ PROPOSED COMMERCIAL BUILDING CONNECTION.
- ⑭ PROPOSED 4"x4" TEE CONNECTION.
- ⑮ PROPOSED 4" **COMMERCIAL** WATER METER.
- ⑯ PROPOSED 4" SCH 40 PVC WATER LINE.
- ⑰ PROPOSED 4" BACKFLOW PREVENTER


**PRELIMINARY FIRELINE NOTES**

- ① PROPOSED 12"x12" TEE AND VALVE PER COS STD DET 2362-2.
- ② PROPOSED 12" BACKFLOW PREVENTOR.
- ③ PROPOSED 12" POLYWRAPPED CLASS 350 DIP FIRE LINE.
- ④ PROPOSED GARAGE CONNECTION.
- ⑤ PROPOSED BUILDING MOUNTED FDC.
- ⑥ PROPOSED FIRE HYDRANT RELOCATION.
- ⑦ PROPOSED FIRE HYDRANT.
- ⑧ PROPOSED 12" POLYWRAPPED CLASS 350 FIRE LOOP, REF FIRE LIFE SAFETY PLANS FOR DETAILS.
- ⑨ PROPOSED 16"x6" TAPPING SLEEVE AND VALVE PER COS STD. DET. 2362-2.
- ⑩ PROPOSED 6" POLYWRAPPED CLASS 350 DIP FIRE LINE.

- UTILITY NOTES**
1. REFER TO CITY STANDARD AND DETAILS FOR TRENCHING, BEDDING, AND BACKFILL, AND TRENCH COMPACTION REQUIREMENTS.
  2. ALL FILL MATERIAL IS TO BE IN PLACE, AND COMPACTED BEFORE INSTALLATION OF PROPOSED UTILITIES.
  3. CONTRACTOR SHALL NOTIFY THE UTILITY AUTHORITIES INSPECTORS 72 HOURS BEFORE CONNECTING TO ANY EXISTING LINE.
  4. SANITARY SEWER PIPE SHALL BE AS FOLLOWS:  
PRIVATE: PVC SDR 35 PER ASTM D 3034
  5. CONTRACTOR IS RESPONSIBLE FOR COMPLYING TO THE SPECIFICATIONS OF THE CITY OF SCOTTSDALE WITH REGARDS TO MATERIALS AND INSTALLATION OF THE WATER LINE AND WITH COS AND MAG REQUIREMENTS FOR UTILITY CROSSINGS.
  6. IT IS THE CONTRACTOR'S RESPONSIBILITY TO DEFLECT ELECTRIC, GAS CABLE, AND TELEPHONE CONDUIT AND PIPING AS REQUIRED TO AVOID UTILITY CONFLICTS.
  7. THE CONTRACTOR IS SPECIFICALLY CAUTIONED THAT THE LOCATION AND/OR ELEVATION OF EXISTING UTILITIES AS SHOWN ON THESE PLANS IS BASED ON RECORDS OF THE VARIOUS UTILITY COMPANIES, AND WHERE POSSIBLE, MEASUREMENTS TAKEN IN THE FIELD. THE INFORMATION IS NOT TO BE RELIED ON AS BEING EXACT OR COMPLETE. THE CONTRACTOR MUST CALL THE APPROPRIATE UTILITY COMPANIES AT LEAST 72 HOURS BEFORE ANY EXCAVATION TO REQUEST EXACT FIELD LOCATION OF UTILITIES. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO RELOCATE ALL EXISTING UTILITIES WHICH CONFLICT WITH THE PROPOSED IMPROVEMENTS SHOWN ON THE PLANS.
  8. CONTRACTOR IS RESPONSIBLE FOR ALL NECESSARY PERMITS, INSPECTIONS AND/OR CERTIFICATIONS REQUIRED BY CITY CODES AND/OR UTILITY SERVICE COMPANIES.
  9. CONTRACTOR SHALL COORDINATE WITH ALL UTILITY COMPANIES FOR INSTALLATION REQUIREMENTS AND SPECIFICATIONS IN REGARDS TO TAPS, HYDRANTS, VALVES, ETC.
  10. CONTRACTOR IS RESPONSIBLE FOR PAVEMENT REPLACEMENT REQUIRED FOR ALL UTILITY INSTALLATIONS PER CITY OF SCOTTSDALE STANDARDS.
  11. WATER TIGHT CONNECTION SHALL BE MADE USING A RESILIENT CONNECTOR "SEAL BOOT" PER ASTM C-923.
  12. CONTRACTOR SHALL MAINTAIN A MINIMUM OF 4 FEET COVER ON ALL WATER LINES.
  13. ALL SANITARY SEWER AND WATER WORK DESIGNATED AS "PRIVATE" IN THIS SET OF PLANS SHALL BE INSTALLED BY A LICENSED PLUMBER.
  14. BACKFLOW PREVENTER AND VAULT FOR THE IRRIGATION TO BE PROVIDED BY THE GC.
  15. INSPECTION OF THE WATER PIPING CONNECTING THE METER TO THE BACKFLOW PREVENTER SHALL BE CONDUCTED BY A CITY BACKFLOW PREVENTION SPECIALIST PRIOR TO CLSM AND BACKFILL. DSPM 6-1.417.



- PRELIMINARY SEWER NOTES**
- ① PROPOSED 12" PVC SEWER MAIN, LENGTH PER PLAN.
  - ② PROPOSED PUBLIC MANHOLE, INVERT PER PLAN.
  - ③ PROPOSED 8" PVC SEWER SERVICE, LENGTH PER PLAN.
  - ④ PROPOSED BUILDING CONNECTION.
  - ⑤ SEWER/STORM DRAIN CROSSING.
  - ⑥ SEWER/WATER MAIN CROSSING PER COS STD DET 2401.
  - ⑦ SEWER/FIRE MAIN CROSSING PER COS STD DET 2401.
  - ⑧ PROPOSED 8" SEWER WYE AND CLEANOUT, INVERT PER PLAN
  - ⑨ PROPOSED GREASE INTERCEPTOR.
  - ⑩ PROPOSED PRIVATE MANHOLE, INVERT PER PLAN.



BY DATE APPR

REVISION

NO.

**Kimley»Horn**

© 2022 KIMLEY-HORN AND ASSOCIATES, INC.  
7740 North 16th Street, Suite 300  
Phoenix, Arizona 85020 (602) 944-5500

DESIGNED BY: DJH  
DRAWN BY: DJH  
CHECKED BY: MLD  
DATE: SEP. 2022

SCALE (H): 1"=50'  
SCALE (V): NONE


**OPTIMA MCDOWELL MOUNTAIN VILLAGE  
PRELIMINARY UTILITY PLAN  
18777 N SCOTTSDALE RD.  
SCOTTSDALE, ARIZONA 85255**

FOR REVIEW ONLY  
NOT FOR CONSTRUCTION PURPOSES  
**Kimley»Horn**  
ENGINEER: VISE DELMARTER  
PE NO. 30886 DATE 09/23/22


PROJECT NO.  
191007011  
DRAWING NAME  
UT1  
1 OF 2

Q.S.#: 39-45

C:\Users\Tobin.Kopp\AppData\Local\Temp\Acp\Pub\202308\Pre\UT.dwg Sep 02, 2022 Tobin.Kopp  
 XREFS: x1b x1f x2m x2n x2o x2p x2q x2r x2s x2t x2u x2v x2w x2x x2y x2z x30 x31 x32 x33 x34 x35 x36 x37 x38 x39 x40 x41 x42 x43 x44 x45 x46 x47 x48 x49 x50 x51 x52 x53 x54 x55 x56 x57 x58 x59 x60 x61 x62 x63 x64 x65 x66 x67 x68 x69 x70 x71 x72 x73 x74 x75 x76 x77 x78 x79 x80 x81 x82 x83 x84 x85 x86 x87 x88 x89 x90 x91 x92 x93 x94 x95 x96 x97 x98 x99 x100 x101 x102 x103 x104 x105 x106 x107 x108 x109 x110 x111 x112 x113 x114 x115 x116 x117 x118 x119 x120 x121 x122 x123 x124 x125 x126 x127 x128 x129 x130 x131 x132 x133 x134 x135 x136 x137 x138 x139 x140 x141 x142 x143 x144 x145 x146 x147 x148 x149 x150 x151 x152 x153 x154 x155 x156 x157 x158 x159 x160 x161 x162 x163 x164 x165 x166 x167 x168 x169 x170 x171 x172 x173 x174 x175 x176 x177 x178 x179 x180 x181 x182 x183 x184 x185 x186 x187 x188 x189 x190 x191 x192 x193 x194 x195 x196 x197 x198 x199 x200 x201 x202 x203 x204 x205 x206 x207 x208 x209 x210 x211 x212 x213 x214 x215 x216 x217 x218 x219 x220 x221 x222 x223 x224 x225 x226 x227 x228 x229 x230 x231 x232 x233 x234 x235 x236 x237 x238 x239 x240 x241 x242 x243 x244 x245 x246 x247 x248 x249 x250 x251 x252 x253 x254 x255 x256 x257 x258 x259 x260 x261 x262 x263 x264 x265 x266 x267 x268 x269 x270 x271 x272 x273 x274 x275 x276 x277 x278 x279 x280 x281 x282 x283 x284 x285 x286 x287 x288 x289 x290 x291 x292 x293 x294 x295 x296 x297 x298 x299 x300 x301 x302 x303 x304 x305 x306 x307 x308 x309 x310 x311 x312 x313 x314 x315 x316 x317 x318 x319 x320 x321 x322 x323 x324 x325 x326 x327 x328 x329 x330 x331 x332 x333 x334 x335 x336 x337 x338 x339 x340 x341 x342 x343 x344 x345 x346 x347 x348 x349 x350 x351 x352 x353 x354 x355 x356 x357 x358 x359 x360 x361 x362 x363 x364 x365 x366 x367 x368 x369 x370 x371 x372 x373 x374 x375 x376 x377 x378 x379 x380 x381 x382 x383 x384 x385 x386 x387 x388 x389 x390 x391 x392 x393 x394 x395 x396 x397 x398 x399 x400 x401 x402 x403 x404 x405 x406 x407 x408 x409 x410 x411 x412 x413 x414 x415 x416 x417 x418 x419 x420 x421 x422 x423 x424 x425 x426 x427 x428 x429 x430 x431 x432 x433 x434 x435 x436 x437 x438 x439 x440 x441 x442 x443 x444 x445 x446 x447 x448 x449 x450 x451 x452 x453 x454 x455 x456 x457 x458 x459 x460 x461 x462 x463 x464 x465 x466 x467 x468 x469 x470 x471 x472 x473 x474 x475 x476 x477 x478 x479 x480 x481 x482 x483 x484 x485 x486 x487 x488 x489 x490 x491 x492 x493 x494 x495 x496 x497 x498 x499 x500 x501 x502 x503 x504 x505 x506 x507 x508 x509 x510 x511 x512 x513 x514 x515 x516 x517 x518 x519 x520 x521 x522 x523 x524 x525 x526 x527 x528 x529 x530 x531 x532 x533 x534 x535 x536 x537 x538 x539 x540 x541 x542 x543 x544 x545 x546 x547 x548 x549 x550 x551 x552 x553 x554 x555 x556 x557 x558 x559 x560 x561 x562 x563 x564 x565 x566 x567 x568 x569 x570 x571 x572 x573 x574 x575 x576 x577 x578 x579 x580 x581 x582 x583 x584 x585 x586 x587 x588 x589 x590 x591 x592 x593 x594 x595 x596 x597 x598 x599 x600 x601 x602 x603 x604 x605 x606 x607 x608 x609 x610 x611 x612 x613 x614 x615 x616 x617 x618 x619 x620 x621 x622 x623 x624 x625 x626 x627 x628 x629 x630 x631 x632 x633 x634 x635 x636 x637 x638 x639 x640 x641 x642 x643 x644 x645 x646 x647 x648 x649 x650 x651 x652 x653 x654 x655 x656 x657 x658 x659 x660 x661 x662 x663 x664 x665 x666 x667 x668 x669 x670 x671 x672 x673 x674 x675 x676 x677 x678 x679 x680 x681 x682 x683 x684 x685 x686 x687 x688 x689 x690 x691 x692 x693 x694 x695 x696 x697 x698 x699 x700 x701 x702 x703 x704 x705 x706 x707 x708 x709 x710 x711 x712 x713 x714 x715 x716 x717 x718 x719 x720 x721 x722 x723 x724 x725 x726 x727 x728 x729 x730 x731 x732 x733 x734 x735 x736 x737 x738 x739 x740 x741 x742 x743 x744 x745 x746 x747 x748 x749 x750 x751 x752 x753 x754 x755 x756 x757 x758 x759 x760 x761 x762 x763 x764 x765 x766 x767 x768 x769 x770 x771 x772 x773 x774 x775 x776 x777 x778 x779 x780 x781 x782 x783 x784 x785 x786 x787 x788 x789 x790 x791 x792 x793 x794 x795 x796 x797 x798 x799 x800 x801 x802 x803 x804 x805 x806 x807 x808 x809 x810 x811 x812 x813 x814 x815 x816 x817 x818 x819 x820 x821 x822 x823 x824 x825 x826 x827 x828 x829 x830 x831 x832 x833 x834 x835 x836 x837 x838 x839 x840 x841 x842 x843 x844 x845 x846 x847 x848 x849 x850 x851 x852 x853 x854 x855 x856 x857 x858 x859 x860 x861 x862 x863 x864 x865 x866 x867 x868 x869 x870 x871 x872 x873 x874 x875 x876 x877 x878 x879 x880 x881 x882 x883 x884 x885 x886 x887 x888 x889 x890 x891 x892 x893 x894 x895 x896 x897 x898 x899 x900 x901 x902 x903 x904 x905 x906 x907 x908 x909 x910 x911 x912 x913 x914 x915 x916 x917 x918 x919 x920 x921 x922 x923 x924 x925 x926 x927 x928 x929 x930 x931 x932 x933 x934 x935 x936 x937 x938 x939 x940 x941 x942 x943 x944 x945 x946 x947 x948 x949 x950 x951 x952 x953 x954 x955 x956 x957 x958 x959 x960 x961 x962 x963 x964 x965 x966 x967 x968 x969 x970 x971 x972 x973 x974 x975 x976 x977 x978 x979 x980 x981 x982 x983 x984 x985 x986 x987 x988 x989 x990 x991 x992 x993 x994 x995 x996 x997 x998 x999 1000



WEST UTILITY BLOW UP DETAIL



SOUTH UTILITY BLOW UP DETAIL

LEGEND

- PROPERTY LINE
- - - RIGHT OF WAY LINE
- - - STREET CENTERLINE
- - - EASEMENT LINE
- S --- EXISTING SANITARY SEWER MAIN
- W --- EXISTING PUBLIC WATER MAIN
- PROPOSED STORM DRAIN
- W --- PROPOSED WATER MAIN
- F --- PROPOSED FIRELINE
- S --- PROPOSED SEWER MAIN
- ⊙ --- EXISTING SANITARY SEWER MANHOLE
- ⊙ --- EXISTING FIRE HYDRANT
- ⊙ --- PROPOSED SANITARY SEWER MANHOLE
- ⊙ --- PROPOSED FIRE HYDRANT

PRELIMINARY DOMESTIC WATER NOTES

- 1 PROPOSED 8"x12" TEE AND VALVE.
- 2 PROPOSED 8" BACKFLOW PREVENTER.
- 3 PROPOSED 8" POLYWRAPPED CLASS 350 DIP WATERLINE.
- 4 PROPOSED 6" DOMESTIC WATER METER WITH 8"x6" REDUCERS MINIMUM 3' TO EITHER SIDE OF METER.
- 6 PROPOSED CONNECTION TO GARAGE.
- 7 PROPOSED 8" POLYWRAPPED CLASS 350 DIP WATERLINE.
- 8 PROPOSED 8" WATER LOOP.
- 9 PROPOSED DOMESTIC PUMP.
- 10 PROPOSED 2"x12" TEE AND VALVE.
- 11 PROPOSED 2" WATER METER.
- 12 PROPOSED 2" SCH 40 PVC WATER LINE.
- 13 PROPOSED 2" BACKFLOW PREVENTER
- 14 PROPOSED COMMERCIAL BUILDING CONNECTION.
- 15 PROPOSED 4"x4" TEE CONNECTION
- 16 PROPOSED 4" WATER METER.
- 17 PROPOSED 4" SCH 40 PVC WATER
- 18 PROPOSED 4" BACKFLOW PREVENTER
- 19 PROPOSED 4"x12" TEE AND VALVE.

PRELIMINARY FIRELINE NOTES

- 1 PROPOSED 12"x12" TEE AND VALVE PER COS STD DET 2362-2.
- 2 PROPOSED 12" BACKFLOW PREVENTOR.
- 3 PROPOSED 12" POLYWRAPPED CLASS 350 DIP FIRE LINE.
- 4 PROPOSED GARAGE CONNECTION.

PRELIMINARY WATER MAIN

- 1 PROPOSED 16"x12" TAPPING SLEEVE AND VALVE PER COS 2362-2\*.
- 2 PROPOSED 12" POLYWRAPPED DIP WATER MAIN.
- 3 PROPOSED 12" DIP 90° BEND.
- 4 PROPOSED 16" POLYWRAPPED DIP WATER MAIN.
- 5 PROPOSED CONNECTION TO EXISTING 16" MAIN.
- 6 PROPOSED 16"x12" TEE AND VALVE PER COS 2362-2.
- PROPOSED 16" VALVE.

NOTE:  
 EXISTING 16" WATER MAIN IS ACP. REPLACE MINIMUM 3' SECTION OF PIPE WITH NO LESS THAN 6' REMAINING TO NEAREST JOINT. THE EXISTING PIPE SHALL BE REPLACED WITH DIP. RECOMMENDED TO REPLACE ENTIRE SEGMENT BETWEEN LINES WITH DIP AND FITTING UP TO 6' PAST THE NEAREST JOINT ON EACH SIDE.


PVC is prohibited in the COS water distribution system. DSPM 6-1.402

**Kimley»Horn**  
 © 2022 KIMLEY-HORN AND ASSOCIATES, INC.  
 7740 North 16th Street, Suite 300  
 Phoenix, Arizona 85020 (602) 944-5500

OPTIMA MCDOWELL MOUNTAIN VILLAGE  
 PRELIMINARY UTILITY PLAN  
 SCOTTSDALE, ARIZONA 85255

PRELIMINARY  
 NOT FOR CONSTRUCTION PURPOSES  
**Kimley»Horn**  
 ENGINEER  
 LICENSE NUMBER 30885 DATE 09/22/22

PROJECT NO.  
 191007011  
 DRAWING NAME  
 UT2  
 2 OF 2



NO.	REVISION	BY	DATE	APPR.

# Appendix G: Water Feature Areas

## POOL SPA AND COLD PLUNGE AREAS

### Building 1

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	151 sf
Roof Level	Cold Plunge	74 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,364 sf</u>

### Building 2

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	179 sf
Roof Level	Cold Plunge	88 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,406 sf</u>

### Building 3

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	179 sf
Roof Level	Cold Plunge	88 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,406 sf</u>

### Building 4

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	151 sf
Roof Level	Cold Plunge	74 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,364 sf</u>

### Building 5

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	151 sf
Roof Level	Cold Plunge	74 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,364 sf</u>

### Building 6

Grade Level	Spa	92 sf
Grade Level	Cold Plunge	48 sf
Roof Level	Spa	151 sf
Roof Level	Cold Plunge	74 sf
Roof Level	Pool	2,999 sf
Total Area		<u>3,364 sf</u>




Total Water Surface Area 20,268 sf



### <QC\_Railing Schedule\_OMMV Planter-Guardrail Generic Detail>

A	B	C	D	E	F	G
Type	Base Level	Count	Length	Comments	Description	Family
Level 2						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 2	126	2937' - 0 1/8"			Railing
Level 2: 126		126	2937' - 0 1/8"			
Level 3						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 3	130	3155' - 3 1/8"			Railing
Level 3: 130		130	3155' - 3 1/8"			
Level 4						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 4	135	3079' - 0 1/8"			Railing
Level 4: 135		135	3079' - 0 1/8"			
Level 5						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 5	135	3079' - 0 1/8"			Railing
Level 5: 135		135	3079' - 0 1/8"			
Level 6						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 6	135	3079' - 3 1/8"			Railing
Level 6: 135		135	3079' - 3 1/8"			
Level 7						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 7	134	3140' - 6 1/8"			Railing
Level 7: 134		134	3140' - 6 1/8"			
Level 8						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 8	134	3275' - 0 1/8"			Railing
Level 8: 134		134	3275' - 0 1/8"			
Level 9						
050000_SD_101_RAILING - 3 PERFORATED CHANNELS W/ PLANTER	Level 9	131	3087' - 9 7/16"			Railing
Level 9: 131		131	3087' - 9 7/16"			
Grand total: 1060		1060	24832' - 10 5/16"			

# Appendix H: Private Vs Public Utility Exhibit

LEGEND	
PUBLIC SEWER	
PRIVATE SEWER	
PUBLIC WATER	
PRIVATE WATER	