

Michael Voorheis

From: terry@aquadesign.net
Sent: Wednesday, June 7, 2023 5:08 PM
To: Michael Voorheis
Subject: FW: Splash pad Rail Road Park

Follow Up Flag: Flag for follow up
Flag Status: Flagged

Michael, below is the email from Elisa at the Scottsdale Water Conservation Office that explains the exclusion for splash pads. For the response to the comment about getting Water Conservation Office approval, you can state per 6/2/2023 conversation with Elisa Klein, Water Conservation Program Supervisor at the City of Scottsdale Water Resources, splash pads are excluded from the water feature limitation ordinance.

Thanks,
Terry



From: Klein, Elisa <EKLEIN@SCOTTSDALEAZ.GOV>
Sent: Friday, June 2, 2023 4:26 PM
To: 'terry@aquadesign.net' <terry@aquadesign.net>
Subject: Splash pad Rail Road Park

Good afternoon, Terry -

The splash pad is considered a water park and therefor excluded from the water feature limitation ordinance. If you install a water feature that is not excluded on a non-residential property, the water feature will need to be approved by the Water Conservation Office.

Since we have not seen this type of splash pad, could you send us the design? It would be good to see what is being installed.

As mentioned in our phone call, we are updating the ordinance next month. Here is the link to the current ordinance.

Water Feature

https://library.municode.com/az/scottsdale/codes/code_of_ordinances?nodeId=VOLII_CH49WASESED_I_ARTVIIWACO_DIV1WACO_S49-242LIWAFECOUSNEINUSCOARREDE

Thank you for contacting Scottsdale Water,

Elisa Klein
Water Conservation Program Supervisor
City of Scottsdale Water Resources
9312 N 94th Street | Scottsdale, AZ 85258

(480) 312-5670
ScottsdaleAZ.gov/Water

Soak up the latest news from [Water – Use It Wisely!](#)

Water Sustainability through Stewardship, Innovation



Virus-free. www.avg.com