


#291637

203-23



Caliber Engineering Solutions

TO:

Craig Elwood
General Contractor
623.313.4206

PROJECT INFORMATION:

Job Name: Widerhorn Residence
Location: 11612 N. 86th St.
Scottsdale, AZ 85260

SUBJECT: CHANGE TO ENTRY CANOPY JOIST FRAMING

We have issued this letter to inform the building inspector that we have approved to change the joists at the entry overhang shade canopy and back shade canopy. At the entry canopy, the original design had continuous 2x8 joists at 24" o.c. We have approved the use of (2) 2x4's at 24" o.c. continuous at the top of roof w/ a 2x4 vertical brace in-between the top joists and lower soffit joists at no more than 8'-0" o.c. Similarly, at the back patio, we have approved the use of (2) 2x6's at 16" o.c. continuous at the top of roof w/ a 2x4 vertical brace in-between the top joists and lower 2x12 soffit joists at no more than 8'-0" o.c.

Should any questions arise due to this response letter, please do not hesitate to contact us and we can quickly clarify any of our responses.

Respectfully submitted,

Matthew Nieves, MSE, PE
Principal
Caliber Engineering Solutions
480.329.0493
mnieves@caliber-es.com

