

FINAL WATER REPORT

for

COSANTI COMMONS

7000 E. Shea Boulevard
Scottsdale, Arizona 85254

Prepared For:

ESG Architecture & Design

500 Washington Avenue South, Suite 1080
Minneapolis, MN 55415
612.339.5508 www.esgarch.com

Prepared by:



Sustainability Engineering Group

5240 N. 16th Street, Ste. 105
Phoenix, AZ 85016
480.588.7226 www.azSEG.com

Project Number: 230113

Submittal Date: June 22nd, 2023
Resubmittal: December 18th, 2023
Resubmittal: April 8th, 2024
Resubmittal: April 30, 2025 (DRB)



EXPIRATION DATE: 09-30-2025

COS CASE No.: 973-PA-2022; 6-ZN-2023; 2-GP-2023 Plan Check No.: TBD

TABLE OF CONTENTS

1. INTRODUCTION.....	1
1.1. SUMMARY OF PROPOSED DEVELOPEMENT.....	1
1.2. LEGAL DESCRIPTION	1
2. DESIGN DOCUMENTATION	1
2.1. DESIGN COMPLIANCE.....	1
2.2. PROCEDURES, POLICIES AND METHODOLOGIES.....	1
2.3. SOFTWARE ACKNOWLEDGEMENT:	1
3. EXISTING CONDITIONS.....	2
3.1. EXISTING AND PROPOSED ZONING AND LAND USES.....	2
3.2. EXISTING TOPOGRAPHY, VEGETATION AND LANDFORM FEATURES:.....	2
3.3. EXISTING WATER INFRASTRUCTURE:	2
3.4. CERTIFIED FLOW TEST RESULTS OF EXISTING WATER SYSTEM:.....	2
4. PROPOSED CONDITIONS.....	3
4.1. SITE PLAN:.....	3
4.2. PROPOSED WATER SYSTEM:	3
4.3. SECOND SOURCE:	3
4.4. WATER REQUIREMENTS:.....	3
4.5. MAINTENANCE RESPONSIBILITIES:.....	3
5. WATER SYSTEM COMPUTATIONS.....	4
5.1. WATER DEMANDS	4
5.2. SOFTWARE MODELING:	4
5.3. MINIMUM PRESSURE REQUIREMENTS:	5
5.4. WATER SYSTEM ANALYSIS:.....	5
6. SUMMARY / CONCLUSIONS.....	6
6.1. SUMMARY:	6
6.2. PROJECT SCHEDULE:.....	6
7. REFERENCES.....	6



EXPIRATION DATE: 09-30-2025

LIST OF TABLES

TABLE 1	-	Water Demand Calculations
TABLE 2	-	Existing Water Demand Calculations
TABLE 3	-	WaterCAD® Analysis Results

LIST OF FIGURES

FIGURE 1	-	Vicinity Map- Local Aerial
FIGURE 2	-	Aerial
FIGURE 3	-	COS Water Q-S Map 29-44
FIGURE 4	-	Proposed Site plan

LIST OF APPENDICES

APPENDIX I	-	Fire Hydrant Flow Test
APPENDIX II	-	Utility Plan
APPENDIX III	-	Water Modeling Reports
APPENDIX IV	-	Supplemental Water Conservation Measures Tables and Exhibits

1. INTRODUCTION

1.1. SUMMARY OF PROPOSED DEVELOPEMENT

Cosanti Commons is a proposed 189-unit high-density multifamily project located north of Shea Boulevard between N. 70th Street and N. 71st Place in Scottsdale, Arizona. The project will raze an existing office complex on the eastern portion of the site and construct 1-, 2- and 3-bedroom residential units. The existing commercial development on the western portion of the site will be maintained. Domestic, fire and irrigation service to the residential development will be provided off the existing public 8" ACP water line looping through the site. The purpose of this final report is to provide a water analysis for general plan and zoning review.

Refer to **FIGURE 1** for a Vicinity Map.

1.2. LEGAL DESCRIPTION

The existing parcel located in Section 22, Township 3 North, Range 4 East will be subdivided maintaining the existing commercial site on the west side and the proposed residential development on the east side.

- Existing APN: 175-42-140, Lot 1 of 7000 E. Shea Boulevard, according to the plat of record in the office of the County Recorder of Maricopa County, Arizona, in Book 1701 of Maps, Page 37. The total disturbed land area is 4.36 net acres (189,956.46 sq. ft.).

2. DESIGN DOCUMENTATION

2.1. DESIGN COMPLIANCE

The proposed water system is designed to meet design criteria of the City of Scottsdale ("the City") Water Resources Department, the Arizona Department of Environmental Quality ("ADEQ"), and Maricopa County Environmental Services Department ("MCESD").

2.2. PROCEDURES, POLICIES AND METHODOLOGIES

The general methodology used to evaluate public water infrastructure consists of modeling a local network of water distribution mains to meet the city's pressure, velocity, and water demand requirements during daily demand and fire events. Connection to the water system is modeled as a reservoir and pump. The pump will simulate a pressure drop and available flow from the existing water system as depicted by the fire flow test.

2.3. SOFTWARE ACKNOWLEDGEMENT:

Bentley WaterCAD® Version 10.04 is the computer modeling tool used in this water study.

3. EXISTING CONDITIONS

3.1. EXISTING AND PROPOSED ZONING AND LAND USES

The parcel is presently zoned PUD-PSD, planned unit development with planned shared development overlay.

3.2. EXISTING TOPOGRAPHY, VEGETATION AND LANDFORM FEATURES:

The parcel is fully developed. The topography generally slopes to the south and west approximately

Refer to **FIGURE 2** for an aerial of the overall project existing conditions.

3.3. EXISTING WATER INFRASTRUCTURE:

See **FIGURE 3** - City of Scottsdale (QS 29-44)

- A 12" ACP main is located in Shea Boulevard approximately 28' south of the street centerline running east-west along the entire frontage.
- An 8" ACP main is located in North 70th Street approximately 24' east of the street centerline running north-south along the entire frontage.
- An 8" ACP main is located in East Sahuaro Drive approximately 24' north of the street centerline across a part of the site's frontage.
- An 8" ACP main extends through the site connecting to the mains in North 70th Street and East Sahuaro Drive. The onsite main is public located within a 12' wide easement for water.
- Hydrants exist within the site and along North 70th Street and Sahuaro Drive.
- Existing building water meters and fire lines are located off the mains within the site.
- Existing meter sizes are shown on the QS map.

3.4. CERTIFIED FLOW TEST RESULTS OF EXISTING WATER SYSTEM:

Certified fire hydrant flow testing was performed on January 26, 2023, by Arizona Flow Testing LLC at 7:00 a.m. The fire flow test recorded a static pressure of 90.0 psi and residual pressure of 67.0 psi at 2,431 gpm. The extrapolated flow at 20 psi is 4,434 gpm and at 30 psi is 4,079 gpm.

The test adjusted to 72 psi static pressure results in a residual pressure of 49.0 psi and a flow of 2,431 gpm. The adjusted flow at 20 psi is 3,776 gpm and at 30 psi is 3,365 gpm. The City of Scottsdale requires the adjusted pressure parameters to be used in hydraulic analysis. Test documentation is included in **APPENDIX I**.

4. PROPOSED CONDITIONS

4.1. SITE PLAN:

FIGURE 4 depicts the proposed site plan. The onsite structure and service lines located on the eastern side of the site will be removed. Fee credit for existing meters removed as shown on the utility plans will be requested. The existing water line running north-south will remain with the leg extending to the east removed.

The eastern portion of the property will be re-developed with a residential structure containing 189 units and require new domestic, irrigation and fire service.

4.2. PROPOSED WATER SYSTEM:

The new domestic and irrigation meters will be tapped off the existing onsite 8" ACP water line and installed with backflow prevention. The new domestic meters will be one 2" and one 3" and the landscape meter will be **1"**. A new 6" DIP fire line will be provided to the building. Two new fire hydrants provide adequate coverage to the proposed building. Three existing fire hydrants will be removed, one of them near the southwest corner of the building, one in the center of the building and one near the northwestern corner of the limit of disturbance.

See **APPENDIX II** for the utility plan.

4.3. SECOND SOURCE:

The existing water system has sufficient valves to allow for shutdowns in the event of service disruption and assures second sourcing for emergency service.

4.4. WATER REQUIREMENTS:

The city's design standards govern the fire flow rates used for all buildings per Section 6-1.500 of the City of Scottsdale's Design Standards & Policies Manual (DS&PM"), dated January 2018 along with Appendix B in the International Fire Code (IFC).

4.5. MAINTENANCE RESPONSIBILITIES:

Water meter and service line connections to the public main will be located within existing easements and be maintained by the city. The owner will privately maintain on-site domestic and landscape services and backflow preventers as well as the fire line.

5. WATER SYSTEM COMPUTATIONS

5.1. WATER DEMANDS

Table 1: WATER DEMAND CALCULATIONS						
	Area (sq.ft.)	Dwelling Units	ADD (gpm/unit)	Avg. Day Demand (gpm)	Max. Day Demand (gpm)	Peak Hour (gpm)
Residential East	-	189	0.27	51.0	102.1	178.6
Commercial/Retail West	79,200	-	1.11E-03	87.9	175.8	307.7
TOTAL DEMAND (gpm):				138.9	277.9	486.3

Peaking Factors: Max Day = 2.0, Peak Hour = 3.5

For illustrative purposes, Table 2 calculates demand for the existing east and west commercial/retail buildings.

Table 2: EXISTING WATER DEMAND CALCULATIONS					
	Area (sq.ft.)	ADD (gpm/unit)	Avg. Day Demand (gpm)	Max. Day Demand (gpm)	Peak Hour (gpm)
Ex. Commercial/Retail (east)	24,629	1.11E-03	27.3	54.7	95.7
Ex. Commercial/Retail (west)	79,200	1.11E-03	87.9	175.8	307.7
TOTAL DEMAND (gpm):			115.3	230.5	403.4

Peaking Factors: Max Day = 2.0, Peak Hour = 3.5

Refer to **APPENDIX IV** for Supplemental Water Conservation Tables and Exhibits.

5.2. SOFTWARE MODELING:

Bentley WaterCAD® Version 10.04 is the computer modeling tool used in this study.

Network analysis input parameters included the following:

- Pipe diameters (inches)
- Pipe lengths (feet)
- Pipes invert elevations (feet – MSL)
- A reservoir and a pump to model the fire flow test.
- System demands (gpm)
- Fire flows (gpm)
- Model piping is ductile iron pipe using Hazen-Williams frictional losses (C = 130)

Output parameters included but were not limited to:

- Pressure (psi)
- Flow rates (gpm)

- Velocities (fps)

5.3. MINIMUM PRESSURE REQUIREMENTS:

The following system pressure requirements are in accordance with the City's design standards:

Average day, maximum day and peak hour flow demands:

- Minimum pressure = 50 psi
- Maximum pressure = 120 psi

Maximum day plus coincident fire flow demand:

- Minimum pressure = 30 psi
- Maximum pressure = 120 psi

Fire Flow Requirements

- The building area is 295,000 sf. Assuming Type IIB construction, Table B105.1 of the IFC requires a fire flow of 8,000 gpm. All structures will be provided with automatic sprinkler systems which allow for a 75% reduction in required fire flow per Section B105.2 which is 2,000 gpm. The minimum fire flow is 2,500 gpm for high-rise (3-story) commercial and multi-family residential properties, per Section 6-1.501 of the DS&PM. The site will require the minimum allowable fire flow of 2,500 gpm plus maximum day demand.

Head loss in the public mains shall not exceed 10 feet per 1,000 feet length of pipe.

5.4. WATER SYSTEM ANALYSIS:

A summary of the modeling results is presented below in Table 2. Detailed WaterCAD® reports are presented in **APPENDIX III**.

Table 3: WaterCAD® Analysis Results							
Demand Scenario	Water Demand (GPM)	Pressure (PSI)				Max. Velocity (ft/s)	Pipe ID
		Min.	Node	Max.	Node		
Average Day	138.9	70	J-8	74	J-4	0.68	P-14
Maximum Day	277.9	70	J-8	74	J-4	1.36	P-14
Peak Hour	486.3	69	J-8	73	J-4	2.38	P-14
FF + MDD	2,778	31	J-6	41	FH-1	8.03	P-14

These results indicate that the proposed water system meets the City's criteria for daily water usage and fire flow events.

6. SUMMARY / CONCLUSIONS

6.1. SUMMARY:

The proposed water connections are designed to meet criteria of the City's Design Standards and Policies Manual, the Arizona Department of Environmental Quality ("ADEQ"), and Maricopa County Environmental Services Department ("MCESD").

The hydraulic output indicates that the surrounding existing public water system and fire hydrants are sufficient to provide domestic, irrigation and fire service to this project.

Pressure regulating valves preset to 80 psi will be required on all water service connections to the building. Backflow prevention will be provided on all metered service connections.

6.2. PROJECT SCHEDULE:


As a residential apartment development, the infrastructure and buildings are proposed to be constructed in a single phase.

7. REFERENCES

1. COS Water Q-S MAP 29-44
2. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 6 – Water)

FIGURES

- 1. Vicinity Map***
- 2. Aerial***
- 3. Water Q-S 29-44***
- 4. Proposed Site Plan***



**FIGURE 1 –
Vicinity Map**




**FIGURE 2 –
Aerial**

NOTICE

THIS DOCUMENT IS PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.

THE CITY OF SCOTTSDALE



GENERAL NOTES:

- THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE GIS DEPARTMENT AT (480) 312-7792.
- THE SECTION LINE BEARING AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTENED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS "CALCULATED" ON THE MAP.

LEGEND:

- Air Release Valve
- Non-potable Air Release Valve
- Blowoff
- Cap
- Cathodic Protection
- Fill Drain
- Fire Hydrant
- Non-GPS Point
- Pressure Reducing Valve
- Pump
- Reducer
- Sample Station
- Water Manhole
- Non-Potable Manhole
- Well
- Valve
- Non-potable Valve
- Vault
- Water Main
- Non-Potable Main
- Fire / Private Main
- Non-Scottsdale Main

VICINITY MAP

CHOLLA STREET
SHEA BOULEVARD
SCOTTSDALE ROAD
68TH STREET
CENTER

NORTH

SCALE: 1" = 100'

The map scale of 1" = 100' is based on a full size print of 30" x 36"

WATER

QUARTER SECTION MAP

29-44

SE 1/4 SEC. 22 T3N R4E

FIGURE 3


CITY OF SCOTTSDALE

SCOTTSDALE GEOGRAPHIC INFORMATION SYSTEMS

3629 North Drinkwater Boulevard
Scottsdale, Arizona 85251

FIGURE 4 - Proposed Site Plan

1 TECHNICAL REQUIREMENTS
A.21.fb 1" = 40'-0"



EXISTING BUILDINGS SF:	
(PER CASE 30-DR-2020)	
BUILDING A/C:	+/-18,500 SF
BUILDING B/D:	+/-18,500 SF
BUILDING E:	+/-12,200 SF
BUILDING F:	+/- 7,200 SF
BUILDING G:	+/- 7,200 SF
BUILDING H:	+/-15,600 SF
TOTAL:	+/-79,200 SF
LOT 2 BLACK ROCK: +/- 1,977 SF	
LOT 3 BUILDING I: +/- 5,600 SF (AZ BREAD +/-2,800 SF)	

PARKING METRICS - EXISTING LOT 3:	
COSANTI COMMONS EXISTING LOT 3 PARKING (NOT PART OF REZONE REQUEST)	
APPROVED SITE PLAN FOR EXISTING LOT 3 (BLACK ROCK COFFEE)	GENERAL ZONING PARKING REQUIREMENT
EXISTING COMMERCIAL LOT 3 - NOT PART OF REZONE REQUEST (C-2 (C) ZONING)	EXISTING COMMERCIAL LOT 3 - NOT PART OF REZONE REQUEST (C-2 (C) ZONING)
STANDARD VEHICLE PARKING PER USE [Table 9.103.A]	1,977 SF**** / 300
MIXED USE COMMERCIAL CENTER USE (TOTAL REQUIRED)	7
TOTAL VEHICLE PARKING PROVIDED	10 (SURFACE TO REMAIN)
**** Per Site Plan data, Black Rock Coffee Bar, Case# 30-DR-2020, Lot 3 = Building I (Arizona Bread Company and Fitness 4 Home)	

PROJECT DATA SUMMARY:				
LOOSE NO:	173 PA-2022, 2- GP-2023, 6- 2N-2023, 3- DA-2023			
Project Address:	COMMERCIAL/RETAIL BUILDINGS: 7000 E Shea Blvd, Bldgs A, B, C, D, E, G, H and multiple suite numbers (existing per County) EXISTING COMMERCIAL/RETAIL SITE: C-2 (Central Business) Scottsdale, AZ 85254			
APN (EXISTING):	EXISTING COMMERCIAL/RETAIL SITE: 175-42-1365 (per County) EXISTING RESIDENTIAL SITE: 175-42-1365 (per County)			
APN (PROPOSED):	OVERALL SITE: 175-42-140 (per Plot)			
QS:	EXISTING COMMERCIAL/RETAIL SITE: C-2 (Central Business) EXISTING RESIDENTIAL SITE: C-2 (Central Business)			
Zoning Classification (EXISTING):	OVERALL SITE: PUD-PSD (Planned Unit Development with Planned Shared Development Overlay) -- APPROVED WITH CASES: 2-OP-2023, 6-2N-2023, 3-DA-2023			
Zoning Classification (PROPOSED):				
ZONING SUMMARY:				
COSANTI COMMONS				
PLANNED UNIT DEVELOPMENT WITH PLANNED SHARED DEVELOPMENT OVERLAY -- APPROVED WITH CASES: 2-OP-2023, 6-2N-2023, 3-DA-2023	PROPOSED OVERALL LOT (PUD-PSD ZONING)	EXISTING COMMERCIAL (PUD-PSD ZONING)	PROPOSED RESIDENTIAL (PUD-PSD ZONING)	ESG
STANDARD USE	MIXED USE CENTER (RETAIL, OFFICE, DENTAL OFFICE, HARM SALON, HEALTH FOOD STORE, SPORTS TRAINING, CHESS INSTRUCTOR, RESTAURANT, PARKING & MULTI-FAMILY)	MIXED USE CENTER (RETAIL, OFFICE, DENTAL OFFICE, HARM SALON, HEALTH FOOD STORE, SPORTS TRAINING, CHESS INSTRUCTOR, RESTAURANT, PARKING & MULTI-FAMILY)	MIXED USE CENTER (RETAIL, OFFICE, DENTAL OFFICE, HARM SALON, HEALTH FOOD STORE, SPORTS TRAINING, CHESS INSTRUCTOR, RESTAURANT, PARKING & MULTI-FAMILY)	MULTI-FAMILY
TOTAL LOT AREA (GROSS, WITH CITY OWNED PARCELS)	204,142 S.F. (4,687 AC)	204,142 S.F. (4,687 AC)	204,142 S.F. (4,687 AC)	204,142 S.F. (4,687 AC)
TOTAL LOT AREA (GROSS, WITHOUT CITY OWNED PARCELS)	375,447 S.F. (8,639 AC)	375,447 S.F. (8,639 AC)	375,447 S.F. (8,639 AC)	375,447 S.F. (8,639 AC)
TOTAL LOT AREA (NET, WITHOUT CITY OWNED PARCELS, BEFORE 4' ALLEY DEDICATION)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)
TOTAL FUTURE LOT AREA (NET, WITHOUT CITY OWNED PARCELS, AFTER 4' ALLEY DEDICATION)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)	316,041 S.F. (7,255 AC)
RESIDENTIAL GSI	189 / 18,615 = 321.93	189 / 18,615 = 321.93	189 / 18,615 = 321.93	189 / 18,615 = 321.93
DWELLING QUANTITY	189 UNITS	189 UNITS	189 UNITS	189 UNITS
EFFICIENCY: 30 UNITS	189 / 30 = 6.3	189 / 30 = 6.3	189 / 30 = 6.3	189 / 30 = 6.3
EFFICIENCY: 35 UNITS	189 / 35 = 5.4	189 / 35 = 5.4	189 / 35 = 5.4	189 / 35 = 5.4
EFFICIENCY: 40 UNITS	189 / 40 = 4.7	189 / 40 = 4.7	189 / 40 = 4.7	189 / 40 = 4.7
EFFICIENCY: 45 UNITS	189 / 45 = 4.2	189 / 45 = 4.2	189 / 45 = 4.2	189 / 45 = 4.2
EFFICIENCY: 50 UNITS	189 / 50 = 3.8	189 / 50 = 3.8	189 / 50 = 3.8	189 / 50 = 3.8
EFFICIENCY: 55 UNITS	189 / 55 = 3.4	189 / 55 = 3.4	189 / 55 = 3.4	189 / 55 = 3.4
EFFICIENCY: 60 UNITS	189 / 60 = 3.1	189 / 60 = 3.1	189 / 60 = 3.1	189 / 60 = 3.1
EFFICIENCY: 65 UNITS	189 / 65 = 2.9	189 / 65 = 2.9	189 / 65 = 2.9	189 / 65 = 2.9
EFFICIENCY: 70 UNITS	189 / 70 = 2.7	189 / 70 = 2.7	189 / 70 = 2.7	189 / 70 = 2.7
EFFICIENCY: 75 UNITS	189 / 75 = 2.5	189 / 75 = 2.5	189 / 75 = 2.5	189 / 75 = 2.5
EFFICIENCY: 80 UNITS	189 / 80 = 2.4	189 / 80 = 2.4	189 / 80 = 2.4	189 / 80 = 2.4
EFFICIENCY: 85 UNITS	189 / 85 = 2.2	189 / 85 = 2.2	189 / 85 = 2.2	189 / 85 = 2.2
EFFICIENCY: 90 UNITS	189 / 90 = 2.1	189 / 90 = 2.1	189 / 90 = 2.1	189 / 90 = 2.1
EFFICIENCY: 95 UNITS	189 / 95 = 2.0	189 / 95 = 2.0	189 / 95 = 2.0	189 / 95 = 2.0
EFFICIENCY: 100 UNITS	189 / 100 = 1.9	189 / 100 = 1.9	189 / 100 = 1.9	189 / 100 = 1.9
EFFICIENCY: 105 UNITS	189 / 105 = 1.8	189 / 105 = 1.8	189 / 105 = 1.8	189 / 105 = 1.8
EFFICIENCY: 110 UNITS	189 / 110 = 1.7	189 / 110 = 1.7	189 / 110 = 1.7	189 / 110 = 1.7
EFFICIENCY: 115 UNITS	189 / 115 = 1.6	189 / 115 = 1.6	189 / 115 = 1.6	189 / 115 = 1.6
EFFICIENCY: 120 UNITS	189 / 120 = 1.6	189 / 120 = 1.6	189 / 120 = 1.6	189 / 120 = 1.6
EFFICIENCY: 125 UNITS	189 / 125 = 1.5	189 / 125 = 1.5	189 / 125 = 1.5	189 / 125 = 1.5
EFFICIENCY: 130 UNITS	189 / 130 = 1.4	189 / 130 = 1.4	189 / 130 = 1.4	189 / 130 = 1.4
EFFICIENCY: 135 UNITS	189 / 135 = 1.4	189 / 135 = 1.4	189 / 135 = 1.4	189 / 135 = 1.4
EFFICIENCY: 140 UNITS	189 / 140 = 1.3	189 / 140 = 1.3	189 / 140 = 1.3	189 / 140 = 1.3
EFFICIENCY: 145 UNITS	189 / 145 = 1.3	189 / 145 = 1.3	189 / 145 = 1.3	189 / 145 = 1.3
EFFICIENCY: 150 UNITS	189 / 150 = 1.3	189 / 150 = 1.3	189 / 150 = 1.3	189 / 150 = 1.3
EFFICIENCY: 155 UNITS	189 / 155 = 1.2	189 / 155 = 1.2	189 / 155 = 1.2	189 / 155 = 1.2
EFFICIENCY: 160 UNITS	189 / 160 = 1.2	189 / 160 = 1.2	189 / 160 = 1.2	189 / 160 = 1.2
EFFICIENCY: 165 UNITS	189 / 165 = 1.1	189 / 165 = 1.1	189 / 165 = 1.1	189 / 165 = 1.1
EFFICIENCY: 170 UNITS	189 / 170 = 1.1	189 / 170 = 1.1	189 / 170 = 1.1	189 / 170 = 1.1
EFFICIENCY: 175 UNITS	189 / 175 = 1.1	189 / 175 = 1.1	189 / 175 = 1.1	189 / 175 = 1.1
EFFICIENCY: 180 UNITS	189 / 180 = 1.0	189 / 180 = 1.0	189 / 180 = 1.0	189 / 180 = 1.0
EFFICIENCY: 185 UNITS	189 / 185 = 1.0	189 / 185 = 1.0	189 / 185 = 1.0	189 / 185 = 1.0
EFFICIENCY: 190 UNITS	189 / 190 = 1.0	189 / 190 = 1.0	189 / 190 = 1.0	189 / 190 = 1.0
EFFICIENCY: 195 UNITS	189 / 195 = 1.0	189 / 195 = 1.0	189 / 195 = 1.0	189 / 195 = 1.0
EFFICIENCY: 200 UNITS	189 / 200 = 0.9	189 / 200 = 0.9	189 / 200 = 0.9	189 / 200 = 0.9
EFFICIENCY: 205 UNITS	189 / 205 = 0.9	189 / 205 = 0.9	189 / 205 = 0.9	189 / 205 = 0.9
EFFICIENCY: 210 UNITS	189 / 210 = 0.9	189 / 210 = 0.9	189 / 210 = 0.9	189 / 210 = 0.9
EFFICIENCY: 215 UNITS	189 / 215 = 0.9	189 / 215 = 0.9	189 / 215 = 0.9	189 / 215 = 0.9
EFFICIENCY: 220 UNITS	189 / 220 = 0.9	189 / 220 = 0.9	189 / 220 = 0.9	189 / 220 = 0.9
EFFICIENCY: 225 UNITS	189 / 225 = 0.8	189 / 225 = 0.8	189 / 225 = 0.8	189 / 225 = 0.8
EFFICIENCY: 230 UNITS	189 / 230 = 0.8	189 / 230 = 0.8	189 / 230 = 0.8	189 / 230 = 0.8
EFFICIENCY: 235 UNITS	189 / 235 = 0.8	189 / 235 = 0.8	189 / 235 = 0.8	189 / 235 = 0.8
EFFICIENCY: 240 UNITS	189 / 240 = 0.8	189 / 240 = 0.8	189 / 240 = 0.8	189 / 240 = 0.8
EFFICIENCY: 245 UNITS	189 / 245 = 0.8	189 / 245 = 0.8	189 / 245 = 0.8	189 / 245 = 0.8
EFFICIENCY: 250 UNITS	189 / 250 = 0.8	189 / 250 = 0.8	189 / 250 = 0.8	189 / 250 = 0.8
EFFICIENCY: 255 UNITS	189 / 255 = 0.7	189 / 255 = 0.7	189 / 255 = 0.7	189 / 255 = 0.7
EFFICIENCY: 260 UNITS	189 / 260 = 0.7	189 / 260 = 0.7	189 / 260 = 0.7	189 / 260 = 0.7
EFFICIENCY: 265 UNITS	189 / 265 = 0.7	189 / 265 = 0.7	189 / 265 = 0.7	189 / 265 = 0.7
EFFICIENCY: 270 UNITS	189 / 270 = 0.7	189 / 270 = 0.7	189 / 270 = 0.7	189 / 270 = 0.7
EFFICIENCY: 275 UNITS	189 / 275 = 0.7	189 / 275 = 0.7	189 / 275 = 0.7	189 / 275 = 0.7
EFFICIENCY: 280 UNITS	189 / 280 = 0.7	189 / 280 = 0.7	189 / 280 = 0.7	189 / 280 = 0.7
EFFICIENCY: 285 UNITS	189 / 285 = 0.7	189 / 285 = 0.7	189 / 285 = 0.7	189 / 285 = 0.7
EFFICIENCY: 290 UNITS	189 / 290 = 0.6	189 / 290 = 0.6	189 / 290 = 0.6	189 / 290 = 0.6
EFFICIENCY: 295 UNITS	189 / 295 = 0.6	189 / 295 = 0.6	189 / 295 = 0.6	189 / 295 = 0.6
EFFICIENCY: 300 UNITS	189 / 300 = 0.6	189 / 300 = 0.6	189 / 300 = 0.6	189 / 300 = 0.6
EFFICIENCY: 305 UNITS	189 / 305 = 0.6	189 / 305 = 0.6	189 / 305 = 0.6	189 / 305 = 0.6
EFFICIENCY: 310 UNITS	189 / 310 = 0.6	189 / 310 = 0.6	189 / 310 = 0.6	189 / 310 = 0.6
EFFICIENCY: 315 UNITS	189 / 315 = 0.6	189 / 315 = 0.6	189 / 315 = 0.6	189 / 315 = 0.6
EFFICIENCY: 320 UNITS	189 / 320 = 0.6	189 / 320 = 0.6	189 / 320 = 0.6	189 / 320 = 0.6
EFFICIENCY: 325 UNITS	189 / 325 = 0.6	189 / 325 = 0.6	189 / 325 = 0.6	189 / 325 = 0.6
EFFICIENCY: 330 UNITS	189 / 330 = 0.6	189 / 330 = 0.6	189 / 330 = 0.6	189 / 330 = 0.6
EFFICIENCY: 335 UNITS	189 / 335 = 0.6	189 / 335 = 0.6	189 / 335 = 0.6	189 / 335 = 0.6
EFFICIENCY: 340 UNITS	189 / 340 = 0.5	189 / 340 = 0.5	189 / 340 = 0.5	189 / 340 = 0.5
EFFICIENCY: 345 UNITS	189 / 345 = 0.5	189 / 345 = 0.5	189 / 345 = 0.5	189 / 345 = 0.5
EFFICIENCY: 350 UNITS	189 / 350 = 0.5	189 / 350 = 0.5	189 / 350 = 0.5	189 / 350 = 0.5
EFFICIENCY: 355 UNITS	189 / 355 = 0.5	189 / 355 = 0.5	189 / 355 = 0.5	189 / 355 = 0.5
EFFICIENCY: 360 UNITS	189 / 360 = 0.5	189 / 360 = 0.5	189 / 360 = 0.5	189 / 360 = 0.5
EFFICIENCY: 365 UNITS	189 / 365 = 0.5	189 / 365 = 0.5	189 / 365 = 0.5	189 / 365 = 0.5
EFFICIENCY: 370 UNITS	189 / 370 = 0.5	189 / 370 = 0.5	189 / 370 = 0.5	189 / 370 = 0.5
EFFICIENCY: 375 UNITS	189 / 375 = 0.5	189 / 375 = 0.5	189 / 375 = 0.5	189 / 375 = 0.5
EFFICIENCY: 380 UNITS	189 / 380 = 0.5	189 / 380 = 0.5	189 / 380 = 0.5	189 / 380 = 0.5
EFFICIENCY: 385 UNITS	189 / 385 = 0.5	189 / 385 = 0.5	189 / 385 = 0.5	189 / 385 = 0.5
EFFICIENCY: 390 UNITS	189 / 390 = 0.5	189 / 390 = 0.5	189 / 390 = 0.5	189 / 390 = 0.5
EFFICIENCY: 395 UNITS	189 / 395 = 0.5	189 / 395 = 0.5	189 / 395 = 0.5	189 / 395 = 0.5
EFFICIENCY: 400 UNITS	189 / 400 = 0.5	189 / 400 = 0.5	189 / 400 = 0.5	189 / 400 = 0.5
EFFICIENCY: 405 UNITS	189 / 405 = 0.5	189 / 405 = 0.5	189 / 405 = 0.5	189 / 405 = 0.5
EFFICIENCY: 410 UNITS	189 / 410 = 0.4	189 / 410 = 0.4	189 / 410 = 0.4	189 / 410 = 0.4
EFFICIENCY: 415 UNITS	189 / 415 = 0.4	189 / 415 = 0.4	189 / 415 = 0.4	189 / 415 = 0.4
EFFICIENCY: 420 UNITS	189 / 420 = 0.4	189 / 420 = 0.4	189 / 420 = 0.4	189 / 420 = 0.4
EFFICIENCY: 425 UNITS	189 / 425 = 0.4	189 / 425 = 0.4	189 / 425 = 0.4	189 / 425 = 0.4
EFFICIENCY: 430 UNITS	189 / 430 = 0.4	189 / 430 = 0.4	189 / 430 = 0.4	189 / 430 = 0.4
EFFICIENCY: 435 UNITS	189 / 435 = 0.4	189 / 435 = 0.4	189 / 435 = 0.4	189 / 435 = 0.4
EFFICIENCY: 440 UNITS	189 / 440 = 0.4	189 / 440 = 0.4	189 / 440 = 0.4	189 / 440 = 0.4
EFFICIENCY: 445 UNITS	189 / 445 = 0.4	189 / 445 = 0.4	189 / 445 = 0.4	189 / 445 = 0.4
EFFICIENCY: 450 UNITS	189 / 450 = 0.4	189 / 450 = 0.4	189 / 450 = 0.4	189 / 450 = 0.4
EFFICIENCY: 455 UNITS	189 / 455 = 0.4	189 / 455 = 0.4	189 / 455 = 0.4	189 / 455 = 0.4
EFFICIENCY: 460 UNITS	189 / 460 = 0.4	189 / 460 = 0.4	189 / 460 = 0.4	189 / 460 = 0.4
EFFICIENCY: 465 UNITS	189 / 465 = 0.4	189 / 465 = 0.4	189 / 465 = 0.4	189 / 465 = 0.4
EFFICIENCY: 470 UNITS	189 / 470 = 0.4	189 / 470 = 0.4	189 / 470 = 0.4	189 / 470 = 0.4
EFFICIENCY: 475 UNITS	189 / 475 = 0.4	189 / 475 = 0.4	189 / 475 = 0.4	189 / 475 = 0.4
EFFICIENCY: 480 UNITS	189 / 480 = 0.4	189 / 480 = 0.4	189 / 480 = 0.4	189 / 480 = 0.4
EFFICIENCY: 485 UNITS	189 / 485 = 0.4	189 / 485 = 0.4	189 / 485 = 0.4	189 / 485 = 0.4
EFFICIENCY: 490 UNITS	189 / 490 = 0.4	189 / 490 = 0.4	189 / 490 = 0.4	189 / 490 = 0.4
EFFICIENCY: 495 UNITS	189 / 495 = 0.4	189 / 495 = 0.4	189 / 495 = 0.4	189 / 495 = 0.4
EFFICIENCY: 500 UNITS	189 / 500 = 0.4	189 / 500 = 0.4	189 / 500 = 0.4	189 / 500 = 0.4
EFFICIENCY: 505 UNITS	189 / 505 = 0.4	189 / 505 = 0.4	189 / 505 = 0.4	189 / 505 = 0.4
EFFICIENCY: 510 UNITS	189 / 510 = 0.4	189 / 510 = 0.4	189 / 510 = 0.4	189 / 510 = 0.4
EFFICIENCY: 515 UNITS	189 / 515 = 0.4	189 / 515 = 0.4	189 / 515 = 0.4	189 / 515 = 0.4
EFFICIENCY: 520 UNITS	189 / 520 = 0.4	189 / 520 = 0.4	189 / 520 = 0.4	189 / 520 = 0.4
EFFICIENCY: 525 UNITS	189 / 525 = 0.4	189 / 525 = 0.4	189 / 525 = 0.4	189 / 525 = 0.4
EFFICIENCY: 530 UNITS	189 / 530 = 0.4	189 / 530 = 0.4	189 / 530 = 0.4	189 / 530 = 0.4
EFFICIENCY: 535 UNITS	189 / 535 = 0.4	189 / 535 = 0.4	189 / 535 = 0.4	189 / 535 = 0.4
EFFICIENCY: 540 UNITS	189 / 540 = 0.4	189 / 540 = 0.4	189 / 540 = 0.4	189 / 540 = 0.4
EFFICIENCY: 545 UNITS	189 / 545 = 0.4	189 / 545 = 0.4	189 / 545 = 0.4	189 / 545 = 0.4
EFFICIENCY: 550 UNITS	189 / 550 = 0.4	189 / 550 = 0.4	189 / 550 = 0.4	189 / 550 = 0.4
EFFICIENCY: 555 UNITS	189 / 555 = 0.4	189 / 555 = 0.4	189 / 555 = 0.4	189 / 555 = 0.4
EFFICIENCY: 560 UNITS	189 / 560 = 0.4	189 / 560 = 0.4	189 / 560 = 0.4	189 / 560 = 0.4
EFFICIENCY: 565 UNITS	189 / 565 = 0.4	189 / 565 = 0.4	189 / 565 = 0.4	189 / 565 = 0.4
EFFICIENCY: 570 UNITS	189 / 570 = 0.4	189 / 570 = 0.4	189 / 570 = 0.4	189 / 570 = 0.4
EFFICIENCY: 575 UNITS	189 / 575 = 0.4	189 / 575 = 0.4	189 / 575 = 0.4	189 / 575 = 0.4
EFFICIENCY: 580 UNITS	189 / 580 = 0.4	189 / 580 = 0.4	189 / 580 = 0.4	189 / 580 = 0.4
EFFICIENCY: 585 UNITS	189 / 585 = 0.4	189 / 585 = 0.4	189 / 585 = 0.4	189 / 585 = 0.4
EFFICIENCY: 590 UNITS	189 / 590 = 0.4	189 / 590 = 0.4	189 / 590 = 0.4	189 / 590 = 0.4
EFFICIENCY: 595 UNITS	189 / 595 = 0.4	189 / 595 = 0.4	189 / 595 = 0.4	189 / 595 = 0.4
EFFICIENCY: 600 UNITS	189 / 600 = 0.3	189 / 600 = 0.3	189 / 600 = 0.3	189 / 600 = 0.3
EFFICIENCY: 605 UNITS	189 / 605 = 0.3	189 / 605 = 0.3	189 / 605 = 0.3	189 / 605 = 0.3
EFFICIENCY: 610 UNITS	189 / 610 = 0.3	189 / 610 = 0.3	189 / 610 = 0.3	189 / 610 = 0.3
EFFICIENCY: 615 UNITS	189 / 615 = 0.3	189 / 615 = 0.3	189 / 615 = 0.3	189 / 615 = 0.3
EFFICIENCY: 620 UNITS	189 / 620 = 0.3	189 / 620 = 0.3	189 / 620 = 0.3	189 / 620 = 0.3
EFFICIENCY: 625 UNITS	189 / 625 = 0.3	189 / 625 = 0.3	189 / 625 = 0.3	189 / 625 = 0.3
EFFICIENCY: 630				

APPENDICIES

- I. FH Flow Test***
- II. Utility Plan***
- III. Water Model Reports***
- IV. Supplemental Water
Conservation
Measures Tables and
Exhibits***

Arizona Flow Testing LLC

Project Name: 7000 Shea Blvd.
Project Address: 7000 East Shea Blvd., Scottsdale, Arizona, 85254
Client Project No.: Not Provided
Arizona Flow Testing Project No.: 23045
Flow Test Permit No.: C71231
Date and time flow test conducted: January 26, 2023 at 7:00 AM
Data is current and reliable until: July 26, 2023
Conducted by: Floyd Vaughan – Arizona Flow Testing, LLC (480-250-8154)
Witnessed by: Chris Mendez – City of Scottsdale-Inspector (602-9028-9046)

Raw Test Data

Static Pressure: **90.0 PSI**
(Measured in pounds per square inch)

Residual Pressure: **67.0 PSI**
(Measured in pounds per square inch)

Pitot Pressure: **32.0 PSI**
(Measured in pounds per square inch)

Diffuser Orifice Diameter: One 4-inch Pollard Diffuser
(Measured in inches)

Coefficient of Diffuser: 0.9

Flowing GPM: **2,431 GPM**
(Measured in gallons per minute)

GPM @ 20 PSI: **4,434 GPM**

Data with 18 PSI Safety Factor

Static Pressure: **72.0 PSI**
(Measured in pounds per square inch)

Residual Pressure: **49.0 PSI**
(Measured in pounds per square inch)

Approx. distance between hydrants: 280 Feet

Main size: 8-Inch


Flowing GPM: **2,431 GPM**

GPM @ 20 PSI: **3,776 GPM**

Scottsdale requires a maximum Static Pressure of 72 PSI for AFES Design.

Flow Test Location

North ↑



INDEX OF DRAWINGS

SHEET INDEX

	SHEET NO.:	DESCRIPTION:	LATEST DATE:	REVISION:
●	1	C4.00	PRELIMINARY COVER SHEET & KEYMAP	04/30/2025
●	2	C4.10	PRELIMINARY UTILITY PLAN	04/30/2025
●	3	C4.11	PRELIMINARY UTILITY PLAN	04/30/2025

● FILLED CIRCLE INDICATES PLAN IS INCLUDED WITH THIS SUBMITTAL

QUANTITIES

WATER QUANTITIES

DESC.	QTY.	UNIT
6" DIP	86	LF
2" TYPE "K" COPPER LINE	74	LF
1" TYPE "K" COPPER LINE	39	LF
8"x6" TEE	2	EA
8"x6" BEND	1	EA
FIRE HYDRANT ASSEMBLY (INLCUDES GV)	2	EA
2" WATER METER	2	EA
1" WATER METER	1	EA
2" BACKFLOW PREVENTER	2	EA
1" BACKFLOW PREVENTER	1	EA

SEWER QUANTITIES

DESC.	QTY.	UNIT
6" PVC	177	LF
8" PVC	16	LF

(QUANTITIES SHOWN ARE FOR PERMITTING PURPOSES ONLY. CONTRACTOR IS RESPONSIBLE FOR DETERMINING QUANTITIES FOR BIDDING PURPOSES.)

LEGEND

PROPOSED UTILITY LEGEND:

-----X"W-----

-----X"S-----

PROPERTY LINE

EASEMENT LINE

WATER LINE

SEWER LINE

FIRE HYDRANT

FDC

WATER METER

GATE VALVE

T.S.V.B.&C.

BACK FLOW PREVENTER

CAP

BUILDING CONNECTION

SEWER CLEAN OUT

EXISTING LEGEND

-----S-----

-----W-----

-----G-----

-----TV-----

-----E-----

-----OHE-----

-----SD-----

SEWER LINE

SEWER MANHOLE

WATER LINE

WATER VALVE

FIRE HYDRANT

GAS LINE

UNDERGROUND TELEVISION LINE

UNDERGROUND ELECTRIC LINE

OVERHEAD ELECTRIC LINE

ELECTRIC TRANSFORMER

ELECTRIC JUNCTION BOX

ELECTRIC METER

STORM DRAIN LINE

STORM CATCH BASIN

STORM MANHOLE

REMOVAL LEGEND:

////////// PIPE REMOVAL

COSANTI COMMONS

PRELIMINARY COVER SHEET & KEYMAP

7000 E. SHEA BLVD SCOTTSDALE, AZ 85254

A PORTION OF THE SOUTHEAST QUARTER OF SECTION 22, TOWNSHIP 3 NORTH, RANGE 4 EAST OF THE GILA AND SALT RIVER MERIDIAN, MARICOPA COUNTY, ARIZONA.

NO-CONFLICT BLOCK

NO CONFLICT SIGNATURE BLOCK

UTILITY	UTILITY COMPANY	NAME OF COMPANY REPRESENTATIVE	TELEPHONE NUMBER	DATE SUBMITTED
ELECTRIC	APS	ADRIANNE BRENNAN	(602) 493-4401	01/24/2023
TELEPHONE	CENTURYLINK	KATHY HADRICH	(602) 630-5480	01/24/2023
NATURAL GAS	SW GAS	X	(XXX) XXX-XXXX	01/24/2023
CABLE/TV	COX	GLENN STEPHENS	(XXX) XXX-XXXX	01/24/2023
OTHER	X	X	(XXX) XXX-XXXX	XX/XX/XXXX

ENGINEER'S CERTIFICATION:
I, AUSTIN BROOKS, AS THE ENGINEER OF RECORD FOR THIS DEVELOPMENT, HEREBY CERTIFY THAT ALL UTILITY COMPANIES LISTED ABOVE HAVE BEEN PROVIDED FINAL IMPROVEMENT PLANS FOR REVIEW, AND THAT ALL CONFLICTS IDENTIFIED BY THE UTILITIES HAVE BEEN RESOLVED. IN ADDITION, "NO CONFLICT" FORMS HAVE BEEN OBTAINED FROM EACH UTILITY COMPANY AND ARE INCLUDED IN THIS SUBMITTAL.

SIGNATURE

DATE

NOTES FOR IMPROVEMENTS PLANS WHERE THERE IS AN EXISTING ACP OR PVC PIPE:
ANY WATER LINE PROJECT THAT INVOLVES CONNECTING TO AN EXISTING ACP OR PVC PIPE REQUIRES SPECIAL ATTENTION. PER DSPM SECTION 6-1.408:

FITTINGS INSTALLED INTO ASBESTOS CEMENT PIPE (ACP) OR PVC PIPE WITHIN 6- FEET OF ANOTHER FITTING OR JOINT WILL REQUIRE THAT SECTION OF PIPE TO BE REMOVED AND REPLACED WITH DUCTILE IRON PIPE (DIP).

EXISTING TEES, TAPPING SLEEVES AND RELATED APPURTENANCES THAT ARE NOT UTILIZED BY THE DEVELOPMENT SHALL BE REMOVED BY THE CONTRACTOR.

A MINIMUM 3-FOOT SECTION OF PIPE SHALL BE REMOVED, WITH NO LESS THAN 6 FEET REMAINING TO THE NEAREST JOINT. THE REMOVED PIPE SHALL BE REPLACED WITH DIP.

WHEN MORE THAN 3- FEET OF EXISTING ACP OR PVC WATER LINES ARE EXPOSED DURING CONSTRUCTION AND THE BEDDING IS DISTURBED, THE WATER LINE MUST BE REPLACED WITH DIP (MINIMUM CLASS 350) WITH MECHANICAL JOINTS OR FLANGED JOINTS TO 3- FEET PAST THE SIDES OF THE EXPOSED CROSSING TRENCH. REFER TO MAG STANDARD DETAIL NO. 403-3.

NO TAPPING SLEEVE AND VALVE SHALL BE USED ON ACP PIPE. VALVES WILL NEED TO BE CUT INTO ACP PIPE.

DISPOSAL OF MATERIALS CONTAINING ASBESTOS AND/OR LEAD SHALL BE IN CONFORMANCE WITH ALL REGULATIONS, LAWS AND ORDINANCES.

VICINITY MAP

PROJECT TEAM

OWNER

TRAMMELL CROW COMPANY
2575 E. CAMELBACK RD, SUITE 400
PHOENIX, ARIZONA 85016
PHONE: 602-809-0211
ATTN.: PAUL TUCHIN
EMAIL: PTUCHIN@TRAMMELLCROW.COM

CIVIL ENGINEER

SUSTAINABILITY ENGINEERING GROUP
5240 N. 16TH STREET, SUITE 105
PHOENIX, ARIZONA 85016
PHONE: 480-588-7226
ATTN.: ALI FAKIH
EMAIL: ALI@AZSEG.COM

SURVEY

SUPERIOR SURVEYING SERVICES, INC.
2122 W. LONE CACTUS DRIVE, SUITE 11
PHOENIX, ARIZONA 85027
PHONE: 623-869-0223 (EXT. 103)
ATTN.: JAMES WILLIAMSON
EMAIL: JAMES@SUPERIORSURVEYING.COM

ARCHITECT

ESG ARCHITECTURE & DESIGN
350 N. 5TH STREET, SUITE 400
MINNEAPOLIS, MINNESOTA 55401
PHONE: 612-339-5508
ATTN.: LAURA EDER
EMAIL: LAURA.EDER@ESGARCH.COM

LANDSCAPE

COLLECTIV LANDSCAPE ARCHITECTS
1426 N. 2ND STREET, SUITE 200
PHOENIX, ARIZONA 85004
PHONE: 602.358.7711 EXT. 106
ATTN: MICHAEL CHAPMAN
EMAIL: MIKEC@COLLECTIVLA.COM

PROJECT INFO

PROJECT LOCATION:

SITE ADDRESS: 7000 E. SHEA BLVD SCOTTSDALE, AZ 85254

PROJECT DESCRIPTION:

THIS PROJECT IS FOR A MIXED USE NEIGHBORHOOD BUILDING, WITH TWO COURTYARD TERRACES.

SITE DATA:

ASSESSOR PARCEL NUMBER:

175-42-140

ZONING:

PUD-PSD

GROSS AREA:

375,468.94 SF (8.62 AC)

NET AREA:

315,981.40 SF (7.25 AC)

DISTURBED AREA:

189,956.46 SF (4.36 AC)

BASIS OF BEARING:

MONUMENT LINE OF SCOTTSDALE ROAD, ALSO BEING THE EAST LINE OF THE SOUTHEAST QUARTER OF SECTION 22, USING A BEARING OF NORTH 00 DEGREES 13 MINUTES 09 SECONDS EAST PER THE RECORD OF SURVEY "GEODETIC DENSIFICATION AND CADASTRAL SURVEY", IN BOOK 763 OF MAPS, PAGE 38, RECORDS OF MARICOPA COUNTY, ARIZONA.

BENCHMARK:

THE BENCHMARK USED FOR THIS SURVEY IS THE MARICOPA COUNTY DEPARTMENT OF TRANSPORTATION UNIQUE POINT ID 5842, BEING A 3" CITY OF SCOTTSDALE BRASS CAP IN HANDHOLE, LOCATED AT THE INTERSECTION OF SCOTTSDALE ROAD & CHOLLA STREET, HAVING AN ELEVATION OF 1369.407 FEET, NAVD88.

LEGAL PARCEL DESCRIPTION:

LOT 1 OF 7000 EAST SHEA BOULEVARD, ACCORDING TO THE PLAT OF RECORD IN THE OFFICE OF THE COUNTY RECORDER OF MARICOPA COUNTY, ARIZONA, IN BOOK 1701 OF MAPS, PAGE 37.

APPENDIX II

NOT FOR CONSTRUCTION

SUSTAINABILITY ENGINEERING GROUP

SEG

5240 N. 16TH STREET SUITE 105 PHOENIX, ARIZONA 85016
WWW.AZSEG.COM TEL. 480.588.7226 FAX 480.259.3534

PROJECT COSANTI COMMONS

LOCATION 7000 E. SHEA BLVD SCOTTSDALE, AZ 85254

DRAWN

DESIGNED

CHECKED

FINAL QC

PROJ. MGR.

LR

DJ

SC

AB

AB

12/27/2024

12/27/2024

01/15/2025

04/30/2025

04/30/2025

DATE: 04/30/2025

ISSUED FOR: DRB

REVISION NO.:

DATE:

JOB NO.: 230113

SHEET TITLE: PRELIMINARY COVER SHEET & KEYMAP

PAGE NO.:

SHEET NO.:



1 OF 3

C4.00

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.

CASE FILE NO'S: 973-PA-2022, 672N-2023, 2 GP-2023

MATCHLINE - REFER TO SHEET C4.10



PRELIMINARY WATER NOTES

- 1 CONNECTION TO EXISTING WATER LINE.
- 2 SAWCUT, REMOVE AND REPLACE EXISTING PAVEMENT.
- 3 PROPOSED TEE, SIZE PER PLAN.
- 4 PROPOSED FIRE HYDRANT ASSEMBLY.
- 5 PROPOSED GATE VALVE WITH VALVE BOX AND COVER.
- 6 6" DUCTILE IRON PIPE. LENGTH PER PLAN.
- 7 PROPOSED FITTING, SIZE & ANGLE PER PLAN.
- 12 FIRE CONNECTION TO BUILDING.

PRELIMINARY SEWER NOTES


- 4 SEWER CONNECTION TO BUILDING.
- 5 CONNECTION TO EXISTING STUB.
- 6 REMOVE & REPLACE 8" PVC SEWER LINE. LENGTH PER PLAN.

LEGEND

REFER TO SHEET C4.00

NOTE

EASEMENTS LABELED TO BE ABANDONED WILL BE ABANDONED UPON COMPLETION OF DEMOLITION.



APPENDIX II

0' 20' 40' 60'

SCALE: 1" = 20'

NOT FOR
CONSTRUCTION

SUSTAINABILITY
ENGINEERING
GROUP



SEG



PROJECT
COSANTI COMMONS

LOCATION
7000 E. SHEA BLVD
SCOTTSDALE, AZ 85254

DRAWN	LR	12/27/2024
DESIGNED	DJ	12/27/2024
CHECKED	SC	01/15/2025
FINAL QC	AB	04/30/2025
PROJ. MGR.	AB	04/30/2025

DATE: 04/30/2025

ISSUED FOR: DRB

REVISION NO.	DATE
1	
2	
3	
4	

JOB NO.: 230113


SHEET TITLE:

**PRELIMINARY UTILITY
PLAN**

PAGE NO.: 3 OF 3

SHEET NO.: **C4.11**

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.
CASE FILE NO'S: 973-PA-2022, 672N-2023, 2 GP-2023



APPENDIX III

Average Day Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,523.05	72	167.06	72
EX-FH-2	1,355.47	0	1,523.04	72	167.57	72
EX-FH-3	1,355.14	0	1,523.01	73	167.87	73
FH-1	1,355.00	0	1,523.05	73	168.05	73
FH-2	1,353.27	0	1,523.01	73	169.74	73
J-1	1,356.11	0	1,523.05	72	166.94	72
J-2	1,356.27	0	1,523.05	72	166.78	72
J-3	1,354.70	0	1,523.04	73	168.34	73
J-4	1,352.21	0	1,523.02	74	170.81	74
J-5	1,354.37	0	1,523.01	73	168.64	73
J-6	1,353.43	26	1,523.01	73	169.58	73
J-7	1,355.38	0	1,523.01	73	167.63	73
J-8	1,360.34	88	1,523.00	70	162.66	70
J-9	1,355.10	26	1,523.03	73	167.93	73
J-10	1,354.78	0	1,523.05	73	168.27	73

APPENDIX III

Average Day Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.000	0.21
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.000	0.21
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.000	0.21
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.000	0.21
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.000	0.21
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.000	0.21
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.000	0.21
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.16
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.05
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.05
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.000	0.56
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.000	0.52
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.000	0.68
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.000	0.68
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.10
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.10

APPENDIX III

Average Day Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,523.06	139	166.06	PMP-1

APPENDIX III

Average Day Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	139	1,357.00

APPENDIX III

Maximum Day Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,522.34	72	166.35	72
EX-FH-2	1,355.47	0	1,522.31	72	166.84	72
EX-FH-3	1,355.14	0	1,522.21	72	167.07	72
FH-1	1,355.00	0	1,522.36	72	167.36	72
FH-2	1,353.27	0	1,522.20	73	168.93	73
J-1	1,356.11	0	1,522.35	72	166.24	72
J-2	1,356.27	0	1,522.34	72	166.07	72
J-3	1,354.70	0	1,522.29	73	167.59	73
J-4	1,352.21	0	1,522.24	74	170.03	74
J-5	1,354.37	0	1,522.21	73	167.84	73
J-6	1,353.43	51	1,522.20	73	168.77	73
J-7	1,355.38	0	1,522.21	72	166.83	72
J-8	1,360.34	176	1,522.17	70	161.83	70
J-9	1,355.10	51	1,522.26	72	167.16	72
J-10	1,354.78	0	1,522.33	72	167.55	72

APPENDIX III

Maximum Day Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.000	0.42
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.000	0.42
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.000	0.42
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.000	0.42
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.000	0.42
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.000	0.42
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.000	0.42
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.33
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.09
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.09
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.001	1.12
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.001	1.03
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.001	1.36
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.001	1.36
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.20
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.20

APPENDIX III

Maximum Day Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,522.36	278	165.36	PMP-1

APPENDIX III

Maximum Day Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	278	1,357.00

APPENDIX III

Peak Hour Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,520.55	71	164.56	71
EX-FH-2	1,355.47	0	1,520.48	71	165.01	71
EX-FH-3	1,355.14	0	1,520.19	71	165.05	71
FH-1	1,355.00	0	1,520.62	72	165.62	72
FH-2	1,353.27	0	1,520.17	72	166.90	72
J-1	1,356.11	0	1,520.58	71	164.47	71
J-2	1,356.27	0	1,520.56	71	164.29	71
J-3	1,354.70	0	1,520.42	72	165.72	72
J-4	1,352.21	0	1,520.28	73	168.07	73
J-5	1,354.37	0	1,520.19	72	165.82	72
J-6	1,353.43	89	1,520.17	72	166.74	72
J-7	1,355.38	0	1,520.19	71	164.81	71
J-8	1,360.34	308	1,520.09	69	159.75	69
J-9	1,355.10	89	1,520.34	71	165.24	71
J-10	1,354.78	0	1,520.53	72	165.75	72

APPENDIX III

Peak Hour Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.000	0.73
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.000	0.73
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.000	0.73
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.000	0.73
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.000	0.73
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.000	0.73
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.000	0.73
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.57
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.16
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.16
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.002	1.96
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.002	1.81
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.003	2.38
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.003	2.38
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.34
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.34

APPENDIX III

Peak Hour Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,520.62	486	163.62	PMP-1

APPENDIX III

Peak Hour Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	486	1,357.00

APPENDIX III

Fire Flow Demand

Fire Flow Results Table - Time: 0.00 hours

Label	Flow (Total Needed) (gpm)	Fire Flow (Available) (gpm)	Pressure (Maximum) (psi)	Flow (Total Available) (gpm)	Pressure (Calculate d Residual) (psi)	Pressure (Calculated Zone Lower Limit @ Total Flow Needed) (psi)	Junction w/ Minimum Pressure (Zone @ Total Flow Needed)	Pipe w/ Maximu m Velocity	Velocity of Maximu m Pipe (ft/s)
EX-FH-1	2,500	3,500	72	3,500	10	38	EX-FH-2	P-1	16.71
EX-FH-2	2,500	3,500	72	3,500	5	36	J-3	P-1	14.53
EX-FH-3	2,500	3,500	72	3,500	9	36	J-8	P-15	17.56
FH-1	2,500	3,500	72	3,500	21	41	J-8	P-17	2.68
FH-2	2,500	3,427	73	3,427	0	31	J-6	P-8	22.20
J-1	2,500	3,500	72	3,500	13	39	J-2	P-1	17.78
J-2	2,500	3,500	72	3,500	11	38	EX-FH-1	P-1	17.26
J-3	2,500	3,500	73	3,500	2	36	EX-FH-2	P-1	13.24
J-4	2,500	3,500	74	3,500	2	37	J-5	P-15	13.99
J-5	2,500	3,500	73	3,500	5	35	J-6	P-15	15.98
J-6	2,551	3,435	73	3,486	0	31	FH-2	P-8	22.25
J-7	2,500	3,500	72	3,500	11	35	J-8	P-15	18.32
J-8	2,676	3,500	70	3,676	4	38	J-7	P-12	23.46
J-9	2,551	3,500	72	3,551	15	38	J-8	P-15	19.74
J-10	2,500	3,500	72	3,500	19	40	J-8	P-15	21.54

APPENDIX III

Split FF
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,454.05	42	98.06	42
EX-FH-2	1,355.47	0	1,452.85	42	97.38	42
EX-FH-3	1,355.14	500	1,449.03	41	93.89	41
FH-1	1,355.00	1,000	1,455.25	43	100.25	43
FH-2	1,353.27	1,000	1,446.15	40	92.88	40
J-1	1,356.11	0	1,454.48	43	98.37	43
J-2	1,356.27	0	1,454.28	42	98.01	42
J-3	1,354.70	0	1,451.96	42	97.26	42
J-4	1,352.21	0	1,449.52	42	97.31	42
J-5	1,354.37	0	1,448.07	41	93.70	41
J-6	1,353.43	51	1,446.24	40	92.81	40
J-7	1,355.38	0	1,450.29	41	94.91	41
J-8	1,360.34	176	1,450.26	39	89.92	39
J-9	1,355.10	51	1,452.58	42	97.48	42
J-10	1,354.78	0	1,454.41	43	99.63	43

APPENDIX III

Split FF
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.005	3.32
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.005	3.32
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.005	3.32
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.005	3.32
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.005	3.32
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.005	3.32
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.005	3.32
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.017	6.71
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.016	6.38
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.005	3.39
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.017	6.58
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.001	1.12
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.023	7.70
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.024	8.03
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.024	8.03
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.001	1.97
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.001	1.97

APPENDIX III

Split FF
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,356.97	1,455.27	2,778	98.30	PMP-1

APPENDIX III

Split FF

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	2,778	1,357.00

APPENDIX III

Average Day Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,522.29	72	166.30	72
EX-FH-2	1,355.47	0	1,522.26	72	166.79	72
EX-FH-3	1,355.14	0	1,522.15	72	167.01	72
FH-1	1,355.00	0	1,522.32	72	167.32	72
FH-2	1,353.27	0	1,522.15	73	168.88	73
J-1	1,356.11	0	1,522.30	72	166.19	72
J-2	1,356.27	0	1,522.29	72	166.02	72
J-3	1,354.70	0	1,522.24	72	167.54	72
J-4	1,352.21	0	1,522.19	74	169.98	74
J-5	1,354.37	0	1,522.16	73	167.79	73
J-6	1,353.43	26	1,522.15	73	168.72	73
J-7	1,355.38	0	1,522.15	72	166.77	72
J-8	1,360.34	226	1,522.09	70	161.75	70
J-9	1,355.10	26	1,522.22	72	167.12	72
J-10	1,354.78	0	1,522.28	72	167.50	72

APPENDIX III

Average Day Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.000	0.43
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.000	0.43
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.000	0.43
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.000	0.43
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.000	0.43
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.000	0.43
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.000	0.43
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.17
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.26
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.26
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.001	1.44
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.001	1.19
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.001	1.36
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.001	1.36
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.20
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.20

APPENDIX III

Average Day Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,522.32	279	165.32	PMP-1

APPENDIX III

Average Day Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	279	1,357.00

APPENDIX III

Maximum Day Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,519.70	71	163.71	71
EX-FH-2	1,355.47	0	1,519.61	71	164.14	71
EX-FH-3	1,355.14	0	1,519.19	71	164.05	71
FH-1	1,355.00	0	1,519.80	71	164.80	71
FH-2	1,353.27	0	1,519.22	72	165.95	72
J-1	1,356.11	0	1,519.74	71	163.63	71
J-2	1,356.27	0	1,519.72	71	163.45	71
J-3	1,354.70	0	1,519.53	71	164.83	71
J-4	1,352.21	0	1,519.34	72	167.13	72
J-5	1,354.37	0	1,519.22	71	164.85	71
J-6	1,353.43	53	1,519.22	72	165.79	72
J-7	1,355.38	0	1,519.18	71	163.80	71
J-8	1,360.34	452	1,518.99	69	158.65	69
J-9	1,355.10	53	1,519.44	71	164.34	71
J-10	1,354.78	0	1,519.69	71	164.91	71

APPENDIX III

Maximum Day Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.000	0.85
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.000	0.85
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.000	0.85
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.000	0.85
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.000	0.85
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.000	0.85
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.000	0.85
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.34
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.51
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.51
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.004	2.89
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.003	2.37
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.003	2.71
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.003	2.71
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.40
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.40

APPENDIX III

Maximum Day Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,519.80	558	162.80	PMP-1

APPENDIX III

Maximum Day Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	558	1,357.00

APPENDIX III

Peak Hour Demand
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,513.19	68	157.20	68
EX-FH-2	1,355.47	0	1,512.92	68	157.45	68
EX-FH-3	1,355.14	0	1,511.76	68	156.62	68
FH-1	1,355.00	0	1,513.46	69	158.46	69
FH-2	1,353.27	0	1,511.82	69	158.55	69
J-1	1,356.11	0	1,513.29	68	157.18	68
J-2	1,356.27	0	1,513.25	68	156.98	68
J-3	1,354.70	0	1,512.72	68	158.02	68
J-4	1,352.21	0	1,512.17	69	159.96	69
J-5	1,354.37	0	1,511.84	68	157.47	68
J-6	1,353.43	93	1,511.82	69	158.39	69
J-7	1,355.38	0	1,511.73	68	156.35	68
J-8	1,360.34	791	1,511.18	65	150.84	65
J-9	1,355.10	93	1,512.46	68	157.36	68
J-10	1,354.78	0	1,513.15	69	158.37	69

APPENDIX III

Peak Hour Demand
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.001	1.49
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.001	1.49
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.001	1.49
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.001	1.49
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.001	1.49
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.001	1.49
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.001	1.49
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.000	0.59
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.000	0.00
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.000	0.90
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.000	0.90
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.010	5.05
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.007	4.15
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.009	4.74
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.009	4.74
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.000	0.69
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.000	0.69

APPENDIX III

Peak Hour Demand
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,357.00	1,513.47	977	156.47	PMP-1

APPENDIX III

Peak Hour Demand

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	977	1,357.00

APPENDIX III

Fire Flow Demand

Fire Flow Results Table - Time: 0.00 hours

Label	Flow (Total Needed) (gpm)	Fire Flow (Available) (gpm)	Pressure (Maximum) (psi)	Flow (Total Available) (gpm)	Pressure (Calculate d Residual) (psi)	Pressure (Calculated Zone Lower Limit @ Total Flow Needed) (psi)	Junction w/ Minimum Pressure (Zone @ Total Flow Needed)	Pipe w/ Maximum Velocity	Velocity of Maximu m Pipe (ft/s)
EX-FH-1	2,500	3,500	71	3,500	2	32	EX-FH-2	P-1	16.92
EX-FH-2	2,500	3,409	71	3,409	0	30	J-3	P-1	14.36
EX-FH-3	2,500	3,494	71	3,494	0	29	J-8	P-15	18.95
FH-1	2,500	3,500	71	3,500	13	35	J-8	P-12	2.89
FH-2	2,500	3,208	72	3,208	0	24	J-6	P-8	20.81
J-1	2,500	3,500	71	3,500	5	33	J-2	P-1	18.01
J-2	2,500	3,500	71	3,500	4	32	EX-FH-1	P-1	17.47
J-3	2,500	3,349	71	3,349	0	30	EX-FH-2	P-1	12.88
J-4	2,500	3,342	72	3,342	0	30	J-5	P-15	14.98
J-5	2,500	3,393	71	3,393	0	28	J-6	P-15	17.03
J-6	2,553	3,215	72	3,268	0	24	FH-2	P-8	20.86
J-7	2,500	3,484	71	3,484	2	28	J-8	P-15	19.60
J-8	2,952	3,350	69	3,802	0	31	J-7	P-12	24.27
J-9	2,553	3,500	71	3,553	6	31	J-8	P-15	21.17
J-10	2,500	3,500	71	3,500	11	34	J-8	P-15	23.11

APPENDIX III

Split FF
Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
EX-FH-1	1,355.99	0	1,440.52	37	84.53	37
EX-FH-2	1,355.47	0	1,439.07	36	83.60	36
EX-FH-3	1,355.14	500	1,434.08	34	78.94	34
FH-1	1,355.00	1,000	1,441.96	38	86.96	38
FH-2	1,353.27	1,000	1,431.36	34	78.09	34
J-1	1,356.11	0	1,441.03	37	84.92	37
J-2	1,356.27	0	1,440.79	37	84.52	37
J-3	1,354.70	0	1,437.99	36	83.29	36
J-4	1,352.21	0	1,435.04	36	82.83	36
J-5	1,354.37	0	1,433.29	34	78.92	34
J-6	1,353.43	53	1,431.45	34	78.02	34
J-7	1,355.38	0	1,435.22	35	79.84	35
J-8	1,360.34	452	1,435.02	32	74.68	32
J-9	1,355.10	53	1,438.34	36	83.24	36
J-10	1,354.78	0	1,440.83	37	86.05	37

APPENDIX III

Split FF
Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Material	Length (ft)	Start Node	Stop Node	Hazen- Williams C	Headloss Gradient (ft/ft)	Velocity (ft/s)
P-1	8.0	Asbestos Cement	163	FH-1	J-1	140.0	0.006	3.68
P-2	8.0	Asbestos Cement	41	J-1	J-2	140.0	0.006	3.68
P-3	8.0	Asbestos Cement	48	J-2	EX-FH-1	140.0	0.006	3.68
P-4	8.0	Asbestos Cement	253	EX-FH-1	EX-FH-2	140.0	0.006	3.68
P-5	8.0	Asbestos Cement	189	EX-FH-2	J-3	140.0	0.006	3.68
P-6	8.0	Asbestos Cement	514	J-3	J-4	140.0	0.006	3.68
P-7	8.0	Asbestos Cement	305	J-4	J-5	140.0	0.006	3.68
P-8	8.0	Asbestos Cement	105	J-5	J-6	140.0	0.018	6.72
P-9	8.0	Asbestos Cement	6	J-6	FH-2	140.0	0.016	6.38
P-10	8.0	Asbestos Cement	193	J-5	EX-FH-3	140.0	0.004	3.04
P-11	8.0	Asbestos Cement	75	EX-FH-3	J-7	140.0	0.015	6.24
P-12	8.0	Asbestos Cement	53	J-7	J-8	140.0	0.004	2.89
P-13	8.0	Asbestos Cement	101	J-7	J-9	140.0	0.031	9.12
P-14	8.0	Asbestos Cement	75	J-9	J-10	140.0	0.033	9.46
P-15	8.0	Asbestos Cement	34	J-10	FH-1	140.0	0.033	9.46
P-16	24.0	Asbestos Cement	61	R-1	PMP-1	140.0	0.001	2.17
P-17	24.0	Asbestos Cement	53	PMP-1	FH-1	140.0	0.001	2.17

APPENDIX III

Split FF
Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,356.00	On	1,356.96	1,441.99	3,058	85.03	PMP-1

APPENDIX III

Split FF

Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,357.00	3,058	1,357.00


APPENDIX III

Pump Definition Detailed Report: PMP-1

Element Details			
ID	77	Notes	
Label	PMP-1		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	113.19 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	3,365 gpm
Shutoff Head	166.32 ft	Maximum Operating Head	69.30 ft
Design Flow	2,431 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft²	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True

APPENDIX III

Pump Definition Detailed Report: PMP-1



APPENDIX III

INSTRUCTIONS

IDENTIFY WATER CONSERVATION MEASURES ABOVE THOSE REQUIRED BY CITY CODE THAT THE DEVELOPMENT(S) PROPOSE TO IMPLEMENT. ENTER AN "X" FOR EACH PROPOSED MEASURE.

TABLE 2: APPROVED SUPPLEMENTAL WATER CONSERVATION MEASURES		
7000 Block Shea Boulevard - 973-PA-2022		
PROPOSED FOR THIS DEVELOPMENT (ENTER "X")	MEASURE	DESCRIPTION
X	1. Submetering	Multi-family and mixed-use developments SUBMETER UNITS for leak detection and for occupants ability to manage their own water use
X	2. No outdoor water features	Decorative water features outdoors can be a source of water use that is not functional
	3. Indoor water features submetered	Water features have proven to be a source of leaks. Submetering that is capable of alerts to the building monitoring system greatly reduce water waste
X	4. Limitation on functional turf grass	Functional grass turf are areas used for congregation of large number of people and should be limited to up to 10% of the landscapable area
	5. Limitations on artificial turf	Artificial turf is a large source of heat especially during summer months.
	6. Landscaped Rainwater harvesting	Earthworks, such as berms and basins, are encouraged to promote passive rainwater harvesting for planned plants and trees
X	7. Cooling tower controllers with monitoring technology	Arizona high evapotranspiration rates, cooling towers use significantly more water here than in other states. Monitory systems can optimize this water use.
	8. Pools and splashpads submeters with monitoring technology	Pools and splashpad can be a source of leaks. Submetering that is capable of alerts to the building monitoring system greatly reduce water waste. Timers on Splash pads
NOTES: Greywater systems and large areas of artificial turf are not recommended by water conservation. This list represents water conservation measures that the conservation office has approved and has shown to provide proven water savings.		
TABLE INPUT VALUES LAST UPDATED:		5/19/2023

INSTRUCTIONS

INPUT DEVELOPMENT NAME, CASE NUMBER, AND QUANTITY VALUES TO DETERMINE TOTAL AVERAGE DAILY WATER USE PER THE 2018 DESIGN STANDARDS AND POLICY MANUAL (DS7PM) CHAPTER 6 USING GALLONS PER DAY (GPD) VALUES FROM FIGURE 6-1.2

TABLE 1: QUANTITY INPUT TABLE FOR THE DEVELOPMENT**7000 Block Shea Boulevard - 973-PA-2022**

WATER USE DEVELOPMENT TYPE/CATEGORY	AVERAGE UNIT WATER USE PER DS&PM CH. 6 (GPD/UNIT)	INPUT APPLICABLE QUANTITY FOR DEVELOPMENT IN THIS COLUMN	NUMERICAL UNIT	TOTAL AVERAGE WATER USE (GPD)	NOTES
Category: Residential/ Commerical Residential/ Hotel					
< 2 DU/ac	485.6		DU	-	Community pool demands not included here. Refer to separate category.
2 – 2.9 DU/ac	470.4		DU	-	
3 – 7.9 DU/ac	248.2		DU	-	
8 – 11.9 DU/ac	227.6		DU	-	
12 – 22 DU/ac	227.6		DU	-	
High Density Condominium (condo)	185.3	204	DU	37,801	
Resort Hotel	446.3		ROOM	-	Includes site amenities such as 1 "standard" restaurant w/ associated dedicated kitchen, laundry service, landscaping, fountains, and 1 medium capacity pool. Large event venues/kitchens or multiple/large pools and multiple restaurants are not included.
Category: Commerical/ Other					
Restaurant	1.3		FT2	-	
Commercial/Retail	0.80	203,659	FT2	162,927	
Commerical High Rise	0.60		FT2	-	per IBC highrise is at or over 75 feet to highest finished floor
Office	0.60		FT2	-	
Institutional	1,340		ACRE	-	
Industrial	1,027		ACRE	-	
Research and Development	1,284		ACRE	-	
Category: Special Use Areas					
Natural Area Open Space	-		ACRE	-	Zero water demand
Developed Open Space - Parks	1,786		ACRE	-	
Developed Open Space- Golf Course	4,285		ACRE	-	
Category: Evaporation from Swimming Pools/Spas, Cooling, Turf Area Irrigation, Other Outdoor Consumptive Uses					
Extra large pool (60k to 100k gallons)	274		EA	-	Annual mean ETo = 74.75 in as collected by AZ Met. Kc = 1.1. Average pool size of 400 sq. ft. loses 20,490 gallons per year, or 51.23 gallons per sq ft, not including backwashing or leaks, per AMWUA calculator.
Large pool (above 30k to 60k gallons)	154		EA	-	
Medium pool (15k to 30k gallons)	75	1	EA	75	
Small pool or spa (under 15k gallons)	51		EA	-	
Total Bermuda Turf Area	0.10		FT2	-	1 sq ft of non-overseeded turf at 60% efficiency with increased Kc is 35 gallons per sq ft per year, per AMWUA calculator.
Total Overseeded Turf Area	0.02		FT2	-	1 sq ft of overseeded turf at 60% efficiency with increased Kc is 9 gallons per sq ft per year, per AMWUA calculator.
Evaporative Cooling/ Cooling Towers	-		TOTAL COOLING TONNAGE	-	Based on 1.50 cycles of concentration and average annual daily utilization of 68%. Water use is linear with respect to total cooling capacity tonnage. Based on US Dept of Energy Efficiency and Renewable Energy data.
Category: Filter Backwash Flows & Make-up Water from Pools & Spas (rapid sand filters)					
Extra large pool (60k to 100k gallons)	229	-	EA	-	Based on once per 7 day backwash @ 50,100, and 150gpm, respectively for each size pool category for 8 minute duration. Quantity values used from pool input values above.
Large pool (above 30k to 60k gallons)	171	-	EA	-	
Medium pool (15k to 30k gallons)	114	1	EA	114	
Small pool or spa (under 15k gallons)	57	-	EA	-	

A. TOTAL AVERAGE DAILY WATER USE FOR THIS DEVELOPMENT**200,918 GPD**

NOTES:
 GPD=GALLONS PER DAY, DU=DWELLING UNITS, FT2=SQUARE FEET, AC=ACRE, EA=EACH UNIT, ETo=EVAPOTRANSPIRATION, Kc=CROP COEFFICIENT, AZMET=ARIZONA METEOROLOGICAL NETWORK, AMWUA=ARIZONA MUNICIPAL WATER USERS ASSOCIATION
 NONE OF THE VALUES OR CALCULATIONS HEREIN ARE INTENDED TO BE USED FOR INFRASTRUCTURE DESIGN, PEAK FLOW DETERMINATION, OR SYSTEM CAPACITY ANALYSIS. FOR THESE PURPOSES REFER TO CH.6 & 7 OF THE CITY'S DESIGN STANDARDS AND POLICY MANUAL FOR THE RESPECTIVE DESIGN VALUES AND PEAKING FACTORS.

TABLE INPUT VALUES LAST UPDATED:

5/19/2023

Water Demand Exhibit Summary

7000 Block Shea Boulevard - 973-PA-2022

1. Total Estimated Water Use per Day on a Sustainable Basis (gallons per day, gpd)

200,918

gpd

2. Net Water (NW) / Consumptive Use (gallons per day, gpd)

51,114

gpd

3. Proposed Water Conservation Measures Above Those Required By City Code

X	1. Submetering	Multi-family and mixed-use developments SUBMETER UNITS for leak detection and for occupants ability to manage their own water use
X	2. No outdoor water features	Decorative water features outdoors can be a source of water use that is not functional
	3. Indoor water features submetered	NOT PROPOSED
X	4. Limitation on functional turf grass	Functional grass turf are areas used for congregation of large number of people and should be limited to up to 10% of the landscapable area
	5. Limitations on artificial turf	NOT PROPOSED
	6. Landscaped Rainwater harvesting	NOT PROPOSED
X	7. Cooling tower controllers with monitoring technology	Arizona high evapotranspiration rates, cooling towers use significantly more water here than in other states. Monitory systems can optimize this water use.
	8. Pools and splashpads submeters with monitoring technology	NOT PROPOSED

4. Annual Economic Value of the Development on a per Gallon of Use Basis (Applies to Commercial or Mixed Use, To be Completed by City)

1. Major City Revenues

\$/1,000 gallons

2. Total Annual Output Impact

\$/1,000 gallons

TABLE INPUT VALUES LAST UPDATED:

5/19/2023

TABLE 4: WATER USE SUMMARY

7000 Block Shea Boulevard - 973-PA-2022

WATER USE SUMMARY FOR THE DEVELOPMENT

USE CATEGORY	AMOUNT	UNITS	% OF TOTAL USE	CALCULATION NOTES
A. TOTAL DAILY AVERAGE WATER USE	200,918	GPD	100.0%	A=B+C, C=D+E, F=B+D
B. OUTDOOR CONSUMPTIVE USE	26,561	GPD	13.2%	
C. TOTAL INDOOR USE	174,357	GPD	86.8%	
D. INDOOR CONSUMPTIVE USE	24,552	GPD	12.2%	
E. WASTEWATER TO SEWER	149,804	GPD	74.6%	
F. TOTAL CONSUMPTIVE USE (NET USE)	51,114	GPD	25.4%	

NOTES:

GPD=GALLONS PER DAY

ALL VALUES ARE FOR AVERAGE WATER USE ANALYSIS ONLY. THIS CALCULATION IS NOT INTENDED TO BE USED FOR INFRASTRUCTURE DESIGN, PEAK FLOW DETERMINATION, OR SYSTEM CAPACITY ANALYSIS. FOR THESE PURPOSES REFER TO CH.6 & 7 OF THE CITY'S DESIGN STANDARDS AND POLICY MANUAL FOR THE RESPECTIVE DESIGN VALUES, PEAKING FACTORS, AND DESIGN REQUIREMENTS.

TOTAL AVERAGE WATER USE (GALLONS PER DAY, GPD)




TABLE INPUT VALUES LAST UPDATED:

5/19/2023

TABLE 5: DETAILED WATER USE BREAKDOWN FOR THE DEVELOPMENT

7000 Block Shea Boulevard - 973-PA-2022

TO RIGHT: WATER USE ALLOCATION --->	A. TOTAL AVERAGE WATER USE (GPD)	B. AVERAGE OUTDOOR CONSUMPTIVE WATER USE ⁽¹⁾			C. AVERAGE INDOOR TOTAL WATER USE ⁽¹⁾			D. AVERAGE INDOOR CONSUMPTIVE WATER USE ⁽²⁾			E. AVERAGE WASTEWATER FLOWS TO SEWER ⁽³⁾			
BELOW: WATER USE DEVELOPMENT TYPE/CATEGORY		UNIT OUTDOOR CONSUMPTIVE WATER USE (GPD/UNIT)	OUTDOOR CONSUMPTIVE USE (GPD)	OUTDOOR CONSUMPTIVE USE (% OF TOTAL USE)	UNIT TOTAL INDOOR WATER USE (GPD/UNIT)	INDOOR TOTAL USE (GPD)	INDOOR TOTAL USE (% OF TOTAL USE)	UNIT CONSUMPTIVE INDOOR WATER USE (GPD/UNIT)	INDOOR CONSUMPTIVE USE (GPD)	INDOOR CONSUMPTIVE USE (% OF TOTAL USE)	WASTEWATER FLOW (GPD/UNIT)	WASTEWATER FLOW (GPD)	WASTEWATER (% OF TOTAL USE)	
Category: Residential/ Commerical Residential/ Hotel														
< 2 DU/ac	-	276.7	-	0.0%	208.9	-	0.0%	20.9	-	0.0%	188	-	0.0%	
2 – 2.9 DU/ac	-	276.7	-	0.0%	193.7	-	0.0%	19.4	-	0.0%	174	-	0.0%	
3 – 7.9 DU/ac	-	72.3	-	0.0%	175.9	-	0.0%	17.6	-	0.0%	158	-	0.0%	
8 – 11.9 DU/ac	-	72.3	-	0.0%	155.3	-	0.0%	15.5	-	0.0%	140	-	0.0%	
12 – 22 DU/ac	-	72.3	-	0.0%	155.3	-	0.0%	15.5	-	0.0%	140	-	0.0%	
High Density Condominium (condo)	37,801	30.0	6,120	3.0%	155.3	31,681.2	15.8%	15.5	3,168.1	1.6%	140	28,513	14.2%	
Resort Hotel	-	44.6	-	0.0%	401.7	-	0.0%	32.1	-	0.0%	370	-	0.0%	
Category: Commerical/ Other														
Restaurant	-	0.10	-	0.0%	1.20	-	0.0%	0.12	-	0.0%	1.08	-	0.0%	
Commercial/Retail	162,927	0.10	20,366	10.1%	0.70	142,561.3	71.0%	0.11	21,384.2	10.6%	0.60	121,177	60.3%	
Commerical High Rise	-	0.10	-	0.0%	0.50	-	0.0%	0.05	-	0.0%	0.45	-	0.0%	
Office	-	0.10	-	0.0%	0.50	-	0.0%	0.05	-	0.0%	0.45	-	0.0%	
Institutional	-	670	-	0.0%	670.0	-	0.0%	100.50	-	0.0%	569.50	-	0.0%	
Industrial	-	154	-	0.0%	873.0	-	0.0%	130.95	-	0.0%	742.05	-	0.0%	
Research and Development	-	192	-	0.0%	1,092.0	-	0.0%	163.80	-	0.0%	928.20	-	0.0%	
Category: Special Use Areas														
Natural Area Open Space	-	-	-	0.0%							-	-	0.0%	
Developed Open Space - Parks	-	1,786	-	0.0%							-	-	0.0%	
Developed Open Space- Golf Course	-	4,285	-	0.0%							-	-	0.0%	
Category: Evaporation from Swimming Pools/Spas, Cooling, Turf Area Irrigation, Other Outdoor Consumptive Uses														
Extra large pool (60k to 100k gallons)	-	274	-	0.0%							-	-	0.0%	
Large pool (above 30k to 60k gallons)	-	154	-	0.0%							-	-	0.0%	
Medium pool (15k to 30k gallons)	75	75	75	0.0%							-	-	0.0%	
Small pool or spa (under 15k gallons)	-	51	-	0.0%							-	-	0.0%	
Total Bermuda Turf Area	-	0.10	-	0.0%							-	-	0.0%	
Total Overseeded Turf Area	-	0.02	-	0.0%							-	-	0.0%	
Evaporative Cooling/ Cooling Towers	-	-	-	0.0%							-	-	0.0%	
Category: Filter Backwash Flows & Make-up Water from Pools & Spas (rapid sand filters)														
Extra large pool (60k to 100k gallons)	-				228.6	-	0.0%				229	-	0.0%	
Large pool (above 30k to 60k gallons)	-				171.4	-	0.0%				171	-	0.0%	
Medium pool (15k to 30k gallons)	114				114.3	114.3	0.1%				114	114	0.1%	
Small pool or spa (under 15k gallons)	-				57.1	-	0.0%				57	-	0.0%	
TOTALS		200,918	26,561	13.2%	174,357			86.8%	24,552		12.2%	149,804		74.6%
F. TOTAL CONSUMPTIVE/NET WATER USE FOR THIS DEVELOPMENT (B. + D.)														
		51,114 GPD		25.4% OF TOTAL USE										

NOTES:
 (1) PER 2018 DS&PM CHAPTER 6, FIGURE 6-1.2
 (2) VARIES FROM 8% TO 15%, TYPICALLY 10%
 (3) WASTEWATER FLOWS TO SEWER ARE CALCULATED AS C. MINUS D.
 GPD=GALLONS PER DAY, DU=DWELLING UNIT, FT2=SQUARE FEET, AC=ACRE, EA=EACH UNIT
 NONE OF THE VALUES OR CALCULATIONS HEREIN ARE INTENDED TO BE USED FOR INFRASTRUCTURE DESIGN, PEAK FLOW DETERMINATION, OR SYSTEM CAPACITY ANALYSIS. FOR THESE PURPOSES REFER TO CH.6 & 7 OF THE CITY'S DESIGN STANDARDS AND POLICY MANUAL FOR THE RESPECTIVE DESIGN VALUES AND PEAKING FACTORS.

TABLE INPUT VALUES LAST UPDATED: 5/19/2023