

**FINAL WATER REPORT**


# SCOTTSDALE CITY CENTER

**7201 East Camelback Road  
Scottsdale, AZ 85251**

**Prepared For:**

**SMITHGROUP**

**455 North 3<sup>rd</sup> Street, Suite 250  
Phoenix, Arizona 85004  
602.265.2200 [www.smithgroup.com](http://www.smithgroup.com)**

<p><b>FINAL Basis of Design Report</b></p> <p><input type="checkbox"/> APPROVED</p> <p><input checked="" type="checkbox"/> APPROVED AS NOTED</p> <p><input type="checkbox"/> REVISE AND RESUBMIT</p> <p style="font-size: small;">Disclaimer: If approved, the approval is granted under the condition that the final construction documents submitted for city review will match the information herein. Any subsequent changes in the water or sewer design that materially impact design criteria or standards will require re-analysis, re-submittal, and approval of a revised basis of design report prior to the plan review submission. This approval is not a guarantee of construction document acceptance. For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.</p> <p><b>BY</b> Levi Dillon                      <b>DATE</b> 8/19/2025</p>	 <p style="font-size: x-small;">9379 E San Salvador Dr. Scottsdale, AZ 85258</p>
--	---

**Prepared by:**



**Sustainability Engineering Group**

**5240 N. 16<sup>th</sup> Street, Suite 105  
Phoenix, AZ 85016  
480.588.7226 [www.azSEG.com](http://www.azSEG.com)**

**Project Number: 221117**


- Submittal: July 06, 2023 (DRB)**
- Revised Submittal: September 15, 2023 (DRB)**
- Revised Submittal: November 1, 2024 (DRB)**
- 2<sup>nd</sup> Submittal: November 12, 2024 (DRB)**
- 3<sup>rd</sup> Submittal: February 21, 2025 (DRB)**
- 4<sup>th</sup> Submittal: July 23, 2025 (DRB)**

Address applicable comments below and herein concurrent to or within the improvement plan submittal:

- 1) **Stipulation:** As shown in the utility plan remove (or abandon if approved) applicable mains and install new sections of 8-inch and 16-inch City standard DIP public water main with related, realignments, appurtenances, and interconnects as shown. Summary: Approximately 200ft of 8-inch DIP on Shoeman Lane. Approximately 50ft of 16-inch DIP along Camelback Rd. Approximately 25ft of 8-inch DIP on Brown Ave. Approximately 100ft of 8-inch DIP along Camelback Rd.
- 2) Brown Ave: Services cannot be directly connected to a 16-inch trans. main. Was also a zoning case comment and a round 2 BOD comment. Install 8-inch public main stub to connect services as shown. DS&PM 6-1.416, K. No service or fire line connections will be made directly to water lines 14 inches or larger in diameter.
- 3) Hydrant line connection to 20-inch transmission main on Shoeman Lane: This connection is not allowed unless there is no other options and/or there are extraordinary circumstances (none described in report). DS&PM 6-1.416, K. No service or fire line connections will be made directly to water lines 14 inches or larger in diameter.
- 4) Connection to Scottsdale Rd main: A size on size tapping sleeve is not allowed. Provide a cut in tee with valves on all legs (or at least 2 of the 3 legs). DS&PM 6-1.408 & 6-1.409
- 5) Special Water Resources review items: confirm 16" transmission main material and submit detailed specifications, details, and any applicable calculations within the plan submittal for Water Resource review and approval. Submit all details with 16" and 20" transmission main tapping sleeve/saddle with the plan submittal for Water Resource review and approval.
- 6) Review and address applicable comments, questions, and suggestions within the BOD report utility plan.

**Case No.: 9-ZN-2020; 1-II-2020; 19-DR-2023**

**Plan Check No.: TBD**



## Table of Contents

1. INTRODUCTION.....	1
1.1. SUMMARY OF PROPOSED DEVELOPMENT:.....	1
1.2. LEGAL DESCRIPTIONS AND AREA:.....	1
2. DESIGN DOCUMENTATION .....	1
2.1. DESIGN COMPLIANCE:.....	1
3. EXISTING CONDITIONS.....	1
3.1. EXISTING ZONING & LAND USE: .....	1
3.2. EXISTING TOPOGRAPHY, VEGETATION AND LANDFORM FEATURES:.....	2
3.3. EXISTING UTILITIES: .....	2
3.4. FIRE HYDRANT FLOW TESTING: .....	2
4. PROPOSED CONDITIONS.....	3
4.1. PROPOSED WATER SYSTEM:.....	3
4.2. MAINTENANCE RESPONSIBILITIES:.....	3
5. WATER SYSTEM COMPUTATIONS.....	3
5.1. WATER FLOW DEMANDS:.....	3
5.2. VARIANCE FROM STATED DESIGN FLOWS: .....	4
5.3. WATER MODELING:.....	4
5.4. WATER MODEL SUMMARY:.....	5
6. SUMMARY.....	5
6.1. SUMMARY OF PROPOSED IMPROVEMENTS: .....	5
6.2. PROJECT SCHEDULE:.....	6
7. REFERENCES.....	6

**LIST OF FIGURES:**

- FIGURE 1 - Vicinity Map
- FIGURE 2 - Local Projects
- FIGURE 3 - Site Plan
- FIGURE 4 - City Water Q-S Map 17-45

**APPENDICIES:**

- APPENDIX I - Fire Hydrant Flow Tests
- APPENDIX II - Water Model Reports
- APPENDIX III - Preliminary Utility Plan
- APPENDIX IV - Utility Line Potholes
- APPENDIX V - International Fire Code 2021

## 1. INTRODUCTION

### 1.1. SUMMARY OF PROPOSED DEVELOPMENT:

City Center is a multi-story development located southeast of the Scottsdale Road/Camelback Road intersection and will replace an existing commercial/office building. This report is a refinement of the *Water Master Plan for Scottsdale Collective*, dated July 23, 2021. Refer to **FIGURE 1** for a Vicinity Map and **FIGURE 2** highlighting major developments along the Camelback corridor.

This report presents a water infrastructure analysis for the redevelopment of the seven commercial parcels comprising City Center. They will be replatted for high density residential and retail uses. The intent of this design report is to evaluate the local water infrastructure providing service to City Center compliant to City, County and State requirements.

### 1.2. LEGAL DESCRIPTIONS AND AREA:

The following parcels are all located within Section 23, Township 2 North, Range 4 East of the Gila and Salt River Base and Meridian, Maricopa County, Scottsdale, Arizona.

- 173-41-016B, 173-41-017A, 173-41-006A, 173-41-005, and 173-41-004.

The parcels total 131,786 square feet or 3.03 acres, more or less.

## 2. DESIGN DOCUMENTATION

### 2.1. DESIGN COMPLIANCE:

Preparation of this report has been done in accordance with the City of Scottsdale Design Standards & Policies Manual (DS&PM) 2018<sup>1</sup> and requirements of Maricopa County Environmental Services Department under jurisdiction of the State of Arizona. Design calculations for the proposed water infrastructure are all based on the DS+PM recommendations in Section 6-1.403.

## 3. EXISTING CONDITIONS

### 3.1. EXISTING ZONING & LAND USE:

This existing parcels are zoned D/DMU-3 PBD DO, Downtown Multiple Use – Type 3. The four northern parcels are presently developed for commercial office use. The three southern parcels are presently undeveloped and being utilized for parking and construction yards.

**3.2. EXISTING TOPOGRAPHY, VEGETATION AND LANDFORM FEATURES:**

This area of Scottsdale is relatively flat with minor grades sloping to the Indian Bend Wash approximately one mile to the east. All parcels have been previously developed with buildings and pavement covering most of the properties and minor site landscaping typical of the downtown vicinity.

**3.3. EXISTING UTILITIES:**

Public water lines abut all sides of the development with a 6" ACP looping through the property from Camelback Road to Brown Avenue.

- Camelback Road: 8" ACP, 12" ACP, 16" DIP and a fire hydrant.
- Brown Avenue: 16" DIP and two fire hydrants.
- Shoeman Lane: 6" ACP, 20" DIP and a fire hydrant.
- Scottsdale Road: 8" CIP and a fire hydrant.

Fire Hydrants and water meters exist around the site's periphery. The water meters to be removed will be inventoried for development fee credit. Refer to **FIGURE 4** for City Quarter Section Map (QS 17-45) and **APPENDIX IV** for the Utility Line Potholes).

**3.4. FIRE HYDRANT FLOW TESTING:**

Flow testing was performed on July 21, 2025, at 7:30 am. A flow test completed with the Scottsdale Collective Master Plan as performed on April 13, 2020, at 6:55 am is included for reference. Results of the tests, including corresponding supply curves, are shown in **APPENDIX I**. Table 1 summarizes the results of those tests.

**Table 1 - SUMMARY OF FIRE HYDRANT FLOW TESTING**

Test Date	Test Description	STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	FLOWING GPM	GPM @ 20 PSI	GPM @ 30 PSI
07/21/2025	Raw Data	104	93	2,578	7,727	7,216
07/21/2025	Data with 32 psi Safety Factor	72	61	2,578	5,965	5,315
4/13/2020	Raw Data	100	90	2,468	7,587	7,058
4/13/2020	Data with 28 psi Safety Factor	72	62	2,468	6,013	5,357

## 4. PROPOSED CONDITIONS

### 4.1. PROPOSED WATER SYSTEM:

Along Camelback Road: City Center will remove a 6" public water line crossing the site and abandon the easement. The 8" ACP end will be extended south towards the property line and looped east to serve a fire line, fire hydrant, domestic meter and landscape meter. A water easement is provided for the meters. The 8" line will then be looped back north and connect to the 16" water line. An existing fire hydrant located near the Arizona Canal will need to be reconnected to the new 8" line. A section of 16" DIP will need to be lowered to cross under the proposed sewer service.

Along Scottsdale Road: The existing fire hydrant will be relocated approximately 150 feet north and reconnected to the existing 8" CIP. A fire line and domestic service will be tapped off the CIP as well.

Along Brown Avenue: The existing 6" tap will be utilized to relocate the existing hydrant. A fire line, and domestic and landscape service will be tapped off the existing 16" DIP. A water easement is provided for the meters.

not allowed see utility plan.

Along Shoeman Lane: An existing fire hydrant will remain at the southeast corner of the property, but its connection to the existing 6" ACP will be removed and reconnected to the existing 20" DIP. New taps off the 6" ACP will provide domestic and fire service. The fire line will connect to a pump room. The existing 20" DIP will be cross connected to the 6" ACP with an 8" DIP to provide additional supply. The reach of the existing 6" ACP, located south of the site and connects to the existing 8" CIP along N Scottsdale Rd, will be upgraded to 8" DIP to provide additional capacity.

Meter sizes are per plan. All existing service lines to the site not used will be removed to the main per City requirements (see APPENDIX III for the Preliminary Utility Plan).

Ok, approximately 200ft. Ensures min 8-inch supply looping around entirety of development.

### 4.2. MAINTENANCE RESPONSIBILITIES:

All proposed water meters and fire hydrants will be installed in rights-of-ways or easements dedicated to the city. Backflow prevention will be provided on all metered services and along with the fire lines will be privately owned and maintained by the building owners.

## 5. WATER SYSTEM COMPUTATIONS

### 5.1. WATER FLOW DEMANDS:

The City design criteria and resulting maximum demands for the average, max day and peak hour flows are shown in Table 2 below.

**Table 2: COS Design Criteria - Average Day Demands**

Land Use	Unit Demand (gpm)	Unit	Max Day Factor	Peak Hour Factor
High Density Residential	0.27	per dwelling	2	3.5
Commercial/Retail	1.11E-03	per sq. ft.	2	3.5
Restaurant < 5,000 sq.ft.	1.81E-03	per sq. ft.	2	3.5

The following Table 3 shows the proposed water demands.

**Table 3: WATER DEMAND CALCULATIONS**

Building/Use	Units or Area (sq. ft.)	Unit Demand (gpm)	Avg. Day Demand (gpm)	Max Day Demand (gpm)	Peak Hour Demand (gpm)
High Density Residential	138	0.27	37.3	74.5	130.4
Restaurant 1	8,590	1.81E-03	15.5	31.1	77.7
Restaurant 2	7,431	1.81E-03	13.5	26.9	67.3
Restaurant 5	8,599	1.81E-03	15.6	31.1	77.8
Commercial/Retail 3	4,100	1.11E-03	4.6	9.1	15.9
Commercial/Retail 4	6,650	1.11E-03	7.4	14.8	25.8
<b>TOTAL DEMANDS:</b>			<b>93.8</b>	<b>187.5</b>	<b>395.0</b>

Fire flow demand: The gross floor area is approximately 375,000 sf and the building is Type IIIB. According to table B105.1 from Appendix B of the International Fire Code, the required fire flow for 375,000 sf. is 8,000 gpm (see **APPENDIX V**). The International Fire Code allows for a 75% fire flow reduction for sprinklered buildings. Based on the sprinklered design for the building, the required fire flow can be reduced to 2,000 gpm. However, per the City of Scottsdale DS&PM, the minimum required fire flow for high-rise structures is 2,500 gpm plus maximum day demand. The residential towers may require building pumps within the structure.

**5.2. VARIANCE FROM STATED DESIGN FLOWS:**

No variance from the stated design criteria in the DS+PM is requested.

**5.3. WATER MODELING:**

Bentley WaterCAD® Version 8i is the computer modeling tool that is used in this final design report. The general methodology will consist of modeling the network of water distribution pipes and inputting demands to evaluate compliance with the City’s pressure, head loss, and water demand requirements during daily demands and fire events. The connection to the water system is modeled as a reservoir and pump. The pump will simulate the pressure drop and the available flow from the existing water system as depicted by the respective fire flow tests. Modeling uses fire flow test data with a safety factor.

**5.4. WATER MODEL SUMMARY:**

A fire flow/hydrant analysis was completed during the max day scenario to verify the waterline network provides adequate fire prevention demand during max day conditions. Splitting the flow among the nearby hydrants, adjacent to the site provides 2,500 gpm. The minimum system pressure under the fire flow scenario was 55 psi which meets the minimum requirements.

The water model layout and reports are included in **APPENDIX II**. **Table 4** presents a summary of the modeling output.

**Table 4: WaterCAD® Analysis Results**

Demand Scenario	Water Demand (GPM)	Pressure (PSI)				Max. Velocity	Pipe ID
		Min.	Node	Max.	Node		
Average Day Demand	93.8	68	J-50	74	J-10	0.23	P-56
Maximum Day Demand	187.5	68	J-50	74	J-10	0.71	P-41
Peak Hour Demand	395.0	68	J-50	74	J-10	1.39	P-41
MD+FF - NEC	2687.5	56	J-50	62	J-10	6.58	P-48
MD+FF - SWC	2687.5	55	J-13	62	J-9	6.55	P-10

**6. SUMMARY**

**6.1. SUMMARY OF PROPOSED IMPROVEMENTS:**

**Table 5** presents the water demands from the accepted Scottsdale Collective Master Plan and indicates a significant reduction in the proposed site demands for the proposed City Center.

**Table 5: WATER DEMAND CALCULATIONS - Parcel A (City Center)**

	Units or Area (sq. ft.)	Unit Demand (gpm)	Avg. Day Demand (gpm)	Max Day Demand (gpm)	Peak Hour Demand (gpm)
High Density Residential	106	0.27	28.6	57.2	100.2
Resort Hotel	214	0.63	134.8	269.6	471.9
Restaurant	20,554	1.81E-03	37.2	74.4	186.0
Retail	20,554	1.11E-03	22.8	45.6	79.9
<b>TOTAL DEMANDS:</b>			<b>223.5</b>	<b>446.9</b>	<b>837.9</b>

This design report supports the development of City Center compliant to the requirements stated in Chapter 6 of the COS DS+PM. This final analysis indicates the existing water infrastructure is sufficient to provide domestic service and fire protection. All existing metered services, fire lines and pipes not

provided for reference only

needed for the master planned development will be inventoried and shown to be removed per requirements of the DS+PM on the final improvement plans.

## **6.2. PROJECT SCHEDULE:**


It is anticipated City Center will be developed as a single phase in 2026/2027.

## **7. REFERENCES**

1. COS QS Water Plan number 17-45
2. City of Scottsdale Design Standards & Policies Manual, 2018 (Chapter 6 – Water)


## *FIGURES*

1. Vicinity Map
2. Local Projects
3. Site Plan
4. City Water Q-S Map 17-45




**FIGURE 1 –  
Vicinity Map**

5240 N. 16th Street, Suite 105  
Phoenix, AZ 85016



# CITY CENTER

PLAZA LEVEL 1 & RETAIL  
EL : 0'-0"




TOTAL RETAIL AREA: ~37,320 SF  
(PREVIOUS DESIGN: 31,698 SF)

FIGURE 3 -  
SITE PLAN

# CITY CENTER


## MODIFIED CONDO CONCEPT – 10 FLOORS RESIDENTIAL FLOOR DIAGRAMS – TALLER CEILINGS

GROSS FLOOR AREA	375,133 SF GROSS
RESIDENTIAL AREA	323,762 SF NET SELLABLE
<i>EFFICIENCY</i>	<i>86%</i>



**FIGURE 3 -  
SITE PLAN**

COMPLETE RESIDENTIAL BUILDING (10 LEVELS)	
TOTAL 2-BR UNITS	98 UNITS
TOTAL 3-BR UNITS	51 UNITS
<i>TOTAL UNITS</i>	<i>149 TOTAL UNITS</i>




**GENERAL NOTES:**  
 \* THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE GIS DEPARTMENT AT (480) 312-7792.  
 \* THE SECTION LINE BEARING AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTENED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS "CALCULATED" ON THE MAP.

**LEGEND:**


- Air Release Valve
- Non-potable Air Release Valve
- Blowoff
- Cap
- Cathodic Protection
- Fill Drain
- Fire Hydrant
- Non-GPS Point
- Pressure Reducing Valve
- Pump
- Reducer
- Sample Station
- Water Manhole
- Non-Potable Manhole
- Well
- Valve
- Non-potable Valve
- Vault
- Water Main
- Non-Potable Main
- Fire / Private Main
- Non-Scottsdale Main

**VICINITY MAP**



**NORTH**

SCALE: 1" = 100'



The map scale of 1" = 100' is based on a full size print of 30" x 36"

**WATER**  
 QUARTER SECTION MAP

**17-45**

SW 1/4 SEC. 23 T2N R4E

**FIGURE 4**

**SCOTTSDALE GEOGRAPHIC INFORMATION SYSTEMS**  
 3629 North Drinkwater Boulevard  
 Scottsdale, Arizona 85251

**NOTICE**  
 THIS DOCUMENT IS PROVIDED FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON FOR FIELD VERIFICATION.  
 THE CITY OF SCOTTSDALE  
 27-AUG-17

## *APPENDICIES*

- I. Fire Hydrant Flow Tests*
- II. Water Model Reports*
- III. Utility Plan*
- IV. Utility Line Modifications*
- V. International Fire Code*

# Arizona Flow Testing LLC

## HYDRANT FLOW TEST REPORT

Project Name: Scottsdale Collective-City Center  
Project Address: Brown Ave. & Shoeman Lane (NWC), Scottsdale, Arizona, 85251  
Client Project No.: Not Provided  
Arizona Flow Testing Project No.: 25633  
Flow Test Permit No.: C79609  
Date and time flow test conducted: July 21, 2025 at 7:30 AM  
Data is current and reliable until: January 21, 2026  
Conducted by: Floyd Vaughan – Arizona Flow Testing, LLC (480-250-8154)  
Witnessed by: Chris Mendez – City of Scottsdale-Inspector (602-9028-9046)

### Raw Test Data

Static Pressure: **104.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **93.0 PSI**  
(Measured in pounds per square inch)

Pitot Pressure: **36.0 PSI**  
(Measured in pounds per square inch)

Diffuser Orifice Diameter: One 4-inch Pollard Diffuser  
(Measured in inches)

Coefficient of Diffuser: 0.9

Flowing GPM: **2,578 GPM**  
(Measured in gallons per minute)

GPM @ 20 PSI: **7,727 GPM**

### Data with 32 PSI Safety Factor

Static Pressure: **72.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **61.0 PSI**  
(Measured in pounds per square inch)

Approx. distance between hydrants: 250 Feet

Main size: Not Provided


Flowing GPM: **2,578 GPM**

GPM @ 20 PSI: **5,965 GPM**


Scottsdale requires a maximum Static Pressure of 72 PSI for AFES Design.

### Flow Test Location

North ↑




## 2025-07-21 FH Flow Test - Raw Data



## APPENDIX I

## 2025-07-21 FH Flow Test - Data with 32 psi Safety Factor



# Arizona Flow Testing LLC

## HYDRANT FLOW TEST REPORT

Project Name: Scottsdale Collective-City Center  
Project Address: Brown Ave. & Shoeman Lane (NWC), Scottsdale, Arizona, 85251  
Client Project No.: Not Provided  
Arizona Flow Testing Project No.: 20137A  
Flow Test Permit No.: C61868  
Date and time flow test conducted: April 13, 2020 at 6:55 AM  
Data is current and reliable until: October 13, 2020  
Conducted by: Floyd Vaughan – Arizona Flow Testing, LLC (480-250-8154)  
Coordinated by: Ray Padilla – City of Scottsdale-Inspector (602-541-0586)

### Raw Test Data

Static Pressure: **100.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **90.0 PSI**  
(Measured in pounds per square inch)

Pitot Pressure: **33.0 PSI**  
(Measured in pounds per square inch)

Diffuser Orifice Diameter: One 4-inch Pollard Diffuser  
(Measured in inches)

Coefficient of Diffuser: 0.9

Flowing GPM: **2,468 GPM**  
(Measured in gallons per minute)

GPM @ 20 PSI: **7,587 GPM**

### Data with 28 PSI Safety Factor

Static Pressure: **72.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **62.0 PSI**  
(Measured in pounds per square inch)

Distance between hydrants: Approx.: 250 feet


Main size: Not Provided

Flowing GPM: **2,468 GPM**

GPM @ 20 PSI: **6,013 GPM**

### Flow Test Location

North ↑



## 2020-04-13 FH Flow Test – Raw Data

ANVIL FIRE
PLLC
| PACKAGED ENCLOSURES | PUMPS | APPS | BLOG | CONTACT



### Logarithmic Graph of Water Supply


Summary: This app provides a  $N^{1.85}$  logarithmic graph based on NFPA 291 recommendations. We also offer a blank PDF logarithmic flow test sheet.

#### Graph Points

- Static Pressure
- Residual Pressure
- Residual Flow

#### Data Points

Flow  Pressure




© Anvil-Fire, PLLC - Copyright 2011-2023 || [INFO@ANVIL-FIRE.COM](mailto:INFO@ANVIL-FIRE.COM) || (406) 624-9408

## APPENDIX I

## 2020-04-13 FH Flow Test – Data with 28 psi Safety Factor

ANVIL FIRE PLLC
| PACKAGED ENCLOSURES | PUMPS | APPS | BLOG | CONTACT



### Logarithmic Graph of Water Supply


Summary: This app provides a N<sup>1.85</sup> logarithmic graph based on NFPA 291 recommendations. We also offer a blank PDF logarithmic flow test sheet.

**Graph Points**

72	Static Pressure
62	Residual Pressure
2468	Residual Flow

**Data Points**


Flow	Pressure
5356.730	30



© Anvil-Fire, PLLC - Copyright 2011-2023 || [INFO@ANVIL-FIRE.COM](mailto:INFO@ANVIL-FIRE.COM) || (406) 624-9408

## APPENDIX I

# 2025-07-15 City Center Water Model.wtg



## 2025-07-15 City Center Water Model.wtg

### Active Scenario: Base

### Average Day Demand

#### Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
J-3	1,270.30	0	1,436.74	72	166.44	72
J-6	1,269.60	37	1,436.74	72	167.14	72
J-7	1,269.00	0	1,436.74	73	167.74	73
J-8	1,269.00	0	1,436.74	73	167.74	73
J-9	1,267.00	28	1,436.74	73	169.74	73
J-10	1,265.40	0	1,436.74	74	171.34	74
J-11	1,266.00	0	1,436.74	74	170.74	74
J-12	1,272.40	14	1,436.74	71	164.34	71
J-13	1,276.00	0	1,436.74	70	160.74	70
J-16	1,275.60	0	1,436.74	70	161.14	70
J-21	1,272.50	0	1,436.74	71	164.24	71
J-22	1,270.11	0	1,436.74	72	166.64	72
J-23	1,270.00	0	1,436.74	72	166.74	72
J-24	1,272.02	0	1,436.74	71	164.72	71
J-25	1,275.70	0	1,436.74	70	161.04	70
J-26	1,278.67	0	1,436.74	68	158.07	68
J-27	1,279.00	0	1,436.74	68	157.74	68
J-32	1,272.70	0	1,436.74	71	164.04	71
J-38	1,278.04	16	1,436.74	69	158.70	69
J-39	1,278.04	0	1,436.74	69	158.70	69
J-40	1,278.50	0	1,436.74	68	158.24	68
J-45	1,276.10	0	1,436.74	70	160.64	70
J-48	1,276.40	0	1,436.74	69	160.34	69
J-49	1,272.10	0	1,436.74	71	164.64	71
J-50	1,279.05	0	1,436.74	68	157.69	68
J-52	1,270.31	0	1,436.74	72	166.43	72

## 2025-07-15 City Center Water Model.wtg

### Active Scenario: Base

### Average Day Demand

### Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Length (Scaled) (ft)	Start Node	Stop Node	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-2	24.0	56	R-1	PMP-1	Ductile Iron	130.0	94	0.07	0.000
P-3	24.0	81	PMP-1	J-3	Ductile Iron	130.0	94	0.07	0.000
P-4	16.0	144	J-3	J-22	Ductile Iron	130.0	16	0.02	0.000
P-6	16.0	55	J-3	J-6	Ductile Iron	130.0	78	0.13	0.000
P-7	16.0	219	J-6	J-7	Ductile Iron	130.0	41	0.07	0.000
P-8	16.0	19	J-7	J-8	Ductile Iron	130.0	4	0.01	0.000
P-9	6.0	309	J-8	J-9	Asbestos Cement	140.0	4	0.05	0.000
P-10	8.0	194	J-9	J-10	Asbestos Cement	140.0	14	0.09	0.000
P-11	8.0	52	J-10	J-11	Cast iron	130.0	14	0.09	0.000
P-12	8.0	153	J-11	J-12	Cast iron	130.0	14	0.09	0.000
P-13	8.0	388	J-12	J-13	Cast iron	130.0	0	0.00	0.000
P-17	16.0	190	J-16	J-27	Ductile Iron	130.0	0	0.00	0.000
P-18	20.0	229	J-52	J-21	Ductile Iron	130.0	0	0.00	0.000
P-25	20.0	309	J-7	J-52	Ductile Iron	130.0	37	0.04	0.000
P-27	16.0	40	J-23	J-24	Ductile Iron	130.0	16	0.02	0.000
P-28	16.0	89	J-24	J-25	Ductile Iron	130.0	16	0.02	0.000
P-29	16.0	70	J-25	J-45	Ductile Iron	130.0	16	0.02	0.000
P-30	16.0	108	J-26	J-27	Ductile Iron	130.0	0	0.00	0.000
P-31	16.0	22	J-45	J-26	Ductile Iron	130.0	0	0.00	0.000
P-38	16.0	11	J-23	J-22	Ductile Iron	130.0	-16	0.02	0.000
P-41	8.0	26	J-38	J-39	Ductile Iron	130.0	0	0.00	0.000
P-42	8.0	23	J-39	J-40	Ductile Iron	130.0	0	0.00	0.000
P-48	8.0	14	J-38	J-45	Ductile Iron	130.0	-16	0.10	0.000
P-50	8.0	36	J-32	J-48	Ductile Iron	130.0	0	0.00	0.000
P-51	8.0	200	J-48	J-49	Ductile Iron	130.0	0	0.00	0.000
P-52	8.0	34	J-32	J-50	Ductile Iron	130.0	0	0.00	0.000
P-53	8.0	32	J-50	J-40	Ductile Iron	130.0	0	0.00	0.000

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Average Day Demand**

**Pump Table - Time: 0.00 hours**

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,270.30	On	1,270.50	1,436.74	94	166.24	PMP-1

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Average Day Demand**

**Reservoir Table - Time: 0.00 hours**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,270.50	94	1,270.50

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Maximum Day Demand**

**Junction Table - Time: 0.00 hours**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
J-3	1,270.30	15	1,436.59	72	166.29	72
J-6	1,269.60	0	1,436.59	72	166.99	72
J-7	1,269.00	0	1,436.59	73	167.59	73
J-8	1,269.00	0	1,436.59	73	167.59	73
J-9	1,267.00	40	1,436.59	73	169.59	73
J-10	1,265.40	0	1,436.58	74	171.18	74
J-11	1,266.00	0	1,436.58	74	170.58	74
J-12	1,272.40	27	1,436.58	71	164.18	71
J-13	1,276.00	0	1,436.58	69	160.58	69
J-16	1,275.60	0	1,436.59	70	160.99	70
J-21	1,272.50	0	1,436.59	71	164.09	71
J-22	1,270.11	0	1,436.59	72	166.48	72
J-23	1,270.00	0	1,436.59	72	166.59	72
J-24	1,272.02	0	1,436.59	71	164.57	71
J-25	1,275.70	0	1,436.59	70	160.89	70
J-26	1,278.67	0	1,436.59	68	157.92	68
J-27	1,279.00	0	1,436.59	68	157.59	68
J-32	1,272.70	0	1,436.57	71	163.87	71
J-38	1,278.04	0	1,436.58	69	158.54	69
J-39	1,278.04	112	1,436.57	69	158.53	69
J-40	1,278.50	0	1,436.57	68	158.07	68
J-45	1,276.10	0	1,436.59	69	160.49	69
J-48	1,276.40	0	1,436.57	69	160.17	69
J-49	1,272.10	0	1,436.57	71	164.47	71
J-50	1,279.05	0	1,436.57	68	157.52	68
J-52	1,270.31	0	1,436.59	72	166.28	72

## 2025-07-15 City Center Water Model.wtg

### Active Scenario: Base

### Maximum Day Demand

#### Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Length (Scaled) (ft)	Start Node	Stop Node	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-2	24.0	56	R-1	PMP-1	Ductile Iron	130.0	194	0.14	0.000
P-3	24.0	81	PMP-1	J-3	Ductile Iron	130.0	194	0.14	0.000
P-4	16.0	144	J-3	J-22	Ductile Iron	130.0	112	0.18	0.000
P-6	16.0	55	J-3	J-6	Ductile Iron	130.0	67	0.11	0.000
P-7	16.0	219	J-6	J-7	Ductile Iron	130.0	67	0.11	0.000
P-8	16.0	19	J-7	J-8	Ductile Iron	130.0	7	0.01	0.000
P-9	6.0	309	J-8	J-9	Asbestos Cement	140.0	7	0.08	0.000
P-10	8.0	194	J-9	J-10	Asbestos Cement	140.0	27	0.17	0.000
P-11	8.0	52	J-10	J-11	Cast iron	130.0	27	0.17	0.000
P-12	8.0	153	J-11	J-12	Cast iron	130.0	27	0.17	0.000
P-13	8.0	388	J-12	J-13	Cast iron	130.0	0	0.00	0.000
P-17	16.0	190	J-16	J-27	Ductile Iron	130.0	0	0.00	0.000
P-18	20.0	229	J-52	J-21	Ductile Iron	130.0	0	0.00	0.000
P-25	20.0	309	J-7	J-52	Ductile Iron	130.0	60	0.06	0.000
P-27	16.0	40	J-23	J-24	Ductile Iron	130.0	112	0.18	0.000
P-28	16.0	89	J-24	J-25	Ductile Iron	130.0	112	0.18	0.000
P-29	16.0	70	J-25	J-45	Ductile Iron	130.0	112	0.18	0.000
P-30	16.0	108	J-26	J-27	Ductile Iron	130.0	0	0.00	0.000
P-31	16.0	22	J-45	J-26	Ductile Iron	130.0	0	0.00	0.000
P-38	16.0	11	J-23	J-22	Ductile Iron	130.0	-112	0.18	0.000
P-41	8.0	26	J-38	J-39	Ductile Iron	130.0	112	0.71	0.000
P-42	8.0	23	J-39	J-40	Ductile Iron	130.0	0	0.00	0.000
P-48	8.0	14	J-38	J-45	Ductile Iron	130.0	-112	0.71	0.000
P-50	8.0	36	J-32	J-48	Ductile Iron	130.0	0	0.00	0.000
P-51	8.0	200	J-48	J-49	Ductile Iron	130.0	0	0.00	0.000
P-52	8.0	34	J-32	J-50	Ductile Iron	130.0	0	0.00	0.000
P-53	8.0	32	J-50	J-40	Ductile Iron	130.0	0	0.00	0.000

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Maximum Day Demand**

**Pump Table - Time: 0.00 hours**

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,270.30	On	1,270.50	1,436.59	194	166.09	PMP-1

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Maximum Day Demand**

**Reservoir Table - Time: 0.00 hours**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,270.50	194	1,270.50

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Peak Hour Demand**

**Junction Table - Time: 0.00 hours**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
J-3	1,270.30	26	1,435.97	72	165.67	72
J-6	1,269.60	0	1,435.97	72	166.37	72
J-7	1,269.00	0	1,435.97	72	166.97	72
J-8	1,269.00	0	1,435.97	72	166.97	72
J-9	1,267.00	94	1,435.96	73	168.96	73
J-10	1,265.40	0	1,435.93	74	170.53	74
J-11	1,266.00	0	1,435.93	74	169.93	74
J-12	1,272.40	67	1,435.91	71	163.51	71
J-13	1,276.00	0	1,435.91	69	159.91	69
J-16	1,275.60	0	1,435.96	69	160.36	69
J-21	1,272.50	0	1,435.96	71	163.46	71
J-22	1,270.11	0	1,435.97	72	165.86	72
J-23	1,270.00	0	1,435.97	72	165.97	72
J-24	1,272.02	0	1,435.96	71	163.94	71
J-25	1,275.70	0	1,435.96	69	160.26	69
J-26	1,278.67	0	1,435.96	68	157.29	68
J-27	1,279.00	0	1,435.96	68	156.96	68
J-32	1,272.70	0	1,435.92	71	163.21	71
J-38	1,278.04	0	1,435.94	68	157.90	68
J-39	1,278.04	219	1,435.92	68	157.88	68
J-40	1,278.50	0	1,435.92	68	157.42	68
J-45	1,276.10	0	1,435.96	69	159.86	69
J-48	1,276.40	0	1,435.92	69	159.52	69
J-49	1,272.10	0	1,435.92	71	163.82	71
J-50	1,279.05	0	1,435.92	68	156.87	68
J-52	1,270.31	0	1,435.96	72	165.65	72

## 2025-07-15 City Center Water Model.wtg

### Active Scenario: Base

### Peak Hour Demand

### Pipe Table - Time: 0.00 hours

Label	Diameter (in)	Length (Scaled) (ft)	Start Node	Stop Node	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-2	24.0	56	R-1	PMP-1	Ductile Iron	130.0	405	0.29	0.000
P-3	24.0	81	PMP-1	J-3	Ductile Iron	130.0	405	0.29	0.000
P-4	16.0	144	J-3	J-22	Ductile Iron	130.0	219	0.35	0.000
P-6	16.0	55	J-3	J-6	Ductile Iron	130.0	161	0.26	0.000
P-7	16.0	219	J-6	J-7	Ductile Iron	130.0	161	0.26	0.000
P-8	16.0	19	J-7	J-8	Ductile Iron	130.0	18	0.03	0.000
P-9	6.0	309	J-8	J-9	Asbestos Cement	140.0	18	0.20	0.000
P-10	8.0	194	J-9	J-10	Asbestos Cement	140.0	67	0.43	0.000
P-11	8.0	52	J-10	J-11	Cast iron	130.0	67	0.43	0.000
P-12	8.0	153	J-11	J-12	Cast iron	130.0	67	0.43	0.000
P-13	8.0	388	J-12	J-13	Cast iron	130.0	0	0.00	0.000
P-17	16.0	190	J-16	J-27	Ductile Iron	130.0	0	0.00	0.000
P-18	20.0	229	J-52	J-21	Ductile Iron	130.0	0	0.00	0.000
P-25	20.0	309	J-7	J-52	Ductile Iron	130.0	143	0.15	0.000
P-27	16.0	40	J-23	J-24	Ductile Iron	130.0	219	0.35	0.000
P-28	16.0	89	J-24	J-25	Ductile Iron	130.0	219	0.35	0.000
P-29	16.0	70	J-25	J-45	Ductile Iron	130.0	219	0.35	0.000
P-30	16.0	108	J-26	J-27	Ductile Iron	130.0	0	0.00	0.000
P-31	16.0	22	J-45	J-26	Ductile Iron	130.0	0	0.00	0.000
P-38	16.0	11	J-23	J-22	Ductile Iron	130.0	-219	0.35	0.000
P-41	8.0	26	J-38	J-39	Ductile Iron	130.0	219	1.39	0.001
P-42	8.0	23	J-39	J-40	Ductile Iron	130.0	0	0.00	0.000
P-48	8.0	14	J-38	J-45	Ductile Iron	130.0	-219	1.39	0.001
P-50	8.0	36	J-32	J-48	Ductile Iron	130.0	0	0.00	0.000
P-51	8.0	200	J-48	J-49	Ductile Iron	130.0	0	0.00	0.000
P-52	8.0	34	J-32	J-50	Ductile Iron	130.0	0	0.00	0.000
P-53	8.0	32	J-50	J-40	Ductile Iron	130.0	0	0.00	0.000

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Peak Hour Demand**

**Pump Table - Time: 0.00 hours**

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,270.30	On	1,270.50	1,435.97	405	165.47	PMP-1

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Peak Hour Demand**

**Reservoir Table - Time: 0.00 hours**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,270.50	405	1,270.50

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - NEC**  
**Junction Table - Time: 0.00 hours**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
J-3	1,270.30	1,500	1,409.29	60	138.99	60
J-6	1,269.60	75	1,409.29	60	139.69	60
J-7	1,269.00	0	1,409.29	61	140.29	61
J-8	1,269.00	0	1,409.29	61	140.29	61
J-9	1,267.00	55	1,409.29	62	142.29	62
J-10	1,265.40	0	1,409.28	62	143.88	62
J-11	1,266.00	0	1,409.28	62	143.28	62
J-12	1,272.40	27	1,409.28	59	136.88	59
J-13	1,276.00	0	1,409.28	58	133.28	58
J-16	1,275.60	0	1,409.06	58	133.46	58
J-21	1,272.50	0	1,409.29	59	136.79	59
J-22	1,270.11	0	1,409.20	60	139.09	60
J-23	1,270.00	0	1,409.19	60	139.19	60
J-24	1,272.02	0	1,409.16	59	137.14	59
J-25	1,275.70	0	1,409.10	58	133.40	58
J-26	1,278.67	0	1,409.06	56	130.39	56
J-27	1,279.00	0	1,409.06	56	130.06	56
J-32	1,272.70	0	1,408.31	59	135.61	59
J-38	1,278.04	31	1,408.78	57	130.74	57
J-39	1,278.04	1,000	1,408.31	56	130.27	56
J-40	1,278.50	0	1,408.31	56	129.81	56
J-45	1,276.10	0	1,409.06	58	132.96	58
J-48	1,276.40	0	1,408.31	57	131.91	57
J-49	1,272.10	0	1,408.31	59	136.21	59
J-50	1,279.05	0	1,408.31	56	129.26	56
J-52	1,270.31	0	1,409.29	60	138.98	60

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - NEC**  
**Pipe Table - Time: 0.00 hours**

Label	Diameter (in)	Length (Scaled) (ft)	Start Node	Stop Node	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-2	24.0	56	R-1	PMP-1	Ductile Iron	130.0	2,688	1.91	0.001
P-3	24.0	81	PMP-1	J-3	Ductile Iron	130.0	2,688	1.91	0.001
P-4	16.0	144	J-3	J-22	Ductile Iron	130.0	1,031	1.65	0.001
P-6	16.0	55	J-3	J-6	Ductile Iron	130.0	156	0.25	0.000
P-7	16.0	219	J-6	J-7	Ductile Iron	130.0	82	0.13	0.000
P-8	16.0	19	J-7	J-8	Ductile Iron	130.0	9	0.01	0.000
P-9	6.0	309	J-8	J-9	Asbestos Cement	140.0	9	0.10	0.000
P-10	8.0	194	J-9	J-10	Asbestos Cement	140.0	27	0.17	0.000
P-11	8.0	52	J-10	J-11	Cast iron	130.0	27	0.17	0.000
P-12	8.0	153	J-11	J-12	Cast iron	130.0	27	0.17	0.000
P-13	8.0	388	J-12	J-13	Cast iron	130.0	0	0.00	0.000
P-17	16.0	190	J-16	J-27	Ductile Iron	130.0	0	0.00	0.000
P-18	20.0	229	J-52	J-21	Ductile Iron	130.0	0	0.00	0.000
P-25	20.0	309	J-7	J-52	Ductile Iron	130.0	73	0.07	0.000
P-27	16.0	40	J-23	J-24	Ductile Iron	130.0	1,031	1.65	0.001
P-28	16.0	89	J-24	J-25	Ductile Iron	130.0	1,031	1.65	0.001
P-29	16.0	70	J-25	J-45	Ductile Iron	130.0	1,031	1.65	0.001
P-30	16.0	108	J-26	J-27	Ductile Iron	130.0	0	0.00	0.000
P-31	16.0	22	J-45	J-26	Ductile Iron	130.0	0	0.00	0.000
P-38	16.0	11	J-23	J-22	Ductile Iron	130.0	-1,031	1.65	0.001
P-41	8.0	26	J-38	J-39	Ductile Iron	130.0	1,000	6.38	0.018
P-42	8.0	23	J-39	J-40	Ductile Iron	130.0	0	0.00	0.000
P-48	8.0	14	J-38	J-45	Ductile Iron	130.0	-1,031	6.58	0.019
P-50	8.0	36	J-32	J-48	Ductile Iron	130.0	0	0.00	0.000
P-51	8.0	200	J-48	J-49	Ductile Iron	130.0	0	0.00	0.000
P-52	8.0	34	J-32	J-50	Ductile Iron	130.0	0	0.00	0.000
P-53	8.0	32	J-50	J-40	Ductile Iron	130.0	0	0.00	0.000

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - NEC**  
**Pump Table - Time: 0.00 hours**

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,270.30	On	1,270.47	1,409.34	2,688	138.87	PMP-1

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Fire Flow Demand + Max Day Demand - NEC**

**Reservoir Table - Time: 0.00 hours**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,270.50	2,688	1,270.50

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - SWC**  
**Junction Table - Time: 0.00 hours**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)	Pressure Head (ft)	Pressure (Maximum) (psi)
J-3	1,270.30	0	1,409.29	60	138.99	60
J-6	1,269.60	75	1,409.08	60	139.48	60
J-7	1,269.00	0	1,408.29	60	139.29	60
J-8	1,269.00	0	1,408.29	60	139.29	60
J-9	1,267.00	55	1,407.66	61	140.66	61
J-10	1,265.40	0	1,404.41	60	139.01	60
J-11	1,266.00	1,000	1,403.41	59	137.41	59
J-12	1,272.40	27	1,403.40	57	131.00	57
J-13	1,276.00	0	1,403.40	55	127.40	55
J-16	1,275.60	0	1,409.29	58	133.69	58
J-21	1,272.50	0	1,407.96	59	135.46	59
J-22	1,270.11	0	1,409.29	60	139.18	60
J-23	1,270.00	0	1,409.29	60	139.29	60
J-24	1,272.02	0	1,409.29	59	137.27	59
J-25	1,275.70	0	1,409.29	58	133.59	58
J-26	1,278.67	0	1,409.29	57	130.62	57
J-27	1,279.00	0	1,409.29	56	130.29	56
J-32	1,272.70	0	1,409.29	59	136.59	59
J-38	1,278.04	31	1,409.29	57	131.25	57
J-39	1,278.04	0	1,409.29	57	131.25	57
J-40	1,278.50	0	1,409.29	57	130.79	57
J-45	1,276.10	0	1,409.29	58	133.19	58
J-48	1,276.40	0	1,409.29	57	132.89	57
J-49	1,272.10	0	1,409.29	59	137.19	59
J-50	1,279.05	0	1,409.29	56	130.24	56
J-52	1,270.31	1,500	1,407.96	60	137.65	60

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - SWC**  
**Pipe Table - Time: 0.00 hours**

Label	Diameter (in)	Length (Scaled) (ft)	Start Node	Stop Node	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
P-2	24.0	56	R-1	PMP-1	Ductile Iron	130.0	2,688	1.91	0.001
P-3	24.0	81	PMP-1	J-3	Ductile Iron	130.0	2,688	1.91	0.001
P-4	16.0	144	J-3	J-22	Ductile Iron	130.0	31	0.05	0.000
P-6	16.0	55	J-3	J-6	Ductile Iron	130.0	2,656	4.24	0.004
P-7	16.0	219	J-6	J-7	Ductile Iron	130.0	2,582	4.12	0.004
P-8	16.0	19	J-7	J-8	Ductile Iron	130.0	155	0.25	0.000
P-9	6.0	309	J-8	J-9	Asbestos Cement	140.0	155	1.76	0.002
P-10	8.0	194	J-9	J-10	Asbestos Cement	140.0	1,027	6.55	0.017
P-11	8.0	52	J-10	J-11	Cast iron	130.0	1,027	6.55	0.019
P-12	8.0	153	J-11	J-12	Cast iron	130.0	27	0.17	0.000
P-13	8.0	388	J-12	J-13	Cast iron	130.0	0	0.00	0.000
P-17	16.0	190	J-16	J-27	Ductile Iron	130.0	0	0.00	0.000
P-18	20.0	229	J-52	J-21	Ductile Iron	130.0	0	0.00	0.000
P-25	20.0	309	J-7	J-52	Ductile Iron	130.0	2,427	2.48	0.001
P-27	16.0	40	J-23	J-24	Ductile Iron	130.0	31	0.05	0.000
P-28	16.0	89	J-24	J-25	Ductile Iron	130.0	31	0.05	0.000
P-29	16.0	70	J-25	J-45	Ductile Iron	130.0	31	0.05	0.000
P-30	16.0	108	J-26	J-27	Ductile Iron	130.0	0	0.00	0.000
P-31	16.0	22	J-45	J-26	Ductile Iron	130.0	0	0.00	0.000
P-38	16.0	11	J-23	J-22	Ductile Iron	130.0	-31	0.05	0.000
P-41	8.0	26	J-38	J-39	Ductile Iron	130.0	0	0.00	0.000
P-42	8.0	23	J-39	J-40	Ductile Iron	130.0	0	0.00	0.000
P-48	8.0	14	J-38	J-45	Ductile Iron	130.0	-31	0.20	0.000
P-50	8.0	36	J-32	J-48	Ductile Iron	130.0	0	0.00	0.000
P-51	8.0	200	J-48	J-49	Ductile Iron	130.0	0	0.00	0.000
P-52	8.0	34	J-32	J-50	Ductile Iron	130.0	0	0.00	0.000
P-53	8.0	32	J-50	J-40	Ductile Iron	130.0	0	0.00	0.000

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: Base**  
**Fire Flow Demand + Max Day Demand - SWC**  
**Pump Table - Time: 0.00 hours**

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)	Pump Definition
PMP-1	1,270.30	On	1,270.47	1,409.34	2,688	138.87	PMP-1

**2025-07-15 City Center Water Model.wtg**

**Active Scenario: Base**

**Fire Flow Demand + Max Day Demand - SWC**

**Reservoir Table - Time: 0.00 hours**

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,270.50	2,688	1,270.50


# 2025-07-15 City Center Water Model.wtg

## Active Scenario: ADD

### Pump Definition Detailed Report: PMP-1

Element Details			
ID	64	Notes	
Label	PMP-1		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	140.90 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	5,965 gpm
Shutoff Head	166.30 ft	Maximum Operating Head	46.20 ft
Design Flow	2,578 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft <sup>2</sup>	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True

**2025-07-15 City Center Water Model.wtg**  
**Active Scenario: ADD**  
**Pump Definition Detailed Report: PMP-1**



**CIVIL ENGINEER**  
SUSTAINABILITY ENGINEERING GROUP  
5240 N. 16TH STREET, SUITE 105  
PHOENIX, ARIZONA 85016  
PHONE: 480-237-2507  
ATTN: ALI FAKIH  
EMAIL: ALI@AZSEG.COM

**CLIENT:**  
SMITH GROUP  
455 N. 3RD STREET, SUITE 250  
PHOENIX, AZ 85004  
PHONE: 602-824-5323  
ATTN: OZ WAGNER  
EMAIL: OZ.WAGNER@SMITHGROUP.COM

**PARCEL DESCRIPTION:**  
HIGH-DENSITY, MULTI-USE DEVELOPMENT INCLUDING RETAIL, RESTAURANTS,  
AND UNDERGROUND PARKING.

**SITE DATA:**  
APN: 173-41-016B, 173-41-017A, 173-41-006A,  
173-41-005 AND 173-41-004.  
ZONING: C-2-DO/C-3-DO  
LOT SIZE: 3.03 ACRES (131,786 SF)  
FLOOD ZONE: ZONE X (AREA OF MINIMAL FLOOD HAZARD)

**BASIS OF BEARING:**  
THE MONUMENT LINE OF CAMELBACK RD FROM THE WEST QUARTER  
CORNER TO THE CENTER OF SECTION 23 WHICH BEARS SOUTH 89  
DEGREES 31 MINUTES 36 SECONDS EAST.

**BENCHMARK:**  
FOUND BRASS CAP IN HAND HOLE WEST QUARTER CORNER OF SECTION  
23 TOWNSHIP 2 N RANGE 4 EAST AT INTERSECTION OF CAMELBACK RD. &  
SCOTTSDALE RD. ELEV=1,277.52 NAVD 88.

# SCOTTSDALE CITY CENTER PRELIMINARY UTILITY PLAN

7201 E. CAMELBACK ROAD, SCOTTSDALE, AZ 85251  
A PORTION OF THE SOUTHWEST QUARTER OF SECTION 23, TOWNSHIP 2  
NORTH, RANGE 4 EAST OF THE GILA AND SALT RIVER BASE AND  
MERIDIAN, MARICOPA COUNTY, ARIZONA.

## NOTES FOR IMPROVEMENT PLANS WHERE THERE IS EXISTING ACP OR PVC PIPE:

ANY WATER LINE PROJECT THAT INVOLVES CONNECTING TO AN EXISTING ACP OR  
PVC PIPE, REQUIRES SPECIAL ATTENTION. PER DSPM SECTION 6-1.408:

FITTINGS INSTALLED INTO ASBESTOS CEMENT PIPE (ACP) OR PVC PIPE WITHIN  
6- FEET OF ANOTHER FITTING OR JOINT WILL REQUIRE THAT SECTION OF PIPE TO  
BE REMOVED AND REPLACED WITH DUCTILE IRON PIPE (DIP). EXISTING TEES, TAPPING  
SLEEVES AND RELATED APPURTENANCES THAT ARE NOT UTILIZED BY THE  
DEVELOPMENT SHALL BE REMOVED BY THE CONTRACTOR. A MINIMUM 3-FOOT  
SECTION OF PIPE SHALL BE REMOVED, WITH NO LESS THAN 6- FEET REMAINING TO  
THE NEAREST JOINT. THE REMOVED PIPE SHALL BE REPLACED WITH DIP.

WHEN MORE THAN 3- FEET OF EXISTING ACP OR PVC WATER LINES ARE EXPOSED  
DURING CONSTRUCTION AND THE BEDDING IS DISTURBED, THE WATER LINE MUST BE  
REPLACED WITH DIP (MINIMUM CLASS 350) WITH MECHANICAL JOINTS OR FLANGED  
JOINTS TO 3- FEET PAST THE SIDES OF THE EXPOSED CROSSING TRENCH. REFER TO  
MAG STD. DET. 403-3.

NO TAPPING SLEEVE AND VALVE SHALL BE USED ON ACP PIPE. VALVES WILL NEED TO  
BE CUT INTO ACP PIPE.


DISPOSAL OF MATERIALS CONTAINING ASBESTOS AND/OR LEAD SHALL BE IN  
CONFORMANCE WITH ALL REGULATIONS, LAWS AND ORDINANCES.

### PRELIMINARY WATER NOTES

- 1 CONNECTION TO EXISTING WATER LINE.
- 2 SAWCUT, REMOVE AND REPLACE EXISTING PAVEMENT.
- 3 PROPOSED TAPPING SLEEVE, VALVE, BOX & COVER.
- 4 PROPOSED FIRE HYDRANT ASSEMBLY.
- 5 6" DUCTILE IRON PIPE. LENGTH PER PLAN.
- 6 8" DUCTILE IRON PIPE. LENGTH PER PLAN.
- 6A 16" DUCTILE IRON PIPE. LENGTH PER PLAN.
- 7 2" COPPER DOMESTIC SERVICE CONNECTION.
- 8 1" IRRIGATION SERVICE CONNECTION.
- 9 BACKFLOW PREVENTION, SIZE TO MATCH WATER METER SIZE.
- 10 DOMESTIC CONNECTION TO BUILDING.
- 11 UTILITY CROSSING.
- 12 PROPOSED FIRE DEPARTMENT CONNECTION.
- 13 FIRE CONNECTION TO BUILDING. INCLUDING DOUBLE CHECK VALVE  
IN RISER ROOM
- 14 PROPOSED REMOTE FIRE DEPARTMENT CONNECTION.
- 15 PROPOSED FITTING, SIZE & ANGLE PER PLAN.
- 15A PROPOSED TEE, SIZE PER PLAN.
- 16 PROPOSED GATE VALVE WITH VALVE BOX AND COVER.
- 17 PROPOSED REDUCER.
- 18 VERTICAL REALIGNMENT.
- 19 AIR RELEASE VALVE and vacuum

### PRELIMINARY SEWER NOTES (ENTIRE ON-SITE SYSTEM IS PRIVATE)

- 1 6" PRIVATE PVC SEWER LINE. LENGTH & SLOPE PER PLAN
- 1A 8" PRIVATE PVC SEWER LINE. LENGTH & SLOPE PER PLAN
- 1B 12" PRIVATE PVC SEWER LINE. LENGTH & SLOPE PER PLAN
- 1C 6" DIP FORCE MAIN. LENGTH PER PLAN
- 2 SEWER CONNECTION TO BUILDING
- 3 REMOVE CAP AND CONNECT TO EXISTING STUB.
- 4 PROPOSED GREASE INTERCEPTOR
- 4A PROPOSED GREASE INTERCEPTOR WITH TRAFFIC RATED COVER
- 5 PROPOSED 4' PRECAST CONCRETE SEWER MANHOLE
- 5A PROPOSED 5' PRECAST CONCRETE SEWER MANHOLE
- 5B PROPOSED 4' POLYMER SEWER MANHOLE (INCLUDING BASE, RISER, AND CONE)
- 6 PROPOSED SEWER CAP
- 7 PROPOSED WETWELL WITH TRAFFIC RATED COVER
- 8 PROPOSED VALVE VAULT WITH TRAFFIC RATED COVER
- 9 PROPOSED CLEANOUT WITH TRAFFIC RATED COVER



### STREET LIGHT & ELECTRICAL NOTES:


- 1 PRIOR TO ISSUANCE OF PERMITS, STREET LIGHT SHALL  
BE EVALUATED FOR COMPLIANCE WITH STREET-SCAPE  
PHASING PLAN AND CITY STANDARDS AND REQUIREMENTS.  
ANY LIGHTS NOT MEETING THESE STANDARDS OR  
REQUIREMENTS WILL BE UPGRADED OR REPLACED WITH  
CONFORMING STREET LIGHTS.
- 2 EXISTING POWER POLES AND LINES TO BE REMOVED. NEW  
ELECTRIC SERVICE WILL BE INSTALLED UNDERGROUND.
- 3 PROPOSED PEDESTRIAN CROSSING WITH HAWK TRAFFIC  
CONTROLS. SEE GRADING PLAN FOR DETAILS.

### PROPOSED UTILITY LEGEND:

	PROPERTY LINE
	EASEMENT LINE
	WATER LINE
	SEWER LINE
	FIRE HYDRANT
	FDC
	WATER METER
	GATE VALVE
	T.S.V.B.&C.
	BACK FLOW PREVENTER
	REDUCER
	CAP
	BUILDING CONNECTION
	SEWER MANHOLE
	SEWER CLEAN OUT

### EXISTING LEGEND

	EX. S	SEWER LINE
	EX. W	WATER LINE
	IRR	IRRIGATION LINE
	SD	STORM DRAIN LINE
	CB	CATCH BASIN
	S	SEWER MANHOLE
	D	STORM MANHOLE
	WV	WATER VALVE
	WMB	WATER METER BOX
	FCB	FIRE HYDRANT
	ECB	ELECTRIC CABINET
	S.L.	STREET LIGHT




PRELIMINARY  
NOT FOR  
CONSTRUCTION

SUSTAINABILITY  
ENGINEERING  
GROUP

SEG



SMITHGROUP



PROJECT SCOTTSDALE CITY CENTER	LOCATION 7201 E. CAMELBACK ROAD, SCOTTSDALE, AZ, 85251.
DRAWN MM	06/13/2025
DESIGNED MM	07/30/2025
CHECKED AK	11/12/2024
FINAL DC SC	11/11/2024
PROJ. MGR. AK	07/30/2025

DATE: 07/30/2025  
ISSUED FOR: DRB

REVISION NO.:	DATE:

JOB NO.: 221117  
SHEET TITLE:


PRELIMINARY UTILITY  
PLAN

PAGE NO.: 1 OF 1  
SHEET NO.: C4.00

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.

# CITY CENTER POTHOLE EXHIBIT

7201 E. CAMELBACK ROAD, SCOTTSDALE, AZ 85251  
A PORTION OF THE SOUTHWEST QUARTER OF SECTION 12, TOWNSHIP 2 NORTH, RANGE 4  
EAST OF THE GILA AND SALT RIVER BASE AND MERIDIAN, MARICOPA COUNTY, ARIZONA.



PRELIMINARY  
NOT FOR  
CONSTRUCTION

SUSTAINABILITY  
ENGINEERING  
GROUP

SEG



5240 N. 16TH STREET SUITE 105 PHOENIX, ARIZONA 85016  
WWW.AZSEG.COM TEL. 480.988.7226 FAX. 480.259.3534

SMITHGROUP



PROJECT: CITY CENTER RESIDENTIAL  
LOCATION: 7201 E. CAMELBACK ROAD, SCOTTSDALE, AZ, 85251

DRAWN: MC 09/21/2023  
DESIGNED: MC 09/21/2023  
CHECKED: MC 09/21/2023  
FINAL DC  
PROJ. MGR: AF 09/21/2023  
DATE: 09/21/2023  
ISSUED FOR: REVIEW

REVISION NO.: DATE:  
JOB NO.: 221117  
SHEET TITLE:


POTHOLE EXHIBIT

PAGE NO.: SHEET NO.:  
1 OF 1

POTHOLES TABLE			
PH#	DESCRIPTION	TOP ELEVATION	BOTTOM ELEVATION
PH-1			
PH-2			
PH-3			
PH-4			
PH-5			
PH-6			
PH-7			
PH-8			
PH-9			
PH-10			
PH-11			
PH-12			
PH-13			
PH-14			
PH-15			
PH-16			
PH-17			
PH-18			
PH-19			
PH-20			
PH-21			
PH-22			
PH-23			
PH-24			
PH-25			
PH-26			

## APPENDIX IV - Utility Line Potholes

SCALE: 1" = 30'



THIS DRAWING IS AN INSTRUMENT OF SERVICE AND THE PROPERTY OF SUSTAINABILITY ENGINEERING GROUP, AND SHALL REMAIN THEIR PROPERTY. THE USE OF THIS DRAWING SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH IT IS PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE.

## APPENDIX B

# FIRE-FLOW REQUIREMENTS FOR BUILDINGS

*The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance or legislation of the jurisdiction.*

---

### User note:

**About this appendix:** Appendix B provides a tool for the use of jurisdictions in establishing a policy for determining fire-flow requirements in accordance with Section 507.3. The determination of required fire flow is not an exact science, but having some level of information provides a consistent way of choosing the appropriate fire flow for buildings throughout a jurisdiction. The primary tool used in this appendix is a table that presents fire flow based on construction type and building area based on the correlation of the Insurance Services Office (ISO) method and the construction types used in the International Building Code®.

---

### SECTION B101 GENERAL

**B101.1 Scope.** The procedure for determining fire-flow requirements for buildings or portions of buildings hereafter constructed shall be in accordance with this appendix. This appendix does not apply to structures other than buildings.

### SECTION B102 DEFINITIONS

**B102.1 Definitions.** For the purpose of this appendix, certain terms are defined as follows:

**FIRE FLOW.** The flow rate of a water supply, measured at 20 pounds per square inch (psi) (138 kPa) residual pressure, that is available for fire fighting.

**FIRE-FLOW CALCULATION AREA.** The floor area, in square feet (m<sup>2</sup>), used to determine the required fire flow.

### SECTION B103 MODIFICATIONS

■ **B103.1 Decreases.** The *fire code official* is authorized to reduce the *fire-flow* requirements for isolated buildings or a group of buildings in rural areas or small communities where the development of full *fire-flow* requirements is impractical.

■ **B103.2 Increases.** The *fire code official* is authorized to increase the *fire-flow* requirements where conditions indicate an unusual susceptibility to group fires or conflagrations. An increase shall be not more than twice that required for the building under consideration.

**B103.3 Areas without water supply systems.** For information regarding water supplies for fire-fighting purposes in rural and suburban areas in which adequate and reliable water supply systems do not exist, the *fire code official* is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

### SECTION B104 FIRE-FLOW CALCULATION AREA

**B104.1 General.** The *fire-flow calculation area* shall be the total floor area of all floor levels within the *exterior walls*, and under the horizontal projections of the roof of a building, except as modified in Section B104.3.

**B104.2 Area separation.** Portions of buildings that are separated by *fire walls* without openings, constructed in accordance with the *International Building Code*, are allowed to be considered as separate *fire-flow calculation areas*.

**B104.3 Type IA and Type IB construction.** The *fire-flow calculation area* of buildings constructed of Type IA and Type IB construction shall be the area of the three largest successive floors.

**Exception:** *Fire-flow calculation area* for open parking garages shall be determined by the area of the largest floor.

### SECTION B105 FIRE-FLOW REQUIREMENTS FOR BUILDINGS

**B105.1 One- and two-family dwellings, Group R-3 and R-4 buildings and townhouses.** The minimum *fire-flow* and flow duration requirements for one- and two-family *dwellings*, Group R-3 and R-4 buildings and *townhouses* shall be as specified in Tables B105.1(1) and B105.1(2).

**B105.2 Buildings other than one- and two-family dwellings, Group R-3 and R-4 buildings and townhouses.** The minimum *fire-flow* and flow duration for buildings other than one- and two-family *dwellings*, Group R-3 and R-4 buildings and *townhouses* shall be as specified in Tables B105.2 and B105.1(2).

**B105.3 Water supply for buildings equipped with an automatic sprinkler system.** For buildings equipped with an *approved automatic sprinkler system*, the water supply shall be capable of providing the greater of:

1. The *automatic sprinkler system* demand, including hose stream allowance.
2. The required *fire flow*.

## APPENDIX V

APPENDIX B

**TABLE B105.1(1)**  
**REQUIRED FIRE FLOW FOR ONE- AND TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

FIRE-FLOW CALCULATION AREA (square feet)	AUTOMATIC SPRINKLER SYSTEM (Design Standard)	MINIMUM FIRE FLOW (gallons per minute)	FLOW DURATION (hours)
0-3,600	No automatic sprinkler system	1,000	1
3,601 and greater	No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2) at the required fire-flow rate
0-3,600	Section 903.3.1.3 of the <i>International Fire Code</i> or Section P2904 of the <i>International Residential Code</i>	500	1/2
3,601 and greater	Section 903.3.1.3 of the <i>International Fire Code</i> or Section P2904 of the <i>International Residential Code</i>	1/2 value in Table B105.1(2)	1

For SI: 1 square foot = 0.0929 m<sup>2</sup>, 1 gallon per minute = 3.785 L/m.

**TABLE B105.1(2)**  
**REFERENCE TABLE FOR TABLES B105.1(1) AND B105.2**

FIRE-FLOW CALCULATION AREA (square feet)					FIRE FLOW (gallons per minute) <sup>b</sup>	FLOW DURATION (hours)
Type IA and IB <sup>a</sup>	Type IIA and IIIA <sup>a</sup>	Type IV and V-A <sup>a</sup>	Type IIB and IIIB <sup>a</sup>	Type V-B <sup>a</sup>		
0-22,700	0-12,700	0-8,200	0-5,900	0-3,600	1,500	2
22,701-30,200	12,701-17,000	8,201-10,900	5,901-7,900	3,601-4,800	1,750	
30,201-38,700	17,001-21,800	10,901-12,900	7,901-9,800	4,801-6,200	2,000	
38,701-48,300	21,801-24,200	12,901-17,400	9,801-12,600	6,201-7,700	2,250	
48,301-59,000	24,201-33,200	17,401-21,300	12,601-15,400	7,701-9,400	2,500	
59,001-70,900	33,201-39,700	21,301-25,500	15,401-18,400	9,401-11,300	2,750	3
70,901-83,700	39,701-47,100	25,501-30,100	18,401-21,800	11,301-13,400	3,000	
83,701-97,700	47,101-54,900	30,101-35,200	21,801-25,900	13,401-15,600	3,250	
97,701-112,700	54,901-63,400	35,201-40,600	25,901-29,300	15,601-18,000	3,500	
112,701-128,700	63,401-72,400	40,601-46,400	29,301-33,500	18,001-20,600	3,750	
128,701-145,900	72,401-82,100	46,401-52,500	33,501-37,900	20,601-23,300	4,000	4
145,901-164,200	82,101-92,400	52,501-59,100	37,901-42,700	23,301-26,300	4,250	
164,201-183,400	92,401-103,100	59,101-66,000	42,701-47,700	26,301-29,300	4,500	
183,401-203,700	103,101-114,600	66,001-73,300	47,701-53,000	29,301-32,600	4,750	
203,701-225,200	114,601-126,700	73,301-81,100	53,001-58,600	32,601-36,000	5,000	
225,201-247,700	126,701-139,400	81,101-89,200	58,601-65,400	36,001-39,600	5,250	
247,701-271,200	139,401-152,600	89,201-97,700	65,401-70,600	39,601-43,400	5,500	
271,201-295,900	152,601-166,500	97,701-106,500	70,601-77,000	43,401-47,400	5,750	
295,901-Greater	166,501-Greater	106,501-115,800	77,001-83,700	47,401-51,500	6,000	
—	—	115,801-125,500	83,701-90,600	51,501-55,700	6,250	
—	—	125,501-135,500	90,601-97,900	55,701-60,200	6,500	
—	—	135,501-145,800	97,901-106,800	60,201-64,800	6,750	
—	—	145,801-156,700	106,801-113,200	64,801-69,600	7,000	
—	—	156,701-167,900	113,201-121,300	69,601-74,600	7,250	
—	—	167,901-179,400	121,301-129,600	74,601-79,800	7,500	
—	—	179,401-191,400	129,601-138,300	79,801-85,100	7,750	
—	High Rise Mixed Use	138,301-Greater	85,101-Greater	8,000	8,000	Use 2,500 min 25% = 2,000

All for 2 hr duration

For SI: 1 square foot = 0.0929 m<sup>2</sup>, 1 gallon per minute = 3.785 L/m, 1 pound per square inch = 6.895 kPa.

a. Types of construction are based on the *International Building Code*.

b. Measured at 20 psi residual pressure.

**TABLE B105.2  
REQUIRED FIRE FLOW FOR BUILDINGS OTHER THAN ONE- AND  
TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

<b>AUTOMATIC SPRINKLER SYSTEM (Design Standard)</b>	<b>MINIMUM FIRE FLOW (gallons per minute)</b>	<b>FLOW DURATION (hours)</b>
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the <i>International Fire Code</i>	25% of the value in Table B105.1(2) <sup>a</sup>	Duration in Table B105.1(2) at the reduced flow rate
Section 903.3.1.2 of the <i>International Fire Code</i>	25% of the value in Table B105.1(2) <sup>b</sup>	Duration in Table B105.1(2) at the reduced flow rate

For SI: 1 gallon per minute = 3.785 L/m.

a. The reduced fire flow shall be not less than 1,000 gallons per minute.

b. The reduced fire flow shall be not less than 1,500 gallons per minute.

**SECTION B106  
REFERENCED STANDARDS**

ICC	IBC—18	International Building Code	B104.2
ICC	IWUIC—18	International Wildland- Urban Interface Code	B103.3
ICC	IRC—18	International Residential Code	Table B105.1(1)
NFPA	1142—17	Standard on Water Supplies for Suburban and Rural Fire Fighting	B103.3