

# WATER CAPACITY REPORT

## McDowell

**PRELIMINARY Basis of Design Report** ACCEPTED ACCEPTED AS NOTED REVISE AND RESUBMIT

Disclaimer: If accepted; the preliminary approval is granted under the condition that a final basis of design report will also be submitted for city review and approval (typically during the DR or PP case). The final report shall incorporate further water or sewer design and analysis requirements as defined in the city design standards and policy manual and address those items noted in the preliminary review comments (both separate and included herein). The final report shall be submitted and approved prior to the plan review submission.

For questions or clarifications contact the Water Resources Planning and Engineering Department at 480-312-5685.

BY Idillon

DATE 3/24/2022

Address the comments below and herein within the final BOD in the DR case:

- 1) The two adjacent taps and cut in tee on the ACP main in McDowell Rd require that this whole section of ACP pipe be replaced with new DIP. Fittings installed into asbestos cement pipe (ACP) or PVC pipe within 6-feet of another fitting or joint will require that section of pipe to be removed and replaced with DIP. DS&PM 6-1.408
- 2) Address comments on utility plan.

Prepared For:

**HOH Investment Group**

11811 N. Tatum BLVD #1051

Phoenix, AZ 85028

Prepared by:

**Sustainability Engineering Group**

8280 E. Gelding Drive, Suite 101

Scottsdale, AZ 85260


480.588.7226 [www.azSEG.com](http://www.azSEG.com)

Project Number: 210929

Submission Date: December 1, 2021

Case No.: TBD

Plan Check No.: TBD



**TABLE OF CONTENTS:**

<b>1. EXECUTIVE SUMMARY</b>		<b>3</b>
<b>2. INTRODUCTION</b>		
2.1 PLAN OBJECTIVE .....		3
2.2 SITE LOCATION .....		3
2.3 PROPOSED DEVELOPMENT .....		3
2.3.1 Existing Site Description .....		4
2.3.2 Proposed Site Development .....		4
<b>3. DESIGN CRITERIA</b>		
3.1 UTILITY DEVELOPER GUIDE CRITERIA .....		4
<b>4. DEMANDS</b>		
4.1 PROJECT USE DESCRIPTION .....		5
4.2 ZONING .....		5
4.3 TABULAR CALCULATION.....		5
<b>5. EXISTING FACILITIES / CONDITIONS</b>		
5.1 PREVIOUS MASTER PLANS .....		6
<b>6. PROPOSED FACILITIES</b>		
6.1 DISTRIBUTION SYSTEM PIPING		
6.1.1 Onsite .....		6
6.1.2 Offsite Infrastructure .....		6
6.2 REQUIRED FACILITIES AND PHASING .....		6
<b>7. SUMMARY/CONCLUSIONS</b>		
7.1 CONFORMANCE TO DESIGN GOALS .....		7
<b>8. REFERENCES</b>		7



**LIST OF TABLES:**

TABLE 1	-	Design Criteria by demand type
TABLE 2	-	Proposed Water Demand Calculations
TABLE 3	-	Water Pressure Results Summary

**LIST OF FIGURES:**

FIGURE 1	-	Vicinity Map
FIGURE 2	-	Aerial Map
FIGURE 3	-	City of Scottsdale (QS 13-47)

**APPENDIX:**

APPENDIX I	-	Flow Test Results
APPENDIX III	-	WaterCAD Results
APPENDIX II	-	Utility Plan

## 1. EXECUTIVE SUMMARY

The proposed development will be a restaurant, with a designated drive through and associated landscaping. The purpose of this water capacity design report is to provide analysis of the impact that this development will have on the city's system.

Water service for the development is to be provided by City of Scottsdale. Existing water infrastructure includes a 12" ACP line in McDowell Road, and a 12" CIP line in Hayden Road.

Refer to **Figure 3** for existing pipes.

On-site fire line improvements will consist of a 6" fire line provided to the building and will be connected to the existing 12" main running along McDowell Road.

No new fire hydrants will be proposed for the site. An existing fire hydrant located approximately 40 ft south of the proposed building will service the site.

Certified fire hydrant flow testing was performed on October 25, 2021 by Arizona Flow Testing, LLC at the location shown on the test results.

Results are as follows:

FLOW TEST: Tested October 25, 2021 at 7:45 a.m.; fire flow test recorded a static pressure of 96 psi and a residual pressure of 80 psi at 1,842 gpm.

Refer to **Appendix I** for fire flow test results.

## 2. INTRODUCTION

### 2.1 PLAN OBJECTIVE:

The purpose of this report is to provide discussions and calculations defining the system concepts necessary to comply with the requirements of the City of Scottsdale for a proposed restaurant at E McDowell Road. Preparation of this report has been done in accordance with the City of Scottsdale Design Standards & Policies Manual (DS+PM) 2018.

### 2.2 SITE LOCATION

The subject property consists of a parcel of land located in a portion of the Southwest Quarter of Section 36, Township 2 North, Range 4 East of the Gila and Salt River Meridian, Maricopa County, Arizona.

- Parcel ID: Parcel 131-04-087H; Zoning is PNC
- Address: 8010 E McDowell Road, Scottsdale 85257

Refer to **FIGURE 1 - Vicinity Map** for the project's location with respect to major cross streets.

### 2.3 EXISTING AND PROPOSED DEVELOPMENTS SURROUNDING THE SITE:

Existing site context related to surrounding developments is as follows:

- North: Parcel 131-04-087F; Parking lot; Zoning PNC.



- West: Parcel 131-04-087J; Two story office and retail center; PNC.
- South: Across McDowell Road, Parcel 131-09-002N; Vacant lot; Zoning C-3.
- East: Across Almeria Road, Parcel 131-04-125; Blue Fox Group; Zoning C-2.

### 2.3.1 EXISTING SITE DESCRIPTION:

The project area includes approximately 16,615 sq. ft. (0.38 acres) of land designated as PNC. The site is currently developed as a parking lot. The site is mostly flat, generally slopes from west to east at approximately 1%.

Refer to **FIGURE 2** for an aerial of the overall project existing conditions.

### 2.3.2 PROPOSED SITE DEVELOPMENT

The proposed project will require the demolition of the existing parking lot, landscape, pavement and curbing removal, and the construction of a restaurant. The new development will consist of a restaurant building with associated drive-thru and landscape areas.

Proposed domestic, fireline and irrigation lines will tap off the existing 12" water main on McDowell Road.

Refer to **APPENDIX II** for Utility Plan.

## 3. DESIGN CRITERIA

### 3.1 UTILITY DEVELOPER GUIDE CRITERIA

This project is designed in accordance with the City of Scottsdale Design Standards & Policies Manual (DS+PM) 2018. The site is located in Scottsdale's pressure zone 1. Refer to **Table 1** below for applicable criteria.

**Table 1: Design Criteria by Demand Type**

Land Use	Average Day Demand (gpm)	Unit	Peaking Factors	
			Max Day	Peak Hour
Restaurant	1.81E-03	per sq. ft.	2	3.5

#### Minimum Pressures:

50 psi at Maximum Day and Peak Hour.

30 psi at Fire Flow conditions.

#### Velocity & Head loss:

10 fps maximum velocity for distribution system.

Hazen-Williams Coefficient      130

#### Fire Flows:

The City’s design standards govern the fire flow rates used for all buildings per Section 6-1.500 of the City of Scottsdale’s Design Standards & Policies Manual (DS&PM), dated 2018. The fire flow to be used is 1,500 gpm minimum for commercial, industrial, and multi-family residential properties, per Section 6-1.501 of the DS&PM

**4. DEMANDS**

**4.1 PROJECT USE DESCRIPTION**

The proposed development at the site consists of one restaurant. Refer to **Table 2** below for the proposed water demand calculations based on the design criteria established in *Section 3.1* above.

**Table 2: Proposed Water Demand Calculations**

Land Use	Unit Count	Unit	ADD per Unit (gpm)	Avg. Day Demand (gpm)	Max Day Demand (gpm)	Peak Hour Demand (gpm)
Restaurant	2,440	per sq. ft.	1.81E-03	4.42	8.84	15.47
Totals				4.42	8.84	15.47

**4.2 ZONING**

The project is located in the water pressure zone 1.

**4.3 TABULAR CALCULATIONS**

The water demands were assigned to nodes based on the building demands.

The Bentley WaterCAD model of this system includes the following input parameters:

1. Pipe diameter (inches)
2. Pipe lengths (feet)
3. Pipe invert elevations (feet)
4. A reservoir and a pump to model the fire flow test performed
5. System demands (gpm)
6. Model piping is PVC using Hazen-Williams frictional losses (C= 130 for aging pipe)
7. Fire Flows

Output parameters include:

1. Pressure (psi)
2. Flow rates (gpm)
3. Velocities (fps)
4. Head loss (feet)

Bentley WaterCAD Version 8i was used to analyze the waterline network for the Average Day, Max Day, Peak Hour and Fire Flow scenarios. Detailed WaterCAD outputs for these scenarios are included in **Appendix II**. Each fire hydrant and junction in the distribution network was assigned a node with elevations corresponding to its finished grade. Water demands for each of the above listed scenarios were mapped to the fire hydrant locations based on the area each hydrant would serve during a fire event.

The results of the WaterCAD analysis were used to verify that the distribution network provides adequate water pressure, and that the pipes are sized correctly for the required fire flow. The minimum system pressures in the distribution network were approximately 74 psi for Average Day, Maximum Day, and Peak Hour scenarios. Table 3 shows the minimum and maximum node pressures for the project’s area for each design scenario.

<b>Table 3 – Water Pressure Results</b>		
<b>Scenario</b>	<b>Minimum Pressure (psi)</b>	<b>Maximum Pressure (psi)</b>
Average Day	74	74
Maximum Day	74	74
Peak Hour	74	74
Fire Flow Demand	30	30

A fire flow/hydrant analysis was completed during the max day scenario to verify the waterline network provides adequate fire prevention demand during max day conditions. Available fire flow within the distribution system to all hydrants in the project’s area exceeded 1,500 gpm with velocities not exceeding 10 fps. The minimum system pressure under the fire flow scenario was 30 psi which meets the minimum requirements.

## **5. EXISTING FACILITIES / CONDITIONS**

### **5.1 PREVIOUS MASTER PLANS**

No existing master plan or water report is available from the City of Scottsdale for this site.

## **6. PROPOSED FACILITIES**

### **6.1 DISTRIBUTION SYSTEM PIPING**

#### **6.1.1 Onsite:**

The proposed water supply will consist of a 2” water meter and domestic service to the building, and one dedicated 6” fire line to the building. Both will be tapped off the 12” main on McDowell Road. The restaurant will also include a 1” landscape service and meter to be tapped off the 12” main on McDowell Road as well.

#### **6.1.2 Offsite Infrastructure:**

No offsite infrastructure is proposed.

Refer to Utility Plan in **Appendix II**.

### **6.2 REQUIRED FACILITIES AND PHASING**

- Proposed facility improvements for this project are limited to a 6” fire line connection, one 2” meter and one 1” landscape meters.
- This project will be constructed in a single phase.

## 7. SUMMARY/CONCLUSIONS

### 7.1 CONFORMANCE TO DESIGN GOALS

- Water designs are done in compliance with The City of Scottsdale Design Standards & Policies Manual (DS+PM) 2018.
- 10 fps maximum velocity is not exceeded.
- Minimum 50 psi @ peak hour required; 74 provided.
- Minimum 30 psi @ fire flow scenario required; 30 provided.

## 8. REFERENCES

1. *City of Scottsdale Design Standards & Policies Manual, 2018*
2. *COS Water Q-S MAP 13-47*



*“LEED®ing and Developing Smart Projects”*

## *FIGURES*










FIGURE 2. AERIAL







**GENERAL NOTES:**  
 \* THIS IS A COMPUTER GENERATED DRAWING. FOR ANY REVISIONS PLEASE CONTACT THE CITY OF SCOTTSDALE GIS DEPARTMENT AT (480) 312-7792.  
 \* THE SECTION LINE BEARING AND DISTANCES ARE BASED ON THE CITY OF SCOTTSDALE GPS SURVEY OF SEPTEMBER, 1991. BEARINGS ARE NAD 83 GRID AND DISTANCES ARE FLATTENED TO GROUND. WHERE NO CORNER WAS FOUND THE DIMENSIONS ARE GIVEN TO CALCULATED SECTION CORNERS AND ARE NOTED AS 'CALCULATED' ON THE MAP.

**LEGEND:**

Air Release Valve	(Symbol)
Non-potable Air Release Valve	(Symbol)
Blowoff	(Symbol)
Cap	(Symbol)
Cathodic Protection	(Symbol)
Fill Drain	(Symbol)
Fire Hydrant	(Symbol)
Non-GPS Point	(Symbol)
Pressure Reducing Valve	(Symbol)
Pump	(Symbol)
Reducer	(Symbol)
Sample Station	(Symbol)
Water Manhole	(Symbol)
Non-Potable Manhole	(Symbol)
Well	(Symbol)
Valve	(Symbol)
Non-potable Valve	(Symbol)
Vault	(Symbol)
Water Main	(Symbol)
Non-Potable Main	(Symbol)
Fire / Private Main	(Symbol)
Non-Scottsdale Main	(Symbol)



**FIGURE 3**  
**WATER**  
 QUARTER SECTION MAP  
**13-47**  
 SW 1/4 SEC. 36 T2N R4E

**NOTICE**  
 THIS DOCUMENT IS FOR GENERAL INFORMATION PURPOSES ONLY. THE CITY OF SCOTTSDALE DOES NOT WARRANT ITS ACCURACY, COMPLETENESS OR SUITABILITY FOR ANY PARTICULAR PURPOSE. IT SHOULD NOT BE RELIED UPON WITHOUT FIELD VERIFICATION.  
 THE CITY OF SCOTTSDALE  
 10-OCT-21



*APPENDIX I*

*Flow Test Results*

# Arizona Flow Testing LLC

## HYDRANT FLOW TEST REPORT

Project Name: McDowell & Hayden  
Project Address: McDowell Road & Hayden Road (NEC), Scottsdale, Arizona, 85257  
Client Project No.: Not Provided  
Arizona Flow Testing Project No.: 21565  
Flow Test Permit No.: C66590  
Date and time flow test conducted: October 25, 2021 at 7:45 AM  
Data is current and reliable until: April 25, 2022  
Conducted by: Floyd Vaughan – Arizona Flow Testing, LLC (480-250-8154)  
Witnessed by: Ray Padilla – City of Scottsdale-Inspector (602-541-0586)

### Raw Test Data

Static Pressure: **96.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **80.0 PSI**  
(Measured in pounds per square inch)

Pitot Pressure: **24.0 PSI**  
(Measured in pounds per square inch)

Diffuser Orifice Diameter: One 4-inch Hose Monster  
(Measured in inches)

Coefficient of Diffuser: .7875

Flowing GPM: **1,842 GPM**  
(Measured in gallons per minute)

GPM @ 20 PSI: **4,273 GPM**

### Data with 24 PSI Safety Factor

Static Pressure: **72.0 PSI**  
(Measured in pounds per square inch)

Residual Pressure: **56.0 PSI**  
(Measured in pounds per square inch)

Distance between hydrants: Approx.: 330 Feet

Main size: Not Provided

Flowing GPM: **1,842 GPM**

GPM @ 20 PSI: **3,481 GPM**

Scottsdale requires a maximum Static Pressure of 72 PSI for AFES Design.

### Flow Test Location

North ↑








*“LEED®ing and Developing Smart Projects”*


## *APPENDIX II*

# *Water Model Results*

8280 E. Gelding Dr., Suite 101  
Scottsdale, AZ 85260

**McDowell WaterCAD 11-26-2021.wtg**  
**Scenario: Base**

Color Coding Legend	
Pipe: Diameter (in)	
<hr/>	
	<= 12.0
	<= 24.0
	Other



# McDowell WaterCAD 11-26-2021.wtg

## Average Day Demand

### Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
FH-1	1,221.28	0	1,391.32	74
J-1	1,221.21	4	1,391.32	74

# McDowell WaterCAD 11-26-2021.wtg

## Average Day Demand

### Pipe Table - Time: 0.00 hours

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Status (Initial)
P-1	12	FH-1	J-1	12.0	Ductile Iron	130.0	4	0.01	Open
P-2	36	FH-1	PMP-1	24.0	Ductile Iron	130.0	-4	0.00	Open
P-3	35	PMP-1	R-1	24.0	Ductile Iron	130.0	-4	0.00	Open

# McDowell WaterCAD 11-26-2021.wtg

## Average Day Demand

### Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	1,225.00	On	1,225.00	1,391.32	4	166.32

# McDowell WaterCAD 11-26-2021.wtg

## Average Day Demand

### Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,225.00	4	1,225.00



# McDowell WaterCAD 11-26-2021.wtg

## Maximum Day Demand

Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
FH-1	1,221.28	0	1,391.32	74
J-1	1,221.21	9	1,391.32	74

# McDowell WaterCAD 11-26-2021.wtg

## Maximum Day Demand

### Pipe Table - Time: 0.00 hours

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diame ter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Status (Initial)
P-1	12	FH-1	J-1	12.0	Ductile Iron	130.0	9	0.03	Open
P-2	36	FH-1	PMP-1	24.0	Ductile Iron	130.0	-9	0.01	Open
P-3	35	PMP-1	R-1	24.0	Ductile Iron	130.0	-9	0.01	Open

# McDowell WaterCAD 11-26-2021.wtg

## Maximum Day Demand

### Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	1,225.00	On	1,225.00	1,391.32	9	166.32

# McDowell WaterCAD 11-26-2021.wtg

## Maximum Day Demand

### Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,225.00	9	1,225.00

# McDowell WaterCAD 11-26-2021.wtg

## Peak Hour Demand

### Junction Table - Time: 0.00 hours

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
FH-1	1,221.28	0	1,391.31	74
J-1	1,221.21	15	1,391.31	74

# McDowell WaterCAD 11-26-2021.wtg

## Peak Hour Demand

### Pipe Table - Time: 0.00 hours

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Flow (gpm)	Velocity (ft/s)	Status (Initial)
P-1	12	FH-1	J-1	12.0	Ductile Iron	130.0	15	0.04	Open
P-2	36	FH-1	PMP-1	24.0	Ductile Iron	130.0	-15	0.01	Open
P-3	35	PMP-1	R-1	24.0	Ductile Iron	130.0	-15	0.01	Open

# McDowell WaterCAD 11-26-2021.wtg

## Peak Hour Demand

### Pump Table - Time: 0.00 hours

Label	Elevation (ft)	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
PMP-1	1,225.00	On	1,225.00	1,391.31	15	166.31

# McDowell WaterCAD 11-26-2021.wtg

## Peak Hour Demand

### Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)
R-1	1,225.00	15	1,225.00



# McDowell WaterCAD 11-26-2021.wtg

## Fire Flow Demand


### Fire Flow Results Table - Time: 0.00 hours

Label	Fire Flow (Needed) (gpm)	Pressure (Calculated Residual) (psi)	Fire Flow (Available) (gpm)	Max Day + Fire Flow at Junction (gpm)	Junction w/ Minimum Pressure (Zone)	Pressure (Calculated System Lower Limit) (psi)	Pipe w/ Maximum Velocity	Velocity of Maximum Pipe (ft/s)
FH-1	1,500	30	3,160	3,160	J-1	30	P-3	2.24

**McDowell WaterCAD 11-26-2021.wtg**  
**Pump Definition Detailed Report: Pump Definition - 1**

Element Details			
ID	35	Notes	
Label	Pump Definition - 1		
Pump Definition Type			
Pump Definition Type	Standard (3 Point)	Design Head	129.36 ft
Shutoff Flow	0 gpm	Maximum Operating Flow	3,481 gpm
Shutoff Head	166.32 ft	Maximum Operating Head	46.20 ft
Design Flow	1,842 gpm		
Pump Efficiency Type			
Pump Efficiency Type	Best Efficiency Point	Motor Efficiency	100.0 %
BEP Efficiency	100.0 %	Is Variable Speed Drive?	False
BEP Flow	0 gpm		
Transient (Physical)			
Inertia (Pump and Motor)	0.000 lb·ft <sup>2</sup>	Specific Speed	SI=25, US=1280
Speed (Full)	0 rpm	Reverse Spin Allowed?	True

**McDowell WaterCAD 11-26-2021.wtg**  
**Pump Definition Detailed Report: Pump Definition - 1**



## *APPENDIX III*

### *Utility Plans*





CIVIL ENGINEER  
SUSTAINABILITY ENGINEERING GROUP  
8280 E. GELDING DR., SUITE 101  
SCOTTSDALE, ARIZONA 85260  
PHONE: 480-588-7226  
ATTN: ALI FAKIH  
EMAIL: ALI@AZSEG.COM

OWNER:  
HOH MCDOWELL LLC  
11811 N. TATUM BLVD #1051  
PHOENIX, ARIZONA 85028

SURVEYOR  
AW LAND SURVEYING, LLC  
P.O. BOX 2170  
CHANDLER, ARIZONA 85244  
PHONE: 480-244-7630  
ATTN: DANIEL ARMUO

# MCDOWELL PRELIMINARY GRADING PLAN

8010 E MCDOWELL ROAD, SCOTTSDALE AZ 85257  
A PORTION OF THE SOUTHWEST QUARTER OF SECTION 36, TOWNSHIP 2 NORTH, RANGE 4 EAST OF THE GILA AND  
SALT RIVER MERIDIAN, MARICOPA COUNTY, ARIZONA.



### PRELIMINARY WATER KEY NOTES

- 1 CONTRACTOR TO VERIFY SIZE AND LOCATION OF EXISTING WATER LINE PRIOR TO CONSTRUCTION.
- 2 GATE VALVE WITH VALVE BOX AND COVER, SIZE PER PLAN.
- 3 6" DUCTILE IRON PIPE. LENGTH PER PLAN.
- 4 CUT-IN TEE, SIZE PER PLAN.
- 5 DOMESTIC CONNECTION TO BUILDING.
- 6 FIRE CONNECTION TO BUILDING.
- 7 BACKFLOW PREVENTION, SIZE TO MATCH WATER METER SIZE.
- 8 2" TYPE "K" COPPER DOMESTIC SERVICE CONNECTION. LENGTH PER PLAN.
- 9 1" TYPE "K" COPPER IRRIGATION SERVICE CONNECTION. LENGTH PER PLAN.
- 10 FIRE DEPARTMENT CONNECTION.
- 11 CONNECTION TO EXISTING WATER LINE. REPLACE AT LEAST 3' OF ACP PIPE PER C.O.S. REQUIREMENTS.

### PRELIMINARY SEWER KEY NOTES

- 1 CONNECT TO EXISTING SEWER MANHOLE.
- 2 4" PVC SEWER LINE. LENGTH AND SLOPE PER PLAN.
- 3 6" PVC SEWER LINE. LENGTH AND SLOPE PER PLAN.
- 4 SEWER CONNECTION TO BUILDING.
- 5 INSTALL SEWER CLEANOUT
- 6 INSTALL SEWER MANHOLE
- 7 WYE CONNECTION
- 8 GREASE INTERCEPTOR

### C.O.S. GENERAL NOTES FOR PUBLIC WORKS CONSTRUCTION

1. ALL CONSTRUCTION IN THE PUBLIC RIGHTS-OF-WAY OR IN EASEMENTS GRANTED FOR PUBLIC USE MUST CONFORM TO THE LATEST MAG UNIFORM STANDARD SPECIFICATIONS AND UNIFORM STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION AS AMENDED BY THE LATEST VERSION OF THE CITY OF SCOTTSDALE SUPPLEMENTAL STANDARD SPECIFICATIONS AND SUPPLEMENTAL STANDARD DETAILS. IF THERE IS A CONFLICT, THE CITY'S SUPPLEMENTAL STANDARD DETAILS WILL GOVERN.
2. THE CITY ONLY APPROVES THE SCOPE, NOT THE DETAIL, OF ENGINEERING DESIGNS; THEREFORE, IF CONSTRUCTION QUANTITIES ARE SHOWN ON THESE PLANS, THEY ARE NOT VERIFIED BY THE CITY.
3. THE APPROVAL OF PLANS IS VALID FOR SIX (6) MONTHS. IF A RIGHT-OF-WAY PERMIT FOR THE CONSTRUCTION HAS NOT BEEN ISSUED WITHIN SIX MONTHS, THE PLANS MUST BE RESUBMITTED TO THE CITY FOR REAPPROVAL.
4. A PUBLIC WORKS INSPECTOR WILL INSPECT ALL WORKS WITHIN THE CITY RIGHTS-OF-WAY AND IN EASEMENTS. NOTIFY INSPECTION SERVICES 24 HOURS PRIOR TO BEGINNING CONSTRUCTION BY CALLING 480-312-5750.
5. WHENEVER EXCAVATION IS NECESSARY, CALL THE BLUE STAKE CENTER, 811, TWO WORKING DAYS BEFORE EXCAVATION BEGINS. THE CENTER WILL SEE THAT THE LOCATION OF THE UNDERGROUND UTILITY LINES IS IDENTIFIED FOR THE PROJECT.
6. RIGHT-OF-WAY PERMITS ARE REQUIRED FOR ALL WORK IN PUBLIC RIGHTS-OF-WAY AND EASEMENTS GRANTED FOR PUBLIC PURPOSES. A RIGHT-OF-WAY PERMIT WILL BE ISSUED BY THE CITY ONLY AFTER THE REGISTRANT HAS PAID A BASE FEE PLUS A FEE FOR INSPECTION SERVICES. COPIES OF ALL PERMITS MUST BE RETAINED ON-SITE AND BE AVAILABLE FOR INSPECTION AT ALL TIMES. FAILURE TO PRODUCE THE REQUIRED PERMITS WILL RESULT IN IMMEDIATE SUSPENSION OF ALL WORK UNTIL THE PROPER PERMIT DOCUMENTATION IS OBTAINED.
7. ALL EXCAVATION AND GRADING THAT IS NOT IN THE PUBLIC RIGHTS-OF-WAY OR NOT IN EASEMENTS GRANTED FOR PUBLIC USE MUST CONFORM TO APPENDIX J, GRADING, OF THE LATEST EDITION OF THE INTERNATIONAL BUILDING CODE. A PERMIT FOR THIS GRADING MUST BE SECURED FROM THE CITY FOR A FEE ESTABLISHED BY THE CITY.

ANY WATER LINE PROJECT THAT INVOLVES CONNECTING TO AN EXISTING ACP OR PVC PIPE REQUIRES SPECIAL ATTENTION. PER DSPM SECTION 6-1.408:


FITTINGS INSTALLED INTO ASBESTOS CEMENT PIPE (ACP) OR PVC PIPE WITHIN 6- FEET OF ANOTHER FITTING OR JOINT WILL REQUIRE THAT SECTION OF PIPE TO BE REMOVED AND REPLACED WITH DUCTILE IRON PIPE (DIP). EXISTING TEES, TAPPING SLEEVES AND RELATED APPURTENANCES THAT ARE NOT UTILIZED BY A DEVELOPMENT SHALL BE REMOVED BY THE CONTRACTOR. A MINIMUM 3-FOOT SECTION OF PIPE SHALL BE REMOVED, WITH NO LESS THAN 6 FEET REMAINING TO THE NEAREST JOINT. THE REMOVED PIPE SHALL BE REPLACED WITH DIP. WHEN MORE THAN 3- FEET OF EXISTING ACP OR PVC WATER LINES ARE EXPOSED DURING CONSTRUCTION AND THE BEDDING IS DISTURBED, THE WATER LINE MUST BE REPLACED WITH DIP (MINIMUM CLASS 350) WITH MECHANICAL JOINTS OR FLANGED JOINTS TO 3- FEET PAST THE SIDES OF THE EXPOSED CROSSING TRENCH. REFER TO MAG STANDARD DETAIL NO. 403-3. NO TAPPING SLEEVE AND VALVE SHALL BE USED ON ACP PIPE. VALVES WILL NEED TO BE CUT INTO ACP PIPE. DISPOSAL OF MATERIALS CONTAINING ASBESTOS AND/OR LEAD SHALL BE IN CONFORMANCE WITH ALL REGULATIONS, LAWS AND ORDINANCES.

### EXISTING LEGEND:

---	PROPERTY LINE	⊙	SEWER MANHOLE	▣	CB	STORM CATCH BASIN
---	CENTER LINE	— EX. W	WATER LINE	⊙	⊙	STORM STORM MANHOLE
---	EASEMENT LINE AS NOTED	WV ⊗	WATER VALVE	⊙	⊙	SIGN
---	EX. S	⊙	FIRE HYDRANT	⊙	⊙	STREET LIGHT
---	SEWER LINE	---	STORM DRAIN LINE			

### PROPOSED UTILITY LEGEND:

---	8"W	WATER LINE	⊗	GATE VALVE	⊙	SEWER MANHOLE
---	8"S	SEWER LINE	⊗	BACKFLOW PREVENTER	⊙	SEWER CLEANOUT
⊙	FDC		┌	CAP		
⊙	WATER METER		}	BUILDING CONNECTION		



### NOTE:


1. EXISTING MANHOLES RIMS AND INVERTS HAVE BEEN SET BASED ON QUARTER SECTION MAP QS# 13-47. DATED 10/10/2021. ELEVATIONS TO BE VERIFIED IN FIELD.

PRELIMINARY  
NOT FOR  
CONSTRUCTION

SUSTAINABILITY  
ENGINEERING  
GROUP



8280 E. GELDING DRIVE SUITE 101, SCOTTSDALE, ARIZONA 85260  
WWW.AZSEG.COM TEL: 480.588.7226 FAX: 480.259.3534



PROJECT MCDOWELL	LOCATION 8010 E MCDOWELL ROAD, SCOTTSDALE, AZ
DRAWN JC	12/01/2021
DESIGNED JC	12/01/2021
QC SC	12/01/2021
FINAL QC AF	12/01/2021
DATE: 12/01/2021	
ISSUED FOR: ZONING	
REVISION NO.:	DATE:
JOB NO.:	210929
SHEET TITLE:	

PRELIMINARY  
UTILITY PLAN